SafetyWithAthar Remote HSE Documentation
Document Title: Heavy Lifting & Crane Operations Method Statement & HSE Plan
Category: Method Statement & HSE Plan | Status: Public-source demo sample (Rev. 0 For revi
---
Summary: Structured RAMS / Method Statement covering crane setup, rigging gear certification, ex

[Page 1] Method Statement (MOS) Critical & Routine Lifting Operations (SWA-MOS-LIFT-004)
Operation Phase | Mandatory Technical Control | Hold Point / Limit | Sign-Off Role
---
* 4.1 Crane Positioning & Mats Verify ground compaction report & 100% outrigger beam extension
  [[HOLD POINT] Prior to boom raise] -> Lifting Supervisor (Gate 01)
* 4.2 Rigging & Color Code Check Inspect shackles, web slings & SWL tags against valid 6-month
  [SWL > 125% load weight] -> Certified Rigger (Gate 02)
* 4.3 Wind & Weather Monitoring Continuous digital anemometer reading at boom tip elevation
  [Cease lift if wind >= 20 knots] -> Crane Operator / HSE (Stop Work)
* 4.4 Exclusion Zone & Taglines Hard physical barriers around slewing radius; twin non-conduct
  [Zero personnel under suspended load] -> Appointed Banksman (Enforced)
Note: Public-source demo sample Rev. 0 For review only. Drafted for client/site HSE authorit

Prepared by Muhammad Athar SafetyWithAthar (https://athar-beep.github.io/safetywithathar/)