

VENTURE GLOBAL LNG

Control Valve Data Sheet

Project	Venture Global Calcasieu Pass, LLC				
Document Title	Control Valve Data Sheet				
Document Number	CP-139000-ICS-DAS-01821-00086				
Document Revision	0				
Document Status	VDR - VENDOR DOC REVIEW				
Document Type	SHP-DWG - SHOP DRAWING				
Security Classification	☐	Public	☒	Company Use	☐ Confidential



SUPPLIER INFORMATION	
Supplier Name	IMI-CCI
Supplier Document Number	A44533US-86-CVDS
PO Number	7400001821

0	29-Sep-2020	Issued for Review	DV	OA	PH
Rev	Date	Description	Originator	Reviewer	Approver
VG LNG REVISION HISTORY					

The information contained herein is the property of Venture Global LNG and may not be copied, published or otherwise reproduced, in whole or in part, without the prior written consent of Venture Global LNG. Venture Global LNG reserves all of its rights and remedies available at law and in equity to safeguard such information. No supplement, amendment or deletion of the policies, procedures or other information contained herein shall be effective unless such modification is approved by the Venture Global LNG Management.

APPROVED - 10/02/2020

					Spec. Data Sheet 						
Quote Nr.				DSV	1.6.01		Project			Calcasieu Pass LNG	
Customer		IMI CCI - CONTROL COMPONENTS INC.					End user				
RFQ Nr.							EPC (if any)		KIEWIT		
Item	Service	POT WAT TO LIQ UNIT N BLOCK					Item Nr.	6		Quantity	1
	Tag	139-000-PCV -39057						Tag notes			
Main Applied Rules	PED (2014/68/UE) Cat.	NO PED		ATEX (2014/34/UE) Cat.		NO ATEX		NACE Requirement		Not required	
	Other applied rules		N.R.								
General	Piping diameter / Schedule	3" - Schedule 40S					Req. Temperature (Env. / Fluid)		68 F / 68 F		
	Req. Body Design P (min / Max)	150 psi.g					Req. Body Design T (min / Max)		20 F / 150 F		
	Fluid / Fluid State	Water / Liquid									
Service Input	Sizing Conditions		Min	Units	Normal	Units	Max		Units		
	Flow Rate		27016,0000	lb/h	34869,6000	lb/h	52210,2000		lb/h		
	Upstream Pressure		130,0000	psi.g	117,0000	psi.g	77,0000		psi.g		
	Downstream Pressure		75,0000	psi.g	75,0000	psi.g	75,0000		psi.g		
	Delta P		55,0000	psi	42,0000	psi	2,0000		psi		
	Temperature		60,0000	F	88,0000	F	100,0000		F		
	Density		62,3800	lb/ft3	62,1100	lb/ft3	62,0000		lb/ft3		
	Viscosity		1,1200	cP	0,7800	cP	0,6800		cP		
Service Results	Remarks										
	CV - calculated		7,2779		10,7728		73,9831				
	CV - oversized		8,7335		12,9274		88,7797				
	Set Pressure		75,0000	psi.g	75,0000	psi.g	75,0000		psi.g		
	Noise level at 1 m.		48,4989	dBA	45,0430	dBA	29,0403		dBA		
	Velocity on inlet line		0,7148	m/s	0,9266	m/s	1,3898		m/s		
	Velocity on outlet line		0,7148	m/s	0,9266	m/s	1,3898		m/s		
Type / Name	Globe		BPM82/AF2/182		Valve Function		Relief				
BODY	Inlet / Outlet Size		3"		Inlet / Outlet conn.		ANSI 150RF				
	Body material		ASME SA-216 WCC		Face Finish		125-250 aarh				
	Body Studs & screws		ASME SA-193 B7		Gaskets		PTFE				
	Body Nuts		ASME SA-194 2H		Balancing System (if appl)		Not Required				
	Packing mat. / Type		N.A.								
					Face to Face mm (inch)		298 (11,732)				
TRIM	Nozzle - Plug Nr.		3"		Stem Guide material		17-4 PH				
	Selected Cv		110,0		Plug material		ASME SA-479 316				
	Leakage Class [FCI 70-3]		IV		Seal - Disc material		316 S.S.				
	Seats Nr.		1		Seat material		ASME SA-479 316				
	Flow action		Close		Characteristic		Quick opening				
ACTUATOR	Actuator size		182		Spring Range		50,75; 92,08 Psi.g (Cod 14)				
	Max operating P / T		111,681 psi.g / 302,0 F		Inverse Mount. (if applic.		Not required				
	Spring case material		ASME SA-216 WCC		Action on fail		Close				
	Diaphragm material		EPDM		Press.sensing/Connection		Internal				
	N° of diaphragms		1		Construction tightness		Closed				
	Spring material		CHROME ALLOY		Condensate tank (if appl)		Not Required				
	Bug screen on vent hole		NO		Vent Hole / Connection		YES / 1/2"NPT				
Gauge (if appl.)		NO		Diaph. protection device / mat. and set (if ap		NO		N.A.		@ SetP. - Spring:	
Other Accessories (if applicable)											
Max flow at 100% opening		409.700,00 lb/h									
Notes											
Filled by		FinelliF		e-mail				Phone			
								Date		24 Jul 2020	
								Page		1 / 2	

