

Chilled Water Coil Output Report

Customer Name	Sample Customer	Date	2026-08-08 19:22
Contact	Engineer	Reference	REF-001
Project	FCU Project	Prepared By	engineer1
Tag / Description	25 kW FCU	Quantity	1

Coil Data

Coil Data	Value
Finned height	558.8 mm
Finned length	1100.0 mm
Rows deep	4
Number of feeds / circuits	22
Number of passes	4
Fins per inch	12.0
Tube material	Copper - wall 0.350 mm
Tube diameter	OD 9.530 mm / ID 8.830 mm
Fin material	Aluminum - 0.120 mm
Fin surface	Wavy + louvers
Face area	0.615 m2
External surface area	47.26 m2

Air Data

Air Data	Value
Total air flow	0.970 m3/s (3492 m3/h / 2055 CFM)
Face velocity	1.58 m/s
Entering dry bulb	26.00 degC
Entering wet bulb	19.40 degC
Entering relative humidity	54.0%
Leaving dry bulb	11.97 degC
Leaving wet bulb	11.60 degC
Leaving relative humidity	95.8%
Condensate rate	12.79 kg/h
Air pressure drop	29.04 Pa
Total capacity	25.55 kW
Sensible capacity	16.78 kW
Latent capacity	8.77 kW

Fluid Data

Fluid Data	Value
Fluid type	Water
Glycol concentration	0.0%
Entering fluid temperature	6.00 degC
Leaving fluid temperature	11.00 degC
Fluid flow rate	4.428 m3/h (1.230 L/s)
Fluid velocity in tubes	0.890 m/s
Fluid pressure drop	11.65 kPa
Supply header velocity	1.000 m/s
Return header velocity	1.000 m/s

Design target: Required capacity 25.04 kW; required leaving air 11.97 degC DB / 11.60 degC WB

This output report summarizes the selected coil operating point. Final production release should follow the organization's normal engineering review and validation procedure.