

7th floor		
6th floor		
5th floor	Stairwell	
4th floor	Supply	
3rd floo (pressurized at 6 air changes per hour)r	Supply 4.25 m ³ /s	
2nd floor (exhausted at 6 air changes per hour)		
Ground floor (pressurized at 6 air changes per hour)		Groun
Basement	Open Ext Door	terior