

TRN246 Solar Plant — Detailed Live Telemetry

Generated: 25/08/2026, 11:03:21
Filter: All parameters · Category: All categories · Source: All sources · Sort: parameter ascending · Rows: 35

CATEGORY	PARAMETER	RAW VALUE	CUSTOMER VALUE	UNIT	REGISTER ADDRESS	DATA QUALITY	SOURCE	DATE	TIME
Device	actpow	2D31313330393534373532	−11309.54752	kW	305031	Good	ana	25 Aug 2026	10:55:30
Electrical	Acurrent	383535	85.5	A	305022	Good	ana	25 Aug 2026	10:55:30
Alarms	alarm	30	0	Raw / not declared	305007	Good	ana	25 Aug 2026	10:55:31
Alarms	alarmcode	3635353335	65535	Raw / not declared	305601	Good	ana	25 Aug 2026	10:55:31
Power	aphpower	3635353335	65535	Raw / not declared	305085	Good	ana	25 Aug 2026	10:55:31
Electrical	Bcurrent	383536	85.60000000000001	A	305023	Good	ana	25 Aug 2026	10:55:30
Power	bphpower	3635353335	65535	Raw / not declared	305087	Good	ana	25 Aug 2026	10:55:31
Electrical	Ccurrent	383535	85.5	A	305024	Good	ana	25 Aug 2026	10:55:30
Device	dailyenegykwh	35363332	5.632	MWh	305005	Good	ana	25 Aug 2026	10:55:31
Alarms	faultalarm	30	0	Raw / not declared	305041	Good	ana	25 Aug 2026	10:55:31
Alarms	faultcode	30	0	Raw / not declared	305600	Good	ana	25 Aug 2026	10:55:31
Device	frq	343939	49.900000000000006	Hz	305036	Good	ana	25 Aug 2026	10:55:30
Environment	internaltemperature	3839	89	°C	305124	Good	ana	25 Aug 2026	10:55:31
Device	inv1	32313334	2134	Raw / not declared	305003	Good	ana	25 Aug 2026	10:55:31
Device	inv2	32313334	2134	Raw / not declared	305003	Good	ana	25 Aug 2026	10:55:31
Device	inv3	32313334	2134	Raw / not declared	305003	Good	ana	25 Aug 2026	10:55:31
Device	inv4	32313334	2134	Raw / not declared	305003	Good	ana	25 Aug 2026	10:55:31
Device	inv5	32313334	2134	Raw / not declared	305003	Good	ana	25 Aug 2026	10:55:31
Power	meterpower	3635353335	65535	Raw / not declared	305083	Good	ana	25 Aug 2026	10:55:31
Electrical	MPPT1current	363136333636303830	616366080	Raw / not declared	305011	Good	ana	25 Aug 2026	10:55:31
Electrical	MPPT1Voltage	3635353336	65536	Raw / not declared	305010	Good	ana	25 Aug 2026	10:55:31
Electrical	MPPT2current	363138393837353230	618987520	Raw / not declared	305013	Good	ana	25 Aug 2026	10:55:31
Electrical	MPPT2Voltage	38393132383936	8912896	Raw / not declared	305012	Good	ana	25 Aug 2026	10:55:31
Device	pf	31303030	1	PF	305035	Good	ana	25 Aug 2026	10:55:30

CATEGORY	PARAMETER	RAW VALUE	CUSTOMER VALUE	UNIT	REGISTER ADDRESS	DATA QUALITY	SOURCE	DATE	TIME
Electrical	phaseABvoltage	37363732	767.2	V	305019	Good	ana	25 Aug 2026	10:55:30
Electrical	phaseBCvoltage	37363936	769.6	V	305020	Good	ana	25 Aug 2026	10:55:30
Electrical	phaseCAvoltage	37363639	766.9000000000001	V	305021	Good	ana	25 Aug 2026	10:55:30
Device	str2A	343238	42.80000000000004	A	307014	Good	ana	25 Aug 2026	10:55:31
Device	STR3A	383737	87.7	A	307015	Good	ana	25 Aug 2026	10:55:31
Device	STR4A	343531	45.1	A	307016	Good	ana	25 Aug 2026	10:55:31
Device	STR5A	383836	88.6000000000001	A	307017	Good	ana	25 Aug 2026	10:55:31
Device	STR6A	343333	43.30000000000004	A	307018	Good	ana	25 Aug 2026	10:55:31
Electrical	string1current	393034	90.4	A	307013	Good	ana	25 Aug 2026	10:55:31
Device	todayyield	3232303234	22.024	MWh	305003	Good	ana	25 Aug 2026	10:55:31
Device	totalenergy	3330363730383438	30670.848	MWh	305008	Good	ana	25 Aug 2026	10:55:31