

Preliminary air balance readings

Taken before final balancing (sample values)

Item	Design (sample)	Measured (sample)	Notes
RTU-1 supply	2000 cfm	1940 cfm	Sample
EF-1	300 cfm	290 cfm	Sample
EF-2	150 cfm	155 cfm	Sample
EF-3	150 cfm	140 cfm	Sample

Page 2 is a landscape page stored with a rotation, as scanners often save them.

BALANCED AIR TESTING (FICTIONAL)

Harborview Family Clinic (fictional) · Project 2026-014

Diffuser readings (sample values)

Room	Diffuser	Design cfm	Measured cfm	Percent	Notes
Exam 1	S-1	180	173	95%	Sample
Exam 2	S-2	180	176	96%	Sample
Exam 3	S-3	180	179	97%	Sample
Exam 4	S-4	180	182	98%	Sample
Waiting	S-5	250	244	98%	Sample
Reception	S-6	150	151	101%	Sample