

NORTHGATE MECHANICAL SERVICES (FICTIONAL)

Harborview Family Clinic (fictional) · Project 2026-014

Specification checklist - Section 23 74 00 (DRAFT)

Prepared for the subcontractor's review. The subcontractor confirms compliance.

Spec para. (sample)	Requirement (summary, sample)	Where shown	PM check
2.1.A	Packaged rooftop unit, gas heat / DX cooling	Product data p. 1	☐ Yes ☐ No
2.1.B	Nominal cooling capacity 5 tons	Product data p. 1	☐ Yes ☐ No
2.2.A	208-230 V / 3 ph / 60 Hz power	Performance data	☐ Yes ☐ No
2.3.C	Factory economizer	Product data p. 1	☐ Yes ☐ No
1.7.A	Manufacturer's warranty, 5 yr heat exchanger	Warranty	☐ Yes ☐ No

This checklist lists where each requirement appears in the package. It does not confirm compliance; the subcontractor's project manager checks each line and signs the cover.