


Fernwick Water Department: 2025 Water Quality Report

This report tells you where your water comes from and what our tests found in 2025. Your water met every federal and state drinking water standard.

Where your water comes from

Fernwick's water comes from three wells near the Fern River. We treat it with chlorine and test it every week.

Lead found in tap water samples (parts per billion)



What we found

Substance	Highest level found	Allowed limit	Meets the standard?
Lead	4.1 parts per billion	15 parts per billion (action level)	Yes
Copper	0.21 parts per million	1.3 parts per million (action level)	Yes
Nitrate	2.4 parts per million	10 parts per million	Yes
Chlorine	1.1 parts per million	4 parts per million	Yes

Questions

Call the Water Department at (555) 010-0140, or come to a Town Council meeting.