

# GENERAL NOTE

1. ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE SPECIFIED.
2. THIS DRAWING IS PRINTED AS PER PAPER SIZE ON A PARTICULAR SCALE, AS MENTIONED IN THE TITLE BLOCK. HOWEVER FOR CLARITY SOME COMPONENTS SHOWN ARE SYMBOLIC AND MAY NOT BE TO SCALE.
3. ALL INVERT LEVELS ARE SHOWN IN MM WITH REFERENCE TO DATUM FLOOR LEVEL.
4. ALL MATERIALS ARE AS PER RESPECTIVE APPROVED MATERIAL SUBMITTAL.
5. ALL AIR HANDLING UNITS SUPPLY AIR DUCT CONNECTION SHALL BE ACOUSTICALLY LINED UP TO AHU ROOM WALLS.
6. ALL AHU ROOMS DOOR TO BE OPENED OUTWARD
7. ALL AIR TERMINALS LOCATIONS TO BE CO-ORDINATED WITH FINAL RCP LAYOUT PRIOR TO INSTALLATION
8. CROSS TALK DUCTS TO BE FABRICATED TO SUIT AT SITE.

# CAUTION

While every attempt has been made in the preparation of this drawing to avoid mistakes, the maker can not guarantee against human error. The contractor on the job must check all dimensions and other details and be responsible for the same.

NO.	DATE	REVISION

# PROJECT NAME:

WESTSIDE  
UTOPIA, BORIVALI

# CLIENT :

TRENT LTD.

# LIGHTING CONSULTANT :

# MEP CONSULTANT :

HVAC Contractor :  
**VOLTAS LIMITED**  
A TATA Enterprise  
DOMESTIC PROJECTS GROUP  
Voltas House-B, T.B.Kadam Marg, Chinchpokali(E) Mumbai-400 033.

# ARCHITECT

TRENT LTD.

DATE : 06.12.2021

SCALE : NTS

DRAWN BY : AS

CHECKED BY : RC

DRAWING NO : VL/DPG/WS-UTP/MSLD- 01 R1

DRAWING NAME :

MAIN-SLD

