CHAPTER NO. 33

ELECTRICAL

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour	Through	Labour	Through
				Rate	Rate	Rate	Rate
1		2	3	4	5	6	7
33.01	RECES	SED CONDUIT PIPE WIRING SYSTEM WITH MODULAR HES:					
	cable (welded Marked coated, numbe module Amp. covere numbe regulat Electro Inspect copper	in PVC insulated copper conductor single core FRLS ISI marked), 1100volts grade to be laid in heavy gauge conduit pipe 20 mm/25 mm dia (1.6mm thick) ISI I, recessed in wall etc., complete with powder anodized concealed metal boxes required for suitable of modules, for having electronic fan regulators (two e), bell push, electronic buzzer, 3pin 6Amp., 3pin 16/20 Sockets and 6 Amp./16/20Amp. Swithces etc., and d with Frame Plate etc., & including the cost of required of modular switches/sockets, step type electronic fan for 100 watts, PVC connector (For Fan Box and finic Buzzer), PVC Bush, Steel Hooks, Circular tion Box (Recessed Type and Deep Type) conduit pipe & wire and other petty material etc. including the cost of and filling up of chases:-					
	(i) a	Wiring fan point without fan box in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (two module).					
			per point	111.09	1096.63	122.20	1107.74
	(i) b	Wiring fan point with sheet metal fan box (shape hexagonal & sheet thickness not less than 1.60 mm) in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (two module).		111.09	1090.03	122.20	1107.74
			per point	111.09	1186.88	122.20	1197.99
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.			33.30		31190
			per point	91.72	723.13	100.89	732.30
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer & powder coated concealed metal box for electronic buzzer).		51.72	. 20.10	.33.33	. 02.30
			per point	91.72	806.91	100.89	816.08

Page 404 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(iv)	Wiring 3 pin 6 Amp. wall socket (Shuttered) point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.	per point	74.59	615.84	82.05	623.30
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket (shuttered) and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.	per point	64.38	375.05	70.82	381.49
	(vi)	Wiring 3 pin 16/20 amp. power plug control (shuttered) and switch.	per				
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch.	point	69.48	405.06	76.43	412.01
	(viii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.	point per point	107.49	311.68 1105.36	70.82	318.12
	(ix)	Wiring TV sockets and Telephone socket points in powder coated/anodized concealed metal boxes recessed in wall required for suitable number of modules, for having TV sockets, Telephone sockets RJ11 & RJ45 (one module) etc., and covered with Frame Plate etc., & including the cost of required number of modular TV sockets, Telephone sockets RJ11 & RJ45 (one module) and other petty material etc. including the cost of cutting and filling up of chases:-	Point	101110	1100100		
	(a)	Wiring TV socket point (one module)		64.38	207.37	70.82	213.81
	(b)	Wiring Telephone socket point RJ11 (one module)		64.38	220.71	70.82	227.15
	(c)	Wiring Telephone socket point RJ45 (one module)		64.38	437.65	70.82	444.09
33.02		SED PVC CONDUIT PIPE WIRING SYSTEM WITH AR SWITCHES:					

Page 405 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mo	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1	cable ((uPVC, state)) ISI Macoated, number push, eand & Accessincluding switched PVC cathooks, Type)	in PVC insulated copper conductor single core FRLS ISI marked), 1100volts grade to be laid in heavy gauge, fire retardant conduit pipe 20mm/25mm dia. (2mm thick) trked, recessed in wall etc., complete with powder anodized concealed metal boxes required for suitable of modules, for having electronic fan regulators, bell electronic buzzer, 3pin 6Amp., 3pin 16/20Amp. Sockets 6Amp./16/20Amp. Switches (Screw Type Modular sories) etc., and covered with Frame Plate etc., & ng the cost of required number of modular es/sockets, step type electronic fan regulator 100watts, connector (For Fan Box and Electronic Buzzer), Steel Circular Inspection Box (Recessed Type and Deep uPVC conduit pipe & copper wire and other petty all etc. including the cost of cutting and filling up of size	3	4	5	6	7
	(i) a	Wiring fan point without fan box in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts.	per point	70.27	855.99	77.30	863.02
	(i) b	Wiring fan point with sheet metal fan box (shape hexagonal & sheet thickness not less than 1.60 mm) in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts.	per	1 3 - 2 /	333.00		33332
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.	point	70.27	935.80	77.30	942.83
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer & powder coated concealed metal box for electronic buzzer).	per	57.55		63.31	490.45
	(iv)	Wiring 3 pin 6 Amp. wall socket (Shuttered) point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.	point per point	57.55	562.49	63.31 53.98	568.25 482.68
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket (shuttered) and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.	Pemi	10.0.		33.33	.02.00
			per point	32.18	324.08	35.40	327.30

Page 406 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mo	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Wiring 3 pin 16/20 amp. power plug control (shuttered) and switch.	per point	46.51	380.92	51.16	385.57
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch.	Penn	10.01		01110	
			per point	32.18	178.27	35.40	181.49
	(viii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.					
			per	50.00	750 74	50.00	750.07
33.03	RECES	SED CONDUIT PIPE WIRING SYSTEM WITH FLUSH	point	53.63	750.71	58.99	756.07
00.00		TYPE SWITCHES:					
	welded Marked coated/ electro buzzer, Amp./1 and co backsic flush p regulat Electro Inspect copper	ISI marked), 1100volts grade to be laid in heavy gauge conduit pipe 20 mm/25 mm dia (1.6mm thick) ISI I, recessed in wall etc., complete with powder anodized concealed metal boxes required for having nic fan regulators (socket size), bell push, electronic 3pin 6Amp., 3pin 16/20 Amp. Sockets and 6/20Amp. Swithces (flush piano type accessories) etc. overed with brown bakelite white glazed translucent de painted sheet 3mm thick etc., & including the cost of piano type switches/sockets, step type electronic fan or 100 watts, PVC connector (For Fan Box and nic Buzzer), PVC Bush, Steel Hooks, Circular tion Box (Recessed Type and Deep Type) conduit pipe & wire and other petty material etc. including the cost of and filling up of chases:-					
	(i) a	conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (socket size).	per point	111.09	858.41	122.20	869.52
	(i) b	Wiring fan point with sheet metal fan box (shape hexagonal & sheet thickness not less than 1.60 mm) in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (socket size).	per point	111.09	944.19	122.20	955.30
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.	per point	91.72	644.36	100.89	653.53

Page 407 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer & powder coated concealed metal box for electronic buzzer).		91.72	718.71	100.89	733.18
	(iv)	Wiring 3 pin 6 Amp. wall socket point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.		74.59	455.66	82.05	463.12
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.		64.38	187.87	70.82	194.31
	(vi)	Wiring 3 pin 16/20 amp. power plug control and switch.	per point	69.48	296.55	76.43	303.50
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch.	per point	64.38	311.68	70.82	318.12
	(viii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.	per point	107.30	955.53	118.03	966.26
33.04	SWITC	CE CONDUIT PIPE WIRING SYSTEM WITH MODULAR HES: in PVC insulated copper conductor single core FRLS					
	cable (I welded Marked (on su having electron Amp./10 etc., & switche PVC co Bush, conduit includir	ISI marked), 1100volts grade to be laid in heavy gauge conduit pipe 20 mm/25 mm dia (1.6mm thick) ISI installed on surface etc., complete with uPVC boxes rface) required for suitable number of modules, for electronic fan regulators (two module), bell push, nic buzzer, 3pin 6Amp., 3pin 16/20 Amp. Sockets and 6/20Amp. Swithces etc., and covered with Frame Plate including the cost of required number of modular es/sockets, step type electronic fan regulator 100 watts, onnector (For Fan Box and Electronic Buzzer), PVC Steel Hooks, Circular Inspection Box (Surface Type) to pipe & copper wire and other petty material etc. and the cost of painting as required:-					
	(i)	Wiring fan point without fan box in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (two module).	per point	68.16	1042.55	74.98	1049.37
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.	per point	68.16	686.53	74.98	693.35

Page 408 CSR - 2010

1		Description	Unit	PI	ains	Sub Mot	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
		2	3	4	5	6	7
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer and plastic surface box for electronic buzzer).	per point	51.04	759.30	56.14	764.40
	(iv)	Wiring 3 pin 6 Amp. wall socket (Shuttered) point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.	per point	40.82	581.07	44.90	585.15
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket (shuttered) and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.	per point	32.66	341.93	35.93	345.20
	(vi)	Wiring 3 pin 16/20 amp. power plug control (shuttered) and switch.	per point	36.75	370.93	40.43	374.61
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch.	per point	32.66	274.87	35.93	278.14
	(viiii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.	•	32.00	214.01	30.93	270.14
33.05 R	RECES	SED HDPE PIPE WIRING SYSTEM WITH MODULAR	per point	68.16	1029.64	74.98	1036.46
I	SWITCH						
ca el in m ha 3 S w or re E b	cable (electric in wall metal k having Bpin 6/ Switche with Fra of mo- regulate Electron box (Re bipe &	in PVC insulated copper conductor single core FRLS (ISI marked), 1100volts grade to be laid in HDPE all conduit pipe 20mm/25mm dia. ISI Marked, recessed etc., complete with powder coated/anodized concealed boxes required for suitable number of modules, for electronic fan regulators, bell push, electronic buzzer, Amp., 3pin 16/20Amp. Sockets and 6Amp./16/20Amp. es (Screw Type Modular Accessories) etc., and covered ame Plate etc., & including the cost of required number dular switches/sockets, step type electronic fan or 100watts, PVC connector (For Fan Box and nic Buzzer), Steel Hooks, Cast Iron circular Inspection ecessed Type and Deep Type) HDPE electrical conduit copper wire and other petty material etc. including the cutting and filling up of chases:-					
	(i) a	Wiring fan point without fan box in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts.	per point	70.27	1061.96	77.30	1068.99

Page 409 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(i) b	Wiring fan point with sheet metal fan box (shape hexagonal & sheet thickness not less than 1.60 mm) in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts.	per point	70.27	1147.74	77.30	1154.77
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.	per point	57.55	690.64	63.31	696.40
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer & powder coated concealed metal box for electronic buzzer).	per point	57.55	774.44	63.31	780.20
	(iv)	Wiring 3 pin 6 Amp. wall socket (Shuttered) point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.	per point	49.07	598.04	53.98	602.95
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket (shuttered) and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.	per point	32.18	340.59	35.40	343.81
	(vi)	Wiring 3 pin 16/20 amp. power plug control (shuttered) and switch.	per point	46.51	380.92	51.16	385.57
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch.	per point	32.18	281.26	35.40	284.48
	(viiii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.	per point	53.63	1048.35	58.99	1053.71
33.06	l	SED HDPE PIPE WIRING SYSTEM WITH FLUSH PIANO WITCHES:					
	cable (I pipe 2 comple require electron Amp./10 and co backsic flush pregulate Electro Inspect electric	in PVC insulated copper conductor single core FRLS SI marked), 1100volts grade to be laid in HDPE conduit 0mm/25mm dia. ISI Marked, recessed in wall etc., te with powder coated/anodized concealed metal boxes of for having electronic fan regulators, bell push, nic buzzer, 3pin 6Amp., 3pin 16/20 Amp. Sockets and 6/20Amp. Swithces (flush piano type accessories) etc. overed with brown bakelite white glazed translucent de painted sheet 3mm thick etc., & including the cost of siano type switches/sockets, step type electronic fan for 100 watts, PVC connector (For Fan Box and nic Buzzer), PVC Bush, Steel Hooks, Cast Iron circular ion box (Recessed Type and Deep Type) HDPE al conduit pipe & copper wire and other petty material luding the cost of cutting and filling up of chases:-					

Sr. No.		Description	Unit	PI	ains	Sub Mo	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(i) a	Wiring fan point without fan box in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts.	per point	70.27	819.27	77.30	826.30
	(i) b	Wiring fan point with sheet metal fan box (shape hexagonal & sheet thickness not less than 1.60 mm) in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts.	per point	70.27	891.03	77.30	898.06
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.	per point	57.55	611.87	63.31	617.63
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer & powder coated concealed metal box for electronic buzzer).	per point	57.55	691.53	63.31	697.29
	(iv)	Wiring 3 pin 6 Amp. wall socket (Shuttered) point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.	per point	49.07	436.73	53.98	441.64
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket (shuttered) and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.	per point	32.18	173.31	35.40	176.53
	(vi)	Wiring 3 pin 16/20 amp. power plug control (shuttered) and switch.	per point	46.51	272.41	51.16	277.06
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch.	per point	32.18	281.26	35.40	284.48
	(viii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.	per point	53.63	872.16	58.99	877.52
33.07	ACCES	CEMENT OF WIRES, SHEETS, SWITCHES AND OTHER SORIES IN THE EXISTING RECESSED CONDUIT PIPE SYSTEM (WITH FLUSH PIANO TYPE SWITCHES):					

Page 411 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mo	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	cable (I gauge v Marked regulat 6Amp., Swithco brown sheet 3 switche PVC co Bush, 8	in PVC insulated copper conductor single core FRLS (SI marked), 1100volts grade to be laid in existing heavy welded conduit pipe 20 mm/25 mm dia (1.6mm thick) ISI I, recessed in wall etc., complete with electronic fan ors (socket size), bell push, electronic buzzer, 3pin 3pin 16/20 Amp. Sockets and 6 Amp./16/20Amp. es (flush piano type accessories) etc. and covered with bakelite white glazed translucent backside painted 3mm thick etc., & including the cost of flush piano type es/sockets, step type electronic fan regulator 100 watts, onnector (For Fan Box and Electronic Buzzer), PVC & copper wire and other petty material etc. including the repair of chases:- (Derived From CSR 33.03)					
	(i) a	Wiring fan point without fan box in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (socket size).	per point	44.91	417.10	49.40	421.59
	(i) b	Wiring fan point with sheet metal fan box (shape hexagonal & sheet thickness not less than 1.60 mm) in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (socket size).	_ .	44.91	417.10		421.59
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.	per point	33.89	197.68		
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer & powder coated concealed metal box for electronic buzzer).	•	33.89	250.73	37.28	254.12
	(iv)	Wiring 3 pin 6 Amp. wall socket point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.	per point	27.34	174.51	30.07	177.24
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.		14.96	96.72	16.46	98.22
	(vi)	Wiring 3 pin 16/20 amp. power plug control and switch.	per point	16.33	139.65	17.96	
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch. Wiring light point in PVC insulated copper conductor single		16.33	71.58		
0.5.5		core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.	per point	45.32	298.56	49.85	303.09
33.08	SWITC	CEMENT OF WIRES, COVER FRAMES, MODULAR HES, CONCEALED METAL BOX AND OTHER SORIES IN THE EXISTING RECESSED CONDUIT PIPE SYSTEM (WITH MODULAR TYPE ACCESSORIES):					

Sr. No.		Description	Unit	PI	ains	Sub Mo	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	cable (heavy thick) I coated numbe module Amp. covered numbe regulat Electro	in PVC insulated copper conductor single core FRLS ISI marked), 1100volts grade to be laid in the existing gauge welded conduit pipe 20 mm/25 mm dia (1.6mm SI Marked, recessed in wall etc., complete with powder anodized concealed metal boxes required for suitable of modules, for having electronic fan regulators (two e), bell push, electronic buzzer, 3pin 6Amp., 3pin 16/20 Sockets and 6Amp./16/20Amp. Swithces etc., and d with Frame Plate etc., & including the cost of required or of modular switches/ sockets, step type electronic fan or 100 watts, PVC connector (For Fan Box and onic Buzzer), PVC Bush, & copper wire and other petty all etc. including the cost of repair of chases:-					
	(i) a	Wiring fan point without fan box in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (two module).		57.09	708.09	62.80	713.80
	(i) b	Wiring fan point with sheet metal fan box (shape hexagonal & sheet thickness not less than 1.60 mm) in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with step type electronic fan regulator 100watts (two module).		57.09	726.58	62.80	732.29
	(ii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade.		45.66	325.48	50.23	330.05
	(iii)	Wiring call-bell point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade with bell push and electronic buzzer 230 volts AC (including the cost of bell push, electronic buzzer & powder coated concealed metal box for electronic buzzer).		45.66			
	(iv)	Wiring 3 pin 6 Amp. wall socket (Shuttered) point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade.	·	39.12	390.85	43.03	394.76
	(v)	Wiring 3 Pin 6 Amp. Plug control comprising wall socket (shuttered) and switch including bonding to existing earth with PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq. mm, 1100volts grade complete.		26.73	311.23	29.40	313.90
	(vi)	Wiring 3 pin 16/20 amp. power plug control (shuttered) and switch.	per point	28.12	363.10	30.93	365.91
	(vii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete without control switch.	per point	25.76	81.01	28.34	83.59
	(viii)	Wiring light point in PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq. mm, 1100volts grade complete with double control switches.	per point	68.87	570.96		

Page 413 CSR - 2010

Sr. No.	Description		Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
33.09	PVC IN	SULATED SINGLE CORE FRLS COPPER CONDUCTOR					
		and erection of PVC insulated single core FRLS copper ctor cable ISI marked left bare in pipe or casing of					
	suitabl or casi	e size excluding the cost of supply and erection of pipe ng.					
	(i)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1 sq.mm, 1100volts grade					
			m	3.57	10.87	3.93	11.23
	(ii)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 1.5 sq.mm, 1100volts grade					
	/:::\	DVC insulated connect conductor single core FDLC coble	m	3.57	14.39	3.93	14.75
	(iii)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 2.5 sq.mm, 1100volts grade	m	3.57	20.58	3.93	20.94
	(iv)	PVC insulated copper conductor single core FRLS cable		0.07	20.00	0.00	20.04
		(ISI marked) overall 4 sq.mm, 1100volts grade	m	4.08	28.54	4.49	28.95
	(v)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 6 sq.mm, 1100volts grade		4.00	40.07	4.40	40.00
	(vi)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 10 sq.mm, 1100volts grade	<u> </u>	4.08	42.87	4.49	43.28
			m	4.08	69.78	4.49	70.19
	(vii)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 16 sq.mm, 1100volts grade					
			m	4.08	107.46	4.49	107.87
	(viii)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 25 sq.mm, 1100volts grade					
			m	5.43	172.46	5.97	173.00
	(ix)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 35 sq.mm, 1100volts grade		0.40	220.77	0.70	227.20
	(x)	PVC insulated copper conductor single core FRLS cable (ISI marked) overall 50 sq.mm, 1100volts grade	m	6.12	226.77	6.73	227.38
			m	6.12	329.44	6.73	330.05
		PVC INSULATED PVC SHEATHED TWIN FLEXIBLE COPPER CONDUCTOR CABLE:	- 111	0.12	329.44	0.73	330.03
	(xi)	Supply and erection of PVC insulated PVC sheathed twin flexible wire with copper conductor complete in all respect as desired by the Engineer-in-charge.					
	(a)	PVC insulated PVC sheathed twin flexible wire with copper conductor of size 0.5 sq.mm (16/0.20mm)					
			m	5.49	15.61	6.04	16.16
	(b)	PVC insulated PVC sheathed twin flexible wire with copper conductor of size 0.75 sq.mm (24/0.20mm)					
			m	5.49	19.02	6.04	19.57
	(c)	PVC insulated PVC sheathed twin flexible wire with copper conductor of size 1.5 sq.mm (48/0.20mm)		F 40	22.00	6.04	22.55
			m	5.49	23.00	6.04	23.55

Page 414 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(d)	PVC insulated PVC sheathed twin flexible wire with copper conductor of size 2.5 sq.mm (80/0.20mm)	m	5.49	29.89	6.04	30.44
33.10 A		XLPE/ PVC INSULATED ARMOURED CABLES	- '''	3.43	29.09	0.04	30.44
	insulate 1 m bel coverin	& laying of aluminium conductor XLPE/ P.V.C. ed PVC sheathed armoured and served cable to be laid ow ground level including excavation, sand cushioning, ag with sand & bricks and back filling the trench etc., of uired size as per PWD General Specifications 2010:-					
	(i)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (Twin Core)	m	38.96	178.19	42.86	182.09
	(ii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (Twin Core)	m	38.96	191.05	42.86	194.95
	(iii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (Twin Core)		38.96	198.23	42.86	202.13
	(iv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (Twin Core)	m	38.96	208.68	42.86	212.58
	(v)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (Twin Core)		38.96	232.84	42.86	236.74
	(vi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (Twin Core)		38.96	270.06	42.86	273.96
	(vii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 4sq.mm (Three Core)		30.30	270.00	42.00	213.30
	(viii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (Three Core)	m	38.96	174.27	42.86	178.17
	(ix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (Three Core)	m	38.96	189.75	42.86	193.65
	(x)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (Three Core)		38.96	206.07	42.86	209.97
	(xi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (Three Core)		38.96	217.82	42.86	221.72
			m	38.96	245.04	42.86	248.94

Page 415 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (Three Core)	m	38.96	284.34	42.86	288.24
	(xiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (Three Core)		00.00	20 1.0 1	12.00	200.21
	(xiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed	m	38.96	331.04	42.86	334.94
		armoured and served cable working voltage 1100volts grade 70sq.mm (Three Core)	m	44.06	406.98	48.47	411.39
	(xv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 95sq.mm (Three Core)		11.00	100.00	10.11	111100
			m	44.06	476.89	48.47	481.30
	(xvi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 120sq.mm (Three Core)					
			m	59.37	571.72	65.31	577.66
	(xvii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 150sq.mm (Three Core)					
			m	69.58	677.91	76.54	684.87
	(xviii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 185sq.mm (Three Core)					
	(xix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed	m	69.58	796.93	76.54	803.89
	(XIX)	armoured and served cable working voltage 1100volts grade 240sq.mm (Three Core)		69.58	992.27	70.54	000 00
	(xx)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 300sq.mm (Three Core)	m	09.36	992.21	76.54	999.23
			m	69.58	1186.30	76.54	1193.26
	(xxi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 400sq.mm (Three Core)	m	69.58	1456.60	76.54	1463.56
	(xxii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (3 ½ Core)					
	(variii)	Alternative conductor VLDE/DVC insulated DVC abouthed	m	38.96	271.32	42.86	275.22
	(xxiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (3 ½ Core)	m	38.96	301.63	42.86	305.53
	(xxiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (3 ½ Core)					
	(xxv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts	m	38.96	366.47	42.86	370.37
	,	grade 70sq.mm (3 ½ Core)	m	44.06	453.92	48.47	458.33
	(xxvi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 95sq.mm (3 ½ Core)		44.00	500.00	40.47	500.00
			m	44.06	533.88	48.47	538.29

Page 416 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxvii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 120sq.mm (3 ½ Core)	m	59.37	662.60	65.31	668.54
	(xxviii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 150sq.mm (3 ½ Core)					
	(xxix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 185sq.mm (3 ½ Core)	m	69.58	758.60	76.54	765.56
	(xxx)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 240sq.mm (3 ½ Core)	m	69.58	908.83	76.54 76.54	
	(xxxi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 300sq.mm (3 ½ Core)	m m	69.58	1349.52	76.54	
	(xxxii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 400sq.mm (3 ½ Core)					
	(xxxiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (4 Core)	m	69.58	1663.95	76.54	1670.91
	(xxxiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts	m	38.96	205.42	42.86	209.32
	()	grade 10sq.mm (4 Core)	m	38.96	211.29	42.86	215.19
	(xxxv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (4 Core)		00.00	000.07	40.00	0.40.07
33.10 B	VID	DE / DVC INCLUATED ADMOLIDED CADLES /LOOSE).	m	38.96	239.37	42.86	243.27
33.10 B		PE/ PVC INSULATED ARMOURED CABLES (LOOSE): & laying of aluminium conductor XLPE/ P.V.C.					
	insulate	ed armoured and served cable to be laid loose in the greench or pipe as per PWD General Specidications					
	(i)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (Twin Core)	m	7.65	85.54	8.42	86.31
	(ii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (Twin Core)	m	7.65	98.40	8.42	99.17
	(iii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (Twin Core)	m	7.65	105.58	8.42	106.35
	(iv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (Twin Core)	m	7.65	116.02	8.42	116.79
	(v)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (Twin Core)					
			m	7.65	140.18	8.42	140.95

Page 417 CSR - 2010

Sr. No.		Description Unit Plains		ains	Sub Mou	untainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (Twin Core)	m	7.65	177.40	8.42	178.17
	(vii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 4sq.mm (Three Core)	m	7.65	81.62	8.42	82.39
	(viii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (Three Core)	m	7.65	97.09	8.42	97.86
	(ix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (Three Core)	m	7.65	113.42	8.42	114.19
	(x)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (Three Core)					
	(xi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (Three Core)	m m	7.65 7.65	125.17 152.39	8.42 8.42	125.94 153.16
	(xii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (Three Core)	m	7.65	191.69	8.42	192.46
	(xiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (Three Core)	m	7.65	238.39	8.42	239.16
	(xiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 70sq.mm (Three Core)	m	10.21	311.79	11.23	312.81
	(xv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 95sq.mm (Three Core)	m	10.21	381.70	11.23	382.72
	(xvi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 120sq.mm (Three Core)					
	(xvii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 150sq.mm (Three Core)	<u>m</u>	15.31	466.32	16.84	467.85
	(xviii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 185sq.mm (Three Core)	m m	22.96	569.94	25.26 25.26	572.24 691.27
	(xix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 240sq.mm (Three Core)	m	22.96	884.30	25.26	886.60
	(xx)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 300sq.mm (Three Core)	m	22.96	1078.34	25.26	1080.64

Page 418 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 400sq.mm (Three Core)	m	22.96	1348.63	25.26	1350.93
	(xxii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (3 ½ Core)					
	(xxiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (3 ½ Core)	m	7.65	178.67	8.42	179.44
	(xxiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (3 ½ Core)	m	7.65	208.98	8.42	209.75
	(xxv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 70sq.mm (3 ½ Core)	m m	7.65	273.81 358.73	11.23	274.58 359.75
	(xxvi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 95sq.mm (3 ½ Core)	m	10.21	438.69	11.23	439.71
	(xxvii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 120sq.mm (3 ½ Core)	m	15.31	557.20	16.84	558.73
	(xxviii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 150sq.mm (3 ½ Core)	m	22.96	650.63	25.26	652.93
	(xxix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 150sq.mm (3 ½ Core)	m	22.96	800.86	25.26	803.16
	(xxx)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 240sq.mm (3 ½ Core)		22.96	1018.27	25.26	1020.57
	(xxxi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 300sq.mm (3 ½ Core)	m	22.96	1241.56		1243.86
	(xxxii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 400sq.mm (3 ½ Core)	m	22.96	1555.99	25.26	1555.99
	(xxxiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (4 Core)	m	7.65	112.77	8.42	113.54
	(xxxiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (4 Core)	m	7.65	118.64	8.42	119.41
	(xxxv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (4 Core)		7.65		8.42	147.48
33.10 C	XLPE/ SURFA	•	m	7.05	140.71	0.42	147.40

Page 419 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	alumini and in	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed ium conductor un-armoured cable working voltage upto cluding 1100 volts grade (on surface) as per PWD Il Specifications 2010:-					
	(i)	Supply and laying of XLPE/ P.V.C. insulated P.V.C. sheathed aluminium conductor un-armoured cable working voltage upto and including 1100 volts grade (on surface) as per PWD General Specifications 2010:-	m	10.21	88.77	11.23	89.79
	(ii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Twin Core)	m	10.21	100.26	11.23	101.28
	(iii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core)					
	(iv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (Twin Core)	m m	10.21	115.28 120.30	11.23	116.30
	(v)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 35sq.mm (Twin Core)	m	10.21	159.60	11.23	160.62
	(vi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 50sq.mm (Twin Core)	m	10.21	179.08	11.23	180.10
	(vii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 4sq.mm (Three Core)	m	10.21	86.55	11.23	87.57
	(viii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Three Core)	m	10.21	97.00	11.23	98.02
	(ix)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Three Core)	m	10.21	114.63	11.23	115.65
	(x)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Three Core)	m	10.21	126.38	11.23	127.40
	(xi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (Three Core)	_	40.24			
	(xii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 35sq.mm (Three Core)	m m	10.21	155.76 197.36	11.23	156.78
	(xiii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 50sq.mm (Three Core)	m m	10.21	241.93	11.23	242.95
	(xiv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 70sq.mm (Three Core)	m	15.31	314.17	16.84	315.70
			111	10.01	J14.17	10.04	313.70

Page 420 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 95sq.mm (Three Core)		15.31	200.24	16.94	204.04
	(xvi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 120sq.mm (Three Core)	m m	22.96	380.31 486.79	16.84 25.26	381.84 489.09
	(xvii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 150sq.mm (Three Core)	m	30.62	583.83	33.68	586.89
	(xviii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 185sq.mm (Three Core)	m	30.62	698.67	33.68	701.73
	(xix)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 240sq.mm (Three Core)	m	30.62	880.37	33.68	883.43
	(xx)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 300sq.mm (Three Core)	m	30.62	1065.01	33.68	1068.07
	(xxi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 400sq.mm (Three Core)					
	(xxii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (3 ½ Core)	<u> </u>	30.62	1328.64	33.68	1331.70
	(xxiii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade	m	10.21	178.48	11.23	179.50
	(xxiv)	35sq.mm (3 ½ Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 50sq.mm (3 ½ Core)	m	10.21	217.96	11.23	218.98
	(xxv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 70sq.mm (3 ½ Core)	m	10.21	272.81	11.23	273.83
	(xxvi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 95sq.mm (3 ½ Core)	m	15.31	356.08	16.84	357.61
	(xxvii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 120sq.mm (3 ½ Core)	m	15.31	432.61	16.84	434.14
	(xxviii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade	m	22.96	534.99	25.26	537.29
		150sq.mm (3 ½ Core)	m	30.62	657.55	33.68	660.61
	(xxix)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 185sq.mm (3 ½ Core)					
			m	30.62	800.26	33.68	803.32

Page 421 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxx)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 240sq.mm (3 ½ Core)					
	(xxxi)	XLPE/ PVC insulated PVC sheathed aluminium conductor	m	30.62	1009.51	33.68	1012.57
	(۸۸۸۱)	unarmoured cable working voltage 1100volts grade 300sq.mm (3 ½ Core)					
			m	30.62	1221.96	33.68	1225.02
	(xxxii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 400sq.mm (3 ½ Core)					
			m	30.62	1519.15	33.68	1522.21
	(xxxiii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (4 Core)					
			m	10.21	108.10	11.23	109.12
	(xxxiv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (4 Core)					
			m	10.21	126.77	11.23	127.79
	(xxxv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (4 Core)					
			m	10.21	145.51	11.23	146.53
33.10 D	THE EX	PVC INSULATED UN-ARMOURED CABLES (LOOSE IN ISTING TRENCH OR PIPE):					
33.10 D	Supply alumini and inc	·					
33.10 D	Supply alumini and inc	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade					
33.10 D	Supply alumini and inc	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core)		7.65	49.70	8.42	50.47
33.10 D	Supply alumini and inc	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade	m				
33.10 D	Supply alumini and ince trench (i)	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Twin Core)	m m	7.65			
33.10 D	Supply alumini and inc trench	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade	m m	7.65	61.19	8.42	61.96
33.10 D	Supply alumini and ince trench (i)	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core)	m m				61.96
33.10 D	Supply alumini and ince trench (i) (ii) (iii)	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (Twin Core)	m m	7.65	61.19	8.42	61.96 76.97
33.10 D	Supply alumini and ince trench (i) (ii) (iii)	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core)	m m m	7.65 7.65	61.19 76.20 81.23	8.42 8.42 8.42	76.97 82.00
33.10 D	Supply alumini and ince trench (i) (ii) (iii)	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto sluding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (Twin Core)	m m m	7.65 7.65 7.65	61.19 76.20 81.23 108.56	8.42 8.42 8.42	76.97 82.00 109.33
33.10 D	Supply alumini and ince trench (i) (ii) (iii) (iv)	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto luding 1100 volts grade to be laid loose in the existing or pipe as per PWD General Specifications 2010:- XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 35sq.mm (Twin Core) XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 35sq.mm (Twin Core)	m m m m	7.65 7.65	61.19 76.20 81.23 108.56	8.42 8.42 8.42	50.47 61.96 76.97 82.00 109.33

Page 422 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(viii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (Three Core)	m	7.65	57.92	8.42	58.69
	(ix)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (Three Core)					
	(x)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (Three Core)	m m	7.65 7.65	75.55 87.30	8.42	76.32 88.07
	(xi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (Three Core)	m	7.65	116.69	8.42	117.46
	(xii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 35sq.mm (Three Core)	m	7.65	146.32	8.42	147.09
	(xiii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 50sq.mm (Three Core)	m	7.65	190.89	8.42	191.66
	(xiv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 70sq.mm (Three Core)					261.61
	(xv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 95sq.mm (Three Core)	m	10.21	260.59	11.23	
	(xvi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 120sq.mm (Three Core)	m m	10.21	326.72 403.64	11.23	327.74 405.17
	(xvii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 150sq.mm (Three Core)	m	22.96	500.68		502.98
	(xviii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 185sq.mm (Three Core)	m	22.96	615.51	25.26	617.81
	(xix)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 240sq.mm (Three Core)	m	22.96	797.22	25.26	799.52
	(xx)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 300sq.mm (Three Core)	m	22.96	981.85	25.26	984.15
	(xxi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 400sq.mm (Three Core)	m	22.96	1245.48	25.26	1247.78
	(xxii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 25sq.mm (3 ½ Core)	m	7.65			140.17

Page 423 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxiii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 35sq.mm (3 ½ Core)	m	7.65	166.92	8.42	167.69
	(xxiv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 50sq.mm (3 ½ Core)					
	(xxv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 70sq.mm (3 ½ Core)	m m	10.21	302.50	11.23	303.52
	(xxvi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 95sq.mm (3 ½ Core)	m	10.21	379.03	11.23	380.05
	(xxvii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 120sq.mm (3 ½ Core)	m	15.31	478.85	16.84	480.38
	(xxviii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 150sq.mm (3 ½ Core)	m	22.96		25.26	576.69
	(xxix)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 185sq.mm (3 ½ Core)	m	22.96	717.10	25.26	719.40
	(xxx)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 240sq.mm (3 ½ Core)	m	22.96	926.35	25.26	928.65
	(xxxi)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 300sq.mm (3 ½ Core)	m	22.96	1138.80	25.26	1141.10
	(xxxii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 400sq.mm (3 ½ Core)	m	22.96	1435.99		1438.29
	(xxxiii)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 6sq.mm (4 Core)	m	7.65		8.42	69.79
	(xxxiv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 10sq.mm (4 Core)	m	7.65			88.46
	(xxxv)	XLPE/ PVC insulated PVC sheathed aluminium conductor unarmoured cable working voltage 1100volts grade 16sq.mm (4 Core)	m	7.65	106.43	8.42	107.20
33.10 E	XLPE/ F	PVC INSULATED ARMOURED CABLES (ON SURFACE):					
	alumini and inc	and laying of XLPE/ P.V.C. insulated P.V.C. sheathed um conductor un-armoured cable working voltage upto cluding 1100 volts grade (on surface) as per PWD Specifications 2010:-					

Page 424 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(i)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (Twin Core)	m	10.21	124.61	11.23	125.63
	(ii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (Twin Core)					
	(iii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (Twin Core)	m m	10.21	137.47 144.65	11.23	138.49 145.67
	(iv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (Twin Core)	m	10.21	155.10	11.23	156.12
	(v)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (Twin Core)		10.21	191.22	11.23	192.24
	(vi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (Twin Core)	m_				
	(vii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 4sq.mm (Three Core)	m	10.21	228.45	11.23	229.47
	(viii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (Three Core)	m	10.21	120.70	11.23	121.72
	(ix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (Three Core)	m	10.21	136.17	11.23	137.19 153.52
	(x)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (Three Core)	m m	10.21	164.25	11.23	165.27
	(xi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (Three Core)	m	10.21	191.47	11.23	192.49
	(xii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (Three Core)	m	10.21	242.73	11.23	243.75
	(xiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (Three Core)		10.21			
	(xiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 70sq.mm (Three Core)	m		289.43	11.23	290.45
	(xv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 95sq.mm (Three Core)	<u> </u>	15.31	365.37	16.84	366.90
			m	15.31	435.28	16.84	436.81

Page 425 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xvi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 120sq.mm (Three Core)	m	22.96	549.47	25,26	551.77
	(xvii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 150sq.mm (Three Core)	m	30.62	653.10		656.16
	(xviii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 185sq.mm (Three Core)	m	30.62	772.12	33.68	775.18
	(xix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 240sq.mm (Three Core)	m	30.62	967.46	33.68	970.52
	(xx)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 300sq.mm (Three Core)	m	30.62	1161.50	33.68	1164.56
	(xxi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 400sq.mm (Three Core)	m	30.62	1431.79	33.68	1434.85
	(xxii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 25sq.mm (3 ½ Core)	m	10.21	217.75	11.23	218.77
	(xxiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 35sq.mm (3 ½ Core)					
	(xxiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 50sq.mm (3 ½ Core)	m	10.21	260.02 324.86	11.23	261.04 325.88
	(xxv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 70sq.mm (3 ½ Core)	m				
	(xxvi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 95sq.mm (3 ½ Core)	<u> </u>	15.31	412.31	16.84	413.84
	(xxvii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 120sq.mm (3 ½ Core)	<u>m</u>	15.31	492.27	16.84	493.80
	(xxviii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 150sq.mm (3 ½ Core)	m	22.96	613.33	25.26	615.63
	(xxix)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts	m	30.62	733.79	33.68	736.85
		grade 185sq.mm (3 ½ Core)	m	30.62	884.02	33.68	887.08

Page 426 CSR - 2010

Sr. No.		Description	Unit Plains		ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxx)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 240sq.mm (3 ½ Core)	m	30.62	1101.43	33.68	1104.49
	(xxxi)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 300sq.mm (3 ½ Core)	m	30.62	1324.72	33.68	1327.78
	(xxxii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 400sq.mm (3 ½ Core)					
	(xxxiii)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 6sq.mm (4 Core)	m	30.62	1639.15	33.68	1642.21
			m	10.21	151.85	11.23	152.87
	(xxxiv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 10sq.mm (4 Core)					
			m	10.21	157.72	11.23	158.74
	(xxxv)	Aluminium conductor XLPE/ PVC insulated PVC sheathed armoured and served cable working voltage 1100volts grade 16sq.mm (4 Core)					
33.11		HEAVY CHACE WELDED CONDUIT DIDES.	m	10.21	185.79	11.23	61.00
33.11	0	HEAVY GUAGE WELDED CONDUIT PIPES:					
	inspect	& erection of pipe for wiring purposes including bends, ion boxes etc., where necessary including painting as D General Specifications 2010:-					
	(i)	Heavy gauge welded conduit pipe 20mm dia. (ISI marked 1.60mm thick) On Surface	m	4.08	68.44	4.49	68.85
	(ii)	Heavy gauge welded conduit pipe 25mm dia. (ISI marked 1.60mm thick) On Surface	m	4.08	84.32	4.49	84.73
	(iii)	Heavy gauge welded conduit pipe 32mm dia. (ISI marked 1.60mm thick) On Surface	m	6.12	121.60	6.73	122.21
	(iv)	Heavy gauge welded conduit pipe 40mm dia. (ISI marked 2mm thick) On Surface	m	6.12	197.39	6.73	198.00
	(v)	Heavy gauge welded conduit pipe 50mm dia. (ISI marked 2mm thick) On Surface	m	6.12	334.13	6.73	334.74
	(vi)	Heavy gauge welded conduit pipe 20mm dia. (ISI marked 1.60mm thick) Flushed	m	15.07	80.71	16.58	82.22
	(vii)	Heavy gauge welded conduit pipe 25mm dia. (ISI marked 1.60mm thick) Flushed	m	15.07	95.46	16.58	96.97
	(viii)	Heavy gauge welded conduit pipe 32mm dia. (ISI marked 1.60mm thick) Flushed	m	17.27	133.00	19.00	134.73
	(ix)	Heavy gauge welded conduit pipe 40mm dia. (ISI marked 2mm thick) Flushed	m	17.27	209.44	19.00	211.17
	(x)	Heavy gauge welded conduit pipe 50mm dia. (ISI marked 2mm thick) Flushed	m	17.27	346.83	19.00	348.56

Page 427 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xi)	Supply and erection of 20mm dia. heavy gauge welded conduit pipe (1.60mm thick) suspension rod for ceiling fan complete in all respect as desired by the Engineer-incharge.					
33.12		PVC, HDPE PIPES & PVC FLEXIBLE PIPES:	m	11.12	80.98	12.23	82.09
	for wiri	& erection of PVC pipes & HDPE pipes (fire retardant) ing purposes including bends, inspection boxes etc., necessary including other petty material as per PWD I Specifications 2010:-					
	(i)	Heavy gauge PVC conduit pipe 20mm dia. (ISI marked 2mm thick) On Surface	m	3.06	27.48	3.37	27.79
	(ii)	Heavy gauge PVC conduit pipe 25mm dia. (ISI marked 2mm thick) On Surface	m	3.06	35.26	3.37	35.57
	(iii)	Heavy gauge PVC conduit pipe 32mm dia. (ISI marked 2mm thick) On Surface	m	4.59	53.28	5.05	53.74
	(iv)	Heavy gauge PVC conduit pipe 40mm dia. (ISI marked 2mm thick) On Surface	m	4.59	69.71	5.05	70.17
	(v)	Heavy gauge PVC conduit pipe 50mm dia. (ISI marked 2mm thick) On Surface	m	4.59	93.83	5.05	94.29
	(vi)	Heavy gauge PVC conduit pipe 20mm dia. (ISI marked 2mm thick) Flushed	m	6.59	32.29	7.25	32.95
	(vii)	Heavy gauge PVC conduit pipe 25mm dia. (ISI marked 2mm thick) Flushed	m	6.59	38.95	7.25	39.61
	(viii)	Heavy gauge PVC conduit pipe 32mm dia. (ISI marked 2mm thick) Flushed	m	7.77	56.70	8.55	57.48
	(ix)	Heavy gauge PVC conduit pipe 40mm dia. (ISI marked 2mm thick) Flushed	m	7.77	73.78	8.55	74.56
	(x)	Heavy gauge PVC conduit pipe 50mm dia. (ISI marked 2mm thick) Flushed	m	7.77	98.56	8.55	99.34
	(xi)	HDPE electrical conduit pipe 20mm dia. (ISI marked) On Surface	m	3.06	65.96	3.37	66.27
	(xii)	HDPE electrical conduit pipe 25mm dia. (ISI marked) On Surface	m	3.06	83.31	3.37	83.62
	(xiii)	HDPE electrical conduit pipe 32mm dia. (ISI marked) On Surface	m	4.59	122.17	5.05	122.63
	(xiv)	HDPE electrical conduit pipe 40mm dia. (ISI marked) On Surface	 	4.59	163.58	5.05	164.04
	(xv)	HDPE electrical conduit pipe 20mm dia. (ISI marked) Flushed	m	10.99	75.17	12.09	76.27
	(xvi)	HDPE electrical conduit pipe 25mm dia. (ISI marked) Flushed	m	10.99	91.40	12.09	92.50
	(xvii)	HDPE electrical conduit pipe 32mm dia. (ISI marked) Flushed	m	12.17	130.00	13.39	131.22
	(xviii)	HDPE electrical conduit pipe 40mm dia. (ISI marked) Flushed	m	12.17	172.06	13.39	173.28

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xix)	Supply and erection of PVC flexible pipe complete with compression glands, having locking arrangement, check-nuts as required:-					
	(a)	PVC flexible pipe 20mm dia.	m	4.07	31.30	4.48	31.71
	(b)	PVC flexible pipe 25mm dia.	m	4.07	37.22	4.48	37.63
	(c)	PVC flexible pipe 32mm dia.	m	4.07	58.54	4.48	58.95
	(d)	PVC flexible pipe 40mm dia.	m	4.07	71.55	4.48	71.96
	(xx)	Supply and erection of PVC flexible pipe complete without compression glands, locking arrangement, check-nuts as required :-					
	(a)	PVC flexible pipe 20mm dia.	m	2.05	10.34	2.26	10.55
	(b)	PVC flexible pipe 25mm dia.	m	2.05	11.51	2.26	11.72
	(c)	PVC flexible pipe 32mm dia.	m	2.05	16.26	2.26	16.47
	(d)	PVC flexible pipe 40mm dia. NIZED IRON PIPES AND G.I. EARTHING:	m	2.05	22.18	2.26	22.39
	painting	inspection boxes etc., where necessary including g as per PWD General Specifications 2010:-					
	(i)	Galvanized iron pipe 15mm dia. (A class) Flushed	m	15.07	98.21	16.58	99.72
	(ii)	Galvanized iron pipe 20mm dia. (A class) Flushed	m	15.07	129.48	16.58	130.99
	(iii)	Galvanized iron pipe 25mm dia. (A class) Flushed	m	15.07	168.67	16.58	170.18
	(iv)	Galvanized iron pipe 32mm dia. (A class) Flushed	m	17.27	221.54		223.27
	(v)	Galvanized iron pipe 40mm dia. (A class) Flushed	m	17.27	262.25	19.00	263.98
	(vi)	Galvanized iron pipe 50mm dia. (A class) Flushed	m	17.27	323.90	19.00	325.63
	(vii)	G.I. EARTHING:			0_00	10100	
	(a)	Earthing of Sheet metal/ iron clad Switches and metallic cases etc., with No. 8 S.W.G. (4mm dia.) G.I. wire in 15mm dia G.I. pipe partly recessed and partly on surface complete with 135cm long 50mm dia. G.I. earth pipe with G.I. reducing socket (50mm x 15mm) including erection of the same, 10 metre below ground level with necessary charcoal & salt mixture etc., up to 13 metre in length (including boring & refilling).		1367.45	3198.00	1504.20	3334.75

Page 429 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(c)	Earthing of Sheet metal/ iron clad Switches and metallic cases etc., with No. 7/12 S.W.G. (7/2.80mm dia.) G.I. wire in 20mm dia G.I. pipe partly recessed and partly on surface complete with 135cm long 50mm dia. G.I. earth pipe with G.I. reducing socket (50mm x 20mm) including erection of the same, 10 metre below ground level with necessary charcoal & salt mixture etc., up to 13 metre in length (including boring & refilling).	each	1367.45	3764.32	1504.20	3901.07
	(d)	Supply and Erection of earth rod 20 mm dia for providing earth connections upto line earth with G.I. Wire No. 8SWG. The rod shall be tapered at one end and flatted on other end. The hole size 10mm dia shall be drilled on the flatened side for facilitating connection with G.I. wire and thimble etc. The road shall be grouted upto complete length vertically.					
	(i)	GI Earth rod 20 mm dia. 3 mtr. Long	m	122.48	632.40	134.73	644.65
	(ii)	GI Earth rod 20 mm dia. 4.5 mtr. Long	m	163.30	868.51	179.63	884.84
	(iii)	GI Earth rod 20 mm dia. 6 mtr. Long	m	183.71	1051.66	202.08	1070.03
	(viii)	G.I. EARTHING (AS ADDITIONAL LENGTH):					
	(a)	Earthing of metallic cases etc., with G.I. wire No. 8 S.W.G. (4mm dia.) in 15mm dia. G.I. pipe on surface including painting etc. (as additional length)	m	7.53	100.24	8.28	100.99
	(b)	Earthing of metallic cases etc., with G.I. wire No. 7/14 S.W.G. (7/2.18mm dia.) in 20mm dia. G.I. pipe on surface including painting etc. (as additional length)	m	7.53	139.56	8.28	140.31
	(c)	Earthing of metallic cases etc., with G.I. wire No. 7/12 S.W.G. (7/2.80mm dia.) in 20mm dia. G.I. pipe on surface including painting etc. (as additional length)	m	7.53	148.37	8.28	149.12
	(d)	Earthing of metallic cases etc., with G.I. wire No. 8 S.W.G. (4mm dia.) in 15mm dia. G.I. pipe recessed in wall and floor etc., (as additional length)					
	(e)	Earthing of metallic cases etc., with G.I. stranded wire No. 7/14 S.W.G. (7/2.18mm) in 20mm dia. G.I. pipe recessed in wall and floor etc. (as additional length)	m	23.72	115.70	26.09	118.07
	(f)	Earthing of metallic cases etc., with G.I. stranded wire No. 7/12 S.W.G. (7/2.80mm) in 20mm dia. G.I. pipe recessed in wall and floor etc. (as additional length)	m m	23.72	153.52 154.80	26.09	155.89 157.17
	(viii)	BONDING TO EARTH WITH G.I. WIRE:		20.72	104.00	20.00	107.17
	(a)	Bonding to earth with G.I. wire No. 8S.W.G. (4mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (on surface) including painting etc.	m	4.09	73.10	4.50	73.51
	(b)	Bonding to earth with G.I. wire No. 7/14S.W.G. (7/2.18mm dia) in 20mm dia. heavy gauge (1.6mm thick) welded conduit pipe (on surface) including painting etc.	m	4.09	82.17	4.50	82.58
	(c)	Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6mm thick) welded conduit pipe (on surface) including painting etc.		7.03	02.17	4.00	
			m	4.09	102.15	4.50	102.56

Page 430 CSR - 2010

	Description	Unit	Plains		Sub Mountainous	
			Labour Rate	Through Rate	Labour Rate	Through Rate
	2	3	4	5	6	7
(d)	Bonding to earth with G.I. wire No. 8S.W.G. (4mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed).	m	24.53	92.58	26.98	95.03
(e)	Bonding to earth with G.I. wire No. 7/14S.W.G. (7/2.18mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed).	m	24.53	101.64	26.98	104.09
(f)	Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed).	m	24.53	144.56	26.98	147.01
(g)	Bonding to earth with 4mm dia. G.I. wire behind casing or fixed with stapples on wall.	m	1.83	9.81	2.01	9.99
	COPPER EARTHING:					
(i)	Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.		1058.14	13791.75	1163.95	13897.56
(ii)	Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.					
	(e) (f) (g)	 (d) Bonding to earth with G.I. wire No. 8S.W.G. (4mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (e) Bonding to earth with G.I. wire No. 7/14S.W.G. (7/2.18mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (f) Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (g) Bonding to earth with 4mm dia. G.I. wire behind casing or fixed with stapples on wall. COPPER EARTHING: (i) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation. (ii) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel f	(d) Bonding to earth with G.I. wire No. 8S.W.G. (4mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (e) Bonding to earth with G.I. wire No. 7/14S.W.G. (7/2.18mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (f) Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (g) Bonding to earth with 4mm dia. G.I. wire behind casing or fixed with stapples on wall. (i) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation. (ii) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of br	(d) Bonding to earth with G.I. wire No. 8S.W.G. (4mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (e) Bonding to earth with G.I. wire No. 7/14S.W.G. (7/2.18mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (f) Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (g) Bonding to earth with 4mm dia. G.I. wire behind casing or fixed with stapples on wall. COPPER EARTHING: (i) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm around the hole of excavation. (ii) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1.4 cement plaster and haudi covered with cast iron lid having	(d) Bonding to earth with G.I. wire No. 8S.W.G. (4mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (e) Bonding to earth with G.I. wire No. 7/14S.W.G. (7/2.18mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (f) Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (g) Bonding to earth with 4mm dia. G.I. wire behind casing or fixed with stapples on wall. (g) Bonding to earth with 4mm dia. G.I. wire behind casing or fixed with stapples on wall. COPPER EARTHING: (i) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm around the hole of excavation. (ii) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level and having size 300mm x 300mm around the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300	(d) Bonding to earth with G.I. wire No. 8S.W.G. (4mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (e) Bonding to earth with G.I. wire No. 7/14S.W.G. (7/2.18mm dia) in 20mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (f) Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (g) Bonding to earth with G.I. wire No. 7/12S.W.G. (7/2.80mm dia) in 25mm dia. heavy gauge (1.6 mm thick) welded conduit pipe (flushed). (g) Bonding to earth with 4mm dia. G.I. wire behind casing or fixed with stapples on wall. COPPER EARTHING: (i) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having bore length). G.I. pipe 20mm dia. (Acclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm around the hole of excavation. (ii) Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 20 mm x 3 mm thick lectrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape or wall and in floor etc., up to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape or wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (Acclass) should be laid in the hole of excavation from bore s

Page 431 CSR - 2010

Sr. No.	Description	Unit	PI	ains	Sub Mou	untainous
			Labour Rate	Through Rate	Labour Rate	Through Rate
1	2	3	4	5	6	7
	(iii) Earthing of Sheet metal/ iron clad switches and metallicases etc., with 25 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 12 cm x 3 mm thick tinned copper plate (made cylindrical burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded be salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre is length (including bore length). G.I. pipe 20mm dia. (A class) should be laid in the hole of excavation from bor surface level to 1 feet below ground level and having wirmesh funnel fixed on the top level of the pipe. 300mm 300mm x 300mm deep haudi of bricks finished with 1: cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.	er 0 0 1) bif y e e n - e e e x				
	(iv) Earthing of Sheet metal/ iron clad switches and metallicases etc., with 25 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 12 cm x 3 mm thick tinned copper plate (made cylindrical burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded be salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre is length (including bore length). G.I. pipe 20mm dia. (A class) should be laid in the hole of excavation from bor surface level to 1 feet below ground level and having wirmesh funnel fixed on the top level of the pipe. 300mm 300mm x 300mm deep haudi of bricks finished with 1: cement plaster and haudi covered with cast iron lid havin size 300mm x 300mm around the hole of excavation.	er 0 0 1) bif y e e n e e e x 4	1058.14	14771.31	1163.95	14877.12
	(v) Earthing of Sheet metal/ iron clad switches and metallicases etc., with 30 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 12 cm x 3 mm thick tinned copper plate (made cylindrical burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded be salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre is length (including bore length). G.I. pipe 20mm dia. (A class) should be laid in the hole of excavation from bor surface level to 1 feet below ground level and having wir mesh funnel fixed on the top level of the pipe. 300mm 300mm x 300mm deep haudi of bricks finished with 1: cement plaster and haudi covered with cast iron lid havin size 300mm x 300mm around the hole of excavation.	er 0 0 1) bif y e e n - e e e x	1987.52	20476.60	2186.27	20675.35
		each	1058.14	15743.56	1163.95	15849.37

Page 432 CSR - 2010

Sr. No.		Description	Unit	Pl	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 30 mm x 3 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.l. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.					
			each	1987.52	22196.75	2186.27	22395.50
	(vii)	Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 25 mm x 5 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.		4050 444	40020.00	14.02.05	40444.70
	(viii)	Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 25 mm x 5 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.		1058.14	18038.98	1163.95	18144.79
			each	1987.52	26257.85	2186.27	26456.60

Page 433 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
		Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 40 mm x 5 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) ourried 10 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.					
		Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 40 mm x 5 mm thick electrolytic copper tape rivetted (with 10 nos. copper rivets) to 30 cm x 120 cm x 3 mm thick tinned copper plate (made cylindrical) courried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper tape on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (Aclass) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.		1058.14	21176.72		21282.53
	t r r k r t e e	Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 8 SWG (4mm dia.) electrolytic copper wire thimbled (with 1 nos. copper thimble) to 30 cm x 60 cm x 3 mm thick tinned copper plate (made cylindrical) burried 10 metre below ground level in the hole of excavation having core dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper wire run through 20mm dia. G.I. pipe (A-Class) on wall and in floor etc., up to 13 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground evel and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.		1987.52	34793.91	2186.27 1163.95	34992.66

Page 434 CSR - 2010

Sr. No.		Description	Unit	Pl	ains	Sub Mo	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xii)	Earthing of Sheet metal/ iron clad switches and metallic cases etc., with 8 SWG (4mm dia.) electrolytic copper wire thimbled (with 1 nos. copper thimble) to 30 cm x 60 cm x 3 mm thick tinned copper plate (made cylindrical) burried 20 metre below ground level in the hole of excavation having bore dia. 125mm and surrounded by salt & charcoal dust mixture (20 kg.) including fixing the copper wire run through 20mm dia. G.I. pipe (A-Class) on wall and in floor etc., up to 23 metre in length (including bore length). G.I. pipe 20mm dia. (A-class) should be laid in the hole of excavation from bore surface level to 1 feet below ground level and having wire mesh funnel fixed on the top level of the pipe. 300mm x 300mm x 300mm deep haudi of bricks finished with 1:4 cement plaster and haudi covered with cast iron lid having size 300mm x 300mm around the hole of excavation.					
			each	1058.14	9047.92	1163.95	9153.73
	(xiii)	Supply and Erection of 20mm x 3mm thick copper tape (As additional length).	m	22.45	327.18	24.70	329.43
	(xiv)	Supply and Erection of 25mm x 3mm thick copper tape (As additional length).	m	22.45	402.52	24.70	404.77
	(xv)	Supply and Erection of 30mm x 3mm thick copper tape (As additional length).	m	22.45	477.30	24.70	479.55
	(xvi)	Supply and Erection of 25mm x 5mm thick copper tape (As additional length).	m	22.45	653.87	24.70	656.12
	(xvii)	Supply and Erection of 40mm x 5mm thick copper tape (As additional length).	m	22.45	1025.01	24.70	
	(xviii)	Supply and Erection of 8 SWG 4mm dia copper wire run through 20mm dia. GI pipe (A-Class) (As additional length).		22.45	192.34	24.70	
33.15	(XiX)	Supply and Erection of 8 SWG 4mm dia copper wire run through 20mm dia. Heavy guage welded conduit pipe (As additional length). Y AND ERECTION OF WIRING ACCESSORIES:		22.45	144.41	24.70	146.66
	Supply sockets accesso includir	and erection of switches, sockets, power switch and and other accessories (flush piano type/ modular pries) in the existing bakelite/ modular cover frame and connections and petty material etc.					
	(i)	Single pole 6amp. switch flush piano type	each	5.10	19.85	5.61	20.36
	(ii)	Two way 6amp. switch flush piano type	each	5.10	23.87	5.61	24.38
	(iii)	Single pole 16amp. switch flush piano type	each	10.20	54.85	11.22	55.87
	(iv)	Single pole 6amp. bell push	each	5.10	23.87	5.61	24.38
	(v)	3pin 6amp. wall socket flush piano type	each	6.80	28.09	7.48	28.77
	(vi)	3pin 16amp. wall socket flush piano type	each	10.20	64.71	11.22	65.73
	(vii)	Step type fan regulator (socket size)	each	6.80	189.96	7.48	190.64
	(viii)	TV socket flush piano type (switch size)	each	5.10	28.33	5.61	28.84
	(ix)	Telephone socket RJ11 flush piano type (switch size) RJ45 flush piano type modem jack for computer with	each	5.10	36.50	5.61	37.01
	(xi)	shutter (switch size) 6amp. one way modular switch (one module)	each each	5.10 5.10	89.08 68.98	5.61 5.61	89.59 69.49

Page 435 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xii)	6amp. two way modular switch (one module)	each	5.10	82.32	5.61	82.83
	(xiii)	16/20amp. one way modular switch (one module)	each	10.20	105.68	11.22	106.70
	(xiv)	6amp. one way modular bell push (one module)	each	5.10	81.62	5.61	82.13
	(xv)	6amp. 3pin modular socket with shuttered (two module)	each	6.80	105.09	7.48	105.77
	(xvi)	16/20amp. 3pin modular socket with shuttered (two module)	each	10.20	153.42	11.22	154.44
	(xvii)	Step type modular electronic fan regulator 100watts (two module)	each	6.80	342.36	7.48	343.04
	(xviii)	Modular TV socket (one module)	each	5.10	72.50	5.61	73.01
	(xix)	Modular Telephone socket (RJ-11) one module					
	(xx)	RJ45 modular type modem jack for computer one module	each	5.10	85.84	5.61	86.35
	(^^)	1045 modular type modern jack for computer one module	each	5.10	302.76	5.61	303.27
	(xxi)	Ceiling rose (flush piano type)	each	5.10	26.54	5.61	27.05
	(xxii)	Bakelite batten holder large size					
	(xxiii)	Call bell 220/230 volts AC ding dong	each	5.10	26.53	5.61	27.04
33 16	` ′	URE CIRCUIT BREAKERS/ RCBO's/ RCCB's:	each	5.10	89.98	5.61	90.49
	RCCB's Genera	and erection of Miniature Circuit Breakers/ RCBO's/s in the existing MCB distribution board as per PWD Specifications 2010 including connections with exize of thimbles/lugs. GROUP-A: (Siemens (Beta Guard), Legrand (Lexic) &					
		Schneider (Neo Break), L&T (Hager)					
	(i)	Miniature circuit breaker single pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	aaah	6.72	231.37	7.40	222.04
	(ii)	Miniature circuit breaker single pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	6.73		7.40	232.04
	/··· >	, , , ,	each	6.73	165.01	7.40	165.68
	(iii)	Miniature circuit breaker single pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	6.73	343.70	7.40	344.37
	(iv)	Miniature circuit breaker single pole 50, 63amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	6.73	389.65	7.40	390.32
	(v)	Miniature circuit breaker double pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/415 volts 50cycles AC supply					
	(vi)	Miniature circuit breaker double pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	10.20	612.67 490.13	11.22	613.69 491.15
	(vii)	Miniature circuit breaker double pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply		10.20		11.22	695.37
	(viii)	Miniature circuit breaker double pole 50, 63amp. (Breaking capacity 10kA, Curve-C)suitable for 240/ 415 volts 50cycles AC supply					
	I	335, 3.00 / 10 ouppi)	each	10.20	811.78	11.22	812.80

Page 436 CSR - 2010

Sr. No.		Description		PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(ix)	Miniature circuit breaker triple pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	820.37	15.05	821.74
	(x)	Miniature circuit breaker triple pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	733.58	15.05	734.95
	(xi)	Miniature circuit breaker triple pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	1029.69	15.05	1031.06
	(xii)	Miniature circuit breaker triple pole 50, 63amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	1152.23	15.05	1153.60
	(xiii)	Miniature circuit breaker four pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	20.41	1230.43	22.45	1232.47
	(xiv)	Miniature circuit breaker four pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	20.41	1051.74	22.45	1053.78
	(xv)	Miniature circuit breaker four pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	20.41	1398.93	22.45	1400.97
	(xvi)	Miniature circuit breaker four pole 50, 63amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	20.41	1546.98	22.45	1549.02
		GROUP-B: (Havell's, HPL, ABB, Indo Asian & other brands approved by PWD)					
	(xvii)	Miniature circuit breaker single pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	6.73	179.09	7.40	179.76
	(xviii)	Miniature circuit breaker single pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply		6.73	125.46		126.13
	(xix)	Miniature circuit breaker single pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply		6.73	261.79	7.40	262.46
	(xx)	Miniature circuit breaker single pole 50, 63amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	6.73	282.44	7.40	283.11
	(xxi)	Miniature circuit breaker double pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	10.20		11.22	486.77
	(xxii)	Miniature circuit breaker double pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply					
	(xxiii)	Miniature circuit breaker double pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts	each	10.20	393.17	11.22	394.19
		50cycles AC supply	each	10.20	547.80	11.22	548.82

Page 437 CSR - 2010

Sr. No.	Description		Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxiv)	Miniature circuit breaker double pole 50, 63amp. (Breaking capacity 10kA, Curve-C)suitable for 240/ 415 volts 50cycles AC supply	each	10.20	616.71	11.22	617.73
	(xxv)	Miniature circuit breaker triple pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	668.43	15.05	669.80
	(xxvi)	Miniature circuit breaker triple pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	591.91	15.05	593.28
	(xxvii)	Miniature circuit breaker triple pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	785.69	15.05	787.06
	(xxviii)	Miniature circuit breaker triple pole 50, 63amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	13.68	916.65	15.05	918.02
	(xxix)	Miniature circuit breaker four pole 0.5 to 4amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	20.41	937.18	22.45	939.22
	(xxx)	Miniature circuit breaker four pole 6 to 32amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	20.41	806.11	22.45	808.15
	(xxxi)	Miniature circuit breaker four pole 40amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply					
	(xxxii)	Miniature circuit breaker four pole 50, 63amp. (Breaking capacity 10kA, Curve-C) suitable for 240/ 415 volts 50cycles AC supply	each	20.41	1061.17	22.45	1063.21
		RCBO'S:	each	20.41	1205.93	22.45	1207.97
	(xxxiii)		each	10.20	1888.56	11.22	1889.58
	(xxxiv)	RCBO (Earth leakage, overload and short circuit protection device) double pole 32amp., sensitivity 30mA (Breaking capacity 10kA and as per standard IEC 61009) suitable for 240/415 volts 50 cycles AC supply	each	10.20	2079.37	11.22	2080.39
	(xxxv)	RCBO (Earth leakage, overload and short circuit protection device) double pole 40amp., sensitivity 30mA (Breaking capacity 10kA and as per standard IEC61009) suitable for 240/415 volts 50 cycles AC supply	each	10.20	2413.76	11.22	2414.78
	(xxxvi)	RCBO (Earth leakage, overload and short circuit protection device) double pole 63amp., sensitivity 30mA (Breaking capacity 10kA and as per standard IEC 61009) suitable for 240/415 volts 50 cycles AC supply	Gauli	10.20	2413.70	11.22	2414.70
		,	each	10.20	2814.45	11.22	2815.47

Page 438 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxxvii)	RCBO (Earth leakage, overload and short circuit protection device) double pole 16/25amp., sensitivity 100/300mA (Breaking capacity 10kA and as per standard IEC 61009) suitable for 240/415 volts 50 cycles AC supply	each	10.20	2279.32	11.22	2280.34
	(xxxviii)	RCBO (Earth leakage, overload and short circuit protection device) double pole 32amp., sensitivity 100/300mA (Breaking capacity 10kA and as per standard IEC 61009) suitable for 240/415 volts 50 cycles AC supply					
	(xxxix)	RCBO (Earth leakage, overload and short circuit protection device) double pole 40amp., sensitivity 100/300mA (Breaking capacity 10kA and as per standard IEC 61009) suitable for 240/415 volts 50 cycles AC supply		10.20	2319.97	11.22	2320.99
	(xl)	RCBO (Earth leakage, overload and short circuit protection device) double pole 63amp., sensitivity 100/300mA (Breaking capacity 10kA and as per standard IEC 61009) suitable for 240/415 volts 50 cycles AC supply	each	10.20	2600.40	11.22	2601.42
			each	10.20	3000.31	11.22	3001.33
	(xli)	RCCB's: Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 16/25amp., sensitivity 30mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply					
	(xlii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 32/40amp., sensitivity 30mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		10.20	1628.28	11.22	1629.30
	(xliii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 63amp., sensitivity 30mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		10.20	1908.81 2189.34	11.22	1909.83 2190.36
	(xliv)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 16/25amp., sensitivity 100mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		10.20	1683.27	11.22	1684.29
	(xlv)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 32/40amp., sensitivity 100mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply					
	(xlvi)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 63amp., sensitivity 100mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		10.20	1983.99	11.22	1985.01
	(xlvii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 16/25amp., sensitivity 300mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		10.20	2291.45	11.22	2292.47
		-,, supp.,	each	10.20	1683.27	11.22	1684.29

Page 439 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xlviii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 32/40amp., sensitivity 300mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply	each	10.20	1983.99	11.22	1985.01
	(xlix)	Residual Current Circuit Breaker (RCCB for earth leakage protection) double pole 63amp., sensitivity 300mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply	each	10.20	2291.45	11.22	2292.47
	(1)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 16/25amp., sensitivity 30mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		20.41	2140.08	22.45	2142.12
	(li)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 32/40amp., sensitivity 30mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply	each	20.41	2198.42	22.45	2200.46
	(lii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 63amp., sensitivity 30mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply	each	20.41	2539.55	22.45	2541.59
	(liii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 16/25amp., sensitivity 100mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply					
	(liv)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 32/40amp., sensitivity 100mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply	each each	20.41	2237.70	22.45 22.45	2239.74 2271.15
	(lv)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 63amp., sensitivity 100mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		20.41	2636.05	22.45	2638.09
	(Ivi)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 16/25amp., sensitivity 300mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply		20.41	2237.70	22.45	2239.74
	(Ivii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 32/40amp., sensitivity 300mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply	each			22.45	
	(Iviii)	Residual Current Circuit Breaker (RCCB for earth leakage protection) four pole 63amp., sensitivity 300mA (as per standard IEC 61008) suitable for 240/415 volts 50 cycles AC supply	each each	20.41	2269.11 2636.05	22.45	2271.15
33.17		METAL DOUBLE DOOR DISTRIBUTION BOARD FOR CBO/ RCCB's:	Gauli	20.41	2000.00	22.40	

Page 440 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1	boards mounti existing Specifi	and erection of sheet metal double door distribution of suitable size and of required no. of ways for ing miniature circuit breakers/ RCBO's/ RCCB's in the g MCB distribution board as per PWD General cations 2010 including connections with suitable size of es and bonding to existing earth etc.	3	4	5	6	7
		GROUP-A: (Siemens (Beta Guard/Minigard), Legrand (Ekinoxe) & Schneider (Neo Break), L&T (Hager vision+)					
	(i)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 4 way each	each	74.43	890.99	81.87	898.43
	(ii)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 8 way each	oach	99 72	1216.72	07.50	1225 50
	(iii)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 12 way each	each	109.12	1492.41	97.59	1225.59 1503.32
	(iv)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 16 way each		109.12	1865.12	120.03	1876.03
	(v)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 4 way each	each	109.12	2408.82	120.03	2419.73
	(vi)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 6 way each					
	(vii)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 8 way each	each	109.12	2919.38 3493.24	120.03 155.96	2930.29 3507.42
	(viii)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 12 way each		141.78	5024.93	155.96	5039.11
	(ix)	Sheet metal double door T.P. & N. (vertical design) distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 4 way each					
			each	109.12	5421.13	120.03	5432.04

Sr. No.		Description		PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(x)	Sheet metal double door T.P. & N. (vertical design) distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 8 way each	h	444.70	0000 05	455.00	0077.40
	(xi)	Sheet metal double door T.P. & N. (vertical design) distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 12 way each	each	141.78	6862.95	155.96	6877.13
		GROUP-B: (Havell's, HPL, ABB, Standard & other brands approved by PWD)	each	141.78	8889.86	155.96	8904.04
		brands approved by 1 44b)					
	(xii)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 4 way each	each	74.43	659.96	81.87	667.40
	(xiii)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 8 way each					
			each	88.72	854.29	97.59	863.16
	(xiv)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 12 way each	each	109.12	1100.56	120.03	1111.47
	(xv)	Sheet metal double door S.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating MCB's/ RCBO/ RCCB's, 16 way each					
			each	109.12	1364.76	120.03	1375.67
	(xvi)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 4 way each	each	109.12	1742.55	120.03	1753.46
	(xvii)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/RCCB's for outgoing 6 way each	each	109.12	2124.70	120.03	2135.61
	(xviii)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/RCCB's for outgoing 8 way each	Caoli	103.12	2124.70	120.00	2100.01
	(xix)	Sheet metal double door T.P. & N. distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/		141.78	2646.73	155.96	2660.91
		RCCB's for outgoing 12 way each	each	141.78	3549.66	155.96	3563.84

Page 442 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xx)	Sheet metal double door T.P. & N. (vertical design) distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 4 way each		400.40	2252.40	400.00	2222.24
	(!\	Object mostal devikle does T.D. O. N. (contical design)	each	109.12	3958.13	120.03	3969.04
	(xxi)	Sheet metal double door T.P. & N. (vertical design) distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 8 way each					
			each	141.78	4680.03	155.96	4694.21
	(xxii)	Sheet metal double door T.P. & N. (vertical design) distribution board (dust protected) provided with bus bar, neutral link and din bar, suitable for incorporating FP/ TPN MCB's/ isolators for incoming and DP/ SP & N/ Single Pole MCB's/ RCBO/ RCCB's for outgoing 12 way each					
			each	141.78	6079.23	155.96	6093.41
	(xxiii)	Sheet metal plug and socket distribution board single pole MCB and neutral enclosure with a two pin and earth plug socket to incorporate in one single pole MCB 10amp.					
			each	76.48	845.17	84.13	852.82
	(xxiv)	Sheet metal plug and socket distribution board single pole MCB and neutral enclosure with a two pin and earth plug socket to incorporate in one single pole MCB 20amp.					
			each	76.48	909.06	84.13	916.71
	(xxv)	Sheet metal plug and socket distribution board triple pole MCB and earth enclosure with a three pin and earth plug socket to incorporate in one triple pole MCB 20amp.	each	76.48	1587.72	84.13	1595.37
	(xxvi)	Sheet metal plug and socket distribution board triple pole MCB and earth enclosure with a three pin and earth plug socket to incorporate in one triple pole MCB 30amp.	each	76.48	1861.51	84.13	1869.16
33.18		SHEET METAL IRON CLAD SWITCHES:					
	surface accordi includir bonding Specific	and erection of sheet metal iron clad switch on existing with G.I. bolts & nuts/ rag bolts and nuts etc., ing to the size of holes in the body of the enclosure ng connections with suitable size of thimbles and g to the existing earth as Per PWD General cations 2010.					
	(i)	Sheet metal iron clad double pole switch 32amp. 415 volts					
			each	102.05	1075.47	112.26	1085.68
	(ii)	Sheet metal iron clad double pole switch 63amp. 415 volts	each	102.05	2195.52	112.26	2205.73
	(iii)	Sheet metal iron clad double pole switch 100amp. 415 volts	each	136.09	4021.62	149.70	4035.23
	(iv)	Sheet metal iron clad double pole switch 200amp. 415 volts	each	136.09	6261.70	149.70	6275.31
	(v)	Sheet metal iron clad triple pole switch with neutral link 32amp. 415 volts	each	134.72	1307.26	148.19	

Page 443 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Sheet metal iron clad triple pole switch with neutral link 63amp. 415 volts	each	134.72	2605.69	148.19	2619.16
	(vii)	Sheet metal iron clad triple pole switch with neutral link 100amp. 415 volts	each	136.09	4776.62	149.70	4790.23
	(viii)	Sheet metal iron clad triple pole switch with neutral link 200amp. 415 volts	each	204.14	8515.88	224.55	8536.29
	(ix)	Sheet metal iron clad triple pole switch with neutral link 320amp. 415 volts	each	408.23	11545.91	449.05	11586.73
	(x)	Sheet metal iron clad triple pole switch with neutral link 400amp. 415 volts	each	408.23	16350.08	449.05	16390.90
33.19	SHEET	METAL IRON CLAD CHANGEOVER SWITCHES:				7 10100	
	switch nuts et switch and bo	and erection of sheet metal iron clad change—over on existing surface with G.I. bolts & nuts / rag bolts and c., according to the size of holes in the body of the including connectiions with suitable size of thimbles onding to the existing earth as per PWD General cations 2010.					
	(i)	Sheet metal iron clad double pole changeover switch 32amp. 415 volts	each	102.05	1166.74	112.26	1176.95
	(ii)	Sheet metal iron clad double pole changeover switch 63amp. 415 volts	each	102.05	2636.06	112.26	2646.27
	(iii)	Sheet metal iron clad double pole changeover switch 100amp. 415 volts	each	136.09	4633.90	149.70	4647.51
	(iv)	Sheet metal iron clad double pole changeover switch 200amp. 415 volts	each	136.09	6388.65	149.70	6402.26
	(v)	Sheet metal iron clad four pole changeover switch 32amp. 415 volts	each	134.72	1705.49	148.19	1718.96
	(vi)	Sheet metal iron clad four pole changeover switch 63amp. 415 volts	each	134.72	4008.12	148.19	4021.59
	(vii)	Sheet metal iron clad four pole changeover switch 100amp. 415 volts	each	136.09	7456.42	149.70	7470.03
	(viii)	Sheet metal iron clad four pole changeover switch 200amp. 415 volts	each	204.14	10361.90	224.55	10382.31
	(ix)	Sheet metal iron clad four pole changeover switch 320amp. 415 volts	each	408.23	13570.72	449.05	13611.54
	(x)	Sheet metal iron clad four pole changeover switch 400amp. 415 volts	each	408.23	17304.19	449.05	17345.01
33.20	SHEET	METAL BUS BAR CHAMBERS (COPPER STRIPS):					

Page 444 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1	fabricar require section section moulds 1.6mm excludi plated fixed w with all thimble	and erection of sheet metal bus-bar chamber (factory ted) duly powder coated on existing surface with d no. of bus-bar strips of suitable length and crossial area. Copper strips of suitable length and crossial area should be tinned and mounted on DMC/ SMC at sufficient distance enclosure made of M.S. sheet thick with hinged cover and lock, fitted with dusting gaskets and secured with sufficient no. of cadmium iron screws and of given overall dimensions and to be with G.I. bolts and nuts/ rag bolts and nuts etc. complete accessories including connections with suitable size of es, bonding to the existing earth and painting etc. as I by the Engineer-in-charge at site.	3	4	5	6	7
	(i)	Sheet metal bus bar chamber suitable for 63amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 230mm and cross sectional area (18mm x 3.3mm) enclosure having over all dimensions (300mm x 345mm x 120mm) nominal	each	134.72	2794.91	148.19	2808.38
	(ii)	Sheet metal bus bar chamber suitable for 63amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 270mm and cross sectional area (18mm x 3.3mm) enclosure having over all dimensions (350mm x 450mm x 150mm) nominal		134.72	3300.36	148.19	3313.83
	(iii)	Sheet metal bus bar chamber suitable for 100amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 230mm and cross sectional area (25mm x 3.3mm) enclosure having over all dimensions (300mm x 345mm x 120mm) nominal	eacii	134.72	3300.30	140.13	3313.63
	(iv)	Sheet metal bus bar chamber suitable for 100amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 270mm and cross sectional area (25mm x 3.3mm) enclosure having over all dimensions (350mm x 450mm x 150mm) nominal	each	136.09 136.09	3163.88 3715.29	149.70 149.70	3177.49 3728.90
	(v)	Sheet metal bus bar chamber suitable for 100amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 365mm and cross sectional area (25mm x 3.3mm) enclosure having over all dimensions (455mm x 455mm x 150mm) nominal	each				
	(vi)	Sheet metal bus bar chamber suitable for 200amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 270mm and cross sectional area (25mm x 5mm) enclosure having over all dimensions (350mm x 450mm x 150mm) nominal	each	136.09 204.14	4450.50 4426.64	149.70 224.55	4464.11 4447.05
	(vii)	Sheet metal bus bar chamber suitable for 200amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 365mm and cross sectional area (25mm x 5mm) enclosure having over all dimensions (455mm x 455mm x 150mm) nominal					
			each	204.14	5345.65	224.55	5366.06

Page 445 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(viii)	Sheet metal bus bar chamber suitable for 200amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 495mm and cross sectional area (25mm x 5mm) enclosure having over all dimensions (610mm x 510mm x 215mm) nominal	each	204.14	6632.26	224.55	6652.67
	(ix)	Sheet metal bus bar chamber suitable for 200amp. 415 volts capacity with 4 tinned copper strip bus bars each of length 635mm and cross sectional area (25mm x 5mm) enclosure having over all dimensions (780mm x 510mm x 215mm) nominal	each	204.14	7735.06	224.55	7755.47
33.21		SWITCH DISCONNECTOR FUSE UNIT:					
Α	SWITCI Enclosi	•					
	HRC F Cubical G.I. Bo sutiable	and erection of Switch Disconnector fuse unit with uses (Panel mounting Cubicle type) in the existing Panel (conforms to IS 13947 (Partl&III) complete with Its, Nuts & Connection on both sides of switch with e size of Thimbles, including cost of HRC fuses as per eneral Specfications 2010.					
	(i)	32Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	67.36	1332.44	74.10	1339.18
	(ii)	63Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	67.36	1970.96	74.10	1977.70
	(iii)	100Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	102.06	4240.00	112.27	4250.21
	(iv)	125Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	102.06	4890.98	112.27	4901.19
	(v)	160Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	153.10			5747.08
	(vi)	200Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	153.10	6669.93	168.41	6685.24
	(vii)	250Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	153.10	8047.24	168.41	8062.55
	(viii)	320Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	244.96	10522.79	269.46	10547.29
	(ix)	400Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	306.18	11613.09	336.80	11643.71
	(x)	630Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses	each	510.31	19793.95	561.34	19844.98
	(xi)	32Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	67.36	1885.76	74.10	1892.50
	(xii)	63Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	67.36	2320.38	74.10	2327.12
	(xiii)	100Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	102.06	4977.13	112.27	4987.34
	(xiv)	125Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	102.06	5503.64	112.27	5513.85

Page 446 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xv)	160Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	153.10	6937.98	168.41	6953.29
	(xvi)	200Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	153.10	7957.50	168.41	7972.81
	(xvii)	250Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	153.10	9736.89	168.41	9752.20
	(xviii)	320Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	244.96	12423.04	269.46	12447.54
	(xix)	400Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	306.18	13891.48	336.80	13922.10
	(xx)	630Amp. 415volts four pole switch disconnector fuse unit with HRC Fuses (with switched neutral)	each	510.31	22613.20	561.34	22664.23
В	SWITCI	H DISCONNECTOR FUSE UNIT (With Sheet Enclosure):					
	HRC F (confor etc. acc & Conr Thimble	and erection of Switch Disconnector fuse unit with fuses in sheet enclosure on the existing surface ms to IS 13947 (Partl&III) complete with G.I. Bolts, Nuts cording to the size of holes in the body of the enclosure nection on both sides of switch with sutiable size of es, including cost of HRC fuses as per PWD General cations 2010.					
	(i)	32Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure					
	(ii)	63Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure	each	2117.77	2117.77	148.19	2131.24
	(iii)	100Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure	each	134.72	3079.39	148.19	3092.86
	(iv)	125Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure	each	153.10	5726.99	168.41	5742.30
			each	153.10	6471.29	168.41	6486.60
	(v)	160Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure				100111	
			each	204.12	7702.18	224.53	7722.59
	(vi)	200Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure					
	(vii)	250Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure	each	204.12	8616.40	224.53	8636.81
	(viii)	320Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure	each	204.12	10347.92	224.53	10368.33
	(ix)	400Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure	each	306.18	13240.52	336.80	13271.14
			each	347.02	15138.52	381.72	15173.22

Page 447 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(x)	630Amp. 415volts three pole & neutral switch disconnector fuse unit with HRC Fuses in sheet enclosure					
			each	408.25	24006.99	449.08	24047.82
33.22		ON LOAD CHANGEOVER SWITCH:					
Α	ON LO	AD CHANGEOVER SWITCH (Without Sheet Enclosure):					
	advance existing complesswitch	and erection of On Load Change over Switch with the neutral UNIT (Panel mounting Cubical type) in the group Cubical Panel. (Confirms to IS 13947 (PartIII). The with G.I. Bolts, Nuts & Connection on both sides of with sutiable size of Thimbles as per PWD General cations 2010.					
	(i)	63amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	67.36	3239.39	74.10	3246.13
	(ii)	100amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	102.06	4535.17	112.27	4545.38
	(iii)	125amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	102.06	6132.25	112.27	6142.46
	(iv)	160amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	153.10	6577.39	168.41	6592.70
	(v)	200amp. 415 volts four Pole on load change over switch with advance neutral UNIT					
	(vi)	250amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	153.10 153.10		168.41 168.41	8102.69 11505.65
	(vii)	320amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	244.96	12245.93		
	(viii)	400amp. 415 volts four Pole on load change over switch with advance neutral UNIT					
	(ix)	630amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	306.18	17534.00	336.80	17564.62
	(x)	800amp. 415 volts four Pole on load change over switch with advance neutral UNIT	each	510.31	21015.29	561.34	21066.32
	(xi)	1000amp. 415 volts four Pole on load change over switch	each	510.31	30224.53	561.34	30275.56
В	ONI	with advance neutral UNIT LOAD CHANGEOVER SWITCH (With Sheet Enclosure)	each	510.31	49928.94	561.34	49979.97
	Supply advance surface Bolts, the en sutiable 2010.	and erection of On Load Change over Switch with the neutral UNIT in sheet enclosure on the existing etc. (Confirms to IS 13947 (PartIII), complete with G.I. Nuts etc. according to the size of holes in the body of closure & Connection on both sides of switch with the size of Thimbles as per PWD General Specifications					
	(i)	63amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	134.72	4484.86	148.19	4498.33

Page 448 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(ii)	100amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	136.09	5980.75	149.70	5994.36
	(iii)	125amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	136.09	8053.76	149.70	8067.37
	(iv)	160amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure		136.09	8468.60	149.70	8482.21
	(v)	200amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	204.14	9822.62	224.55	9843.03
	(vi)	250amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure		204.14		224.55	14133.73
	(vii)	320amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure		408.23	14898.18		14939.00
	(viii)	400amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	408.23	21535.46	449.05	21576.28
	(ix)	630amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	612.37	25141.21	673.61	25202.45
	(x)	800amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	612.37	35760.85	673.61	35822.09
	(xi)	1000amp. 415 volts four Pole on load change over switch with advance neutral UNIT in sheet enclosure	each	714.42	61333.47	785.86	61404.91
33.23		MOULDED CASE CIRCUIT BREAKERS:					
	(conformation (c	ing Cubicle type) in the existing Cubical Panel rms to IEC:60947-II) and relevant PWD general cations 2010 complete with G.I. Bolts, Nuts & ction on both sides of MCCB with sutiable size of es etc.					
	L&T	(Fixed Type Thermal and Magnetic Protection Make: (DU/DH), ABB (T-MAX), Schneider (CVS), ns(3VT1/3VL)):					
	(i)	40-80amp. 415 volts breaking capacity ≥25kA four pole fixed type thermal and magnetic setting MCCB unit	each	102.06	5080.19	112.27	5090.40
	(ii)	100amp. 415 volts breaking capacity ≥25kA four pole fixed type thermal and magnetic setting MCCB unit		102.06	5447.79	112.27	5458.00
		(Adjustable Thermal & Magnetic Protection Make: L&T BB (T-MAX), Schneider (NSX), Seimens(3VT1/3VL)):					
	(iii)	100amp. 415 volts breaking capacity ≥35kA four pole adjustable thermal and magnetic protection MCCB unit	each	102.06	7571.73	112.27	7581.94
	(iv)	125amp. 415 volts breaking capacity ≥35kA four pole adjustable thermal and magnetic protection MCCB unit	each	102.06	8449.88	112.27	8460.09
	(v)	160amp. 415 volts breaking capacity ≥35kA four pole adjustable thermal and magnetic protection MCCB unit					
			each	153.10	11339.64	168.41	11354.95

Page 449 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	200amp. 415 volts breaking capacity ≥35kA four pole adjustable thermal and magnetic protection MCCB unit	each	153.10	13540.16	168.41	13555.47
		(Microprocessor Based Adjustable Thermal and tic Protection Make: L&T (DSINE), ABB (T-MAX), der (NSX), Seimens(3VL)):		133.10	13340.10	100.41	13333.47
	(vii)	250amp. 415 volts breaking capacity ≥50kA four pole microprocessor based adjustable thermal and magnetic protection MCCB unit		450.40		100 11	
	(viii)	315amp. 415 volts breaking capacity ≥50kA four pole microprocessor based adjustable thermal and magnetic	each	153.10	28185.65	168.41	28200.96
		protection MCCB unit	each	204.12	28338.78	224.53	28359.19
	(ix)	400amp. 415 volts breaking capacity ≥50kA four pole microprocessor based adjustable thermal and magnetic protection MCCB unit					
	(x)	500amp. 415 volts breaking capacity ≥50kA four pole microprocessor based adjustable thermal and magnetic protection unit		204.12		224.53	
	(xi)	630amp. 415 volts breaking capacity ≥50kA four pole microprocessor based adjustable thermal and magnetic protection MCCB unit		204.12		224.53	
33.24		AIR CIRCUIT BREAKERS:	each	204.12	31744.39	224.53	31764.80
	industr suitable suitable at site	& erection of air circuit-breaker on the existing ial panel, including bonding to the existing earth with e glands and making necessary connections with e size of thimbles as required by the Engineer-in-Charge and as per PWD General Specifiactions (Make: L&T-U ABB-E Max, Seimens-3WL, Schneider-MVS):-					
	(i)	Air circuit-breaker electrically operated (electrical draw-out type), 4 pole, 800amp. 415 volts complete.			474055 00	4574.75	470000 04
	(ii)	Air circuit-breaker electrically operated (electrical draw-out type), 4 pole, 1000amp. 415 volts complete.			171955.92		172098.81
	(iii)	Air circuit-breaker electrically operated (electrical draw-out type), 4 pole, 1250amp. 415 volts complete.		1632.97	177265.63		177428.93
	(iv)	Air circuit-breaker electrically operated (electrical draw-out type), 4 pole, 1600amp. 415 volts complete.			189723.19 212391.94		189906.90 212596.06
	(v)	Air circuit-breaker electrically operated (electrical draw-out type), 4 pole, 2000amp. 415 volts complete.	each		268757.69		268982.22
	(vi)	Air circuit-breaker electrically operated (electrical draw-out type), 4 pole, 2500amp. 415 volts complete.		22 10.04	200707.00	2 100.01	200002.22
			each	2449.44	303679.87	2694.38	303924.81

Page 450 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mo	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vii)	Air circuit-breaker electrically operated (electrical draw-out type), 4 pole, 3200amp. 415 volts complete.	each	2653 57	377404.65	2018 03	377670.01
			Cacii	2000.07	377 404.03	2310.33	377070.01
33.25	CABLE	TRAY:					
	paint o suppor 50mm : comple	and erection of MS perforated cable tray with DA gray in the existing surface with the help of MS angle iron it (to be painted with approved paint) of size 50mm x x 6mm thick to be fixed with fastners/ nut & bolts etc. It in all respect as desired by the Engineer-in-charge as D General Specifications 2010.					
	(i)	MS perforated cable tray size 150mm x 50mm x 50mm (2mm thick)		00.40	507.44	05.44	570.00
	(ii)	MS perforated cable tray size 300mm x 50mm x 50mm (2mm thick)	m	32.19	567.11	35.41	570.33
			m	32.19	808.42	35.41	811.64
	(iii)	MS perforated cable tray size 450mm x 50mm x 50mm (2mm thick)	m	32.19	1050.64	35.41	1053.86
	(iv)	MS perforated cable tray size 50mm x 50mm (2mm thick) L Type		294.47	294.47	35.41	297.69
33.26	AUTON	NATIC VOLTAGE STABLIZER, TIMER:		201.17	201.11	00.11	207.00
33.26 A	AUTON	IATIC VOLTAGE STABLIZER:					
	voltage circuit and ou having with su the tran box 45 control capacit meter a volt ou	and erection of single phase copper wound automatic stablizer of suitable capacity electronically controlled with input voltage 100-280 volts single phase AC supply itput voltage 220 ± 5% volts single phase AC supply main silicon core copper wound step up transformer itable nos. of turns on primary side and secondary side asformer should be fully insulated inside the MS sheet 60 mm x 350mm x 330mm. There should be power relay and single pole MCB (C-curve, 10kA) of suitable by complete with internal copper wiring along with amp. and volt meter, high voltage cut off 280 volt input (243 atput) and 90 volt maximum boost and overloading ion to be provided.					
	(i)	Automatice voltage stablizer copper wound 4 KVA, input voltage 100-280volts & output voltage 220± 5%volts with power control relay rating 25 amp. (single phase) and Single pole MCB 16 amp. (C-curve, 10kA)		34.09	6926.65	37.50	6930.06
	(ii)	Automatice voltage stablizer copper wound 5 KVA, input voltage 100-280volts & output voltage 220± 5%volts with power control relay rating 32 amp. (single phase) and Single pole MCB 25 amp. (C-curve, 10kA)					
			each	34.09	7947.77	37.50	7951.18

Page 451 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
·	(iii)	Automatice voltage stablizer copper wound 6 KVA, input voltage 100-280volts & output voltage 220± 5%volts with power control relay rating 40 amp. (single phase) and Single pole MCB 32 amp. (C-curve, 10kA)					
	(:, .)	Automotics valters stabilizer senser wayed 0 KMA input	each	34.09	9224.17	37.50	9227.58
	(iv)	Automatice voltage stablizer copper wound 8 KVA, input voltage 100-280volts & output voltage 220± 5%volts with power control relay rating 63 amp. (single phase) and Single pole MCB 63 amp. (C-curve, 10kA)		24.00	40500 50	27.50	40500.00
33.26	TIMER:		each	34.09	10500.58	37.50	10503.99
B							
	(i)	S/E of Microprocessor Based St. Light Controller with digital time switch daily programmed with stand by lithium battery with back up of 6 years with min. time between 2 switching operations is 1 minute, 3 nos. three pole power contactors 40A. with coil voltage 220-230V AC with 1 no. aux. contact NO, 1 no. aux. contactor 6 amp.(2NO+2NC) with coil voltage 220V AC, 3 nos. MCB 2 pole 40amp. (C-curve,10kA)& power wiring with single core PVC insulated FRLS cable 10 sq. mm and control wiring with PVC insulated FRLS cable 1 sq. mm, 1 no. two position selector switch to bypass timer and other accessories & petty material (din rail, 2 nos. 4 pole bakelite terminal strip 63A/440V AC, required nut bolts) should be fixed on bakelite sheet 6mm thick to be mounted in a IP54 surface/ flush mounting powder coated sheet metal (1.60mm thick) cabinet having size 450mmx600mmx150mm to switch 'ON' all the 3 phases & switch 'OFF' 3 phases pre-fixed timings complete in all respect as per satisfaction of Engineer-in-charge.	each	204.14	16558.19	224.55	16578.60
	(ii)	S/E of Microprocessor Based Street Light Controller with digital time switch daily programmed with stand by lithium battery with back up of six years with minimum time between 2 switching operations is 1 minute, 1 nos. 3 pole power contactors 40amp. with coil voltage 220-230V AC with 1 no. auxiliary contact NO, 1 no. MCB double pole 40amp. (C-curve, 10kA characteristic) and power wiring with single core PVC insulated FRLS cable 10 sq. mm & control wiring with PVC insulated FRLS cable 1 sq. mm, 1 no. two position selector switch to bypass timer & other accessories & petty material (din rail, 1 no. 4 pole bakelite terminal strip 63A/ 440 volts AC, required nut bolts) should be fixed on bakelite sheet 6mm thick to be mounted in a IP54 surface/ flush mounting powder coated sheet metal (1.60mm thick) cabinet having size 450mmx600mmx150mm to switch 'ON' all the 3 phases & switch 'OFF' 3 phases predetermined/ pre-fixed timings complete in all respect as per satisfaction of Engineer-incharge.	each	204.14	9897.80	224.55	9918.21
33.27	I	PAINTING INCLUDING LABOUR AND MATERIAL:	eacn	204.14	9897.80	224.55	9918.21
	(i)	Painting of ceiling fan complete with blades, canopy and suspension rod with two coats of approved paint (with brush).					
			each	23.55	100.30	25.91	102.66

Page 452 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(ii)	Painting of steel tubular pole with brackets with two coats of aluminium paint (with brush).					
	(a)	7 metre overall length	each	30.77	101.46	33.85	104.54
	(b)	8 metre overall length	each	35.17	115.96	38.69	119.48
	(c)	8.5 to 9 metre overall length	each	43.96	165.15	48.36	169.55
	(d)	9.5 to 10 metre overall length	each	54.95	186.24	60.45	191.74
	(iii)	Painting of galvanized iron pipe pole including bracket with two coats of aluminium paint (with brush).	Guori	01.00	100.21	00.10	101.71
	(a)	4 metre overall length	each	17.58	37.78	19.34	39.54
	(b)	6.1 metre overall length	each	21.98	52.28	24.18	54.48
	(iv)	Painting of G.I./ Conduit pipes with two coats of approved paint (with brush) including cleaning the surface etc.	Caon	21.30	02.20	24.10	04.40
	(a)	15mm dia G.I. pipe and conduit pipe 20mm dia.	m	3.52	5.48	3.87	5.83
	(b)	20mm dia G.I. pipe and conduit pipe 25mm dia.	m	3.52	6.00	3.87	6.35
	(c)	25mm dia G.I. pipe and conduit pipe 32mm dia.	m	3.52	6.63	3.87	6.98
	(d)	32mm dia G.I. pipe and conduit pipe 40mm dia.	m	3.52	7.48	3.87	7.83
	(e)	40mm dia G.I. pipe and conduit pipe 50mm dia.	m	3.52	7.96	3.87	8.31
	(f)	50mm dia G.I. pipe	m	3.52	9.09	3.87	9.44
	(g) (h)	65mm dia G.I. pipe 80mm dia G.I. pipe	m	4.40	11.43	4.84	11.87
	(i)	100mm dia G.I. pipe	m	4.40	12.60	4.84	13.04
	()		m	4.40	14.94	4.84	15.38
33.28	EREC'	TION, REPAIR AND REWINDING OF FANS:					
	Α	ERECTION OF FANS:					
	(i)	Erection of ceiling fan having connection with PVC insulated PVC sheathed two single core copper conductor (FRLS) cable 0.75mm sq. complete.					
	(ii)	Erection of cabin fan on the wall having connection with PVC insulated PVC sheathed two single core copper	each	40.82	58.53	44.90	62.61
		conductor (FRLS) cable 0.75mm sq. complete.	each	40.82	56.79	44.90	60.87

Page 453 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(iii)	Erection of exhaust fan on the wall/ window grill having connection with PVC insulated PVC sheathed two single core copper conductor (FRLS) cable 0.75mm sq. complete.	each	51.04	100.23	56.14	105.33
	В	REPAIR AND REWINDING OF CEILING FANS:	Guon	01.01	100.20	00.11	100.00
	(i)	Full stator rewinding of a ceiling fan (condensor type) of 900mm sweep, including cleaning & insulating the stator slots, sleeving, soldering, wrapping of cotton tape, varnishing, re–assembling & testing etc., complete.	each	102.05	203.55	112.26	213.76
	(ii)	Full stator rewinding of a ceiling fan (condensor type) of 1200mm sweep, including cleaning & insulating the stator slots, sleeving, soldering, wrapping of cotton tape, varnishing, re–assembling & testing etc., complete.	each	102.05	233.47	112.26	243.68
	(iii)	Full stator rewinding of a ceiling fan (condensor type) of 1400mm sweep, including cleaning & insulating the stator slots, sleeving, soldering, wrapping of cotton tape, varnishing, re–assembling & testing etc., complete.	each	102.05	261.93	112.26	272.14
	(iv)	Full stator rewinding of a exhaust fan (condensor type) of 300mm sweep, including cleaning & insulating the stator slots, sleeving, soldering, wrapping of cotton tape, varnishing, re–assembling & testing etc., complete.	Cacin				
	(v)	Full stator rewinding of a exhaust fan (condensor type) of 380mm sweep, including cleaning & insulating the stator slots, sleeving, soldering, wrapping of cotton tape, varnishing, re–assembling & testing etc., complete.	each	102.05	205.60	112.26	215.81
			each	134.72	296.67	148.19	310.14
	(vi)	Full stator rewinding of a exhaust fan (condensor type) of 450mm sweep, including cleaning & insulating the stator slots, sleeving, soldering, wrapping of cotton tape, varnishing, re–assembling & testing etc., complete.					
			each	204.14	396.01	224.55	416.42
33.29		GI PIPE POLES & BRACKETS:					
Α		GI PIPE POLES					
	and diato a give dia. an above from G not be MCB cover vof requiplinth to fuse be arranged.	and erection of G.I. pipe 'A' quality of suitable length a conforming to I.S. 1239 part-I 1979, including fixing up yen depth below G/L, the hole of excavation about 30 cm and given depth to be filled in up to 15 cm below and G/L with 1:2:4 cement concrete up to a height of 45 cm /L. The radial thick ness of the plinth above G/L should less than 6.35 cm and sufficient to completely flush a listribution board SPN 4way with hinged water tight with locking arrangement having one single pole MCB lired capacity of the same size the outer surface of the to be finished with 1:2 cement plaster 6 mm thick M.S. ox shall have a water proof hinged cover with locking ement including painting of pole with two coats of ed aluminium paint as required:-					

Page 454 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(i)	4 metre long having nominal bore dia. 65mm, planting depth 80cm with pit depth 95cm.	each	395.49	3251.63	435.04	3291.18
	(ii)	6.1 metre long having nominal bore dia. 80mm, planting depth 120cm with pit depth 135cm.	each	456.71	4750.41	502.38	
	(iii)	6.1 metre long having nominal bore dia 100mm, planting depth 120cm with pit depth 135cm.	each	456.71	6285.82	502.38	6331.49
В		GI PIPE POLE BRACKETS:					
		SINGLE ARM BRACKETS:					
	(i)	Supply and erection of G.I. pipe 40mm dia. (A-class) single arm bracket atleast 1 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the top of the GI pipe pole having top outer dia. 80mm with GI reducer 80mm x 40mm with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.					
			each	45.06	638.02	49.57	642.53
	(ii)	Supply and erection of G.I. pipe 40mm dia. (A-class) single arm bracket atleast 1.5 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the top of the GI pipe pole having top outer dia. 80mm with GI reducer 80mm x 40mm with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.					
			each	45.06	755.01	49.57	759.52
	(iii)	Supply and erection of G.I. pipe 40mm dia. (A-class) single arm bracket atleast 1 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the top of the GI pipe pole having top outer dia. 100mm with GI reducer 100mm x 40mm with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.	each	45.06	644.59	49.57	649.10
	(iv)	Supply and erection of G.I. pipe 40mm dia. (A-class) single arm bracket atleast 1.5 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the top of the GI pipe pole having top outer dia. 100mm with GI reducer 100mm x 40mm with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.					
			each	45.06	761.57	49.57	766.08
	(v)	Supply and erection of G.I. pipe 40mm dia. (medium) single arm bracket atleast 1.5 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the existing surface/ wall with 2nos. MS flat clamp 25mm x 5mm, 30cm long and 4nos. fastner 10mm x 750mm long with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.					
			each	52.38	527.29	57.62	532.53

Page 455 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Supply and erection of G.I. pipe 40mm dia. (medium) single arm bracket atleast 2 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the existing surface/ wall with 2nos. MS flat clamp 25mm x 5mm, 30cm long and 4nos. fastner 10mm x 750mm long with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.	each	52.38	650.84	57.62	656.08
	(vii)	Supply and erection of G.I. pipe 50mm dia. (medium) single arm bracket atleast 1.5 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the existing surface/ wall with 2nos. MS flat clamp 25mm x 5mm, 30cm long and 4nos. fastner 10mm x 750mm long with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.	each	J2.30	0.00.04	37.02	050.00
			each	65.47	637.01	72.02	643.56
	(viii)	Supply and erection of G.I. pipe 50mm dia. (medium) single arm bracket atleast 2 metre long arm to give a total overhang at a tentative angle of 100/105°, the bracket should be fixed on the existing surface/ wall with 2nos. MS flat clamp 25mm x 5mm, 30cm long and 4nos. fastner 10mm x 750mm long with two coats of an approved aluminium paint complete in all respect as approved by the Engineer-in-charge at site.					
			each	65.47	791.42	72.02	797.97
С	GI PIPE	BRACKETS FOR 3 STEPPED STEEL TUBULAR	Caon	00.47	701.42	12.02	101.01
		SINGLE ARM BRACKETS:					
	(i)	Supply and erection of G.I. pipe 50mm dia. (medium) Single arm bracket 1.5 metre long each arm welded with MS canopy 80mm inner dia., outer dia 89.5mm (medium), 450mm long suitable for 3 stepped steel tubular swaged and welded pole with top outer section dia. 76.1mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 90mm dia. welded with MS ring of 90mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape having dimensions 225mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-incharge at site.					
			each	69.47	1043.88	76.42	1050.83

Page 456 CSR - 2010

Sr. No.	Description	Unit	PI	ains	Sub Mo	untainous
			Labour Rate	Through Rate	Labour Rate	Through Rate
1	2	3	4	5	6	7
	Supply and erection of G.I. pipe 50mm dia. (media Single arm bracket 2 metre long each arm welded with canopy 80mm inner dia., outer dia 89.5mm (media 450mm long suitable for 3 stepped steel tubular swar and welded pole with top outer section dia. 76.1mm. MS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" so nut bolt of full thread. The bracket should have MS rous sheet 3mm thick 90mm dia. welded with MS ring of 90 dia and 50mm long, 1.62mm thick for covering the top of the canopy. The MS canopy and GI bracket should welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape have dimensions 300mm x 150mm x 5mm thick with two coof an approved aluminium paint as desired by Engineer charge at site.	MS m), ed ihe at ze nd nm nd be iith				
	(iii) Supply and erection of G.I. pipe 50mm dia. (media Single arm bracket 2.5 metre long each arm welded of MS canopy 80mm inner dia., outer dia 89.5mm (media 450mm long suitable for 3 stepped steel tubular sway and welded pole with top outer section dia. 76.1mm. MS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" so nut bolt of full thread. The bracket should have MS rous sheet 3mm thick 90mm dia. welded with MS ring of 90m dia and 50mm long, 1.62mm thick for covering the top of the canopy. The MS canopy and GI bracket should welded at tentative angel 105° (105 degree) inclination of MS sheet 5mm thick triangular in shape have dimensions 375mm x 150mm x 5mm thick with two coof an approved aluminium paint as desired by Engineer charge at site.	vith m), ed ihe at ze nd nm nd be vith	69.47	1229.92 1415.98	76.42	1236.87 1422.93
	(iv) Supply and erection of G.I. pipe 50mm dia. (media Single arm bracket 1.5 metre long each arm welded of MS canopy 125mm inner dia., outer dia 140.8 (medium), 450mm long suitable for 3 stepped steel tube swaged and welded pole with top outer section 114.3mm. The MS canopy should have 3no. holes fixing the bracket at the top end of the pole with the help 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm welded with MS ring of 142mm dia and 50mm log 1.62mm thick for covering the top end of the canopy. MS canopy and GI bracket should be welded at tental angel 105° (105 degree) inclination with MS sheet 50 thick triangular in shape having dimensions 225mm 150mm x 5mm thick with two coats of an approximation and the state of the should be s	m) rith nm lar lia. for of ket lia. ng, he ive nm x ed				
		each	69.47	1228.88	76.42	1235.83

Page 457 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(v)	Supply and erection of G.I. pipe 50mm dia. (medium) Single arm bracket 2 metre long each arm welded with MS canopy 125mm inner dia., outer dia 140.8mm (medium), 450mm long suitable for 3 stepped steel tubular swaged and welded pole with top outer section dia. 114.3mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm dia. welded with MS ring of 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape having dimensions 300mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-in-charge at site.					
			each	69.47	1414.92	76.42	1421.87
	(vi)	Supply and erection of G.I. pipe 50mm dia. (medium) Single arm bracket 2.5 metre long each arm welded with MS canopy 125mm inner dia., outer dia 140.8mm (medium), 450mm long suitable for 3 stepped steel tubular swaged and welded pole with top outer section dia. 114.3mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm dia. welded with MS ring of 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape having dimensions 375mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-in-charge at site.					
		DOUBLE ARM BRACKETS:	each	69.47	1600.98	76.42	1607.93
	(vii)	Supply and erection of G.I. pipe 50mm dia. (medium) Double arm bracket 1.5 metre long each arm welded with MS canopy 80mm inner dia., outer dia 89.5mm (medium), 450mm long suitable for 3 stepped steel tubular swaged and welded pole with top outer section dia. 76.1mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 90mm dia. welded with MS ring of 90mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape having dimensions 225mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-incharge at site.					
			each	95.27	1756.31	104.80	1765.84

Page 458 CSR - 2010

Sr. No.	Description	Unit	PI	ains	Sub Mou	untainous
			Labour Rate	Through Rate	Labour Rate	Through Rate
1	2	3	4	5	6	7
	(viii) Supply and erection of G.I. pipe 50mm dia. (medium Double arm bracket 2 metre long each arm welded w MS canopy 80mm inner dia., outer dia 89.5mm (medium 450mm long suitable for 3 stepped steel tubular swag and welded pole with top outer section dia. 76.1mm. T MS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" sinut bolt of full thread. The bracket should have MS rou sheet 3mm thick 90mm dia. welded with MS ring of 90m dia and 50mm long, 1.62mm thick for covering the top e of the canopy. The MS canopy and GI bracket should welded at tentative angel 105° (105 degree) inclination w MS sheet 5mm thick triangular in shape havi dimensions 300mm x 150mm x 5mm thick with two coa of an approved aluminium paint as desired by Engineer-charge at site.	ith n), ed he at ze nd im nd be tith ng				
	(ix) Supply and erection of G.I. pipe 50mm dia. (mediu	each	95.27	2128.41	104.80	2137.94
	(ix) Supply and erection of G.I. pipe 50mm dia. (medium Double arm bracket 2.5 metre long each arm welded w MS canopy 80mm inner dia., outer dia 89.5mm (medium 450mm long suitable for 3 stepped steel tubular swag and welded pole with top outer section dia. 76.1mm. T MS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" si nut bolt of full thread. The bracket should have MS rou sheet 3mm thick 90mm dia. welded with MS ring of 90m dia and 50mm long, 1.62mm thick for covering the top e of the canopy. The MS canopy and GI bracket should welded at tentative angel 105° (105 degree) inclination w MS sheet 5mm thick triangular in shape havi dimensions 375mm x 150mm x 5mm thick with two coa of an approved aluminium paint as desired by Engineer-charge at site.	ith n), ed he at ze nd im nd be ith ng				
	(x) Supply and erection of G.I. pipe 50mm dia. (medium Double arm bracket 1.5 metre long each arm welded with MS canopy 125mm inner dia., outer dia 140.8m (medium), 450mm long suitable for 3 stepped steel tubus swaged and welded pole with top outer section dia 114.3mm. The MS canopy should have 3no. holes fixing the bracket at the top end of the pole with the help 3nos. ½"x1½" size nut bolt of full thread. The brack should have MS round sheet 3mm thick 142mm dia welded with MS ring of 142mm dia and 50mm lor 1.62mm thick for covering the top end of the canopy. Time MS canopy and GI bracket should be welded at tentatic angel 105° (105 degree) inclination with MS sheet 5m thick triangular in shape having dimensions 225mm 150mm x 5mm thick with two coats of an approvaluminium paint as desired by Engineer-in-charge at site.	ith im iar ia. ior of et ia. ig, he ve im x ed	95.27	2500.51	104.80	2510.04
		each	95.27	1941.31	104.80	1950.84

Page 459 CSR - 2010

Sr. No.		Description		PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1	(xi)	Supply and erection of G.I. pipe 50mm dia. (medium) Double arm bracket 2 metre long each arm welded with MS canopy 125mm inner dia., outer dia 140.8mm (medium), 450mm long suitable for 3 stepped steel tubular swaged and welded pole with top outer section dia. 114.3mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm dia. welded with MS ring of 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape having dimensions 300mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-in-charge at site.		4	5	6	7
	(xii)	Supply and erection of G.I. pipe 50mm dia. (medium) Double arm bracket 2.5 metre long each arm welded with MS canopy 125mm inner dia., outer dia 140.8mm (medium), 450mm long suitable for 3 stepped steel tubular swaged and welded pole with top outer section dia. 114.3mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm dia. welded with MS ring of 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape having dimensions 375mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-in-charge at site.		95.27	2313.41	104.80	2322.94
		TRIPLE ARM BRACKETS:	each	95.27	2685.52	104.80	2695.05
	(xiii)	Supply and erection of G.I. pipe 50mm dia. (medium) Triple arm bracket 1.5 metre long each arm welded with MS canopy 80mm inner dia., outer dia 89.5mm (medium), 450mm long suitable for 3 stepped steel tubular swaged and welded pole with top outer section dia. 76.1mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 90mm dia. welded with MS ring of 90mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5mm thick triangular in shape having dimensions 225mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-incharge at site.					
			each	115.34	2463.01	126.87	2474.54

Page 460 CSR - 2010

Sr. No.	Description	U	Unit	Pla	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1	(xiv) Supply and erection of G.I. pip		3	4	5	6	7
	Triple arm bracket 2 metre long e canopy 80mm inner dia., outer 450mm long suitable for 3 stepp and welded pole with top outer s MS canopy should have 3no. hole the top end of the pole with the hout bolt of full thread. The bracke sheet 3mm thick 90mm dia. welded dia and 50mm long, 1.62mm thick of the canopy. The MS canopy a welded at tentative angel 105° (10 MS sheet 5mm thick triangulations 300mm x 150mm x 5 of an approved aluminium paint as charge at site.	ach arm welded with MS dia 89.5mm (medium), ed steel tubular swaged ection dia. 76.1mm. The s for fixing the bracket at elp of 3nos. ½"x1½" size t should have MS round ed with MS ring of 90mm for covering the top end and GI bracket should be 5 degree) inclination with ular in shape having mm thick with two coats					
			each	115.34	3021.17	126.87	3032.70
	(xv) Supply and erection of G.I. pip Triple arm bracket 2.5 metre lon MS canopy 80mm inner dia., oute 450mm long suitable for 3 stepp and welded pole with top outer s MS canopy should have 3no. hole the top end of the pole with the hout bolt of full thread. The bracke sheet 3mm thick 90mm dia. welded dia and 50mm long, 1.62mm thick of the canopy. The MS canopy a welded at tentative angel 105° (10 MS sheet 5mm thick triangual dimensions 375mm x 150mm x 5 of an approved aluminium paint as charge at site.	g each arm welded with a dia 89.5mm (medium), ed steel tubular swaged ection dia. 76.1mm. The strategies for fixing the bracket at elp of 3nos. ½"x1½" size to should have MS round ed with MS ring of 90mm for covering the top end and GI bracket should be 5 degree) inclination with a lar in shape having mm thick with two coats					
		e	each	95.14	3559.13	104.65	3568.64
	(xvi) Supply and erection of G.I. pip Triple arm bracket 1.5 metre lon MS canopy 125mm inner dia (medium), 450mm long suitable for swaged and welded pole with 114.3mm. The MS canopy shou fixing the bracket at the top end of 3nos. ½"x1½" size nut bolt of 1 should have MS round sheet 3 welded with MS ring of 142mm 1.62mm thick for covering the top MS canopy and GI bracket should angel 105° (105 degree) inclinated thick triangular in shape having 150mm x 5mm thick with two aluminium paint as desired by English	g each arm welded with , outer dia 140.8mm or 3 stepped steel tubular top outer section dia. old have 3no. holes for the pole with the help of ull thread. The bracket from thick 142mm dia. on dia and 50mm long, end of the canopy. The d be welded at tentative on with MS sheet 5mm of dimensions 225mm x coats of an approved					
		e	each	115.34	2648.02	126.87	2659.55

Page 461 CSR - 2010

Sr. No.	Description		PI	ains	Sub Mountainous	
			Labour Rate	Through Rate	Labour Rate	Through Rate
1	(xvii) Supply and erection of G.I. pipe 50mm dia. (medium Triple arm bracket 2 metre long each arm welded with M canopy 125mm inner dia., outer dia 140.8mm (medium 450mm long suitable for 3 stepped steel tubular swage and welded pole with top outer section dia. 114.3mm. The MS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS rour sheet 3mm thick 142mm dia. welded with MS ring 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI brack should be welded at tentative angel 105° (105 degree inclination with MS sheet 5mm thick triangular in shaphaving dimensions 300mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired be Engineer-in-charge at site.	S,), de e e e e e e e e e e e e e e e e e e	4	5	6	7
	(xviii) Supply and erection of G.I. pipe 50mm dia. (medium Triple arm bracket 2.5 metre long each arm welded wi MS canopy 125mm inner dia., outer dia 140.8m (medium), 450mm long suitable for 3 stepped steel tubula swaged and welded pole with top outer section di 114.3mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm di welded with MS ring of 142mm dia and 50mm lon 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree) inclination with MS sheet 5m thick triangular in shape having dimensions 375mm 150mm x 5mm thick with two coats of an approve aluminium paint as desired by Engineer-in-charge at site.	th m ar a. cor of et a. g, ee em x	115.34	3206.16	126.87	3217.69
	FOUR ARM BRACKETS: (xix) Supply and erection of G.I. pipe 50mm dia. (medium) For arm bracket 1.5 metre long each arm welded with M canopy 125mm inner dia., outer dia 140.8mm (medium 450mm long suitable for 3 stepped steel tubular swage and welded pole with top outer section dia. 114.3mm. The MS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" siz nut bolt of full thread. The bracket should have MS rour sheet 3mm thick 142mm dia. welded with MS ring 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI brack should be welded at tentative angel 105° (105 degree inclination with MS sheet 5mm thick triangular in shaphaving dimensions 225mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired to Engineer-in-charge at site.	S), , dd ee eat ee	115.34	3764.33	126.87	3775.86
		each	146.70	3366.01	161.37	3380.68

Page 462 CSR - 2010

Sr. No.	Description	Unit	PI	ains	Sub Mo	untainous
			Labour Rate	Through Rate	Labour Rate	Through Rate
1	(xx) Supply and erection of G.I. pipe 50mm dia. (medium) Fou		4	5	6	7
	arm bracket 2 metre long each arm welded with M canopy 125mm inner dia., outer dia 140.8mm (medium 450mm long suitable for 3 stepped steel tubular swage and welded pole with top outer section dia. 114.3mm. The MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm dia. welded with MS ring of 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree inclination with MS sheet 5mm thick triangular in shap having dimensions 300mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired by Engineer-in-charge at site.), d e e d d of e e et e				
	(xxi) Supply and erection of G.I. pipe 50mm dia. (medium) Fou	each	146.70	4110.21	161.37	4124.88
	arm bracket 2.5 metre long each arm welded with M canopy 125mm inner dia., outer dia 140.8mm (medium 450mm long suitable for 3 stepped steel tubular swage and welded pole with top outer section dia. 114.3mm. Th MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" siz nut bolt of full thread. The bracket should have MS roun sheet 3mm thick 142mm dia. welded with MS ring of 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree inclination with MS sheet 5mm thick triangular in shap having dimensions 375mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired be Engineer-in-charge at site.	S), d e e d f f e e d d f e e e t e o				
		each	146.70	4854.42	161.37	4869.09
	(xxii) Supply and erection of G.I. pipe 50mm dia. (medium) S arm bracket 1.5 metre long each arm welded with M canopy 125mm inner dia., outer dia 140.8mm (medium 450mm long suitable for 3 stepped steel tubular swage and welded pole with top outer section dia. 114.3mm. Th MS canopy should have 3no. holes for fixing the bracket at the top end of the pole with the help of 3nos. ½"x1½" size nut bolt of full thread. The bracket should have MS round sheet 3mm thick 142mm dia. welded with MS ring of 142mm dia and 50mm long, 1.62mm thick for covering the top end of the canopy. The MS canopy and GI bracket should be welded at tentative angel 105° (105 degree inclination with MS sheet 5mm thick triangular in shap having dimensions 225mm x 150mm x 5mm thick with two coats of an approved aluminium paint as desired be Engineer-in-charge at site.	S), d e e d f f e e d d f e e e t e o				
		each	273.64	4866.22	301.00	4893.58

Page 463 CSR - 2010

Sr. No.	Description	Unit	PI	ains	Sub Mou	untainous
			Labour Rate	Through Rate	Labour Rate	Through Rate
1	(xxiii) Supply and erection of G.I. pipe 50mm dia. (medium) Sarm bracket 2 metre long each arm welded with Macanopy 125mm inner dia., outer dia 140.8mm (mediur 450mm long suitable for 3 stepped steel tubular swag and welded pole with top outer section dia. 114.3mm. Table MS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" sinut bolt of full thread. The bracket should have MS rousheet 3mm thick 142mm dia. welded with MS ring 142mm dia and 50mm long, 1.62mm thick for covering top end of the canopy. The MS canopy and GI brackshould be welded at tentative angel 105° (105 degres inclination with MS sheet 5mm thick triangular in shall having dimensions 300mm x 150mm x 5mm thick with the coats of an approved aluminium paint as desired Engineer-in-charge at site.	AS n), ed he at ze nd of he aet ee) pe	4	5	6	7
	(xxiv) Supply and erection of G.I. pipe 50mm dia. (medium) Sarm bracket 2.5 metre long each arm welded with Macanopy 125mm inner dia., outer dia 140.8mm (medium 450mm long suitable for 3 stepped steel tubular swag and welded pole with top outer section dia. 114.3mm. TMS canopy should have 3no. holes for fixing the bracket the top end of the pole with the help of 3nos. ½"x1½" si nut bolt of full thread. The bracket should have MS rou sheet 3mm thick 142mm dia. welded with MS ring 142mm dia and 50mm long, 1.62mm thick for covering top end of the canopy. The MS canopy and GI brack should be welded at tentative angel 105° (105 degree inclination with MS sheet 5mm thick triangular in sha having dimensions 375mm x 150mm x 5mm thick with the coats of an approved aluminium paint as desired Engineer-in-charge at site.	AS n), ed he at ze nd of he aet ee) pe	273.64	5982.53	301.00	6009.8
		each	273.64	7098.84	301.00	7126.2
	ROUND BRACKET OF 5' (5 FEET) DIA.: (xxv) Supply and erection of G.I. pipe 50mm dia. (mediu Round bracket to make a ring of 5'(5 feet) dia. (1.52 me long) with 3nos. inclined member 3' (3 feet) long weld with MS canopy 125mm inner dia., outer dia 140.8m (medium), 450mm long suitable for 3 stepped steel tubu swaged and welded pole with top outer section di 114.3mm. The MS canopy should have 3no. holes fixing the bracket at the top end of the pole with the help 3nos. ½"x1½" size nut bolt of full thread. The brack should have MS round sheet 3mm thick 142mm di welded with MS ring of 142mm dia and 50mm lor 1.62mm thick for covering the top end of the canopy. T MS canopy and GI bracket should be welded at an ang according to the size of ring inclination with MS sheet 5m thick triangular in shape having dimensions 375mm 150mm x 5mm thick with two coats of an approvaluminium paint as desired by Engineer-in-charge at site	tre ed im lar ia. for of et ia. ng, he gel im x ed	25/ 10	<u>4514 01</u>	270 54	4540.2
	GALVANIZED STEEL OCTAGONAL POLES FOR WINVELOCITY OF 160 Km/ HOUR:	each	254.10	4514.91	279.51	4540.3

Page 464 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	suitable pole shall ta open a locking connect for inc arrange suitable at the bolts.T foundarigidity M20 of	and erection of galvanized steel octagonal pole of e length conforming to IS 2629/IS 2633/ IS4759. The hall be in single piece (single hot dip galvanized) and apered towards the top. The bottom section shall have ble slot with exterior surface door & shall have suitable garrangement for housing three phase 4wire cable ction, bakelite sheet, MCB, loop in and out arrangement oming/ outgoing cables. There shall also be suitable ement for the purpose of earthing. Rigid Base plate of e size and thickness shall be welded inside and outside bottom of pole with provision for fixing 4 foundation he octagonal pole shall be bolted on a pre- cast tion with a set of four foundation bolts for greater. The foundation shall be erected over cement concrete given size to fixed up to a required planting depth ground level as required:-					
	(i)	Galvanized octagonal pole overall length 4 metre (sheet thickness 3mm), top dia.(A/F) 70mm and bottom dia. (A/F) 130mm, foundation size below ground level 550mm x 550mm x 900mm, 4Nos. foundation bolts size 16mm dia., length≥ 450mm with base plate dimensions 200mm x 200mm x 12mm thick.		305.18	11843.18	335.70	11873.70
	(ii)	Galvanized octagonal pole overall length 5 metre (sheet thickness 3mm), top dia.(A/F) 70mm and bottom dia. (A/F) 130mm, foundation size below ground level 550mm x 550mm x 1200mm, 4Nos. foundation bolts size 16mm dia., length≥ 600mm with base plate dimensions 200mm x 200mm x 12mm thick.					
	(iii)	Galvanized octagonal pole overall length 6 metre (sheet thickness 3mm), top dia.(A/F) 70mm and bottom dia. (A/F) 130mm, foundation size below ground level 550mm x 550mm x 1200mm, 4Nos. foundation bolts size 20mm dia., length≥ 600mm with base plate dimensions 220mm x 220mm x 12mm thick.		345.22 345.22	14070.26 16360.82	379.74 379.74	14104.78 16395.34
	(iv)	Galvanized octagonal pole overall length 7 metre (sheet thickness 3mm), top dia.(A/F) 70mm and bottom dia. (A/F) 130mm, foundation size below ground level 550mm x 550mm x 1400mm, 4Nos. foundation bolts size 20mm dia., length≥ 700mm with base plate dimensions 240mm x 240mm x 16mm thick.		498.31	18407.22	548.14	18457.05
	(v)	Galvanized octagonal pole overall length 8 metre (sheet thickness 3mm), top dia.(A/F) 70mm and bottom dia. (A/F) 135mm, foundation size below ground level 550mm x 550mm x 1500mm, 4Nos. foundation bolts size 20mm dia., length≥ 750mm with base plate dimensions 240mm x 240mm x 16mm thick.					
			each	498.31	20924.30	548.14	20974.13

Page 465 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Galvanized octagonal pole overall length 9 metre (sheet thickness 3mm), top dia.(A/F) 70mm and bottom dia. (A/F) 155mm, foundation size below ground level 600mm x 600mm x 1700mm, 4Nos. foundation bolts size 24mm dia., length≥ 750mm with base plate dimensions 275mm x 275mm x 16mm thick.	oaah	710.26	25736.79	781.29	25807.82
	(vii)	Galvanized octagonal pole overall length 10 metre (sheet thickness 3mm), top dia.(A/F) 70mm and bottom dia. (A/F) 175mm, foundation size below ground level 600mm x 600mm x 1800mm, 4Nos. foundation bolts size 24mm dia., length≥ 750mm with base plate dimensions 275mm x 275mm x 16mm thick.	each	710.26	29533.73	781.29	29604.76
	(viii)	Galvanized octagonal pole overall length 11 metre (sheet thickness 3mm), top dia.(A/F) 90mm and bottom dia. (A/F) 210mm, foundation size below ground level 600mm x 600mm x 2000mm, 4Nos. foundation bolts size 24mm dia., length≥ 750mm with base plate dimensions 300mm x 300mm x 20mm thick.					
	(ix)	Galvanized octagonal pole overall length 12 metre (sheet thickness 3mm), top dia.(A/F) 90mm and bottom dia. (A/F) 240mm, foundation size below ground level 650mm x 650mm x 2200mm, 4Nos. foundation bolts size 24mm dia., length≥ 850mm with base plate dimensions 320mm x 320mm x 20mm thick.	each	922.23	37522.53		
		CALVANIZED OCTACONAL DOLE DRACKETS	each	922.23	45102.96	1014.45	45195.18
	(x)	GALVANIZED OCTAGONAL POLE BRACKETS Supply and erection of single arm bracket 1 metre long for 4 to 6 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	42.97	1411.15	47.27	1415.45
	(xi)	Supply and erection of single arm bracket 1 metre long for 7 to 8 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
	(xii)	Supply and erection of single arm bracket 1 metre long for 9 to 10 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	53.69	1421.87	59.06	1427.24
	(xiii)	Supply and erection of single arm bracket 1 metre long for 11 to 12 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	71.59	1439.77	78.75	1446.93
			each	85.90	1702.20	94.49	1710.79

Page 466 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xiv)	Supply and erection of single arm bracket 1.5 metre long for 4 to 6 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	42.97	1769.57	47.27	1773.87
	(xv)	Supply and erection of single arm bracket 1.5 metre long for 7 to 8 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
			each	53.69	1780.29	59.06	1785.66
	(xvi)	Supply and erection of single arm bracket 1.5 metre long for 9 to 10 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	71.59	1798.19	78.75	1805.35
	(xvii)	Supply and erection of single arm bracket 1.5 metre long	еасп	71.59	1790.19	76.75	1605.33
	(2011)	for 11 to 12 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
			each	85.90	2058.33	94.49	2066.92
	(xviii)	Supply and erection of single arm bracket 2 metre long for 4 to 6 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
			each	42.97	2188.86	47.27	2193.16
	(xix)	Supply and erection of single arm bracket 2 metre long for 7 to 8 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	53.69	2199.58	59.06	2204.95
	(xx)	Supply and erection of single arm bracket 2 metre long for 9 to 10 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.		90.00	2.00.00	33.03	
			each	71.59	2217.48	78.75	2224.64
	(xxi)	Supply and erection of single arm bracket 2 metre long for 11 to 12 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at					
			each	85.90	2479.92	94.49	2488.51
	(xxii)	Supply and erection of double arm bracket 1 metre long for 4 to 6 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
			each	53.69	2189.23	59.06	2194.60

Page 467 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxiii)	Supply and erection of double arm bracket 1 metre long for 7 to 8 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	71.59	2207.13	78.75	2214.29
	(xxiv)	Supply and erection of double arm bracket 1 metre long for 9 to 10 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	Gacii				
	, ,		each	85.90	2221.44	94.49	2230.03
	(xxv)	Supply and erection of double arm bracket 1 metre long for 11 to 12 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	ooob	107 20	2490.04	140.42	2500.65
	(xxvi)	Supply and erection of double arm bracket 1.5 metre long for 4 to 6 metre long galvanized octagonal pole, the	each	107.38	2489.91	118.12	2500.65
		bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
			each	53.69	2902.62	59.06	2907.99
	(xxvii)	Supply and erection of double arm bracket 1.5 metre long for 7 to 8 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
	(xxviii)	Supply and erection of double arm bracket 1.5 metre long for 9 to 10 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	71.59 85.90	2920.52 2934.83	78.75 94.49	2927.68 2943.42
	(xxix)	Supply and erection of double arm bracket 1.5 metre long for 11 to 12 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	Gacii		2904.03	34.43	2340.42
	()		each	107.38	3204.43	118.12	3215.17
	(xxx)	Supply and erection of double arm bracket 2 metre long for 4 to 6 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	53.69	3745.80	59.06	3751.17
	(xxxi)	Supply and erection of double arm bracket 2 metre long for 7 to 8 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.					
			each	71.59	3763.70	78.75	3770.86

Page 468 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xxxii)	Supply and erection of double arm bracket 2 metre long for 9 to 10 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.	each	85.90	3778.01	94.49	3786.60
	(xxxiii)	Supply and erection of double arm bracket 2 metre long for 11 to 12 metre long galvanized octagonal pole, the bracket should be fixed on the top of the pole having top outer dia. 70mm (A/F) complete in all respect as approved by the Engineer-in-charge at site.		107.38	4046.47	118.12	4057.21
33.31A		3-STEPPED STEEL TUBULAR POLE:					
	pole of s 1980 to ground depth to mixture 80cm lo distribut cover w required be finis	and erection of 3-Stepped steel tubular swaged and welded suitable length conforming to I.S. 2713-1969 (Part I to III) / o fixed up to a required planting depth below level in a hole of excavation about 45 cm dia. and suitable of filled in up to 15 cm below G/L with 1:2:4 cement concrete and having 1:2:4 cement concrete muff of dia. 450mm, and above ground level sufficient to completely flush a MCB ion board SPN 4way (double door) with hinged water tight with locking arrangement having one single pole MCB of a capacity fixed on din bar. The outer surface of the plinth to hed with pure cement including painting of pole with two approved aluminium paint as required:-					
	(i)	Overall length 7 metre, with planting depth 1.25 metre, length of sections 4 metre,1.5 metre and 1.5 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 127mm x 4.5mm, 101.6mm x 3.65mm and 76.1mm x 3.25mm (Bottom, Middle and Top respectively) with approximate weight 74 kg and base plate weight 12 kg. of size 12mm thick about 30 cm dia.		649.22	0620.40	712.15	9702 24
	(ii)	Overall length 8 metre , with planting depth 1.5 metre, length of sections 4.5 metre, 1.75 metre and 1.75 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 127mm x 4.5mm, 101.6mm x 3.65mm and 76.1mm x 3.25mm (Bottom, Middle and Top respectively) with approximate weight 84 kg and base plate weight 12 kg. of size 12mm thick about 30 cm dia.		648.32	9541.69	713.15	8703.31 9609.01
	(iii)	Overall length 8.5 metre, with planting depth 1.5 metre, length of sections 4 metre, 2.25 metre and 2.25 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 168.3mm x 4.5mm, 139.7mm x 4.5mm and 114.3mm x 3.65mm (Bottom, Middle and Top respectively) with approximate weight 126 kg and base plate weight 12 kg. of size 12mm thick about 30 cm dia.		677.92	12282.93		12350.72

Page 469 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(iv)	Overall length 9 metre, with planting depth 1.5 metre, length of sections 4.5 metre, 2.25 metre and 2.25 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 168.3mm x 4.85mm, 139.7mm x 4.5mm and 114.3mm x 3.65mm (Bottom, Middle and Top respectively) with approximate weight 152 kg and base plate weight 12 kg. of size 12mm thick about 30 cm dia.					
	(v)	Overall length 9.5 metre, with planting depth 1.8 metre, length of sections 4.5metre, 2.50metre and 2.50metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 168.3mm x 4.85mm, 139.7mm x 4.5mm and 114.3mm x 3.65mm (Bottom, Middle and Top respectively) with approximate weight 158 kg and base plate weight 12 kg. of size 12mm thick about 30 cm dia.		677.92	13997.89	745.71 752.20	14685.01
	(vi)	Overall length 10 metre , with planting depth 1.8 metre, length of sections 5 metre, 2.50 metre and 2.50 metre (Bottom , Middle and Top respectively), Outer dia and thickness of sections 168.3mm x 4.85mm, 139.7mm x 4.5mm and 114.3mm x 4.5mm (Bottom, Middle and Top respectively) with approximate weight 168 kg and base plate weight 12 kg. of size 12mm thick about 30 cm dia.		683.82	14616.63 15280.35	752.20	14685.01 15348.73
33.31 B		Supply and erection of 3-Stepped steel tubular swaged and welded pole of suitable length conforming to I.S. 1161-1979 (UTS 42 kgf/mm sq.) to fixed up to a required planting depth below ground level in a RCC readymade muff of suitable length and dia. as described under the required sub-head here under. The gap between the pole and muff is to be filled with 1:2:4 cement concrete as required at site:-		003.02	13200.33	732.20	10040.70
	(i)	Overall length 7 metre, with planting depth 1.25 metre (in 1.25 metre long 200mm dia RCC ready made muff), length of sections 4 metre,1.5 metre and 1.5 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 114.3mm x 4.5mm, 88.9mm x 4.05mm and 76.1mm x 3.25mm (Bottom, Middle and Top respectively) with approximate weight 73 kg. (410 SP-2)		510.21	5706 67	561 24	5757 70
	(ii)	Overall length 7.5 metre, with planting depth 1.25 metre (in 1.25 metre long 200mm dia RCC ready made muff), length of sections 4.5 metre,1.5 metre and 1.5 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 114.3mm x 4.5mm, 88.9mm x 4.05mm and 76.1mm x 3.25mm (Bottom, Middle and Top respectively) with approximate weight 79 kg. (410 SP-5)	each	510.31	5706.67	561.34	5757.70
	(iii)	Overall length 8 metre, with planting depth 1.5 metre (in 1.5 metre long 200mm dia RCC ready made muff), length of sections 4.5 metre,1.75 metre and 1.75 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 139.7mm x 4.5mm, 114.3mm x 3.65mm and 88.9mm x 3.25mm (Bottom, Middle and Top respectively) with approximate weight 97 kg. (410 SP-7)	each	510.31	6104.90	561.34	6155.93
			each	510.31	7441.41	7492.44	0.00

Page 470 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mo	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(iv)	Overall length 8 metre, with planting depth 1.5 metre (in 1.5 metre long 200mm dia RCC ready made muff), length of sections 4.5 metre,1.75 metre and 1.75 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 139.7mm x 5.4mm, 114.3mm x 4.5mm and 88.9mm x 3.25mm (Bottom, Middle and Top respectively) with approximate weight 119 kg. (410 SP-15)	each	510.31	8930.24	561.34	8981.27
	(v)	Overall length 8.5 metre, with planting depth 1.5 metre (in 1.5 metre long 300mm dia RCC ready made muff), length of sections 5 metre,1.75 metre and 1.75 metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 165.1mm x 4.5mm, 139.7mm x 4.5mm and 114.3mm x 3.65mm (Bottom, Middle and Top respectively) with approximate weight 141 kg. (410 SP-22)	each	510.31	10259.57	561.34	10310.60
	(vi)	Overall length 9 metre, with planting depth 1.5 metre (in 1.5 metre long 200mm dia RCC ready made muff), length of sections 5 metre, 2 metre and 2metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 114.3mm x 5.4mm, 88.9mm x 4.85mm and 76.1mm x 3.25mm (Bottom, Middle and Top respectively) with approximate weight 108 kg. (410 SP-27)					
			each	510.31	8200.13	561.34	8251.16
	(vii)	Overall length 9 metre, with planting depth 1.5 metre (in 1.5 metre long 300mm dia RCC ready made muff), length of sections 5 metre, 2 metre and 2metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 165.1mm x 139.7mm, 4.5mm x 114.3mm and 3.65mm (Bottom, Middle and Top respectively) with approximate weight 154 kg. (410 SP-32)	each	510.31	11253.28	561.34	11304.31
	(viii)	Overall length 10 metre, with planting depth 1.8 metre (2.00 metre long 300mm dia RCC ready made muff), length of sections 5.20 metre, 2.4 metre and 2.4metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 165.1mm x 4.85mm, 139.7mm x 4.5mm and 114.3mm x 3.65mm (Bottom, Middle and Top respectively) with approximate weight 168 kg. (410 SP-44)	each	510.31	12271.14	561.34	12322.17
	(ix)	Overall length 11 metre, with planting depth 1.8 metre (in 2.00 metre long 300mm dia RCC ready made muff), length of sections 5.6 metre, 2.7 metre and 2.7metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 165.1mm x 5.4mm, 139.7mm x 4.5mm and 114.3mm x 3.65mm (Bottom, Middle and Top respectively) with approximate weight 194 kg. (410 SP-54)					
	1	Overell length 40 moths with alastic 1 th 0 moths	each	510.31	13996.84	561.34	14047.87
	(x)	Overall length 12 metre, with planting depth 2 metre (in 2.00 metre long 350mm dia RCC ready made muff), length of sections 5.8 metre, 3.1 metre and 3.1metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 193.7mm x 5.4mm, 165.1mm x 4.5mm and 139.7mm x 4.5mm (Bottom, Middle and Top respectively) with approximate weight 259 kg. (410 SP-62)					
			each	510.31	18538.50	561.34	18589.53

Page 471 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xi)	Overall length 13 metre, with planting depth 2 metre (in 2.00 metre long 350mm dia RCC ready made muff), length of sections 5.8 metre, 3.6 metre and 3.6metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 219.1mm x 5.6mm, 193.7mm x 4.85mm and 165.1mm x 4.5mm (Bottom, Middle and Top respectively) with approximate weight 333 kg. (410 SP-71)	each	510.31	23450.09	561.34	23501.12
	(xii)	Overall length 16 metre, with planting depth 2 metre (in 2.00 metre long 400mm dia RCC ready made muff), length of sections 7 metre, 4.5 metre and 4.5metre (Bottom, Middle and Top respectively), Outer dia and thickness of sections 219.1mm x 5.9mm, 193.7mm x 4.85mm and 165.1mm x 4.50mm (Bottom, Middle and Top respectively) with approximate weight 405 kg. (410 SP-79)	each	510.31	28271.79	561.34	28322.82
33.32		PCC POLES:		0.0.0.	202 0	551161	
	suitable IS1678- dimens	and erection of pre-stressed cement concrete pole of e length with a given planting depth confirming to -1978 below ground level in excavated pit of suitable sion complete in all respect as per satisfaction of er-in-charge.					
	(i)	PCC pole overall length 8 metre, planting depth 1.5 metre, top dimensions 90mm x 145mm, bottom dimensions 90mm x 220mm, load capacity 200 kg and weight 380 kg.	each	354.17	2587.53	389.59	2622.95
	(ii)	PCC pole overall length 9 metre, planting depth 1.83 metre, top dimensions 105mm x 115mm, bottom dimensions 105mm x 315mm, load capacity 200 kg and weight 478 kg.					
	(iii)	PCC pole overall length 11 metre, planting depth 1.83 metre, top dimensions 152.4mm x 203.2mm, bottom dimensions 152.4mm x 368.3mm, load capacity 363 kg and weight 1146 kg.		421.52	2910.50 6555.19	463.67 541.51	2952.65 6604.42
33.33		OF UNDER GROUND CABLES, DISMENTALLING & TON OF POLES AND CEMENT CONCRETE MUFFS:	Caon	102.20	0000.10	011101	000 11 12
	(i)	Laying of under ground cable to be laid 1 metre below ground level including excavation, sand cushioning, covering with sand & bricks and back filling the trench etc.					
	(ii)	Labour for dismantling G.I. pipe pole upto length 6.1 m.	m	38.96	90.71	42.86	94.61
	(iii)	Labour for dismantling 3-stepped steel tubular pole upto 16m.	each each	158.43 520.94	158.43 520.94	174.27 573.03	174.27 573.03
	(iv)	Erection of G.I. pipe pole upto 6 m length in cement concrete 1:2:4 up to ground level but excluding cost of pole including two coats of approved aluminium paint etc.					
		· ·					

Page 472 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(v)	Erection of 3 stepped steel tubular pole upto 10 m length in cement concrete 1:2:4 up to ground level but excluding cost of pole including two coats of approved aluminium paint etc.	oooh	212.00	1469.00	224.10	1400.10
	(vi)	Making of cement concrete muff of overall size 450mmdia., 45cm long (15cm below ground level) with 1:2:4 cement concrete mixture. The muff is to be made around the steel tubular pole/ GI pipe pole. The outer surface of the muff shall be finished with 1:2 cement plaster with two coats of white snowcem complete in all respect as approved and desired by the Engineer In-Charge at site.		212.90	1468.90 392.34	234.19	1490.19 395.51
	(vii)	Making of cement concrete muff of overall size 450mmdia., 60cm long (15cm below ground level) with 1:2:4 cement concrete mixture. The muff is to be made around the steel tubular pole/ GI pipe pole. The outer surface of the muff shall be finished with 1:2 cement plaster with two coats of white snowcem complete in all respect as approved and desired by the Engineer In-Charge at site.					
	(viii)	Making of CC muff of overall size 450mm dia., 80cm long with 1:2:4 CC mixture. The muff is to be made around the steel tubular pole sufficient to completely flush a MCB DB SPN 4way (DD) with hinged water tight cover with locking arrangement having 1SP MCB of reqd.capacity fixed on din bar. The MCB DB is to be fixed with the pole by a MS flat clamp of size 20mmx2mm thick. The Box shall be fitted with bakelite strip size 8"x1"x3/8" deep fixed with the help of steel screws. 4 Nos. Brass links(3way)of size 1/2"x1/2" is to be fixed on the bakelite strip with the help of steel screws.PVC pipe40mm dia.(2No.x0.60m) should be provided for incoming and outgoing cables. The outer surface of the muff shall be finished with pure cement & 2 coats of white snowcem and making an extra collar will be provided with 1:2:4 Cement Sand & Concrete mixture around the Steel tubular pole. The size of collar (height is 16"&dia is 12" including pole dia i.e. 168.3mm) complete in all respect.		39.29	502.77	43.22	506.70
	(ix)	Making of cement concrete muff of overall size 450mmdia., 45cm long with 1:2:4 cement concrete mixture. The muff is to be made around the steel tubular pole/ GI pipe pole. The outer surface of the muff shall be finished with pure cement and two coats of white snowcem complete in all respect as approved and desired by the Engineer In-Charge at site.		52.81	502.77	43.22	506.70
			each	31.68	392.34	34.85	395.51

Page 473 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mo	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(x)	Making of cement concrete muff of overall size 450mmdia., 60cm long with 1:2:4 cement concrete mixture. The muff is to be made around the steel tubular pole/ GI pipe pole. The outer surface of the muff shall be finished with pure cement and two coats of white snowcem complete in all respect as approved and desired by the Engineer In-Charge at site.		52.04	540.00	50.00	504.57
	(xi)	Making of cement concrete muff of overall size 450mm	each	52.81	516.29	58.09	521.57
	(A)	dia., 80cm long with 1:2:4 cement concrete mixture. The muff is to be made around the steel tubular pole sufficient to completely flush a MCB distribution board SPN 4way (double door IP54) with hinged water tight cover with locking arrangement having two single pole MCB of required capacity fixed on din bar. The MCB distribution board is to be fixed with the pole by a MS flat clamp of size 20mm x 3mm thick. PVC pipe 40 mm dia. (2 No. x 0.60 m) should be provided for incoming and outgoing cables. The outer surface of the muff shall be finished with pure cement and two coats of white snowcem complete in all respect as approved and desired by the Engineer In-Charge at site.					
33.34	OVER	HEAD DISTRIBUTION ALLIMINIUM CADLES & ACSD	each	63.37	1603.90	69.71	1610.24
33.34	1	HEAD DISTRIBUTION ALUMINIUM CABLES & ACSR JCTORS:					
	(i)	Wiring over-head line in two single core cable with aluminium conductor insulated with P.V.C. and P.V.C. sheathed overall 1100 volts grade on G.I. wire 4mm dia. with brass/ aluminium link clips cable.					
	(a)	PVC insulated & PVC sheathed two single core aluminium conductor cable overall 1100 volts grade size 4mm² (1/1.40mm)		4.29	26.47	4.72	26.90
	(b)	PVC insulated & PVC sheathed two single core aluminium conductor cable overall 1100 volts grade size 6mm² (1/1.40mm)		4.29	30.51	4.72	30.94
	(c)	PVC insulated & PVC sheathed two single core aluminium conductor cable overall 1100 volts grade size 10mm² (1/1.40mm)		4.29	38.69	4.72	39.12
	(d)	PVC insulated & PVC sheathed two single core aluminium conductor cable overall 1100 volts grade size 16mm² (1/1.40mm)		4.29	58.21	4.72	58.64
	(ii)	Supply & erection of dead end clamps of di-cast Aluminium (size 20-100sq. mm) for making T line end terminal including cost of nuts & bolts etc. complete in all respect as approved by the Engineer-in-Charge.		7.25	55.21		20.01
			each	40.82	238.66	44.90	242.74

Page 474 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	untainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(iii)	Supply & erection of PG di-cast Aluminium suitable for ACSR conductor size 30-50sq. mm for making T/lines ends including cost of nut and bolts etc. as approved by Engineer-in-charge.					
			each	40.82	98.26	44.90	102.34
	(iv)	Supply & erection of PG di-cast Aluminium suitable for ACSR conductor size 80-100sq. mm for making T/lines ends including cost of nut and bolts etc. as approved by Engineer-in-charge.					
			each	40.82	136.55	44.90	140.63
	(v)	Supply & erection of PVC insulated PVC sheathed aluminium conductor single core cable size 50sq. mm for providing jumpering arrangement on overhead lines.	each	20.39	95.57	22.43	97.61
	(vi)	Supply & erection of PVC insulated PVC sheathed	eacii	20.39	93.37	22.43	97.01
	(**)	aluminium conductor single core cable size 70sq. mm for providing jumpering arrangement on overhead lines.					
			each	20.39	117.23	22.43	119.27
	(vii)	Supply & erection of PVC insulated PVC sheathed aluminium conductor single core cable size 120sq. mm for providing jumpering arrangement on overhead lines.					
			each	20.39	182.41	22.43	184.45
		_T Joint Kit/ Termination for outdoor supply of 1.1 KV					
Α	grade F (i)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable					
	(1)	Size 2 core 16 sq. mm - 35 sq. mm	Each	40.82	599.89	44.90	603.97
	(ii)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable Size 2 core 50 sq. mm - 70 sq. mm	Each	40.82	672.64	44.90	676.72
	(iii)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable Size 3 core 16 sq. mm - 25 sq. mm	Each	81.66	640.73	89.83	648.90
	(iv)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable Size 3 core 35 sq. mm - 70 sq. mm	Each	102.05	733.87	112.26	744.08
	(v)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable					
	(vi)	Size 3 core 95 sq. mm - 185 sq. mm Outdoor/Indoor Cast Resin Type Jointing Kit for Cable	Each	204.14	878.08	224.55	898.49
	(vii)	Size 3 core 240 sq. mm - 300 sq. mm Outdoor/Indoor Cast Resin Type Jointing Kit for Cable	Each	204.14	1238.03	224.55	1258.44
	,	Size 3½ core 25 sq. mm - 50 sq. mm	Each	102.05	733.87	112.26	744.08
	(viii)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable Size 3½ core 70 sq. mm - 150 sq. mm	Each	204.14	878.08	224.55	898.49
	(ix)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable Size 3½ core 185 sq. mm - 300 sq. mm	Each	408.23	1442.12	449.05	1482.94
	(x)	Outdoor/Indoor Cast Resin Type Jointing Kit for Cable Size 3½ core 400 sq. mm	Each	408.23	1541.67	449.05	1582.49
		T Straight Through Joint Kit/ Termination for 1.1 KV					
В	grade I (i)	Straight Through Joint Kit for Cable Size 2 core 16 sq. mm - 35 sq. mm	Each	40.82	584.57	44.90	588.65
	(ii)	Straight Through Joint Kit for Cable Size 2 core 50 sq. mm - 70 sq. mm	Each	40.82	684.12	44.90	688.20
	(iii)	Straight Through Joint Kit for Cable Size 3 core 16 sq. mm - 25 sq. mm	Each	81.66	625.41	89.83	633.58
	(iv)	Straight Through Joint Kit for Cable Size 3 core 35 sq. mm - 70 sq. mm	Each	102.05	745.35	112.26	755.56
	(v)	Straight Through Joint Kit for Cable Size 3 core 95 sq. mm	Each	204.14	931.69	224.55	952.10

Page 475 CSR - 2010

Sr. No.		Description		PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Straight Through Joint Kit for Cable Size 3 core 120 sq. mm - 150 sq. mm	Each	6.12	810.26	6.73	810.87
	(vii)	Straight Through Joint Kit for Cable Size 3 core 185 sq. mm	Each	204.14	1329.93	224.55	1350.34
	(viii)	Straight Through Joint Kit for Cable Size 3 core 240 sq. mm	Each	204.14	1613.29	224.55	1633.70
	(ix)	Straight Through Joint Kit for Cable Size 3 core 300 sq. mm	Each	204.14	1812.40	224.55	1832.81
	(x)	Straight Through Joint Kit for Cable Size 3½ core 25 sq. mm - 35 sq. mm	Each	102.05	745.35	112.26	755.56
	(xi)	Straight Through Joint Kit for Cable Size 3½ core 50 sq. mm Straight Through Joint Kit for Cable Size 3½ core 70 sq.	Each	102.05	775.99	112.26	786.20
	(xii)	mm - 95 sq. mm Straight Through Joint Kit for Cable Size 3½ core 10 sq.	Each	204.14	931.69	224.55	952.10
	(xiv)	mm - 150 sq. mm Straight Through Joint Kit for Cable Size 3½ core 125 sq.	Each	204.14	1008.28	224.55	1028.69
	(xv)	mm Straight Through Joint Kit for Cable Size 3½ core 240 sq.	Each	204.14	1452.46	224.55	1472.87
	(xvi)	mm Straight Through Joint Kit for Cable Size 3½ core 300 sq.	Each	408.23	2016.49	449.05	2057.31
33.34	, ,	mm stringing and sagging of aluminium conductor steel	Each	408.23	2169.67	449.05	2210.49
С		ced (ACSR) on poles including binding with insulators					
	(i)	ACSR-WEASEL conductor (30 sq. mm)		0.05	04.00		04.07
	/ii\	Size (6/2.55 Al.+1/2.55mm GI)	Metre	2.65	21.60	2.92	21.87
	(ii)	ACSR-RABIT conductor (50 sq. mm) Size (6/3.35 Al.+1/3.35mm GI)	Metre	3.32	34.66	3.65	34.99
	(iii)	ACSR-RACOON conductor (80 sq. mm) Size (6/4.09 Al.+1/4.09mm GI)	Metre	4.09	50.72	4.50	51.13
	(iv)	ACSR-DOG conductor (100 sq. mm) Size (6/4.55 Al.+1/4.55mm Gl)	Metre	5.93	67.95	6.52	68.54
33.35		HEAD DISTRIBUTION INSULATORS, STAY SETS & .E GUARDS:					
	(i)	Supply & erection of Egg/ strain insulator as required at site confirming to ISI specifications as approved by					
		Engineer-in-charge.	each	20.39	58.69	22.43	60.73
	(ii)	Supply & erection of 11 KV pin insulator with GI pin confirming to ISI specifications. The item includes supply and erection of nuts bolts and other accessories whatsoever required at site for fixing it to the structure pole. The job is to be completed as approved by Engineer-					
		in-charge.	each	20.39	205.47	22.43	207.51
	(iii)	Supply & erection of 11 KV disc insulator confirming to ISI specifications. The item includes supply and erection of nuts bolts and other accessories whatsoever required at site for fixing it to the structure pole. The job is to be completed as approved by Engineer-in-charge.					
	(iv)	Supply & erection of shackle insulator (medium) with fixing	each	40.82	417.81	44.90	421.89
		bolts and nuts confirming to relevent ISI specifications as approved by Engineer-in-charge.					
			each	20.39	72.36	22.43	74.40

Page 476 CSR - 2010

(vi) Supply & erection of stay set consisiting of 19/20mm dia. 1.8 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for stay, binding, Egg/Strain insulator, MS elbow made out of 16mm plain sheet and a piece of 50mm x 50mm x 6mm size 20cm long angle iron made to the shape as approved by Engineer-in-charge. Stay set complete shall be fixed to the pole by providing suitable size full clamps made out 50mm x 6mm size MS flat with required number of nut and bolts 16mm dia. on one end and shall be embedded in the on the other end. The stay plate shall be covered with cement concrete having total volume of the concrete not less that 0.042Cum. The job shall include excavation of pit and back filling and after pouring concrete with excavated soil etc. as approved/desired by the the Engineer-in-charge. (vii) Supply & erection of stay set consisiting of 19/20mm dia. 2.4 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for	te Rate
(v) Supply & erection of 11 KV lighting arrestor confirming to ISI specifications. The item includes supply and erection of clamps of required size with nut and bolts and a seprate earth to be provided to the lighting arrestor complete as approved by Engineer-in-charge. (vi) Supply & erection of stay set consisiting of 19/20mm dia. 1.8 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for stay, binding, Egg/Strain insulator, MS elbow made out of 16mm plain sheet and a piece of 50mm x 50mm x 6mm size 20cm long angle iron made to the shape as approved by Engineer-in-charge. Stay set complete shall be fixed to the pole by providing suitable size full clamps made out 50mm x 6mm size MS flat with required number of nut and bolts 16mm dia. on one end and shall be embedded in the on the other end. The stay plate shall be covered with cement concrete having total volume of the concrete not less that 0.042Cum. The job shall include excavation of pit and back filling and after pouring concrete with excavated soil etc. as approved/desired by the the Engineer-in-charge. (vii) Supply & erection of stay set consisiting of 19/20mm dia. 2.4 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for	
ISI specifications. The item includes supply and erection of clamps of required size with nut and bolts and a seprate earth to be provided to the lighting arrestor complete as approved by Engineer-in-charge. (vi) Supply & erection of stay set consisiting of 19/20mm dia. 1.8 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for stay, binding, Egg/Strain insulator, MS elbow made out of 16mm plain sheet and a piece of 50mm x 50mm x 6mm size 20cm long angle iron made to the shape as approved by Engineer-in-charge. Stay set complete shall be fixed to the pole by providing suitable size full clamps made out 50mm x 6mm size MS flat with required number of nut and bolts 16mm dia. on one end and shall be embedded in the on the other end. The stay plate shall be covered with cement concrete having total volume of the concrete not less that 0.042Cum. The job shall include excavation of pit and back filling and after pouring concrete with excavated soil etc. as approved/desired by the the Engineer-in-charge. (vii) Supply & erection of stay set consisiting of 19/20mm dia. 2.4 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for	4.90 3044.45
(vi) Supply & erection of stay set consisiting of 19/20mm dia. 1.8 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for stay, binding, Egg/Strain insulator, MS elbow made out of 16mm plain sheet and a piece of 50mm x 50mm x 6mm size 20cm long angle iron made to the shape as approved by Engineer-in-charge. Stay set complete shall be fixed to the pole by providing suitable size full clamps made out 50mm x 6mm size MS flat with required number of nut and bolts 16mm dia. on one end and shall be embedded in the on the other end. The stay plate shall be covered with cement concrete having total volume of the concrete not less that 0.042Cum. The job shall include excavation of pit and back filling and after pouring concrete with excavated soil etc. as approved/desired by the the Engineer-in-charge. (vii) Supply & erection of stay set consisiting of 19/20mm dia. 2.4 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for	7.30
(vii) Supply & erection of stay set consisiting of 19/20mm dia. 2.4 metre long G.I. stay rod duly threaded upto 300mm at one end and shped on the other end. MS plate size 30cm x 30cm x 6mm with 20mm dia. hole drilled in the centre of the plate G.I. stay wire size 7/10 SWG, G.I. thimble for	5.62 2000.66
stay, binding, Egg/Strain insulator, MS elbow made out of 16mm plain sheet and a piece of 50mm x 50mm x 6mm size 20cm long angle iron made to the shape as approved by Engineer-in-charge. Stay set complete shall be fixed to the pole by providing suitable size full clamps made out 50mm x 6mm size MS flat with required number of nut and bolts 16mm dia. on one end and shall be embedded in the on the other end. The stay plate shall be covered with cement concrete having total volume of the concrete not less that 0.042Cum. The job shall include excavation of pit and back filling and after pouring concrete with excavated soil etc. as approved/desired by the the Engineer-in-charge.	5.02 2000.00
(viii) Supply & erection of cradle guard suitable for 2 lines overhead line as required at site as approved by Engineer-in-charge.	6.62 2063.50
(ix) Supply & erection of cradle guard suitable for 4 lines overhead line as required at site as approved by Engineer-in-charge.	2.43 41.86
each 20.39 43.80 2 33.36 A XLPE INSULATED HT ARMOURED CABLES	

Page 477 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1	screene	2 & laying of Circular Aluminium conductor, conductor ed with extruded semiconducting compound, XLPE ed, insulation screened with extruded semiconducting	3	4	5	6	7
	combinations cores la armoure IS:7098 ground	ation in combination with copper tape (0.3KA for 1sec.) aid up, FRLS PVC inner sheathed, galvanised steel striped and overall FRLS PVC sheathed cable confirming to I/II/85 working voltage 11KV(UE) grade to be laid 1 m below level including excavation, sand cushioning, covering with bricks and back filling the trench etc., of the required size:-					
	(i)	Circular Aluminium conductor, conductor screened with					
	(1)	extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 35sq.mm (Three Core)					
	(ii)	Circular Aluminium conductor, conductor screened with	each	53.25	866.25	58.58	871.58
	(")	extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 50sq.mm (Three Core)					
	(iii)	Circular Aluminium conductor, conductor screened with	each	53.25	951.91	58.58	957.24
	()	extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 70sq.mm (Three Core)					
	(is a)	Circular Aluminium conductor conductor caroonad with	each	65.49	1066.59	72.04	1073.14
	(iv)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 95sq.mm (Three Core)					
	(,,)	Circular Aluminium conductor conductor coronad with	each	65.49	1142.06	72.04	1148.61
	(v)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 120sq.mm (Three Core)					
		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	each	65.49	1279.82	72.04	1286.37

Page 478 CSR - 2010

Sr. No.	Description		Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vi)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 150sq.mm (Three Core)					
	(::\	Circular Aluminium and other and other and other	each	77.74	1442.23	85.51	1450.00
	(vii)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 185sq.mm (Three Core)					
			each	77.74	1590.43	85.51	1598.20
	(viii)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 240sq.mm (Three Core)					
	(;)		each	77.74	1878.35	85.51	1886.12
	(ix)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 300sq.mm (Three Core)		77 74	0400.05	05.54	0000 00
	(x)	Circular Aluminium conductor, conductor screened with	each	77.74	2193.05	85.51	2200.82
		extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 400sq.mm (Three Core)	each	77.74	2582.16	85.51	2589.93
33.36 B		PE INSULATED HT ARMOURED CABLES (LOOSE):					
	Supply & laying of Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade to be laid loose in the existing trench or pipe:-						

Page 479 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(i)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 35sq.mm (Three Core)	m	12.25	763.91	13.48	765.14
	(ii)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 50sq.mm (Three Core)		12.25	849.57	13.48	850.80
	(iii)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 70sq.mm (Three Core)		12.20	049.57	13.40	650.60
			m	24.49	964.25	26.94	966.70
	(iv)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 95sq.mm (Three Core)		04.40	1000 70	00.04	104047
	(,,)	Circular Alumainium condustor condustor corconal with	m	24.49	1039.72	26.94	1042.17
	(v)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 120sq.mm (Three Core)					
			m	24.49	1177.48	26.94	1179.93
	(vi)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 150sq.mm (Three Core)					
			m	24.49	1327.64	26.94	1330.09

Page 480 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vii)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 185sq.mm (Three Core)		24.40	4.475.04	20.04	4.470.20
	(viii)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 240sq.mm (Three Core)		24.49	1475.84 1763.76		1478.29
	(ix)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 300sq.mm (Three Core)		24.49	1/03./6	26.94	1766.21
			m	24.49	2078.46	26.94	2080.91
	(x)	Circular Aluminium conductor, conductor screened with extruded semiconducting compound, XLPE insulated, insulation screened with extruded semiconducting combination in combination with copper tape (0.3KA for 1sec.) cores laid up, FRLS PVC inner sheathed, galvanised steel strip armoured and overall FRLS PVC sheathed cable confirming to IS:7098/II/85 working voltage 11KV(UE) grade 400sq.mm (Three Core)					
22.22.2	0/5 (1		m	24.49	2467.57	26.94	2470.02
33.36 C	(i) (ii)	Heat Shrinkable cable end termination for 11 KVA /6.6 Heat Shrinkable for cable size 35 sq. mm (Indoor Type) Heat Shrinkable for cable size 50-95 sq. mm (Indoor Type)	Each	326.59	3016.60	359.25	3049.26
	()	, , , , , , , , , , , , , , , , , , , ,	Each	408.23	3208.32	449.05	3249.14
	(iii)	Heat Shrinkable for cable size 120-185 sq. mm (Indoor Type)	Each	612.37	3915.05	673.61	3976.29
	(iv)	Heat Shrinkable for cable size 240-300 sq. mm (Indoor Type)	Each	694.00	4618.93	763.40	4688.33
	(v)	Heat Shrinkable for cable size 35 sq. mm (Outdoor Type)	Each	326.59	3581.42	359.25	3614.08
	(vi)	Heat Shrinkable for cable size 50-95 sq. mm (Outdoor Type)		408.23	3773.14	449.05	3813.96
	(vii)	Heat Shrinkable for cable size 120-185 sq. mm (Outdoor Type)	Each	612.37	4695.26	673.61	4756.50
	(viii)	Heat Shrinkable for cable size 240-300 sq. mm (Outdoor Type)	Each	694.00	5427.85	763.40	5497.25
	(ix)	Heat Shrinkable for cable size 35 sq. mm (Straight Through Joint)	Each	326.59	8176.46	359.25	8209.12
	(x)	Heat Shrinkable for cable size 50-95 sq. mm (Straight Through Joint)	Each	408.23	8569.21	449.05	8610.03

Page 481 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mou	ıntainous
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xi)	Heat Shrinkable for cable size 120-185 sq. mm (Straight Through Joint)	Each	612.37	9582.27	673.61	9643.51
	(xii)	Heat Shrinkable for cable size 240-300 sq. mm (Straight Through Joint)	Each	694.00	10362.73	763.40	10432.13
33.37	DO	UBLE WALLED CORRUGATED (DWC) HDPE PIPES:		00 1100			.0.020
	Supply pipe to (making back fil	and erection of double walled corrugated (DWC) HDPE be laid 1mtr. below ground level including excavation g necessary trench), placing the pipe in position and ling with excavated soil etc. of the required size.					
	(i)	Double walled corrugated (DWC) HDPE pipe 50/ 38mm (outer/ inner dia.)		22.15	91.01	25 27	9E 12
	(ii)	Double walled corrugated (DWC) HDPE pipe 63/ 51mm (outer/ inner dia.)	m	32.15	81.91	35.37	85.13
	/:::\	Double welled corrugated (DMC) LIDDE =====00/70	m	32.15	99.09	35.37	102.31
	(iii)	Double walled corrugated (DWC) HDPE pipe90/76mm (outer/ inner dia.)	m	32.15	125.77	35.37	128.99
	(iv)	Double walled corrugated (DWC) HDPE pipe 120/103.5mm (outer/ inner dia.)					
	(v)	Double walled corrugated (DWC) HDPE pipe 160/ 136mm (outer/ inner dia.)	m	32.15	160.78	35.37	164.00
	(vi)	Double walled corrugated (DWC) HDPE pipe 180/ 152mm (outer/ inner dia.)	m	32.15	222.98	35.37	226.20
	(vii)	Double walled corrugated (DWC) HDPE pipe 200/ 170mm (outer/inner dia.)	m	32.15	284.54	35.37	287.76
		(odien inner dia.)	m	32.15	346.62	35.37	349.84
33.38		METAL CUBICAL PEDESTAL, TOWER STRUCTURES, T MISCELLANEOUS ITEMS:		02.10	0.0.02	00.01	0.0.0.
	(i)	S/E of SMCpedestal made from 50mmx50mmx6mm thick MS angle iron frame with 5 sides welded & covered with MS sheet 2mm thick & front side hinged with 4" hinges & locking system with heavy duty 12" sliding door.Placed on MS strip of size 12.5mmx2.5mm thick welded with MS sheet with 4no. legs of 50mmx50mmx6mm thick MS angle iron each of 600mm long with MS sheet 100mmx100mmx6mm thick at the bottom end of the legs.Front door welded x-actionally with MS flat 25mmx5mm.The front side with MS sheet each 75mm wide & a bend of 75mm width outwards & inwards on all sides with tappered top 200mm high.And pedestial with 4 Nos supporting members each of MS flat 50mmx6mm thick acc. to cubical size duly welded & complete pedestal to be painted with 1 coat of red oxide & 2 coats of paint &bonding to the existing earth to be erected in the 1:2:4 CC, the platform of 150mm high from ground level & 450mm thick & 150mm from the top of the CCplatform as per Drawing attached.					
	(a)	Cubical Size 900mm high, 600mm wide and 350mm deep	each	565.20	6617.60	621.72	6674.12

Page 482 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous		
				Labour Rate	Through Rate	Labour Rate	Through Rate	
1		2	3	4	5	6	7	
	(b)	Cubical Size 1200mm high, 900mm wide and 350mm						
		deep	each	624.08	9477.71	686.49	9540.12	
	(c)	Cubical Size 1200mm high, 1000mm wide and 500mm			-			
		deep	aaab	EGE 20	11225 00	604.70	11201 61	
	(d)	Cubical Size 1400mm high, 1200mm wide and 500mm	each	565.20	11235.09	621.72	11291.61	
	(4)	deep						
			each	565.20	13538.58	621.72	13595.10	
	(ii)	S/E of SMCpedestal made from 50mmx50mmx6mm thick MS angle iron with 5 sides welded & covered with MS sheet 2mm thick & front side hinged with 4" hinges & locking system with heavy duty 12" sliding door,placed on MS strip of size 12.5mmx2.5mm thick welded with MS sheet with 4no. legs of 50mmx50mmx6mm thick MS angle iron each of 600mm long with MS sheet 100mmx100mmx6mm thick at the bottom end of the legs.Front door welded x-actionally with MS flat 25mmx5mm.The front side with MS sheet each 75mm wide & a bend of 75mm width outwards & inwards on all sides. With tappered top 300mm high.And pedestal with 4 nos. supporting members each of 50mm x 50mm x 6mm thick MS angle iron (according to cubical size) duly welded & complete pedestal to be painted with (one coat of red oxide & two coats of paint) & bonding to the existing earth.And to be erected in the 1:2:4 CCplatform of 150mm high from ground level &450mm thick & 150mm from the top of the CCplatform as per Drawing attached.						
	(a)	Cubical Size 1200mm high, 1500mm wide and 350mm deep	each	565.20	13887.07	621.72	13943.59	
	(b)	Cubical Size 1200mm high, 1800mm wide and 350mm		2.2.2.23			11111111	
		deep			454.5	667 =		
	(iii)	S/E of M.S. Junction box 205mm x 155mm x 95mm made	each	565.20	15814.79	621.72	15871.31	
	(III)	from M.S. Sheet 16 SWG (1.60 mm thick) with top side of dimensions 155mm x 95mm, bottom side 155mm x 95mm, right side 205mm x 95 mm, left side 205mm x 95mm, back side 205mm x 155mm (all sides fixed) and front side hinged with dimensions 205mm x 155mm. Junction box should have one locking arrangement and 2 nos. hinges on front side. It should have 1 No. Brass terminal connecting strip, 1 No. Kit kat 16 Amp/240 Volts along with M.S. Flat 20mm x 2mm clamp with nuts and bolts for fixing on the pole. The junction box should be painted with one coat of good quality primer and two coats of post office red enamel paint inside and outside complete in all respect.						
			each	57.64	368.86	63.40	374.62	

Page 483 CSR - 2010

Sr. No.	Description		Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(iv)	S/E of M.S. Junction box 300 mm x 200 mm x 100 mm made from M.S. Sheet 16 SWG (1.60 mm thick) with top side of dimensions 200 mm x 100 mm, bottom side 200 mm x 100 mm, right side 300 mm x 100 mm, left side 300 mm x 100 mm, back side 300 mm x 200 mm (all sides fixed) and front side hinged with dimensions 300 mm x 200 mm. Junction box should have one locking arrangement and 2 nos. hinges on front side. It should have 1 No. Brass terminal connecting strip, 1 No. Kit kat 16 Amp/240 Volts along with M.S. Flat 20 mm x 2 mm clamp with nuts and bolts for fixing on the pole. The junction box should be painted with one coat of good quality primer and two coats of post office red enamel paint inside and outside complete in all respect.					
		iliside and odiside complete in all respect.	each	57.64	439.88	63.40	445.64
	(v)	S/E of M.S. Angle Iron structure upto 8.4 meter high 1500 mm base & 750 mm at the top. & 6nos horizontal support of M.S. Angle iron 50mmx50mmx5mm from G/L of length 1.46 m x4, 1.33mx4, 1.24 mx4, 1.11 mx4, 0.98mx4 & 0.84mx4 from bottom to top resp., 6 nos.inclined angle support of M.S.Angle iron 50mmx50mmx5mm from G/Lof length 1.87mx8, 1.79mx8, 1.70mx8,1.64mx8, 1.54mx8 & 1.31 mtr x 8 from bottom to top resp.,2 nos. horizontal support for Ladder of M.S.Angle iron 30mmx30mmx5mm of lengths 1.10 m & 1.35m to be welded with M.S.Angle iron 65mmx65mmx6mm.,4 nos. vertical angle support for the raising of tower of M.S. Angle Iron 65mmx65mmx6mm for the fixing of the above horizontal and vertical supports of length 8.4m each and for the fixing of octagonal platform on it.The vertical angle supports to be welded with M.S. base plates of thickness 20mm &10mm each of size 200mmx200mm 4nos.each under the base plate,spacer of M.S. Flat 40mmx5mm(24 nos.) for inclined angles to be erected with nuts & bolts 16 mm dia (176 Nos.)					
	(vi)	S/E of M.S. Tower Ladder suitable for tower structure of height 8.4 mtr made from M.S. Angle iron 30 mm x 30 mm x 5 mm of length 6.94 mtr with 24 nos. steps made from M.S. Rods 16 mm for climbing on the tower/ octagonal platform. Each rod should be 300 mm long and welded with vertical M.S. angle iron of tower ladder.		879.22	42825.66	967.14	
			each	761.47	3918.92	837.62	3995.07

Page 484 CSR - 2010

Sr. No.		Description		PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(vii)	S/E of M.S. Octagonal top of the tower structure of height 8.4 meter & base consists of 8 sides of M.S.Angle Iron 40mmx40mm x5 mm. Out of 8 sides, 4 sides of length 760 mm and 4 sides of length 700mm. The octagonal top of 8 Nos. vertical supports each of length 840 mm for mounting railing on it. The top end of the railing of 8 sides for fixing the fittings on it. Out of 8 sides, 4 sides of length 830 mm & 4 sides of length 650 mm. The platform of the octagonal top of mesh made from M.S. Square bars 8 mm dia of weight 41 Kg. The platform of opening (double door) with frame of M.S. Angle iron 40 mm x 40 mm x 5 mm with locking arrangement. The octagonal top of railing made from M.S. Flat 40mmx5mm having 8 sides between the top & bottom (in middle). Out of 8 sides, 4 sides of length 830 mm and 4 sides of length 650 mm. The whole platform of base made from M.S. Channel 75mmx40mmx4mm fixed x-sectionally having lengths 1750 mm x 2, 460 mm x 2 and 760 mm x 4 for fixing the opening system platform mesh etc on it.					
			each	761.47	10708.59	837.62	10784.74
	(viii)	Making of foundation 2050 mm deep suitable for tower of height 8.4 mtr and base 1500 mm x 1500 mm with 100 mm (4") cement concrete 1:5:10 with brick blast 40 mm guage. Foundation should have R.C.C. hand mixed 1:1½::3 with centering and shuttering complete in all respect. Foundation should have cold twisted deformed bars for slab reinforcement (10 mm dia), columns (12 mm dia) and rings (8 mm dia).For slab reinforcement, there should be 8 Nos. steel bars each of length 1000 mm for each column for bottom and top seperately. For R.C.C. Column, there should be 6 Nos. vertical steel bars each of length 2100 mm and 8 Nos. rings of dia 300 mm each for each column. At the top of each column there should be 10 mm thick M.S. Base plate size 200 mm x 200 mm. Foundation should have the provision of M.S. Nuts and bolts of size 20 mm dia 700 mm long 4 nos. for each column for fixing the tower on it Foundation should be 150 mm above ground level.		525.98	23452.79	578.58	23505.39
	(iv)	Supply 8 praction of 11 KV CO switch confirming to ISI	each	525.98	23452.79	578.58	23505.39
	(ix)	Supply & erection of 11 KV GO switch confirming to ISI specifications. The item includes supply and erection of operating pipe and handle arrangement of MS flat 50mm x 6mm and channels 75mm x 40mm sheet. The GO switch is to be fitted with locking arrangement so as it locks upward on 'ON' position and locks downward in 'OFF' position. The entire GO switch assembly/unit should be properly earthed and the job is to be completed as approved by Engineer-in-charge.		400.01	7540 70	470.0	7505.05
	(x)	Supply & erection of 'D' iron clamp 50mm x 6mm flat iron complete with fixing bolts and nuts (16mm x 200mm) including making holes in the pole as approved by	each	163.31	7518.72	179.64	7535.05
		Engineer-in-charge.					
			each	20.39	99.01	22.43	101.05

Page 485 CSR - 2010

Sr. No.	Description		Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xi)	Supply & erection of 'V' shape cross arm of MS channel 75mm x 40mm as per standard drawing. The item include supply and erection of half clamp made out of 50mm x 6mm flat including cost of nut and bolts as approved by Engineer-in-charge.	agah	40.82	462.07	44.00	467.15
	(xii)	Supply & erection of 11 KV Top Hamper made out of MS flat 50mm x 6mm as per standard drawing. The item includes supply and erection of nut and bolts (19mmx 125mm) as required. The job is to be completed as approved by Engineer-in-charge.			463.07	44.90	467.15
	(xiii)	S/E of M.S. Cooler stand of made from M.S. Angle iron 40 mm x 40 mm x 5 mm having dimensions of base 700 mm x 700 mm and top 700 mm x 700 mm on which cooler is to be fixed. M.S. Angle iron (4 no) legs of stand should be 700 mm high. The stand should be painted with one coat of primer and two coats of approved paint.	each	40.82	209.81	44.90	213.89
	(xiv)	S/E of M.S. Flat bracket made from 50 mm x 6 mm of length 600 mm and width 300 mm for installing metal hallide flood light fitting on it. Bracket should be fixed with the existing pipe of cover shed with M.S. Flat clamp of size 50 mm x 6 mm The bracket should be painted with one coat of primer and two coats of approved paint.	each	135.03	1510.97	148.53	1524.47
			m	84.40	406.04	92.84	414.48
	(xv)	S/E of M.S. Channel bracket made from 100 mm x 50 mm of length 600 mm and height 600 mm with M.S. Angle Iron 40 mm x 40 mm x 5 mm for installing metal hallide flood light fitting on it. Bracket should be fixed /welded with the existing pipe of cover shed. The bracket should be painted with one coat of primer and two coats of approved paint.					-
	(xvi)	MS sheet metal box (1mm thick) of length 1225mm breadth 400mm height 425mm with MS angle iron 40mm x 40mm x 5mm frame at the base of the box for storing metal hallide flud light fitting in it. Sheet metal should have top portion hinged with 6" (6 inch) hinges and divided into equal 8 compartments with sheet 1mm thick.	m_	84.40	848.34	92.84	856.78
			each	337.55	2983.80	371.31	3017.56
	(xvii)	Supply and Erection of MS angle iron size 50mm x 50mm x 5mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.					
	(xviii)	Supply and Erection of MS angle iron size 50mm x 50mm x 6mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.	m	40.07	186.41	44.08	190.42
			m	40.07	259.16	44.08	263.17

Page 486 CSR - 2010

Sr. No.		Description	Unit	PI	ains	Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1		2	3	4	5	6	7
	(xix)	Supply and Erection of MS angle iron size 30mm x 30mm x 5mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.					
	(xx)	Supply and Erection of MS angle iron size 40mm x 40mm x 5mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.	<u>m</u>	40.07	124.80	44.08	128.81
		, ,	m	40.07	155.57	44.08	159.58
	(xxi)	Supply and Erection of MS channel iron size 100mm x 50mm x 6mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.					
			m	48.11	435.31	52.92	440.12
	(xxii)	Supply and Erection of MS channel iron size 75mm x 40mm x 4mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.					
	(:::)	Country and Francisco of MO flat in a size 40 and a Francisco	m	48.11	327.50	52.92	332.31
	(xxiii)	Supply and Erection of MS flat iron size 40mm x 5mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.					
			m	32.07	95.79	35.28	99.00
	(xxiv)	Supply and Erection of MS flat iron size 50mm x 5mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.					
			m	32.07	130.09	35.28	133.30
	(xxv)	Supply and Erection of MS flat iron size 25mm x 5mm thick with cutting, bending and necessary holes as desired by Engineer-in-charge at site.					
			m	32.07	69.10	35.28	72.31
33.38 A		heavy duty aluminium thimbles/lugs for cable endition duly crimped including making necessary					
_ A	(i)	Aluminium cable core size 4 sq. mm - 6 sq. mm	Each	10.21	12.22	11.23	13.24
	(ii)	Aluminium cable core size 10 sq. mm - 16 sq. mm	Each	10.21	13.35	11.23	14.37
	(iii)	Aluminium cable core size 25 sq. mm - 35 sq. mm	Each	11.32	16.28	12.45	
	(iv)	Aluminium cable core size 50 sq. mm	Each	13.60		14.96	
	(v)	Aluminium cable core size 70 sq. mm	Each	13.60	25.83	14.96	27.19
	(vi)	Aluminium cable core size 95 sq. mm	Each	16.33		17.96	31.50
	(vii)	Aluminium cable core size 120 sq. mm	Each	16.33		17.96	
	(viii)	Aluminium cable core size 150 sq. mm	Each	20.39		22.43	
	(ix)	Aluminium cable core size 185 sq. mm	Each	20.39	50.92	22.43	52.96
	(x)	Aluminium cable core size 240 sq. mm	Each Each	27.22 27.22	77.51	29.94 29.94	80.23 103.25
	(xi) (xii)	Aluminium cable core size 300 sq. mm Aluminium cable core size 400 sq. mm	Each	27.22	100.53 133.21	29.94	135.93
	(XII)	Aluminium cable core size 400 sq. mm	Each	40.82	193.62	44.90	197.70
	(xiv)	Aluminium cable core size 500 sq. mm	Each	40.82	240.56	44.90	244.64
	(xv)	Aluminium cable core size 800 sq. mm	Each	40.82		44.90	330.09
	(xvi)	Aluminium cable core size 1000 sq. mm	Each	81.66	542.84		551.01
33.38		heavy duty Copper thimbles/lugs for cable end		000	0.2.0.		001.01
В		ation duly crimped including making necessary					
	(i)	Copper cable core size 4 sq. mm - 6 sq. mm	Each	10.21	16.80	11.23	17.82
	(ii)	Copper cable core size 10 sq. mm - 16 sq. mm	Each	10.21	21.25	11.23	
	(iii)	Copper cable core size 25 sq. mm - 35 sq. mm	Each	11.32	31.43		
	(iv)	Copper cable core size 50 sq. mm	Each	13.60		14.96	
	(v)	Copper cable core size 70 sq. mm	Each	13.60		14.96	
	(vi)	Copper cable core size 95 sq. mm	Each	16.33		17.96	
	(vii)	Copper cable core size 120 sq. mm	Each	16.33		17.96	94.15

Page 487 CSR - 2010

Sr. No.	Description		Unit	Plains		Sub Mountainous	
				Labour Rate	Through Rate	Labour Rate	Through Rate
1	2		3	4	5	6	7
33.38	S/E of heavy duty brass single compression gland for cable						
С	end termination duly complete with checknuts etc. including						
	(i)	Gland for Aluminium cable 2,3 core size 2.5 sq. mm	Each	20.39	32.71	22.43	34.75
	(ii)	Gland for Aluminium cable 2,3,4 core size 4 sq. mm	Each	20.39	35.52	22.43	37.56
	(iii)	Gland for Aluminium cable 2,3,4 core size 6 sq. mm	Each	20.39	39.40	22.43	41.44
	(iv)	Gland for Aluminium cable 4 core size 10 sq. mm	Each	27.22	42.35	29.94	45.07
	(v)	Gland for Aluminium cable 3,4 core size 16 sq. mm	Each	27.22	61.00	29.94	63.72
	(vi)	Gland for Aluminium cable 31/2,4 core size 25-35 sq. mm					
			Each	40.82	80.58	44.90	84.66
	(vii)	Gland for Aluminium cable 31/2,4 core size 50 sq. mm	Each	40.82	93.74	44.90	97.82
	(viii)	Gland for Aluminium cable 31/2,4 core size 70 sq. mm	Each	51.04	103.96	56.14	109.06
	(ix)	Gland for Aluminium cable 31/2,4 core size 95-120 sq. mm					
			Each	51.04	127.06	56.14	132.16
	(x)	Gland for Aluminium cable 3½ core size 150 sq. mm	Each	51.04	156.63	56.14	161.73
	(xi)	Gland for Aluminium cable 3½ core size 185 sq. mm	Each	81.66	209.08	89.83	217.25
	(xii)	Gland for Aluminium cable 3½ core size 240 sq. mm	Each	81.66	233.01	89.83	241.18
	(xiii)	Gland for Aluminium cable 3½ core size 300 sq. mm	Each	102.05	282.95	112.26	293.16
	(xiv)	Gland for Aluminium cable 3½ core size 400 sq. mm	Each	102.05	358.99	112.26	369.20
	(xv)	Gland for Aluminium cable 3½ core size 500 sq. mm	Each	136.09	435.27	149.70	448.88
	(xvi)	Gland for Aluminium cable 3½ core size 630 sq. mm	Each	204.14	570.18	224.55	590.59
33.39	DISMANTLING WIRING POINTS:						
	(i)	Fan, light or call bell point.	each	5.93	5.99	6.52	6.58
	(ii)	Wall socket, power plug point	Gacii	5.35	5.55	0.02	0.50
	(,		each	3.69	3.72	4.06	4.09

Page 488 CSR - 2010