

SECTION A. DETAILS OF THE PERSON ORDERING THE REPORT

Name Amersham Lettings Ltd

Address _____

SECTION B. REASON FOR PRODUCING THIS REPORT

Date(s) on which inspection and testing was carried out 2026-06-30

SECTION C. DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier Tenant

Address 12 High Street, Amersham, Buckinghamshire, HP7 0AA

Description of premises Residential ☐ Commercial ☐ Industrial ☐ Other ☐

Estimated age of wiring system _____ Evidence of additions / alterations? Yes ☐ No ☐ Not apparent ☐

Installation records available? (Regulation 651.1) Yes ☐ No ☐ Date of last inspection _____

SECTION D. EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of the electrical installation covered by this report Whole installation

Agreed limitations including the reasons (see Regulation 653.2) _____

Agreed with: _____

Operational limitations including the reasons _____

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2018 as amended to **A3:2024**.

It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

SECTION E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety) _____

Overall assessment of the installation in terms of its suitability for continued use: **SATISFACTORY**

*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

SECTION F. RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' (code FI). Observations classified as 'Improvement recommended' (code C3) should be given due consideration.

Subject to the necessary remedial action being taken, I/We recommend that the installation is further inspected and tested by 2031-06-30

SECTION G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Inspected and tested by: Name (Capitals) <u>D. JORDAN</u> Signature <u>D. Jordan</u> For/on behalf of <u>Jordan Electrical Ltd</u> Position _____ Date <u>2026-06-30</u>	Report authorised for issue by: Name (Capitals) <u>D. JORDAN</u> Signature <u>D. Jordan</u> For/on behalf of <u>Jordan Electrical Ltd</u> Position _____ Date <u>2026-06-30</u>
--	---

SECTION H. SCHEDULE(S)

1 Inspection Schedule(s) and 1 Schedule(s) of Circuit Details and Test Results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

SECTION I. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing arrangements

TN-C

☐

TN-S

☐

TN-C-S

☒

TT

☐

IT

☐

Number and Type of Live Conductors

AC 1-phase, 2-wire

☐

AC 1-phase, 3-wire

☐

AC 2-phase, 3-wire

☐

AC 3-phase, 3-wire

☐

AC 3-phase, 4-wire

☐

Nature of Supply Parameters

Nominal voltage, U / U0

230 V

Nominal frequency, f

Prospective fault current, Ipf

External earth fault loop impedance, Ze

0.21 Ω

(Note: (1) by enquiry (2) by enquiry or by measurement)

Supply Protective Device

BS (EN)

Type

Rated current

SECTION J. PARTICULARS OF INSTALLATION REFERRED TO IN THE REPORT

Means of Earthing

Distributor's facility

☐

Installation earth electrode

☐

Details of Installation Earth Electrode (where applicable)

Type (e.g. rod(s), tape etc)

Location

Electrode resistance to Earth

Main Protective Conductors

Earthing conductor: Material

csa

Main protective bonding: Material

csa

To water installation pipes

☐

To gas installation pipes

☐

To oil installation pipes

☐

To structural steel

☐

To lightning protection

☐

Main switch / Switch-fuse / Circuit-breaker / RCD

Location

BS (EN)

No of poles

Current rating

SECTION K. OBSERVATIONS

Referring to the attached inspection schedule(s) and schedule(s) of circuit details and test results:

No remedial action is required

☐

The following observations are made (see below)

☒

OBSERVATION(S) Include schedule reference, as appropriate	Classification code
[Item 4.10] No RCD test labels at consumer unit	C3
[Item 6.4] Bathroom supplementary bonding not verified at one location	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 - Danger present. Risk of injury. Immediate remedial action required

C2 - Potentially dangerous - urgent remedial action required

C3 - Improvement recommended

FI - Further investigation required without delay

Report No: FC-SAMPLE01

Page 2 of 6

Jordan Electrical Ltd · Generated with FieldCert

GENERIC SCHEDULE OF CIRCUIT DETAILS

Report No: FC-SAMPLE01

Distribution board details

DB reference: DB1 (hallway)Location: Supplied from: Zdb (Ω): 0.21Ipf (kA):

Main switch BS (EN): Rating (A): Voltage (V): SPD type(s): Correct polarity confirmed ☐Phase sequence confirmed ☐

CIRCUIT DETAILS															
1 Circuit number	2 Circuit description	3 Type of wiring	4 Reference method	5 Number of points served	6 Live (mm²)	7 cpc (mm²)	8 BS (EN)	9 Type	10 Rating (A)	11 Breaking capacity (kA)	12 Maximum permitted Zs (Ω)	13 BS (EN)	14 Type	15 IΔn (mA)	16 Rating (A)
1	Kitchen ring							B	32		1.37				
2	Downstairs sockets							B	32		1.37				
3	Lighting ground floor							B	6		7.28				
4	Electric shower							B	40		1.09				

GENERIC SCHEDULE OF TEST RESULTS

17 Circuit number	18 r1 (line) (Ω)	19 rn (neutral) (Ω)	20 r2 (cpc) (Ω)	21 (R1 + R2) (Ω)	22 R2 (Ω)	23 Test voltage (V)	24 Live-Live (MΩ)	25 Live-Earth (MΩ)	26 Polarity	27 Maximum measured Zs (Ω)	28 RCD disconnection time (ms)	29 Test button operation	30 AFDD manual test	31 Remarks
1								200	OK	0.61	24			
2								200	OK	0.72	26			
3								150	OK	1.94	22			
4								200	OK	0.38	19			

Tested by name (Capitals): D. JORDAN

Signature: D. Jordan

Date: 2026-06-30

CONDITION REPORT INSPECTION SCHEDULE FOR RESIDENTIAL AND SIMILAR PREMISES WITH UP TO 100 A SUPPLY

Report No: FC-SAMPLE01

Acceptable condition ✓	Unacceptable condition C1 or C2	Improvement recommended C3	Further investigation FI	Not verified N/V	Limitation LIM	Not applicable N/A
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)					
1.0	Condition of intake equipment: service cable, service head, earthing arrangement, meter tails, metering equipment, isolator (where present)					✓
1.1	Person ordering work / duty holder notified of inadequacies in the intake equipment					✓
1.2	Consumer's isolator (where present)					✓
1.3	Consumer's meter tails					✓
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)					
2.0	Presence of adequate arrangements for other sources such as microgenerators (551.6; 551.7)					✓
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)					
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)					✓
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)					✓
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13)					✓
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)					✓
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)					✓
3.6	Confirmation of main protective bonding conductor sizes (544.1)					✓
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)					✓
3.8	Accessibility and condition of other protective bonding connections (543.3.1; 543.3.2)					✓
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)					
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)					✓
4.2	Security of fixing (134.1.1)					✓
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)					✓
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)					✓
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)					✓
4.6	Presence of main linked switch (as required by 462.1.201) (462.1.201)					✓
4.7	Operation of main switch (functional check) (643.10)					✓
4.8	Manual operation of circuit breakers and RCDs to prove disconnection (643.10)					✓
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)					✓
4.10	Presence of RCD six-monthly test notice at or near consumer unit / distribution board (514.12.2)					C3
4.11	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)					✓
4.12	Presence of other required labelling (please specify) (Section 514)					✓
4.13	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)					✓
4.14	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)					✓
4.15	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.5; 522.8.11)					✓
4.16	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1)					✓
4.17	RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)					✓
4.18	RCD(s) provided for additional protection / requirements - includes RCBOs (411.3.3; 415.1)					✓
4.19	Confirmation of indication that SPD is functional (651.4)					✓
4.20	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)					✓
4.21	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)					✓
4.22	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)					✓
5.0	FINAL CIRCUITS					
5.1	Identification of conductors (514.3.1)					✓
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)					✓
5.3	Condition of insulation of live parts (416.1)					✓
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)					✓
5.4.1	To include the integrity of conduit and trunking systems (metal and plastic)					✓
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)					✓

5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	✓
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
5.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	✓
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
5.10	Concealed cables installed in prescribed zones (see Extent and limitations) (522.6.202)	✓
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Extent and limitations) (522.6.204)	✓
5.12	Provision of additional requirements for protection by RCD not exceeding 30 mA	✓
5.12.1	For all socket-outlets of rating 32A or less, unless an exception is permitted (411.3.3)	✓
5.12.2	For the supply of mobile equipment not exceeding 32A rating for use outdoors (411.3.3)	✓
5.12.3	For cables concealed in walls at a depth of less than 50mm (522.6.202; 522.6.203)	✓
5.12.4	For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.202; 522.6.203)	✓
5.12.5	For final circuits supplying luminaires within domestic (household) premises (411.3.4)	✓
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
5.14	Band II cables segregated / separated from Band I cables (528.1)	✓
5.15	Cables segregated / separated from communications cabling (528.2)	✓
5.16	Cables segregated / separated from non-electrical services (528.3)	✓
5.17	Termination of cables at enclosures - indicate extent of sampling in Extent and Limitations of the report (Section 526)	✓
5.17.1	Connections soundly made and under no undue strain (526.6)	✓
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
5.17.3	Connections of live conductors adequately enclosed (526.5)	✓
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2)	✓
5.19	Suitability of accessories for external influences (512.2)	✓
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)	✓
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER	
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	✓
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	✓
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	✓
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)	C3
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 2.5m from zone 1 (701.512.3)	✓
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	✓
6.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	✓
6.8	Suitability of current-using equipment for particular position within the location (701.55)	✓
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS	
7.02	Swimming pools and other basins (Section 702)	N/A
7.03	Rooms and cabins containing sauna heaters (Section 703)	N/A
7.04	Construction and demolition site installations. (BS 7375 should also be consulted within this special location. Findings which contravene BS 7375 may need to be reported separately.) (Section 704)	N/A
7.05	Agricultural and horticultural premises (Section 705)	N/A
7.06	Conducting locations with restricted movement (Section 706)	N/A
7.08	Electrical installations in caravan / camping parks and similar locations (Section 708)	N/A
7.09	Marinas and similar locations (Section 709)	N/A
7.11	Exhibitions, shows and stands. (BS 7909 should also be consulted within this special location. Findings which contravene BS 7909 may need to be reported separately.) (Section 711)	N/A
7.12	Solar photovoltaic (PV) power supply systems (Section 712)	N/A
7.14	Outdoor lighting installations (Section 714)	N/A
7.15	Extra-low voltage lighting installations (Section 715)	N/A
7.17	Mobile or transportable units (Section 717)	N/A
7.21	Electrical installations in caravans and motor caravans (Section 721)	N/A
7.22	Electric vehicle charging installations (Section 722)	N/A
7.29	Operating and maintenance gangways (Section 729)	N/A
7.30	Onshore units of electrical connections for inland navigation vessels (Section 730)	N/A

7.40	Temporary electrical installations for structures, amusement devices and booths at fairgrounds, amusement parks and circuses. (BS 7909 should also be consulted within this special location. Findings which contravene BS 7909 may need to be reported separately.) (Section 740)	N/A
7.53	Heating cables and embedded heating systems (Section 753)	N/A