

Date 2026-07-07

Certificate Serial No/Ref: FC-SAMPLE01

Jordan Electrical Ltd

Electrical Installation Condition Report

(Requirements for Electrical Installations - BS 7671 IET Wiring Regulations)

A. DETAILS OF THE CLIENT OR PERSON ORDERING THE WORK

Name: Amersham Lettings Ltd

Address:

B. REASON FOR PRODUCING THIS REPORT

Date(s) inspection and testing carried out: 2026-06-30

C. DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier: Tenant

Address: 12 High Street, Amersham, Buckinghamshire, HP7 0AA

Description of premises: Domestic

N/A

Commercial

N/A

Industrial

N/A

Other

N/A

Estimated age of the wiring system

Years

Evidence of additions or alterations: Yes

N/A

No

N/A

Installation records available? (Regulation 651.1) Yes

N/A

No

N/A

Date of last inspection:

Unknown

D. EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of the electrical installation covered by this report: Whole installation

Agreed limitations including the reasons, see Regulation 653.2:

Limitations agreed with:

Operational limitations including the reasons:

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671:2018 (IET Wiring Regulations) as amended to 2024. It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

Overall assessment of the installation in terms of its suitability for continued use:

SATISFACTORY

An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified

F. RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further investigation required' (code F1). Observations classified as 'Improvement recommended' (code C3) should be given due consideration.

Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by: 2031-06-30

G. OBSERVATIONS AND RECOMMENDATIONS FOR ACTIONS TO BE TAKEN

Referring to the attached schedules of inspection and test results, and subject to the limitations specified under 'Extent and limitations of inspection and testing':

There are no items adversely affecting electrical safety or ☒ The following observations and recommendations are made

Item No	Observations	Classification Code
1	Inspection Schedule Item 4.10: No RCD test labels at consumer unit	C3
2	Inspection Schedule Item 6.4: Bathroom supplementary bonding not verified at one location	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 Danger Present. Risk of injury. Immediate remedial action required **C2** Potentially dangerous. Urgent remedial action required **C3** Improvement recommended **FI** Further investigation required without delay

Immediate remedial action required for items:

Urgent remedial action required for items:

Improvement recommended for items:

Further investigation required for items:

H. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Trading Title: Registration Number (if applicable):

For the INSPECTION, TESTING AND ASSESSMENT of the report:

Name: Position: Signature: Date:

Report reviewed and authorised for issue by:

Name: Position: Signature: Date:

SCHEDULES

1 schedule(s) of circuit details and test results and 1 inspection schedule are attached. The attached schedules are part of this document and this report is valid only when they are attached to it.

I. SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

Earthing Arrangements		Number and Type of Live Conductors		Nature of Supply Parameters		Supply Protective Device	
TN-S:	N/A	1-phase (2-wire):	N/A	Nominal voltage, U/Uo:	230	V	BS (EN):
TN-C-S:	☒	1-phase (3-wire):	N/A	Nominal frequency, f:		Hz	Type:
TT:	N/A	2-phase (3-wire):	N/A	Prospective fault current, Ipf:		kA	Rated current: A
IT:	N/A	3-phase (3-wire):	N/A	External earth fault loop impedance, Ze:	0.21	Ω	
TN-C:	N/A	3-phase (4-wire):	N/A	Note: (1) by enquiry (2) by enquiry or by measurement			
Confirmation of supply polarity:			☒				

J. PARTICULARS OF INSTALLATION REFERRED TO IN THIS REPORT

Means of Earthing		Details of Installation Earth Electrode (where applicable)	
Distributor's facility:	N/A	Type:	
Installation earth electrode:	N/A	Resistance to Earth:	Ω
Main Switch / Switch-Fuse / Circuit-Breaker / RCD			
Location:		BS (EN):	
		Number of poles:	
		Current rating:	A
Earthing and Protective Bonding Conductors			
Earthing conductor material:		csa:	mm ²
Main bonding material:		csa:	mm ²
To water installation pipes	N/A	To gas installation pipes	N/A
To oil installation pipes	N/A	To structural steel	N/A
To lightning protection	N/A		

INSPECTION SCHEDULE FOR DOMESTIC & SIMILAR PREMISES WITH UP TO 100A SUPPLY		
Item	Description	Outcome
1.0	EXTERNAL CONDITION OF INTAKE EQUIPMENT (VISUAL INSPECTION ONLY)	
1.0	Condition of intake equipment: service cable, service head, earthing arrangement, meter tails, metering equipment, isolator (where present)	Pass
1.1	Person ordering work / duty holder notified of inadequacies in the intake equipment	Pass
1.2	Consumer's isolator (where present)	Pass
1.3	Consumer's meter tails	Pass
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)	
2.0	Presence of adequate arrangements for other sources such as microgenerators (551.6; 551.7)	Pass
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)	
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	Pass
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)	Pass
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13)	Pass
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)	Pass
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)	Pass
3.6	Confirmation of main protective bonding conductor sizes (544.1)	Pass
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)	Pass
3.8	Accessibility and condition of other protective bonding connections (543.3.1; 543.3.2)	Pass
4.0	CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)	
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)	Pass
4.2	Security of fixing (134.1.1)	Pass
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)	Pass
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)	Pass
4.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)	Pass
4.6	Presence of main linked switch (as required by 462.1.201) (462.1.201)	Pass
4.7	Operation of main switch (functional check) (643.10)	Pass
4.8	Manual operation of circuit breakers and RCDs to prove disconnection (643.10)	Pass
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	Pass
4.10	Presence of RCD six-monthly test notice at or near consumer unit / distribution board (514.12.2)	C3
4.11	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)	Pass
4.12	Presence of other required labelling (please specify) (Section 514)	Pass
4.13	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432, 433)	Pass
4.14	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	Pass
4.15	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.5; 522.8.11)	Pass
4.16	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1)	Pass
4.17	RCD(s) provided for fault protection - includes RCBOs (411.4.204; 411.5.2; 531.2)	Pass
4.18	RCD(s) provided for additional protection / requirements - includes RCBOs (411.3.3; 415.1)	Pass
4.19	Confirmation of indication that SPD is functional (651.4)	Pass
4.20	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	Pass
4.21	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	Pass
4.22	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	Pass
5.0	FINAL CIRCUITS	
5.1	Identification of conductors (514.3.1)	Pass
5.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	Pass
5.3	Condition of insulation of live parts (416.1)	Pass
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	Pass
5.4.1	To include the integrity of conduit and trunking systems (metal and plastic)	Pass
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	Pass
Acceptable condition PASS Unacceptable condition C1 or C2 Improvement recommended C3 Further investigation FI Not verified N/V Limitation LIM Not applicable N/A		

INSPECTION SCHEDULE FOR DOMESTIC & SIMILAR PREMISES WITH UP TO 100A SUPPLY		
Item	Description	Outcome
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	Pass
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	Pass
5.8	Presence and adequacy of circuit protective conductors (411.3.1; Section 543)	Pass
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	Pass
5.10	Concealed cables installed in prescribed zones (see Extent and limitations) (522.6.202)	Pass
5.11	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (see Extent and limitations) (522.6.204)	Pass
5.12	Provision of additional requirements for protection by RCD not exceeding 30 mA	Pass
5.12.1	For all socket-outlets of rating 32A or less, unless an exception is permitted (411.3.3)	Pass
5.12.2	For the supply of mobile equipment not exceeding 32A rating for use outdoors (411.3.3)	Pass
5.12.3	For cables concealed in walls at a depth of less than 50mm (522.6.202; 522.6.203)	Pass
5.12.4	For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.202; 522.6.203)	Pass
5.12.5	For final circuits supplying luminaires within domestic (household) premises (411.3.4)	Pass
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	Pass
5.14	Band II cables segregated / separated from Band I cables (528.1)	Pass
5.15	Cables segregated / separated from communications cabling (528.2)	Pass
5.16	Cables segregated / separated from non-electrical services (528.3)	Pass
5.17	Termination of cables at enclosures - indicate extent of sampling in Extent and Limitations of the report (Section 526)	Pass
5.17.1	Connections soundly made and under no undue strain (526.6)	Pass
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	Pass
5.17.3	Connections of live conductors adequately enclosed (526.5)	Pass
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	Pass
5.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2)	Pass
5.19	Suitability of accessories for external influences (512.2)	Pass
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)	Pass
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	Pass
6.0 LOCATION(S) CONTAINING A BATH OR SHOWER		
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)	Pass
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)	Pass
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)	Pass
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2018 (701.415.2)	C3
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 2.5m from zone 1 (701.512.3)	Pass
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)	Pass
6.7	Suitability of accessories and controlgear etc. for a particular zone (701.512.3)	Pass
6.8	Suitability of current-using equipment for particular position within the location (701.55)	Pass
7.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS		
7.02	Swimming pools and other basins (Section 702)	N/A
7.03	Rooms and cabins containing sauna heaters (Section 703)	N/A
7.04	Construction and demolition site installations. (BS 7375 should also be consulted within this special location. Findings which contravene BS 7375 may need to be reported separately.) (Section 704)	N/A
7.05	Agricultural and horticultural premises (Section 705)	N/A
7.06	Conducting locations with restricted movement (Section 706)	N/A
7.08	Electrical installations in caravan / camping parks and similar locations (Section 708)	N/A
7.09	Marinas and similar locations (Section 709)	N/A
7.11	Exhibitions, shows and stands. (BS 7909 should also be consulted within this special location. Findings which contravene BS 7909 may need to be reported separately.) (Section 711)	N/A
7.12	Solar photovoltaic (PV) power supply systems (Section 712)	N/A
7.14	Outdoor lighting installations (Section 714)	N/A
7.15	Extra-low voltage lighting installations (Section 715)	N/A
Acceptable condition PASS Unacceptable condition C1 or C2 Improvement recommended C3 Further investigation FI Not verified N/V Limitation LIM Not applicable N/A		

INSPECTION SCHEDULE FOR DOMESTIC & SIMILAR PREMISES WITH UP TO 100A SUPPLY		
Item	Description	Outcome
7.17	Mobile or transportable units (Section 717)	N/A
7.21	Electrical installations in caravans and motor caravans (Section 721)	N/A
7.22	Electric vehicle charging installations (Section 722)	N/A
7.29	Operating and maintenance gangways (Section 729)	N/A
7.30	Onshore units of electrical connections for inland navigation vessels (Section 730)	N/A
7.40	Temporary electrical installations for structures, amusement devices and booths at fairgrounds, amusement parks and circuses. (BS 7909 should also be consulted within this special location. Findings which contravene BS 7909 may need to be reported separately.) (Section 740)	N/A
7.53	Heating cables and embedded heating systems (Section 753)	N/A

Acceptable condition	PASS	Unacceptable condition	C1 or C2	Improvement recommended	C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
----------------------	------	------------------------	----------	-------------------------	----	-----------------------	----	--------------	-----	------------	-----	----------------	-----

DISTRIBUTION BOARD DETAILS

DB reference:

DB1 (hallway)

Location: Supplied from: No of phases:

Main switch BS (EN): Rating: A Voltage: V SPD type(s): Zs at DB: Ω Ip_f at DB: kA

Confirmation of supply polarity

N/A

Confirmation of phase sequence

N/A

SPD status indicator checked

N/A

SCHEDULE OF CIRCUIT DETAILS AND TEST RESULTS

Circuit Details																			Test Result Details										
Circuit number	Circuit description	Type of wiring	Reference method	Number of points served	Live (mm²)	cpc (mm²)	Max disconnect time (s)	BS (EN)	Type	Rating (A)	Breaking capacity (kA)	Maximum permitted Zs (Ω)	BS (EN)	Type	IΔn (mA)	Rating (A)	r1 (line) (Ω)	r _n (neutral) (Ω)	r2 (cpc) (Ω)	R1+R2 (Ω)	R2 (Ω)	Test voltage (V)	Live-Live (MΩ)	Live-Earth (MΩ)	Polarity	Maximum measured Zs (Ω)	Disconnect time (ms)	Test button	AFDD test
1	Kitchen ring								B	32		1.37												200	✓	0.61	24		
2	Downstairs sockets								B	32		1.37												200	✓	0.72	26		
3	Lighting ground floor								B	6		7.28												150	✓	1.94	22		
4	Electric shower								B	40		1.09												200	✓	0.38	19		
CODES FOR TYPE OF WIRING		A Thermoplastic insulated/sheathed cables			B Thermoplastic cables in metallic conduit			C Thermoplastic cables in nonmetallic conduit			D Thermoplastic cables in metallic trunking			E Thermoplastic cables in nonmetallic trunking			F Thermoplastic /SWA cables			G Thermosetting /SWA cables			H Mineral insulated cables			O Other			

Tested by name:

D. Jordan

Signature:

D. Jordan

Date:

2026-06-30