

Ground Floor DBs and Panels

Electrical Store:

Control Panel-05 LP1-CKT-20 (FOLIO PSP-08)

Control Panel-06 LP1-11

Control Panel-07 LP1-24

Control Panel-08 LP1-14 (FOLIO PSP-5)

GF Low Current Room (Nearby Electrical Store):

UPS-IDF: 01

ENC-SF: 02

DGP-FCU: N1

Electrical Room (Lounge Area):

Control Panel-01 PP1-CKT-03 (FOLIO-PSP-01)

Control Panel-03 PP1-CKT-01

Control Panel-02 PP1-CKT-05 (FOLIO-PSP-04)

Control Panel-XX PP1-CKT-11

MDB-01

SMDB-G

PP1-GF

LP1-GF

LCP-GF-03 LP1/GF-Q.05

Electrical Room (Behind the Cloak Room):

Control Panel-11 PP1-16 (FOLIO-PSP-09)

Control Panel-10 PP1-16 (FOLIO-PSP-10)

Control Panel-09 PP1-41 (FOLIO-PSP-11)

Electrical Room (Nearby VVIP Green Room):

LPP2-GF

Touch Zone-01 Panel (IP: 10.4.101.4)

LCP-GF-02 (Control Panel-D2-LPP3-CKT-36)

LCP-GF-01 (Control Panel-D1-LPP3-CKT-38)

LPP3-GF

FOLIO-PSP-13 (LPP3-CKT-35)

FOLIO-PSP-12 (LPP3-CKT-31,34)

BMS Room:

Touch Zone-02 (IP: 10.4.101.5)

ENC-GF

Electrical Room-01 (Under kitchen):

DPK-FF

SMDB/KIT-FF

SMDB/KIT-GF

Coffeeshop:

3PH-12-Way with Main Breaker

Electrical Room-02 (Under kitchen):

LPK1-GF

LPK2-GF (Coffee shop)

Control Panel (Empty)

STC HUB Room IUA001 SEC-A:

Control Panel-CKT-LPP2-02 (FOLIO-PSP-15)

Control Panel-CKT-LPP2-29 (FOLIO-PSP-14)

Theatre Area:

Left side:

SP-02

SP-01

Right side:

SP-04

SP-03

Theatre Area (Low Current Room):

UPS Power Panel-IDF-03

Theatre Area (Electrical Room):

First Panel: 0533973807

Duplex SP Panel: Supply 380/230V AC

First Floor DBs and Panels

Low Current Room (Near Theatre):

ENC-FF

Touch Zone-05 (IP: 10.4.101.8)

Electrical Room (Near Theatre):

SMDB-FF

LPP2-FF

LCP-1F-01 (LPP2-CKT-26)

LPP1-FF

LCP-1F-02 (LPP1-CKT-24)

Low Current Room (Near Artist Green Room):

UPS-FF-IDF-05

STC Main MDB IUA001

STC HVAC

STC Access Control Panel IUA001

STC BATB Box IUA001

Second Floor DBs and Panels

Low Current Room (Nearby Lounge Area):

ENC-SF-01

UPS Power Panel

Electrical Room (Nearby Lounge Area):

LP1-SF

LCP-2F-02

PP1-SF

Electrical Room (Nearby UDC Office Corridor):

ELP-FF

DPK-SF

PP3-SF

LP2-SF

PP2-SF

LCP-2F-01

Low Current Room (Nearby HR Office):

UPS-SF-IDF-06

Third Floor DBs and Panels

Electrical Room:

LPP1-TH

DPAC-3 (FCU)

DPAC-2 (FCU)

LCP-3F-01 (LPP1-TH-Q-34)

SMDB-TF

Kitchen:

DB: No name

Low Current Room:

Touch Panel-07 (IP: 10.4.101.10)

UPS-IDF-08

Roof Area:

DGP-TF-02

DGP-TF-01

Control Panel-02 (DPAC1-RF, CKT-07)

Control Panel-01 (DPAC1-RF, CKT-14)

DPAC1-RF-01

DPAC1-RF

DP-2-RF

North DBs and Panels

DB-NG-UPS

SMDB-NG

DB-NG

South DBs and Panels

XXX

XXX

XXX