

REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-AR-0011
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	20-Jan-26	NEED REPLY BY DATE :	27-Jan-26

SUBMISSION OF : ☒ Q&A ☐ Drawing ☒ Document ☐ Others (as specified below)


SUBJECT : Request for Confirmation - Indicate Wall Structure and Wall Finishes Type for D22 6th Floor


Total Page (s) : 2 (Including this page)

FUNCTION :	<input type="checkbox"/> Structural (ST)	<input type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input checked="" type="checkbox"/> Achitectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

(1) CONTRACTOR REQUEST FOR INFORMATION :

Indicate Wall Structure and Wall Finishes Type for D22 6th Floor.

Requested by : 
Engineering Manager

Reviewed by : 
Project Manager

(2) ATTN : Commtech Asia (Thailand)

☐ For Approval ☐ See Note ☒ Please Clarify

Note : Aurecon to confirm the wall finishings for the highlighted areas

From : GAA Group

By : 

Name / Position Mr. Itsarate Trachuengtong/
Project Manager

Date : 20-Jan-26

Reviewed By : 
Commtech Asia (Thailand)

Name / Position Finlay Coady
Sr. Project Manager
Date : 21 January 2026

(3) ATTN : AURECON

☐ For Approval ☐ See Note ☐ Please Clarify

Note : SLA: Please refer to the notes in the attached markup.

From : Commtech Asia (Thailand)

By :

Name / Position ()

Date :

Reviewed By : Tarkoon Suwansukhum
AURECON

Name / Position (Tarkoon S / Architect)

Date : 29 January 2026

(4) ATTN : STT GDC

☒ Clarification only ☐ Not Approved
☐ Approved for proceeding work
☐ Approved with comments, proceeding work in compliance with comments
☐ Approved with comments, not for proceeding work and need to re-submit

Note : Concur with SLA's response

From : AURECON

By :

Name / Position ()


Date :

Reviewed By : STT GDC 

Name / Position Sirawit Thepsuwan

Date : 4 Feb 2026

Indicate wall structure, wall finishes for D22 6th FL



The wall above and beside the door D22 shall be wall material 2 (block wall) and wall finish 2 (plaster and paint).