

REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-EL-0029
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	17-Jan-26	NEED REPLY BY DATE :	24-Jan-26

SUBMISSION OF : ☒ Q&A ☒ Drawing ☐ Document ☐ Others (as specified below)

SUBJECT : Request for Information - Add Junction Box for Phase 1 on 3rd, 4th and 5th Floor for Convenience for Tie-In in the Future Phase.


Total Page (s) : 2 (Including this page)

FUNCTION : ☐ Structural (ST) ☒ Electrical & Communication (EL) ☐ Mechanical (ME) ☐ Vertical Transport (VT)

☐ Architectural (AR) ☐ Fire Protection (FI) ☐ Hydraulic & Sanitary (HY) ☐ Other (O)

(1) CONTRACTOR REQUEST FOR INFORMATION :

Request for confirmation for adding Junction Boxes for Phase 1 on 3rd, 4th and 5th Floor for Convenience for Tie-in in the Future Phase.

Requested by : 
Engineering Manager

Reviewed by : 
Project Manager

(2) ATTN : Commtech Asia (Thailand)

☐ For Approval ☐ See Note ☒ Please Clarify

Note : Aurecon to confirm the location of the junction boxes.

From : GAA Group

By : 
Name / Position Mr. Itsarate Trachuengtong/
Project Manager

Date : 17-Jan-26

Reviewed By : 
Commtech Asia (Thailand)

Name / Position Finlay Coady
Sr. Project Manager
Date : 2nd February 2026

(3) ATTN : AURECON

☐ For Approval ☐ See Note ☐ Please Clarify


Note : AUR :
No objection to the proposed additional junction boxes in Phase 1 for future connection convenience.
However, please propose the installation locations for Levels 3, 4, and 5 in the shop drawings for our review and consideration.

CONTRACTOR DOCUMENT REVIEW
☐ ACCEPTED
☐ REJECTED
☒ MAKE CORRECTIONS NOTED & PROCEED
☐ REVISE AND RESUBMIT

Aurecon Consulting (Thailand) Co., Ltd.
By : Chutikarn Sinsopa
Date : 07 February 2026
Project No. : 523213-01
Data version : 02 February 2026

This review is only for general confirmation with the design concept of the project and does not constitute an endorsement of the design or construction. Any action taken is subject to the requirements of the contract documents.
This review does not release the Contractor of his contractual obligations nor of his responsibility to the Employer.
Any amendment does not constitute an order or authority for a price variation to the contract.

From : Commtech Asia (Thailand)

By : 
Name / Position ()

Date : 07 February 2026

Reviewed By : AURECON
Name / Position Chutikarn Sinsopa
Electrical Engineer

(4) ATTN : STT GDC

☐ Clarification only ☐ Not Approved


☐ Approved for proceeding work

☐ Approved with comments, proceeding work in compliance with comments

☐ Approved with comments, not for proceeding work and need to re-submit

Note :

From : AURECON

By : 
Name / Position ()

Date : 07 February 2026

Reviewed By : STT GDC
Name / Position
Date :

NOTE :

- 1.SUBCONTRACTOR OF PHASE 1 PROVIDES TO INSTALL THE JUNCTION BOX OF FIRE ALARM NETWORK SIGNAL ON EACH FLOOR TO PREPARE FOR TIE-IN THE FUTURE PHASE.
2. TS : 1P TWISTED PAIR W/SHIELD 16 AWG FRC CABLE