

## REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-AR-0038
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	3-Feb-26	NEED REPLY BY DATE :	10-Feb-26

SUBMISSION OF : ☒ Q&A ☐ Drawing ☐ Document ☐ Others (as specified below)

SUBJECT : Request for Information - Change of Ceiling Panel Specification from Gypsum Board to Metal Pan Ceiling Board

Total Page (s) : 1 (Including this page)


FUNCTION :	<input type="checkbox"/> Structural (ST)	<input type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input checked="" type="checkbox"/> Architectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

## (1) CONTRACTOR REQUEST FOR INFORMATION :

As per the current drawing and specification, the ceiling panel is indicated as gypsum ceiling board. However, we propose to change the ceiling panel material from gypsum board to metal pan

ceiling board, which will be consistent with the ceiling system used in the previous phase.

Kindly review and confirm if we can proceed with the metal pan ceiling board in place of the gypsum ceiling board for BKK2. The proposed material will match the previous phase Terra phase 4,6



Requested by :   
Engineering Manager


Reviewed by :   
Project Manager

## (2) ATTN : Commtech Asia (Thailand)

☐ For Approval ☐ See Note ☒ Please Clarify

Note : Please Aurecon to provide clarification.

From : GAA Group


By :   
Name / Position : Mr. Itsarate Trachuengtong/  
Project Manager  
Date : 3-Feb-26

Reviewed By :   
Commtech Asia (Thailand)  
Name / Position : Aphisakda Phueakchanthuek  
Construction Engineer  
Date : 2/5/2026


## (3) ATTN : AURECON

☐ For Approval ☐ See Note ☒ Please Clarify

Note : SLA: Level 6 South building used the gypsum board ceiling panel per below. Changing to metal pan is not accept due to the cost is higher.



From : Commtech Asia (Thailand)

By :   
Name / Position : ( Aphisakda Phueakchanthuek )  
Construction Engineer  
Date : 2/5/2026

Reviewed By : Tarkoon suwansukhum  
AURECON  
Name / Position : ( Tarkoon S / Architect )  
Date : 6 February 2026

## (4) ATTN : STT GDC

☐ Clarification only ☐ Not Approved  
☐ Approved for proceeding work  
☐ Approved with comments, proceeding work in compliance with comments  
☐ Approved with comments, not for proceeding work and need to re-submit

Note :

From : AURECON

By :  
Name / Position :  
Date :

Reviewed By : STT GDC

Name / Position  
Date :