

REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-AR-0036
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	23-Jan-26	NEED REPLY BY DATE :	30-Jan-26

SUBMISSION OF :	<input checked="" type="checkbox"/> Q&A	<input type="checkbox"/> Drawing	<input type="checkbox"/> Document	<input type="checkbox"/> Others (as specified below)
SUBJECT : Request for Information - Request for Tile Grout Specification and Colour Schemes for BKK2				

Total Page (s) : 1 (Including this page)

FUNCTION :	<input type="checkbox"/> Structural (ST)	<input type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input checked="" type="checkbox"/> Architectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

(1) CONTRACTOR REQUEST FOR INFORMATION :

GAA would like to request the specifications and color schemes for the tile grout in each room, as these details are not indicated in the construction drawings.

Requested by : 
Engineering Manager

Reviewed by : 
Project Manager

(2) ATTN : Commtech Asia (Thailand)

For Approval See Note Please Clarify

From : GAA Group

By : 

Name / Position : Mr. Itsarate Trachuengtong/
Project Manager

Date : 23-Jan-26

Note :

Aurecon to provide the tile grout specification

Reviewed By : Commtech Asia (Thailand)

Name / Position : Finlay Coady

Date : Sr. Project Manager
30th January 2026

(3) ATTN : AURECON

For Approval See Note Please Clarify

From : Commtech Asia (Thailand)

By :

Name / Position : ()

Date :

Note :

SLA: The tile grout joint colour shall be match with the tile colour and not lighter than the tile colour. The tile colour shall follow specification in AR-4501.

Reviewed By : Tarkoon Suwansukhum
AURECON

Name / Position : (Tarkoon S / Architect)

Date : 3 February 2026

(4) ATTN : STT GDC

- Clarification only Not Approved
- Approved for proceeding work
- Approved with comments, proceeding work in compliance with comments
- Approved with comments, not for proceeding work and need to re-submit

From : AURECON

By :

Name / Position : ()

Date :

Note :

Reviewed By : STT GDC

Name / Position :

Date :

