

REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-AR-0037
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	23-Jan-26	NEED REPLY BY DATE :	30-Jan-26

SUBMISSION OF : ☒ Q&A ☐ Drawing ☐ Document ☐ Others (as specified below)

SUBJECT : Request for Information - Confirm to Change Weberdry S3000S to Proofex GPE due to Discontinued Product

Total Page (s) : 3 (Including this page)


FUNCTION :	<input type="checkbox"/> Structural (ST)	<input type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input checked="" type="checkbox"/> Architectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

(1) CONTRACTOR REQUEST FOR INFORMATION :

Gaa would like to inform you that weberdry S3000S has been discontinued by Saint-Gobain. Therefore, we would like to propose Proofex GPE as an alternative solution for your consideration.

Requested by : 

Engineering Manager


Reviewed by : 


Project Manager

(2) ATTN : Commtech Asia (Thailand)

☐ For Approval ☐ See Note ☒ Please Clarify

Note : GAA need to provide specification sheet for Proofex GPE


From : GAA Group
By : 
Name / Position : Mr. Itsarate Trachuengtong/
Project Manager
Date : 23-Jan-26

Reviewed By : 
Commtech Asia (Thailand)
Name / Position : Finlay Coady
Sr. Project Manager
Date : 30th January 2026

(3) ATTN : AURECON

☐ For Approval ☐ See Note ☐ Please Clarify

Note : SLA: Change from weberdry S3000S to Proofex GPE is accepted.

From : Commtech Asia (Thailand)
By :
Name / Position ()
Date :
Reviewed By : 
AURECON
Name / Position (Tarkoon S / Architect)
Date : 3 February 2026

(4) ATTN : STT GDC

☐ Clarification only ☐ Not Approved
☐ Approved for proceeding work
☐ Approved with comments, proceeding work in compliance with comments
☐ Approved with comments, not for proceeding work and need to re-submit

Note :

From : AURECON
By :
Name / Position ()
Date :
Reviewed By : STT GDC
Name / Position
Date :



22 January 2026

Ref: PDP036-2026

Subject: Notice of discontinuation of *Weberdry S3000S* and recommendation of *Proofex GPE*

To : Valued Customer

Saint-Gobain (Thailand) Co., Ltd., a leading provider of construction chemicals and waterproofing solutions under the brands **Weber** sincerely appreciates your continued trust and support. We would like to inform you that **the product Weberdry S3000S will be discontinued**, and to ensure the continuity of your projects, we are pleased to recommend **Proofex GPE** as the replacement product, which offers reliable performance, durability, and ease of use in line with our commitment to providing innovative and high-quality solutions.

Discontinued Product

Weberdry S3000S

Recommended Replacement

Proofex GPE

We sincerely thank you for your continued trust in our products and for your ongoing support of our products and company.

Sincerely,



Poothorn Sornsiri

**(Construction Chemicals
Product & Solution Lead)**



Suwat Thongpran

(Business Development Director)

Saint-Gobain (Thailand) Co., Ltd.

Gypsum Metropolitan Tower 539/2 Si Ayutthaya Road, Ratchathewi, • Bangkok • 10400 • Thailand • Tel +66(0)2 700 9444
www.saint-gobain.co.th • www.saintgobainformula.com • www.gyproc.co.th • www.isover.com • www.th.weber



