

REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-EL-0007
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	20-Jan-26	NEED REPLY BY DATE :	27-Jan-26

SUBMISSION OF : ☒ Q&A ☐ Drawing ☒ Document ☐ Others (as specified below)

SUBJECT : Request for Confirmation - Fire Alarm System Interface with Mechanical Equipment

Total Page (s) : 3 (Including this page)

FUNCTION :	<input type="checkbox"/> Structural (ST)	<input checked="" type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input type="checkbox"/> Architectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

(1) CONTRACTOR REQUEST FOR INFORMATION :

According to mechanical drawings, Fire alarm interface signals are required for certain equipment.

However, The fire alarm system diagram does not indicate these interfaces.

We would appreciate your confirmation on the list of equipment that shall receive signals from the Fire Alarm Systems.

Note : It would be an additional cost for some items.



Requested by : 
Engineering Manager

Reviewed by : 
Project Manager

(2) ATTN : Commtech Asia (Thailand)

☐ For Approval ☐ See Note ☒ Please Clarify


Note : Aurecon to confirm the fire alarm interface signals.


From : GAA Group
By : 
Name / Position Mr. Itsarate Trachuengtong/
Project Manager
Date : 20-Jan-26
Reviewed By : 
Commtech Asia (Thailand)
Name / Position Finlay Coady
Sr. Project Manager
Date : 22nd January 2026

(3) ATTN : AURECON

☐ For Approval ☐ See Note ☐ Please Clarify

Note :
AUR :
- Based on the Mechanical drawings, control modules shall be provided to interface with the MCP panels for the Gas Purge Fan (GPF), Fresh Air Fan (FAF), and FCU that require fire alarm signals.
- AUR confirms that the MCP panels for the PAHU require fire alarm signal interfacing.
- The MCP panels for ACU-DFCU do not require fire alarm signal interfacing, as indicated in the Mechanical drawings.

CONTRACTOR DOCUMENT REVIEW
☐ ACCEPTED
☐ REJECTED
☒ MAKE CORRECTIONS NOTED & PROCEED
☐ REVISE AND RESUBMIT
Aurecon Consulting (Thailand) Co., Ltd.
By : 
Date : 22 January 2026
Project No : 523213-01
Date received : 22 January 2026
This review is only for general confirmation with the design concept of the project and general compliance with the information given in the contract documents. Any other technical documents, the responsibility of the Contractor.
This review does not relieve the Contractor of his contractual obligations nor of his complete accuracy & correctness.
Any amendment does not constitute an order or authority for a price variation to the contract.

From : Commtech Asia (Thailand)
By :
Name / Position (
Date :
Reviewed By : AURECON 
Name / Position (Chutikarn Sinsopa
Electrical Engineer)
Date : 27 January 2026

(4) ATTN : STT GDC

☐ Clarification only ☐ Not Approved
☐ Approved for proceeding work
☐ Approved with comments, proceeding work in compliance with comments
☐ Approved with comments, not for proceeding work and need to re-submit

Note :

From : AURECON
By :
Name / Position (
Date :
Reviewed By : STT GDC
Name / Position
Date :

Refer. Drawing :

523213-02-DRG-ME-8000, 523213-02-DRG-EL-0170, 523213-02-DRG-ME-8004,
523213-02-DRG-ME-8005, 523213-02-DRG-ME-8011

Description :

We note that the mechanical drawings specify that Gas Purge Fan (GPF) ,Fresh Air Fan (FAF), ACU-DFCU, FCU required signal from fire alarm system.

However, that signal is not shown in the Fire alarm schematic diagram. Kindly confirm the required signal interface and advise how it shall be implemented.

