

**REQUEST FOR INFORMATION (RFI)**

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-AR-0032
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	21-Jan-26	NEED REPLY BY DATE :	28-Jan-26

SUBMISSION OF :	<input checked="" type="checkbox"/> Q&A	<input type="checkbox"/> Drawing	<input checked="" type="checkbox"/> Document	<input type="checkbox"/> Others (as specified below)
<b>SUBJECT :</b> Request for Information - Confirm the Correct Floor Finishes for ID Works 1st-ID Works and 2nd to 5th Toilet				

Total Page (s) : 2 (Including this page)

FUNCTION :	<input type="checkbox"/> Structural (ST)	<input type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input checked="" type="checkbox"/> Architectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

**(1) CONTRACTOR REQUEST FOR INFORMATION :**

Floor Finishes by AR Drawings and ID Drawings have discrepancies, please confirm.

Requested by:   
Engineering ManagerReviewed by:   
Project Manager**(2) ATTN : Commtech Asia (Thailand)** For Approval     See Note     Please Clarify

From : GAA Group

By : Name / Position : Mr. Itsarate Trachuengtong/  
Project Manager

Date : 21-Jan-26

Note :

Aurecon to review discrepancies from GAA and confirm materials

Reviewed By : Commtech Asia (Thailand)

Name / Position : Finlay Coady

Date : Sr. Project Manager  
30th January 2026**(3) ATTN : AURECON** For Approval     See Note     Please Clarify

From : Commtech Asia (Thailand)

By :

Name / Position ( )

Date :

Note :

SLA: Please follow Interior design drawing shown on AR-4501 to 4513.  
Toilet level 2 to 5 to follow the same room finish as ID drawing.Reviewed By : Tarkoon Suwansukhum  
AURECON

Name / Position ( Tarkoon S / Architect )

Date : 3 February 2026

**(4) ATTN : STT GDC**

- Clarification only     Not Approved
- Approved for proceeding work
- Approved with comments, proceeding work in compliance with comments
- Approved with comments, not for proceeding work and need to re-submit

From : AURECON

By :

Name / Position ( )

Date :

Note :

Please follow SLA's response.

Reviewed By : STT GDC 

Name / Position : Sirawit Thepsuwan VP PMO

Date : 6 Feb 2026

CC :

 STT GDC AURECON Commtech Asia  
(Thailand) GAA OTHERS.....

Attached 1 : 523213-01-RFI-AR-0032 Confirm the correct Floor Finishes for ID Works 1st-ID Works and 2nd to 5th Toilet

No.	Drawings	Queries	Location	Remark																																																															
RFI-032	<table border="1"> <thead> <tr> <th colspan="6">FLOOR FINISH</th> </tr> <tr> <th>FLOOR NO.</th> <th>LOCATION</th> <th>DESCRIPTION</th> <th>IMAGE</th> <th>SPECIFICATION</th> <th>SUPPLIER</th> </tr> </thead> <tbody> <tr> <td><input checked="" type="checkbox"/></td> <td>TECHNICAL ASSISTANCE CENTER</td> <td>FLOOR TILE</td> <td></td> <td>CARPET TILE FLOW STRESS DARK GREY COLOR CODE : 20200000000000000000000000000000</td> <td>VSPAC (KHJN (BBB 0819228151))</td> </tr> <tr> <td><input checked="" type="checkbox"/> (AR CODE : F1)</td> <td>LOBBY</td> <td>FLOOR TILE</td> <td></td> <td>HOMOGENOUS CERAMIC TILE MATTE FINISHES GREY COLOR CODE : ED41941 (R10 SIDE 600x1200 mm.)</td> <td>ELEGANT DECOR TILE (KHJN NAUN (95229239))</td> </tr> <tr> <td><input checked="" type="checkbox"/> (AR CODE : F7)</td> <td>LOBBY</td> <td>FLOOR TILE</td> <td></td> <td>HOMOGENOUS CERAMIC TILE MATTE FINISHES LIGHT GREY COLOR CODE : ED41940 (R10 SIDE 600x1200 mm.)</td> <td>ELEGANT DECOR TILE (KHJN NAUN (95229239))</td> </tr> <tr> <td><input checked="" type="checkbox"/> (AR CODE : F7)</td> <td>TOILET/SHOWER /CHANGING ROOM/JANITOR</td> <td>FLOOR TILE</td> <td></td> <td>HOMOGENOUS CERAMIC TILE MATTE FINISHES DARK GREY COLOR CODE : ED41942 (R10 SIDE 300x600 mm.)</td> <td>ELEGANT DECOR TILE (KHJN NAUN (95229239))</td> </tr> <tr> <td><input checked="" type="checkbox"/> (AR CODE : F7)</td> <td>PANTRY ROOM</td> <td>FLOOR TILE</td> <td></td> <td>WOODEN CERAMIC TILE IN MATTE FINISHES CODE : ED41191 (R10 SIDE 200x1200 mm.)</td> <td>ELEGANT DECOR TILE (KHJN NAUN (95229239))</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td>SECURITY ROOM</td> <td>FLOOR TILE</td> <td></td> <td>VINYL TILE NATURAL CREATION WYMANLAND COLLECTION CODE : 12 206 SANOTONE</td> <td>VSPAC / ARVITRONIC (CORNING) (KHJN (BBB 0819228151))</td> </tr> </tbody> </table> <table border="1"> <tr> <td><input checked="" type="checkbox"/> F1</td> <td>HALL, LOBBY, MANTRAP</td> <td>FLOOR TILE</td> <td>600x1200 HOMOGENOUS FLOOR TILE NON SLIP R10</td> <td>COTTO OR VECERA</td> </tr> <tr> <td><input checked="" type="checkbox"/> F7</td> <td>TOILET, PANTRY, JANITOR, CHANGING ROOM</td> <td>CERAMIC TILE</td> <td>400x800 HOMOGENOUS TILE (WATERPROOF) WITH WATERPROOF SYSTEM SKA TOPSEAL 107 SYSTEM</td> <td>SICA / COTTO</td> </tr> <tr> <td><input checked="" type="checkbox"/> F8</td> <td>TECHNICAL ASSISTANT RM.</td> <td>CARPET TILE</td> <td>500x500 CARPET TILE REFER TO D</td> <td>INTERFACE</td> </tr> </table> <p>&lt;&lt; ID      &lt;&lt; AR      &lt;&lt; AR      &lt;&lt; AR</p> <p><b>Level-1</b>      Reception Hall      Security Room 1      Hall 1.1      Fireman Lift Lobby      Corridor 1.1      Technical Assistance RM.      Pantry      Security Room 2  <b>Level-2 to 5</b>      Toilet Rooms</p> <p><b>AR</b>      <b>ID</b></p> <p>F1      CT 01 &amp; 02      F1      VT 01      F1      CT 01 &amp; 02      F1      CT 01 &amp; 02      F1      CT 01 &amp; 02      F8      C 01      F1      CT 05      F1      VT 01      F7      N/A</p>	FLOOR FINISH						FLOOR NO.	LOCATION	DESCRIPTION	IMAGE	SPECIFICATION	SUPPLIER	<input checked="" type="checkbox"/>	TECHNICAL ASSISTANCE CENTER	FLOOR TILE		CARPET TILE FLOW STRESS DARK GREY COLOR CODE : 20200000000000000000000000000000	VSPAC (KHJN (BBB 0819228151))	<input checked="" type="checkbox"/> (AR CODE : F1)	LOBBY	FLOOR TILE		HOMOGENOUS CERAMIC TILE MATTE FINISHES GREY COLOR CODE : ED41941 (R10 SIDE 600x1200 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))	<input checked="" type="checkbox"/> (AR CODE : F7)	LOBBY	FLOOR TILE		HOMOGENOUS CERAMIC TILE MATTE FINISHES LIGHT GREY COLOR CODE : ED41940 (R10 SIDE 600x1200 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))	<input checked="" type="checkbox"/> (AR CODE : F7)	TOILET/SHOWER /CHANGING ROOM/JANITOR	FLOOR TILE		HOMOGENOUS CERAMIC TILE MATTE FINISHES DARK GREY COLOR CODE : ED41942 (R10 SIDE 300x600 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))	<input checked="" type="checkbox"/> (AR CODE : F7)	PANTRY ROOM	FLOOR TILE		WOODEN CERAMIC TILE IN MATTE FINISHES CODE : ED41191 (R10 SIDE 200x1200 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))	<input checked="" type="checkbox"/>	SECURITY ROOM	FLOOR TILE		VINYL TILE NATURAL CREATION WYMANLAND COLLECTION CODE : 12 206 SANOTONE	VSPAC / ARVITRONIC (CORNING) (KHJN (BBB 0819228151))	<input checked="" type="checkbox"/> F1	HALL, LOBBY, MANTRAP	FLOOR TILE	600x1200 HOMOGENOUS FLOOR TILE NON SLIP R10	COTTO OR VECERA	<input checked="" type="checkbox"/> F7	TOILET, PANTRY, JANITOR, CHANGING ROOM	CERAMIC TILE	400x800 HOMOGENOUS TILE (WATERPROOF) WITH WATERPROOF SYSTEM SKA TOPSEAL 107 SYSTEM	SICA / COTTO	<input checked="" type="checkbox"/> F8	TECHNICAL ASSISTANT RM.	CARPET TILE	500x500 CARPET TILE REFER TO D	INTERFACE	<p><b>Confirm the correct Floor Finishes for ID Works</b>          Floor Finishes by AR Drawings and ID Drawings have discrepancies</p> <p><b>ID Drawings</b>          CT01: Homogenous Ceramic Tile 600x1200mm <b>Elegant</b>          CT02: Homogenous Ceramic Tile 600x1200mm <b>Elegant</b>          CT03: Homogenous Ceramic Tile 300x600mm <b>Elegant</b>          CT05: Wooden Ceramic Tile 200x1200mm <b>Elegant</b>          VT01: Vinyl Tile <b>Vspac</b>          C01: Carpet Tile <b>Vspac</b></p> <p><b>AR Drawings</b>          F1: Homogenous Floor Tile non slip 600x1200mm <b>Cotto or Vecera</b>          F7: Homogenous Tile w/ Waterproof <b>Sika Topseal 107</b> 400x800mm <b>Cotto</b>          F8: Carpet Tile 500x500mm <b>INTERFACE</b></p> <p style="border: 2px solid red; padding: 5px;"><b>SLA: Please follow Interior design drawing shown on AR-4501 to 4513.</b>  <b>Toilet level 2 to 5 to follow the same room finish as ID drawing.</b></p>	Level 1 - ID Works Level 2 - 5 Toilets	CT01: AR CODE F1 CT02: AR CODE F7 CT03: AR CODE F7 CT05: AR CODE F7
FLOOR FINISH																																																																			
FLOOR NO.	LOCATION	DESCRIPTION	IMAGE	SPECIFICATION	SUPPLIER																																																														
<input checked="" type="checkbox"/>	TECHNICAL ASSISTANCE CENTER	FLOOR TILE		CARPET TILE FLOW STRESS DARK GREY COLOR CODE : 20200000000000000000000000000000	VSPAC (KHJN (BBB 0819228151))																																																														
<input checked="" type="checkbox"/> (AR CODE : F1)	LOBBY	FLOOR TILE		HOMOGENOUS CERAMIC TILE MATTE FINISHES GREY COLOR CODE : ED41941 (R10 SIDE 600x1200 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))																																																														
<input checked="" type="checkbox"/> (AR CODE : F7)	LOBBY	FLOOR TILE		HOMOGENOUS CERAMIC TILE MATTE FINISHES LIGHT GREY COLOR CODE : ED41940 (R10 SIDE 600x1200 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))																																																														
<input checked="" type="checkbox"/> (AR CODE : F7)	TOILET/SHOWER /CHANGING ROOM/JANITOR	FLOOR TILE		HOMOGENOUS CERAMIC TILE MATTE FINISHES DARK GREY COLOR CODE : ED41942 (R10 SIDE 300x600 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))																																																														
<input checked="" type="checkbox"/> (AR CODE : F7)	PANTRY ROOM	FLOOR TILE		WOODEN CERAMIC TILE IN MATTE FINISHES CODE : ED41191 (R10 SIDE 200x1200 mm.)	ELEGANT DECOR TILE (KHJN NAUN (95229239))																																																														
<input checked="" type="checkbox"/>	SECURITY ROOM	FLOOR TILE		VINYL TILE NATURAL CREATION WYMANLAND COLLECTION CODE : 12 206 SANOTONE	VSPAC / ARVITRONIC (CORNING) (KHJN (BBB 0819228151))																																																														
<input checked="" type="checkbox"/> F1	HALL, LOBBY, MANTRAP	FLOOR TILE	600x1200 HOMOGENOUS FLOOR TILE NON SLIP R10	COTTO OR VECERA																																																															
<input checked="" type="checkbox"/> F7	TOILET, PANTRY, JANITOR, CHANGING ROOM	CERAMIC TILE	400x800 HOMOGENOUS TILE (WATERPROOF) WITH WATERPROOF SYSTEM SKA TOPSEAL 107 SYSTEM	SICA / COTTO																																																															
<input checked="" type="checkbox"/> F8	TECHNICAL ASSISTANT RM.	CARPET TILE	500x500 CARPET TILE REFER TO D	INTERFACE																																																															