

REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-AR-0041
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	6-Feb-26	NEED REPLY BY DATE :	13-Feb-26

SUBMISSION OF : ☒ Q&A ☒ Drawing ☐ Document ☐ Others (as specified below)

SUBJECT : Request for Information - Confirm External Paint Color and Technical Specification for Generators Room

Total Page (s) : 2 (Including this page)

FUNCTION :	<input type="checkbox"/> Structural (ST)	<input type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input checked="" type="checkbox"/> Architectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

(1) CONTRACTOR REQUEST FOR INFORMATION :

Please provide confirmation on the external paint color and technical specifications for the generator rooms.




Requested by :   
Engineering Manager

Reviewed by :   
Project Manager

(2) ATTN : Commtech Asia (Thailand)

☐ For Approval ☐ See Note ☒ Please Clarify

Note : Please Aurecon to provide confirmation on the external paint color and technical specifications for the generator rooms clarification.

From : GAA Group  
By :   
Name / Position : Mr. Itsarate Trachuengtong/  
Project Manager  
Date : 6-Feb-26  
Reviewed By :   
Name / Position : Aphisakda Phueakchanthuek  
Construction Engineer  
Date : 2/9/2026

(3) ATTN : AURECON

☐ For Approval ☐ See Note ☐ Please Clarify

Note : SLA: Please refer to the notes in the attached markup.

From : Commtech Asia (Thailand)  
By :   
Name / Position ( )  
Date :   
Reviewed By : Tarkoon Suwansukhum  
AURECON  
Name / Position ( Tarkoon S / Architect )  
Date : 10 February 2026


(4) ATTN : STT GDC

☐ Clarification only ☐ Not Approved  
☐ Approved for proceeding work  
☐ Approved with comments, proceeding work in compliance with comments  
☐ Approved with comments, not for proceeding work and need to re-submit

Note :

From : AURECON  
By :   
Name / Position ( )  
Date :   
Reviewed By : STT GDC  
Name / Position  
Date :






SOFFIT FINISHES SCHEDULE

SOFFIT NO.	HATCH PATTERN	LOCATION	DESCRIPTION	SPECIFICATION
SF1		DATA HALL, TOILET	COLOR PAINT	SUPERSHIELD DURACLEAN MATT SHADE (M101) PEARL WHITE
SF2		AS INDICATED	COLOR PAINT	EMULSION PAINT (RAL 7012) BASALT GREY
SF3		CORRIDOR	COLOR PAINT	EMULSION PAINT (RAL 7047) TELEGREY
SF4		GENERATOR ROOM	PAINT	EXPOSED CEILING WITH EXTERNAL PAINT
EX		AS INDICATED	EXISTING	EXISTING

**NOTE:**  
- EXTERNAL PAINT COLOUR AND SPECIFICATION FOR GENERATOR ROOMS NEED TO CONFIRM.



TYPICAL DETAIL

SLA: The genset ceiling shall be paint Dark grey RAL 7012