

REQUEST FOR INFORMATION (RFI)

PROJECT :	BKK2	R.F.I. NO. :	523213-01-RFI-AR-0033
TO :	CTA	ATTENTION :	CTA
SUBMITTED DATE:	21-Jan-26	NEED REPLY BY DATE :	28-Jan-26

SUBMISSION OF : ☒ Q&A ☐ Drawing ☒ Document ☐ Others (as specified below)


SUBJECT : Request for Information - Confirm the Correct Ceiling Finishes for ID Works 1st to 5th Floor

Total Page (s) : 2 (Including this page)

FUNCTION :	<input type="checkbox"/> Structural (ST)	<input type="checkbox"/> Electrical & Communication (EL)	<input type="checkbox"/> Mechanical (ME)	<input type="checkbox"/> Vertical Transport (VT)
	<input checked="" type="checkbox"/> Architectural (AR)	<input type="checkbox"/> Fire Protection (FI)	<input type="checkbox"/> Hydraulic & Sanitary (HY)	<input type="checkbox"/> Other (O)

(1) CONTRACTOR REQUEST FOR INFORMATION :

Ceiling Finishes by AR Drawings and ID Drawings have discrepancies, Please confirm.


Requested by : 
Engineering Manager


Reviewed by : 
Project Manager

(2) ATTN : Commtech Asia (Thailand)

☐ For Approval ☐ See Note ☒ Please Clarify

Note : Aurecon to review discrepancies from GAA and confirm ceiling finishes

From : GAA Group
By : 
Name / Position : Mr. Itsarate Trachuengtong/
Project Manager
Date : 21-Jan-26

Reviewed By : 
Commtech Asia (Thailand)
Name / Position : Finlay Coady
Sr. Project Manager
Date : 30th January 2026

(3) ATTN : AURECON

☐ For Approval ☐ See Note ☐ Please Clarify


Note : SLA: Please follow Interior design drawing shown on AR-4501 to 4513.
Toilet level 2 to 5 to follow the same room finish as ID drawing.

From : Commtech Asia (Thailand)
By :
Name / Position ()
Date :
Reviewed By : Tarkoon Suwansukhum
AURECON
Name / Position (Tarkoon S / Architect)
Date : 3 February 2026

(4) ATTN : STT GDC

☒ Clarification only ☐ Not Approved
☐ Approved for proceeding work
☐ Approved with comments, proceeding work in compliance with comments
☐ Approved with comments, not for proceeding work and need to re-submit

Note : Please follow SLA's response

From : AURECON
By :
Name / Position ()
Date :
Reviewed By : STT GDC 
Name / Position : Sirawit Thepsuwan VP PMO
Date : 6 Feb 2026

Attached 1 : 523213-01-RFI-AR-0033 Confirm the correct Ceiling Finishes for ID Works 1st to 5th Floor

No.	Drawings	Queries	Location	Remark																																																																									
	<table><tr><th>CEILING NO.</th><th>LOCATION</th><th>DESCRIPTION</th><th>RANGE</th><th>SPECIFICATION</th><th>SUPPLIER</th></tr><tr><td>C1</td><td>LIFT LOBBY, ENTRANCE LOBBY, HALL, SECURITY RM, 2, TOILET, SHOWER</td><td>GYPSUM BOARD CEILING</td><td></td><td>8MM THK MOISTURE RESISTANT GYPSUM BOARD SET PLASTER W/ MOISTURE RESISTANT PAINT FINISH CODE : PG2</td><td>SBM GYPSUM SCS</td></tr><tr><td>C2</td><td>PANTRY, TAC</td><td>GYPSUM BOARD CEILING</td><td></td><td>600 X 600 HX1.6M BAR CEILING ACOUSTIC BOARD CODE : PG2</td><td>SBM GYPSUM SCS</td></tr></table> <p><< ID</p> <table><tr><th>CEILING NO.</th><th>LOCATION</th><th>DESCRIPTION</th><th>SPECIFICATION</th><th>SUPPLIER</th></tr><tr><td>C1</td><td>LIFT LOBBY, CHECKED HALL</td><td>GYPSUM BOARD CEILING</td><td>9 MM THK GYPSUM BOARD, 4 TAPERED EDGE , PLASTER AT JOINT AND EMULSION PAINT WITH 600X600 MM. READY MADE ACCESS PANEL.</td><td>SBM GYPSUM SCS</td></tr><tr><td>C2</td><td>LIFT LOBBY, CHECKED HALL</td><td>GYPSUM BOARD CEILING</td><td>9 MM THK GYPSUM BOARD ON 600X600 MM THK T-BAR AND EMULSION PAINT</td><td>SBM GYPSUM SCS</td></tr><tr><td>C3</td><td>SECURITY 2</td><td>ACOUSTIC CEILING</td><td>ACOUSTIC CEILING ON 600X1200 MM T-BAR BPPF CORTESA ARMYSTRONG</td><td>SBM GYPSUM SCS</td></tr><tr><td>C4</td><td>CBM, MEP ROOM, TRUCK LOADING AREA</td><td>EXPOSED CEILING</td><td>EXPOSED CEILING SKIN COATED AND EMULSION PAINT</td><td>TGA</td></tr><tr><td>C5</td><td>DROP-OFF</td><td>ALUMINIUM CEILING</td><td>2 MM THK ALUCOLUX ALUMINIUM PANEL</td><td>BFM</td></tr><tr><td>C6</td><td>WATER STORAGE TANK</td><td>EXPOSED CEILING</td><td>EXPOSED CEILING AND WATERPROOF SRA TOPSEAL 10T</td><td>SRA</td></tr><tr><td>C7</td><td>TOILET</td><td>GYPSUM BOARD CEILING</td><td>9 MM THK MOISTURE RESISTANT GYPSUM BOARD & TAPER EDGE PLASTER WITH READY MADE ACCESS PANEL</td><td>SBM GYPSUM SCS</td></tr><tr><td>C8</td><td>GENERATOR ROOM</td><td>EXPOSED CEILING</td><td>EXPOSED CEILING WITH EXTERNAL FRAMING</td><td>SBM GYPSUM SCS</td></tr><tr><td>C9</td><td>DATA HALL</td><td>EXPOSED CEILING</td><td>600X1200 MM STRUCTURE CEILING GRID WITH CEILING TILE 380X380 (THK) WITH TOUCH DUST FREE GYPSUM CEILING BOARD</td><td>TGA / TATE OR CBS</td></tr><tr><td>C10</td><td>CHILLER PLANT ROOM</td><td>ACOUSTIC CEILING</td><td>EXPOSED CEILING PLASTER 100 MM THK ROCKWOOL 100kg/m³ WRAP WITH BLACK GLASS CLOTH MECHANICAL FRAMING</td><td></td></tr></table> <p><< AR</p> <div><p>Level - 1</p><p>Reception Hall</p><p>Security Room 1</p><p>Hall 1.1</p><p>Fireman Lift Lobby</p><p>Corridor 1.1</p><p>Technical Assistance RM.</p><p>Pantry</p><p>Security Room 2</p><p>Level - 2 to 5</p><p>Toilet Rooms</p></div> <div><p>AR</p><p>C2</p><p>C2</p><p>C2</p><p>C2</p><p>C2</p><p>C1</p><p>C2</p><p>C2</p><p>C2</p><p>C7</p></div> <div><p>ID</p><p>C1</p><p>C1</p><p>C1</p><p>C1</p><p>C4</p><p>C2</p><p>C2</p><p>C1</p><p>N/A</p></div>	CEILING NO.	LOCATION	DESCRIPTION	RANGE	SPECIFICATION	SUPPLIER	C1	LIFT LOBBY, ENTRANCE LOBBY, HALL, SECURITY RM, 2, TOILET, SHOWER	GYPSUM BOARD CEILING		8MM THK MOISTURE RESISTANT GYPSUM BOARD SET PLASTER W/ MOISTURE RESISTANT PAINT FINISH CODE : PG2	SBM GYPSUM SCS	C2	PANTRY, TAC	GYPSUM BOARD CEILING		600 X 600 HX1.6M BAR CEILING ACOUSTIC BOARD CODE : PG2	SBM GYPSUM SCS	CEILING NO.	LOCATION	DESCRIPTION	SPECIFICATION	SUPPLIER	C1	LIFT LOBBY, CHECKED HALL	GYPSUM BOARD CEILING	9 MM THK GYPSUM BOARD, 4 TAPERED EDGE , PLASTER AT JOINT AND EMULSION PAINT WITH 600X600 MM. READY MADE ACCESS PANEL.	SBM GYPSUM SCS	C2	LIFT LOBBY, CHECKED HALL	GYPSUM BOARD CEILING	9 MM THK GYPSUM BOARD ON 600X600 MM THK T-BAR AND EMULSION PAINT	SBM GYPSUM SCS	C3	SECURITY 2	ACOUSTIC CEILING	ACOUSTIC CEILING ON 600X1200 MM T-BAR BPPF CORTESA ARMYSTRONG	SBM GYPSUM SCS	C4	CBM, MEP ROOM, TRUCK LOADING AREA	EXPOSED CEILING	EXPOSED CEILING SKIN COATED AND EMULSION PAINT	TGA	C5	DROP-OFF	ALUMINIUM CEILING	2 MM THK ALUCOLUX ALUMINIUM PANEL	BFM	C6	WATER STORAGE TANK	EXPOSED CEILING	EXPOSED CEILING AND WATERPROOF SRA TOPSEAL 10T	SRA	C7	TOILET	GYPSUM BOARD CEILING	9 MM THK MOISTURE RESISTANT GYPSUM BOARD & TAPER EDGE PLASTER WITH READY MADE ACCESS PANEL	SBM GYPSUM SCS	C8	GENERATOR ROOM	EXPOSED CEILING	EXPOSED CEILING WITH EXTERNAL FRAMING	SBM GYPSUM SCS	C9	DATA HALL	EXPOSED CEILING	600X1200 MM STRUCTURE CEILING GRID WITH CEILING TILE 380X380 (THK) WITH TOUCH DUST FREE GYPSUM CEILING BOARD	TGA / TATE OR CBS	C10	CHILLER PLANT ROOM	ACOUSTIC CEILING	EXPOSED CEILING PLASTER 100 MM THK ROCKWOOL 100kg/m³ WRAP WITH BLACK GLASS CLOTH MECHANICAL FRAMING		<p>Confirm the correct Ceiling Finishes for ID Works</p> <p>Ceiling Finishes by AR Drawings and ID Drawings have discrepancies</p> <div><p>SLA: Please follow Interior design drawing shown on AR-4501 to 4513.</p><p>Toilet level 2 to 5 to follow the same room finish as ID drawing.</p></div>	<p>Level 1 - ID Works</p>	
CEILING NO.	LOCATION	DESCRIPTION	RANGE	SPECIFICATION	SUPPLIER																																																																								
C1	LIFT LOBBY, ENTRANCE LOBBY, HALL, SECURITY RM, 2, TOILET, SHOWER	GYPSUM BOARD CEILING		8MM THK MOISTURE RESISTANT GYPSUM BOARD SET PLASTER W/ MOISTURE RESISTANT PAINT FINISH CODE : PG2	SBM GYPSUM SCS																																																																								
C2	PANTRY, TAC	GYPSUM BOARD CEILING		600 X 600 HX1.6M BAR CEILING ACOUSTIC BOARD CODE : PG2	SBM GYPSUM SCS																																																																								
CEILING NO.	LOCATION	DESCRIPTION	SPECIFICATION	SUPPLIER																																																																									
C1	LIFT LOBBY, CHECKED HALL	GYPSUM BOARD CEILING	9 MM THK GYPSUM BOARD, 4 TAPERED EDGE , PLASTER AT JOINT AND EMULSION PAINT WITH 600X600 MM. READY MADE ACCESS PANEL.	SBM GYPSUM SCS																																																																									
C2	LIFT LOBBY, CHECKED HALL	GYPSUM BOARD CEILING	9 MM THK GYPSUM BOARD ON 600X600 MM THK T-BAR AND EMULSION PAINT	SBM GYPSUM SCS																																																																									
C3	SECURITY 2	ACOUSTIC CEILING	ACOUSTIC CEILING ON 600X1200 MM T-BAR BPPF CORTESA ARMYSTRONG	SBM GYPSUM SCS																																																																									
C4	CBM, MEP ROOM, TRUCK LOADING AREA	EXPOSED CEILING	EXPOSED CEILING SKIN COATED AND EMULSION PAINT	TGA																																																																									
C5	DROP-OFF	ALUMINIUM CEILING	2 MM THK ALUCOLUX ALUMINIUM PANEL	BFM																																																																									
C6	WATER STORAGE TANK	EXPOSED CEILING	EXPOSED CEILING AND WATERPROOF SRA TOPSEAL 10T	SRA																																																																									
C7	TOILET	GYPSUM BOARD CEILING	9 MM THK MOISTURE RESISTANT GYPSUM BOARD & TAPER EDGE PLASTER WITH READY MADE ACCESS PANEL	SBM GYPSUM SCS																																																																									
C8	GENERATOR ROOM	EXPOSED CEILING	EXPOSED CEILING WITH EXTERNAL FRAMING	SBM GYPSUM SCS																																																																									
C9	DATA HALL	EXPOSED CEILING	600X1200 MM STRUCTURE CEILING GRID WITH CEILING TILE 380X380 (THK) WITH TOUCH DUST FREE GYPSUM CEILING BOARD	TGA / TATE OR CBS																																																																									
C10	CHILLER PLANT ROOM	ACOUSTIC CEILING	EXPOSED CEILING PLASTER 100 MM THK ROCKWOOL 100kg/m³ WRAP WITH BLACK GLASS CLOTH MECHANICAL FRAMING																																																																										