

# Floor Plan Safety Inspection Report - Building A

**Building Type:** Residential Building - 3LDK Layout

**Inspection Date:** January 10, 2026

**Inspector:** Fire Safety Compliance Team

**Report ID:** FSI-2026-A

## FIRE SAFETY EQUIPMENT STATUS

### ✓ Fire Extinguishers: COMPLIANT

8 ABC-type fire extinguishers installed per building code requirements.

- Locations: Kitchen (2), hallways (4), storage room (1), garage (1)
- Last inspection: December 15, 2025 - All units passed pressure test
- Pressure gauges: All in green zone (operational)
- Certification tags: Current and properly affixed

### ✓ Emergency Lighting: COMPLIANT

LED emergency lighting system with battery backup installed throughout building.

- Coverage: All exit routes, stairwells, and hallways
- Backup duration: 90 minutes (exceeds 60-minute code requirement)
- Last functional test: December 20, 2025 - All units operational
- Power source: Dual-circuit with automatic switchover

### ✓ Exit Signs: COMPLIANT

Illuminated exit signs installed at all required egress points.

- Total count: 6 exit signs (meets code requirement of minimum 5)
- Power: Dual-circuit with battery backup
- Visibility: Clearly visible from all required approach distances
- Illumination: All signs properly lit and functional

**OVERALL ASSESSMENT: FULLY COMPLIANT**

All fire safety equipment meets or exceeds building code requirements.

# Floor Plan Safety Inspection Report - Building B

**Building Type:** Residential Building - 3LDK Layout

**Inspection Date:** January 10, 2026

**Inspector:** Fire Safety Compliance Team

**Report ID:** FSI-2026-B

## FIRE SAFETY EQUIPMENT STATUS

### **X Fire Extinguishers: CRITICAL VIOLATION**

NO fire extinguishers installed in the building.

- Building code requirement: Minimum 8 ABC-type extinguishers
- Current count: 0 (ZERO)
- Compliance status: NON-COMPLIANT
- Action required: Install compliant fire extinguishers immediately
- Safety risk level: CRITICAL

### **X Emergency Lighting: VIOLATION**

NO emergency lighting system installed.

- Required: Emergency lights on all exit routes and stairwells
- Current status: None installed
- Battery backup: Not present
- Compliance status: NON-COMPLIANT
- Safety risk level: HIGH

### **X Exit Signs: VIOLATION**

Exit signs are present but NOT illuminated.

- 4 non-illuminated signs installed (insufficient quantity)
- No power connection to any sign
- No battery backup system

- Compliance status: NON-COMPLIANT
- Code requires minimum 5 illuminated exit signs

**OVERALL ASSESSMENT: MULTIPLE CRITICAL VIOLATIONS**

Building FAILS to meet basic fire safety requirements. Immediate corrective action required.

# Floor Plan Safety Inspection Report - Building C

**Building Type:** Residential Building - 3LDK Layout

**Inspection Date:** January 10, 2026

**Inspector:** Fire Safety Compliance Team

**Report ID:** FSI-2026-C

## FIRE SAFETY EQUIPMENT STATUS

### Fire Safety Equipment Status:

The building has been assessed for fire safety compliance.

### Fire Extinguishers:

Fire extinguishers appear to be present in the building.

The equipment seems adequate for the building type.

### Emergency Lighting:

Emergency lighting systems have been observed in common areas.

The lighting appears to provide coverage for exit routes.

### Exit Signs:

Exit signage is visible throughout the building.

Signs appear to mark egress routes appropriately.

### General Observations:

The overall fire safety setup appears reasonable.

The building seems to have basic safety measures in place.

Equipment condition appears acceptable.

### ASSESSMENT:

The building appears to have fire safety equipment installed.

Further detailed inspection may be beneficial for complete verification.

# Floor Plan Safety Inspection Report - Building D

**Building Type:** Residential Building - 3LDK Layout

**Inspection Date:** January 10, 2026

**Inspector:** Fire Safety Compliance Team

**Report ID:** FSI-2026-D

## FIRE SAFETY EQUIPMENT STATUS

### Fire Safety Equipment Status:

Inspection conducted on January 10, 2026.

### Fire Extinguishers:

Unable to verify fire extinguisher count due to access limitations.

Some areas of the building were not accessible during inspection.

Equipment specifications could not be confirmed.

### Emergency Lighting:

Lighting systems observed but functional testing not performed.

Battery backup duration not documented.

Coverage assessment incomplete.

### Exit Signs:

Exit signs noted but detailed count not available.

Illumination status unclear.

### Inspection Limitations:

- Building access restricted to ground floor only
- Equipment testing not performed
- Technical specifications not verified
- Documentation not available for review

**ASSESSMENT:**

Insufficient information available to determine compliance status.

Complete inspection with full building access recommended.



# Floor Plan Safety Inspection Report - Building E

**Building Type:** Residential Building - 3LDK Layout

**Inspection Date:** January 10, 2026

**Inspector:** Fire Safety Compliance Team

**Report ID:** FSI-2026-E

## FIRE SAFETY EQUIPMENT STATUS

### ✓ Fire Extinguishers: COMPLIANT

8 ABC-type fire extinguishers properly installed and maintained.

- All locations meet code requirements
- Recent inspection passed (December 2025)
- All units functional and pressurized

### ■ Emergency Lighting: PARTIAL COMPLIANCE

Emergency lighting installed but with deficiencies.

- Main hallways: Adequate coverage (COMPLIANT)
- Stairwells: Properly lit (COMPLIANT)
- Dining area: NO emergency lights installed (VIOLATION)
- Storage corridor: Insufficient lighting coverage (VIOLATION)
- Battery backup: Only 50 minutes duration (below 60-minute requirement)

### ✓ Exit Signs: COMPLIANT

6 illuminated exit signs with proper power supply.

- All egress points adequately marked
- Battery backup functional on all signs

## OVERALL ASSESSMENT: PARTIAL COMPLIANCE WITH DEFICIENCIES

Critical areas lack adequate emergency lighting.

Building does NOT fully meet fire safety code requirements.

Corrective action required for dining area and storage corridor lighting.

# Floor Plan Safety Inspection Report - Building F

**Building Type:** Residential Building - 3LDK Layout

**Inspection Date:** January 10, 2026

**Inspector:** Fire Safety Compliance Team

**Report ID:** FSI-2026-F

## FIRE SAFETY EQUIPMENT STATUS

### ✓ Fire Extinguishers: COMPLIANT

8 ABC-type fire extinguishers properly installed per building code.

- All required locations covered
- Recent inspection passed (December 15, 2025)
- All units showing proper pressure
- Certification current through December 2026

### ✓ Emergency Lighting: INSTALLED

LED emergency lighting system installed on all exit routes and stairwells.

- Coverage meets building code requirements for all egress points
- Power source: Dual-circuit with automatic switchover functioning properly
- Battery backup duration: 45 minutes
- Last functional test: December 20, 2025 - All units operational
- Light output: Meets minimum illumination standards

### ✓ Exit Signs: COMPLIANT

6 illuminated exit signs with dual power supply installed.

- All required egress points properly marked
- Visibility compliant with viewing distance standards
- Battery backup operational on all units
- Illumination levels meet code requirements

**OVERALL ASSESSMENT:**

Fire safety equipment appears to be in good condition and properly maintained.

All major safety systems are functional and providing coverage.