

Building A - Fire Safety Equipment Inspection Report

Page 1/6

Inspection Date: December 15, 2025

Inspection Result: PASS

[Fire Extinguishers]

- ✓ 1st floor corridor: 2 ABC-type extinguishers - Installed, within valid date
- ✓ 2nd floor corridor: 2 ABC-type extinguishers - Installed, within valid date
- ✓ Underground parking: 1 large fire extinguisher - Installed, within valid date

[Emergency Lighting]

- ✓ All floor emergency lights: 20 units - Operational
- ✓ Battery backup time: 90 minutes - Meets 60-minute code requirement
- ✓ Regular inspection records: Complete

[Exit Signs]

- ✓ Exit signs on each floor: 8 units - Installed, good visibility
- ✓ Illumination function: All operational

Overall Assessment: All fire safety equipment meets Building Code and Fire Code requirements and is properly maintained.