

Dynamic Price-Enabled Strategic Energy Management Scheme in Cloud-Enabled Smart Grid

Ayan Mondal, *Member, IEEE*, Sudip Misra, *Senior Member, IEEE*, and
Aishwariya Chakraborty, *Student Member, IEEE*

Abstract—In this paper, the problem of provisioning high-quality energy service in the presence of competitive prosumers and micro-grids in cloud-enabled smart grid is studied. Oligopolistic prosumers behave non-cooperatively and store the excess generated energy for future use, which increases the load on the main grid and degrades the performance of the smart grid. To address this problem, we propose a dynamic cloud-based pricing scheme, named SmartPrice, to enforce cooperation among the prosumers for ensuring high quality of service provided by the micro-grids. In SmartPrice, using cloud infrastructure, each micro-grid calculates a reward factor for each prosumer based on his/her behavior to enforce cooperation among them. We model the interaction between each micro-grid and the prosumers using a single-leader-multiple-followers Stackelberg game, where the micro-grids and the prosumers act as the leaders and the followers, respectively. Each micro-grid determines the unit energy price to be charged/paid and each prosumer determines the quantity of excess energy to be supplied for ensuring high revenue. Thus, SmartPrice enforces cooperation among the micro-grids and prosumers. Additionally, using SmartPrice, the price for unit energy charged from the prosumers reduces by 23.37-35.63%, thereby ensuring high revenue and the number of prosumers served by the micro-grids increases by 38.19-53.14%.

Index Terms—Smart Grid, Micro-Grid, Cloud, Cooperation Enforcing, Dynamic Pricing, Oligopoly, Game Theory.

I. INTRODUCTION

To acquire high reliability over the existing power system, the conventional energy distribution grid is envisioned to be enhanced with overlaying communication networks, thereby modernizing the traditional electric grid — a term which is coined as the *smart grid* [1]. A cloud-enabled smart grid is a cyber-physical system capable of ensuring the efficient and robust functioning of the electric network with viable energy management models such as generation, transmission, distribution, and usage. In traditional power distribution systems, the main grid, which is a centralized energy generation unit, distributes energy to the prosumer unidirectionally. Additionally, there is no facility such that the prosumers can interact with the main grid in real-time. Therefore, the prosumers pay based on their energy usage after a fixed interval. On the contrary, in smart grid, the modernized energy distribution network is

equipped with a bidirectional electricity exchange facility, and the energy requirement of each small geographical area is served by a single or a group of micro-grids. Additionally, smart grid is equipped with duplex communication and cloud infrastructure to support the communication and computation needs of the system [2]. Therefore, each prosumer can request energy from the micro-grids in real-time using cloud-enabled energy distribution, which is one of the important features of a smart grid.

In a smart grid, micro-grids are responsible for generating energy from renewable sources such as solar power, biomass, wind, and geothermal power. In each slot of a day, different micro-grids generate variable amounts of energy. Thus, when a micro-grid does not possess an adequate quantity of generated energy, the users requesting for its service must experience a significant quantity of delay before getting served. An alternative, in this case, is to seek the service from the main grid, which incurs higher costs to the users. Thus, to prevent energy deficit and reduce costs, micro-grids often share their surplus energy with other micro-grids to provide service to the users. However, this process of energy transfer also leads to the wastage of energy units, thereby leading to loss. In such situations, the presence of the energy generation capability of the prosumers may help to resolve the issue. However, as the prosumers are rational, they may behave non-cooperatively and decide to store the energy at their-end [3] instead of supplying the excess quantity of energy to the micro-grids. Hence, for ensuring a high quality of service (QoS) of energy management, we need to motivate the prosumers to act in cooperation. However, as per our knowledge, in the existing literature, there is no such scheme, to the best of our knowledge, which focuses on motivating the prosumers to behave cooperatively while ensuring high QoS provided by micro-grids and revenue of the prosumers.

Therefore, in this paper, we introduce a *dynamic cooperation enforcing pricing* scheme, named *SmartPrice*, for a cloud-enabled smart grid using a single-leader-multiple-followers Stackelberg game. As per our knowledge, no work in existing literature addressed a similar problem in smart grid. For the aforementioned problem, the Stackelberg game is one of the best choices, as the prosumers and the micro-grids are rational, and try to maximize their benefits. Thereby, we argue that the energy market in the cloud-enabled smart grid has similarities with the oligopolistic market. In SmartPrice, each micro-grid acts as the leader and determines the price for the unit quantity of energy to be charged for each prosumer. Additionally, if there is energy deficiency at the micro-grid end, it decides the

Ayan Mondal is with the Computer Science, Univ Rennes, Inria, CNRS, IRISA, France. (Email: ayan.mondal@irisa.fr).

Sudip Misra is with the Department of Computer Science and Engineering, Indian Institute of Technology Kharagpur, India (Email: smisra@cse.iitkgp.ac.in).

Aishwariya Chakraborty is with the Advanced Technology Development Centre, Indian Institute of Technology Kharagpur, India (Email: aishwariya-ach@iitkgp.ac.in).

quantity of energy to be procured from each prosumer. On the other hand, each prosumer decides his/her optimal strategy – cooperation or non-cooperation – based on the price charged to the micro-grids. In SmartPrice, for ensuring high QoS, each micro-grid provides an incentive to the cooperative prosumers in the form of revenue to the prosumers, which influences the prosumers to behave cooperatively. In summary, our primary contributions are as follows:

- 1) We present a *dynamic cooperation enforcing pricing* scheme (SmartPrice) for the real-time energy consumption of the prosumers in the presence of energy generation and storage capacity at the prosumer-end in cloud-enabled smart grid.
- 2) We use a single-leader-multiple-followers Stackelberg game to model the interaction between the prosumers and the micro-grids through cloud infrastructure. In SmartPrice, the micro-grids act as the leaders, and the prosumers act as the followers.
- 3) To obtain the optimal solution, i.e., Stackelberg equilibrium, of the proposed scheme, SmartPrice, we present three algorithms. Initially, each prosumer decides the quantity of energy to be requested to the micro-grid. Thereafter, using the cloud infrastructure, each micro-grid decides the optimal price to be charged to each prosumer. If the micro-grid requires energy, it requests the prosumers having surplus energy and decides the amount to be procured from cooperative prosumers. On the other hand, using the third algorithm, each prosumer decides his/her strategy of whether to cooperate or not.

The paper is organized as follows. In Section II, we briefly present the existing literature in the area of pricing and distributed energy management in smart grid, and identified the lacuna in the existing works. The system model is discussed in Section III. The proposed SmartPrice scheme is described in Section IV. We analyze the simulation results of the proposed scheme in Section V. Finally, in Section VI, the paper concludes by citing directions for future work.

II. RELATED WORKS

In the past few years, several researchers worked on proposing different schemes for smart-grid, viz., [3]–[13]. We discuss some of these works here. Bakker *et al.* [5] formulated a pricing-based energy management scheme, which is dynamic in nature. They designed it as a congestion game. Zaman *et al.* [14] studied the problem of the existence of multiple Nash equilibrium in the electricity distribution market using a co-evolutionary approach. Barabadi and Yaghmaee [15] considered a predetermined base price and proposed a pricing scheme using utility and prospect theory. The authors observed that their proposed scheme enforces the customers to follow the desired norm curve. In another work, a dynamic pricing scheme for PHEVs comprising of two components – local price and roaming price – was proposed by Misra *et al.* [6]. In another work, Neeraj *et al.* [16] proposed a coalitional game-based energy management scheme for PHEVs in smart grid. Jiang *et al.* [17] proposed a Stackelberg game-based pricing scheme for blockchain-enabled smart grid in the presence of

non-cooperative entities. The concept of pricing according to different timings, i.e., on-peak and off-peak hours, was explored by Erol-Kantarci and Moustah [8] and Molderink *et al.* [7]. In this work, the authors designed an energy management scheme where customers are required to pay higher charges to get instantaneous service. Irtija *et al.* [18] considered that the prosumers are cooperative in nature and proposed a contract-theory based energy distribution scheme. Ajula *et al.* [19] proposed an energy management scheme for distributed data centers using renewable energy in smart grid. The authors also evaluated the optimal allocation of data center resources for processing the energy requests. In another work, Ali and Hassanein [20] proposed an energy consumption management scheme for the wireless sensor networks in smart greenhouses, while using a learning algorithm. On the other hand, Vamvakas *et al.* [21], [22] proposed a machine learning-based power allocation scheme while characterizing the service providers in terms of price and service reputation. Chen *et al.* [23] proposed a pricing scheme for the customers having flexible appliances. They also studied the effect of storage devices at the customer end.

Abido [24] proposed a multi-objective optimization problem for the conventional energy distribution grid. In this work, the author ensured a trade-off between the economic and environmental impact, while considering that fuel combustion, i.e., a non-renewable energy resource, is used to generate the energy. In another work, Bunn and Oliveira [25] considered the presence of multiple energy suppliers. In the presence of traders, each prosumer is mapped to a supplier. Additionally, the authors ensured the balance between the quantity of energy generated by the supplier and the quantity of energy requested by the customers using agent-based computational methods. In another work, Sun *et al.* [26] proposed an optimal cluster formation scheme for intentional islanding in smart grid using deep learning method. The proposed scheme ensures low power imbalance and stable clusters. Baek *et al.* [27] proposed a security-aware energy management scheme in smart grid. The authors explored different security techniques such as identity-based encryption, signature, and proxy re-encryption, in the context of smart grid. Furthermore, Paudel *et al.* [28] and Misra *et al.* [29], Huang *et al.* [30], and Anoh *et al.* [31] proposed different energy management schemes for peer-to-peer energy trading using evolutionary, coalition, and Stackelberg games, respectively. Similarly, Tushar *et al.* [32] and Han *et al.* [33] also proposed cooperative game-based peer-to-peer energy management schemes in smart grid. On the other hand, Farzan *et al.* [10] explored the idea of predicting energy usage of customers based on the analysis of historical data (for long term) and adaptive model (short term) and proposed a distributed energy management scheme. Souza *et al.* [34] analyzed the feasibility of integrating wireless sensor networks for verifying the installation of smart meters in smart grid. In another work, Avancini *et al.* [35] proposed and designed an IoT-enabled smart meter for efficient distributed energy management, while ensuring continuous monitoring of the home appliances. Kamyab *et al.* [11] proposed an energy distribution scheme for smart grids with multiple suppliers and consumers. The authors explored two non-cooperative




Fig. 1: Schematic Diagram of Cloud-enabled Smart Grid

schemes – central price decision by the service provider and distributed load profile decision by customers. Mediawathe *et al.* [13] studied the advantages of the presence of energy generation units with the customers, which helps them to supply excess energy to the centralized energy storage. Another game-theoretic scheme was proposed by Samadi *et al.* [12] in which the authors explored the possibility of sharing excess generated energy between the micro-grids and the customers for maximizing the profit of the customers. Similarly, energy management schemes using cooperative and non-cooperative games and genetic algorithm are proposed by Wang *et al.* [36]. Lokeshgupta and Sivasubramani [37] designed a cooperative game theory-based home energy management scheme for smart grid. Instead of energy generation units, Mondal *et al.* [3] proposed the presence of energy storage units with the customers which help them to store surplus energy for future use.

Synthesis: In the existing literature, researchers proposed several pricing schemes for load distribution to ensure high QoS. Additionally, there are a few schemes proposed in the existing literature which take into consideration the energy storage facility. In these works, the authors claimed that the stored energy can be used by the respective customer as per their needs. Thus, using the existing energy management schemes, the prosumers behave non-cooperatively, and the QoS of energy supplied by the micro-grids degrades significantly. Hence, in this work, we introduce dynamic cooperation enforcing a pricing scheme in the presence of cloud infrastructure while ensuring that the energy requirement of the prosumers is satisfied. Additionally, we ensure that the prosumers, who are willing to cooperate for enhancing the QoS, get an incentive, which eventually motivates the other non-cooperative prosumers to cooperate.

III. SYSTEM MODEL

We consider a cloud-enabled energy management system comprising of multiple prosumers and micro-grids, as shown

in Figure 1. The energy demand of the prosumers is served by a micro-grid and the main grid. In other words, each prosumer is associated with a single micro-grid, and each micro-grid serves a single geographical region. However, to reduce the energy load on the main grid, each micro-grid along with the prosumers aims to ensure that the energy requirement of the prosumers is fulfilled. On the other hand, we consider that each prosumer and each micro-grid are capable of generating energy and are also enabled with a storage facility. Therefore, we assume that the prosumers having surplus energy either store the energy at their end or supply the energy to the micro-grid, which requires energy. We consider that based on these choices, the prosumers is divided into two categories — *cooperative* and *non-cooperative*.

The cooperative prosumers are willing to give back the excess quantity of energy to the micro-grid which can be supplied to the other prosumers. On the other hand, the non-cooperative prosumers behave selfishly and store the excess quantity of energy that can be used in the future for his/her usage. Additionally, we consider that the micro-grids access the information about the energy profile of the associated prosumers using cloud infrastructure, and the prosumers are honest, i.e., they provide correct information to the micro-grids.

In this work, each micro-grid $m \in \mathcal{M}$ serves a set of prosumers which is represented as \mathcal{N}_m . The set of prosumers are denoted by \mathcal{N} , where $\mathcal{N}_m \subseteq \mathcal{N}$ and each prosumer $n \in \mathcal{N}$ has a requirement of $x_n(t)$ quantity of energy. Additionally, we consider that each prosumer n generates $g_n(t)$ quantity of energy at time instant t , where $g_n(t) \geq 0$. Hence, if prosumer n generates a lesser quantity of energy than his/her requirement, i.e., $g_n(t) < x_n(t)$, s/he requests to micro-grid m for excess amount energy, i.e., $(x_n(t) - g_n(t))$. On the other hand, each prosumer n having excess quantity of energy, i.e., $g_n(t) > x_n(t)$, either may supply the excess $(g_n(t) - x_n(t))$ quantity of energy to the micro-grid m or store the aforementioned quantity of energy if $(g_n(t) - x_n(t)) \leq S_n$, where S_n denotes the storage capacity available at the prosumer-end. On the other hand, we consider that each micro-grid m having $G_m(t)$ quantity of generated energy. Hence, considering that $(G_m(t) - \sum_{n \in \mathcal{N}_m} x_n(t)) < 0$, the micro-grid m requests \mathcal{N}_m set of prosumers to supply the deficient quantity of energy. The micro-grids also supply energy to the cooperative prosumers in low price as an incentive for cooperation. Thereby, each micro-grid decides the price for serving energy to the prosumers based on their behavior — cooperative and non-cooperative. We argue that the cooperative prosumers help the micro-grid to reduce the load on the main grid. Therefore, the micro-grids need to ensure that the cooperative behavior is rewarded over non-cooperative behavior in order to motivate the prosumers to behave cooperatively. The list of symbols is presented in Table I.

IV. DYNAMIC COOPERATION ENFORCING PRICING (SMARTPRICE) SCHEME

In this work, the interaction among each micro-grid in the cloud-based smart grid with the prosumers connected with it is

TABLE I: List of Symbols

Symbol	Description
\mathcal{M}	Set of micro-grids
\mathcal{N}	Set of prosumers
\mathcal{N}_m	Set of prosumers connected with micro-grid m
$G_m(t)$	Amount of generated energy by micro-grid m
$X_m(t)$	Amount of requested energy to micro-grid m
$S_m(t)$	Amount of deficit energy for micro-grid m
$g_n(t)$	Amount of generated energy by prosumer n
$x_n(t)$	Amount of required energy by prosumer n
$e_n(t)$	Amount of requested energy by prosumer n
$d_n^m(t)$	Amount of energy supplied to micro-grid m by prosumer n
$\mathcal{B}_n(\cdot)$	Utility function of each prosumer n
$\mathcal{U}_m(\cdot)$	Utility function of each micro-grid m
$r_n(\cdot)$	Reward factor of prosumer n
α	Reward controlling factor
$\beta_n^c(t)$	Cooperation index of prosumer n
γ_m	Generation cost of per unit of energy for micro-grid m
$p_m^n(t)$	Price per unit energy for each prosumer n
$p_m^b(t)$	Base price per unit of energy
$p_m^{v,n}(t)$	Variable price per unit of energy
$p_m^{n*}(t)$	Optimum price per unit charged by micro-grid m
$c_m^{n*}(t)$	Optimum price paid by micro-grid m to prosumer n
$d_n^{m*}(t)$	Optimum amount of energy supplied to micro-grid m by prosumer n

modeled using a single-leader-multiple-followers Stackelberg game [38], [39]. Here, each micro-grid, acting as the leader, utilizes the cloud infrastructure to determine the price of unit energy supplied to the prosumers, while ensuring that the generated energy is maximally utilized. Additionally, the micro-grids, having deficient energy, determine the quantity of energy to be procured from the prosumers. On the other hand, the prosumers act as the followers and determine the quantity of energy to be procured from the micro-grids. Additionally, the prosumers also determine his/her behavioral preference – cooperative or non-cooperative, when the micro-grids have a deficit of energy due to less quantity of energy generated¹. Based on the behavioral strategy of each prosumer, the micro-grids calculate the reward factor using cloud infrastructure, as discussed in Section IV-A, and accordingly determine the price for the unit quantity of energy. We also discussed the justification for using Stackelberg game theory in this work in the subsequent sections.

A. Reward Factor for Cooperation

Motivated by the work of Chakraborty *et al.* [40], we introduce the reward factor for cooperation in demand-based

¹If the prosumers cannot satisfy the energy requirement of the micro-grids, the micro-grids consume energy from the main grid and fulfill the energy requirement of the prosumers.

energy distribution system. Initially, each prosumer n has same reward factor $r_n(\cdot)$ which is equal to one, i.e., $r_n(0) = 1$, $\forall n \in \mathcal{N}$. The reward factors of the prosumers are updated in each iteration by the micro-grids, when the micro-grids have energy scarcity. The reward factor $r_n(t)$ of each prosumer n in iteration t is calculated using *weighted moving average* and represented as follows:

$$r_n(t) = \alpha f(\beta_n^c(t)) + (1 - \alpha)r_n(t - 1) \quad (1)$$

where α is the reward factor controlling factor and $\beta_n^c(t)$ and $f(\cdot)$ are the cooperation index and the mean historical cooperation function, as defined in Definitions 1 and 2, respectively. It is to be noted that if the micro-grids have sufficient energy in an iteration, using SmartPrice, the prosumers are considered to be cooperative.

Definition 1. We define the cooperation index $\beta_n^c(t)$ as a binary variable, where it is calculated as follows:

$$\beta_n^c(t) = \begin{cases} 1 & \text{if prosumer } n \text{ is cooperative} \\ 0 & \text{otherwise} \end{cases} \quad (2)$$

Definition 2. Based on the cooperation index $\beta_n^c(t)$, we calculate the mean historical cooperation factor based on the past h iterations using cloud infrastructure. Therefore, we define $f(\beta_n^c(t))$ as follows, where $t > 0$:

$$f(\beta_n^c(t)) = \begin{cases} \frac{1}{t} \sum_{\tau=1}^t \beta_n^c(\tau), & \text{if } t < (h - 1) \\ \frac{1}{h} \sum_{\tau=t-h+1}^t \beta_n^c(\tau), & \text{otherwise} \end{cases} \quad (3)$$

where h is a constant and controls the change in $f(\beta_n^c(t))$.

We consider that there are two prosumers n_1 and n_2 , where n_1 cooperates in each iteration, whereas n_2 behaves non-cooperatively in past one iteration at least. Hence, we have, $f(\beta_1^c(t)) = 1$. However, for prosumer n_2 , we have, $f(\beta_2^c(t)) < 1$. Therefore, even if both the prosumers n_1 and n_2 behaves cooperatively in the current iteration, reward factor for prosumer n_1 will be higher than that of prosumer n_2 , i.e., $r_1(t) > r_2(t)$.

B. Stackelberg Game: The Justification

To design the dynamic cooperation enforcing pricing scheme, *SmartPrice*, we consider a multi-stage Stackelberg game. Initially, each prosumer determines the quantity of energy to be procured from the micro-grid, while considering the quantity of energy generated at their end. Based on this, the micro-grid determines the price for a unit quantity of energy for each prosumer using the reward factor while ensuring high revenue in the cloud-enabled smart grid. In this scenario, if the micro-grids have a deficient quantity of energy, they request the other associated prosumers with surplus energy. Based on the price charged to the micro-grids and the quantity of required energy, each prosumer, i.e., a follower, having surplus energy decides his/her behavior — cooperate and non-cooperate. Here, the micro-grid ensures that the energy requirement of the prosumers is satisfied. On the

other hand, the prosumers having excess energy ensure high revenue. Based on the behavior of the prosumers, the micro-grids calculate the reward factor for each prosumer, which will affect the price for the unit quantity of energy to be procured for each prosumer in the next iteration. Thereby, the proposed pricing scheme leads to an *oligopolistic market*, as the energy requirement of the prosumers is satisfied by the micro-grids, i.e., in the presence of other prosumers having surplus energy or the small energy suppliers. Therefore, we use a single-leader-multiple-followers Stackelberg game to model the SmartPrice scheme.

C. Game Formulation

In SmartPrice, we use a single-leader-multiple-followers Stackelberg game, where each micro-grid acts as the leader and evaluates the optimum price for the unit quantity of energy for each prosumer while ensuring high revenue in the cloud-enabled smart grid. On the other hand, the prosumers act as the followers and determine their behavioral strategies, while ensuring high quality of service (QoS) and high revenue. In the following sections, we discuss the utility functions, the equilibrium strategies, and the equilibrium solution of the proposed scheme, SmartPrice.

1) *Utility Function of Each Micro-Grid*: The utility function $\mathcal{U}_m(\cdot)$ of each micro-grid m signifies the revenue earned while ensuring that the energy requirement of the prosumers are fulfilled. We consider that $\mathcal{U}_m(\cdot)$ has two components such as revenue function $\mathcal{R}_m(\cdot)$ and cost function $\mathcal{C}_m(\cdot)$. Hence, we define the utility function $\mathcal{U}_m(\cdot)$ as $-\mathcal{U}_m(\cdot) = \mathcal{R}_m(\cdot) - \mathcal{C}_m(\cdot)$. Here, we consider that the payoff of $\mathcal{R}_m(\cdot)$ depends on the quantity of energy requested by the prosumers, i.e., $X_m(t)$, the quantity of generated energy $G_m(t)$, the price for unit quantity of energy $p_m^n(t)$ for each prosumer n . We define that $p_m^n(t)$ comprises of two components — *base price* ($p_m^b(t)$) and *variable price* $p_m^{v,n}(t)$. On the other hand, the payoff of $\mathcal{C}_m(\cdot)$ depends on the quantity of deficient energy $D_m(t)$ and the price $p_m^n(t)$ to be paid to each prosumer n for consuming unit quantity of energy. The different parameters of utility function $\mathcal{U}_m(t)$ are discussed as follows:

a) *Quantity of Requested Energy*: In SmartPrice, initially, each prosumer n evaluates the quantity of energy to requested $e_n(t)$ based on the quantity of generated energy $g_n(t)$ and required energy x_n . We evaluate $e_n(t)$ as follows:

$$e_n(t) = \begin{cases} x_n(t) - g_n(t), & \text{if } x_n(t) - g_n(t) > 0 \\ 0, & \text{otherwise} \end{cases} \quad (4)$$

Hence, the amount energy requested to micro-grid m , $X_m(t)$, is defined as follows:

$$X_m(t) = \sum_{n \in \mathcal{N}_m} e_n(t) \quad (5)$$

b) *Base price for unit quantity of energy*: Based on the quantity of generated energy $G_m(t)$, micro-grid m decides a *base-price* $p_m^b(t)$ per unit of energy, which is defined as follows:

$$p_m^b(t) = \gamma_m + \alpha_m e^{\frac{X_m(t)}{G_m(t)}} \quad (6)$$

where γ_m is the cost incurred by micro-grid m for generating unit quantity of energy and α_m is a constant which controls the minimum profit of the micro-grid. The micro-grids need to determine α_m optimally using cloud infrastructure. Due to the fact that if the α_m is high, the prosumers having excess quantity of energy prefer to store energy for future. On the other hand, if α_m is low, the revenue of the micro-grid reduces.

c) *Variable price for the unit quantity of energy*: In the proposed scheme, SmartPrice, we introduce the variable price, which eventually enforces cooperation among the prosumers. The variable price $p_m^{v,n}(t)$ is influenced by the reward factor of each prosumer. Thereby, we argue that the prosumers having high reward factor eventually pay less for consuming unit quantity of energy. We define $p_m^{v,n}(t)$ as follows:

$$p_m^{v,n}(t) = \phi_m \frac{e_m(t)}{X_m(t)} e^{\pi \frac{1}{r_n(t) + \delta}} \quad (7)$$

where π and δ are constants and $\pi, \delta > 0$. ϕ_m is a constant defined by micro-grid m , such that the following condition is satisfied:

$$\Phi_m(t) \geq \phi_m \frac{e_m(t)}{X_m(t)} e^{\pi \frac{1}{1 + \delta}} \quad (8)$$

where $\Phi_m(t)$ signifies the marginal revenue earned by micro-grid m . Therefore, for consuming unit quantity of energy, each prosumer n needs to pay $p_m^n(t)$, defined as follows:

$$p_m^n(t) = p_m^b(t) + p_m^{v,n}(t) \quad (9)$$

Therefore, we evaluate the revenue function $\mathcal{R}_m(\cdot)$ of micro-grid m as defined below:

$$\mathcal{R}_m(t) = \sum_{n \in \mathcal{N}_m} e_n(t) p_m^n(t) \quad (10)$$

d) *Excess Quantity of Requested Energy*: Considering the fact that the quantity of energy generated $G_m(t)$ by micro-grid m is less than the quantity of requested energy $X_m(t)$, each micro-grid m collects the information about prosumers having excess quantity of generated energy using cloud infrastructure and them to supply the surplus quantity of requested energy $S_m(t)$, where $S_m(t) = (X_m(t) - G_m(t))$. We argue that with the increase in $S_m(t)$, the payoff of $\mathcal{U}_m(\cdot)$ of micro-grid m decreases. Here, in each iteration, each micro-grid m identifies the prosumers having excess quantity of energy by initializing a binary variable $s_n(t)$ with the help of cloud infrastructure. We define $s_n(t)$ as follows:

$$s_n(t) = \begin{cases} 1, & \text{if } g_n(t) > x_n(t) \\ 0, & \text{otherwise} \end{cases} \quad (11)$$

Thereafter, each micro-grid determines the quantity of energy $d_n^m(t)$ to be requested to each prosumer n , where $s_n(t) = 1$ and $n \in \mathcal{N}_m$, such that the following condition is satisfied:

$$\sum_{n \in \mathcal{N}_m} s_n(t) d_n^m(t) \geq S_m(t) \quad (12)$$

e) *Price for the unit quantity of energy Consumption:*

In the proposed scheme, SmartPrice, we consider that, for consuming energy from each prosumer n , micro-grid m determines the price $c_m^n(t)$ per unit of energy based on the previous reward factor of each prosumer using cloud infrastructure. We argue that in order to enforce cooperation, the micro-grids pay higher to the prosumers with high reward factor. We consider that the micro-grid pays at least $p_m^b(t)$ to ensure marginal profit of the prosumers. Additionally, similar to the variable price $p_m^{v,n}(t)$ as mentioned earlier, each micro-grid m gives an incentive to the cooperative prosumers by paying $c_m^{v,n}(t)$, defined as follows:

$$c_m^{v,n}(t) = \psi_m \frac{d_n^m(t)}{S_m(t)} e^{\pi \frac{1}{r_n(t)+\delta}} \quad (13)$$

where ψ_m is a constant defined by micro-grid m and $\psi_m < \phi_m$. Therefore, the cost $c_m^n(t)$ incurred by each micro-grid m for consuming unit energy from prosumer n is defined as follows:

$$c_m^n(t) = p_m^b(t) + c_m^{v,n}(t) \quad (14)$$

Therefore, we evaluate the cost function $\mathcal{C}_m(t)$ of each micro-grid m is defined as follows:

$$\mathcal{C}_m(\cdot) = \sum_{n \in \mathcal{N}_m} s_n(t) d_n^m(t) c_m^n(t) \quad (15)$$

Thereby, from Equations (10) and (15), the overall utility function $\mathcal{U}_m(\cdot)$ is defined as follows:

$$\mathcal{U}_m(\cdot) = \sum_{n \in \mathcal{N}_m} [e_n(t) p_m^n(t) - s_n(t) d_n^m(t) c_m^n(t)] \quad (16)$$

In SmartPrice, the objective of each micro-grid is to maximize while optimizing the price $p_m^n(t)$ to be charged for consuming the unit quantity of energy.

2) *Utility Function of Each Prosumer:* Utility function $\mathcal{B}_n(\cdot)$ of each prosumer n signifies the profit earned by storing energy at his/her end or by selling energy to the micro-grids. Each prosumer n aims to procure energy at less price. Additionally, s/he decides his/her strategy, i.e., storing or selling energy to the micro-grids. Thereby, we consider that the payoff of $\mathcal{B}_n(\cdot)$ depends on the revenue earned by selling $d_n^m(t)$ quantity of energy to micro-grid m or paying less for consuming $e_n(t)$ quantity of energy from micro-grid m . Therefore, we argue that the utility function $\mathcal{B}_n(\cdot)$ needs to satisfy the following properties.

- i) Each prosumer n aims to pay less while fulfilling his/her energy requirement. Hence, we argue that, in the proposed scheme, SmartPrice, the cooperative prosumers always have the advantage of paying less while consuming energy.
- ii) Each prosumer tries to sell the excess quantity of energy at a high price. In SmartPrice, we ensure that the cooperative prosumers always get a better price for the unit quantity of energy than other prosumers.
- iii) To motivate the cooperative prosumers to sell a high quantity of excess energy, we consider the price for the

unit quantity of energy increases with the increase in the quantity of energy sold to the micro-grids.

Therefore, we define the generalized utility function $\mathcal{B}_n(\cdot)$ of each prosumer n as follows²:

$$\mathcal{B}_n(\cdot) = d_n^m(t) c_m^n(t) - e_n(t) p_m^n(t) \quad (17)$$

Each prosumer n aims to maximize the payoff of his/her utility function $\mathcal{B}_n(\cdot)$ by optimizing the quantity of energy $d_n^m(t)$ to be supplied to the micro-grid that requires energy. We argue that the decision of the prosumer eventually affects the price charged to/by the micro-grids.

D. Existence of Stackelberg Equilibrium

As discussed earlier, the price for the unit quantity of energy decided by the micro-grids not only depends on the quantity of energy procured but also depends on the strategy of the prosumer — cooperative or non-cooperative — over the past. Here, in SmartPrice, we consider that the prosumers are rational. Hence, we argue that each prosumer tries to maximize his/her payoff, which leads to a non-cooperative game. However, by introducing the reward factor, SmartPrice aims to ensure a sense of cooperation among the prosumers.

Given the price for the unit quantity of energy decided by each micro-grid, the prosumers determine their optimal strategies, which is considered as the Nash equilibrium strategies of the prosumers. Here, Nash equilibrium signifies that each prosumer cannot ensure a high payoff by deviating from the chosen strategy. Based on the strategies of the prosumers, each micro-grid determines the price for the unit quantity of energy, which is considered as the Stackelberg equilibrium. Here, Stackelberg equilibrium symbolizes that there exists an equilibrium amount in the leader-follower hierarchy, as the leader maximizes its payoff, given that the followers have their optimal opinions, i.e., Nash equilibrium strategies. We define the Stackelberg equilibrium of SmartPrice, which replicates an oligopolistic market, in Definition 3. Furthermore, we prove the existence of Stackelberg equilibrium in Theorem 1.

Definition 3. *Stackelberg equilibrium of SmartPrice is defined as $\langle p_m^{n*}(t), c_m^{n*}(t), d_n^{m*}(t) \rangle$ while considering the following conditions are satisfied:*

$$\mathcal{B}_n(p_m^{n*}(t), c_m^{n*}(t), d_n^{m*}(t)) \geq \mathcal{B}_n(p_m^n(t), c_m^{n*}(t), d_n^{m*}(t)) \quad (18)$$

$$\mathcal{U}_m(p_m^{n*}(t), c_m^{n*}(t), d_n^{m*}(t)) \geq \mathcal{U}_m(p_m^n(t), c_m^{n*}(t), d_n^{m*}(t)) \quad (19)$$

where $p_m^{n*}(t)$, $c_m^{n*}(t)$, $d_n^{m*}(t)$ are the optimum price charged by micro-grid m for unit quantity of energy, the optimum price charged to micro-grid m by prosumer n , and the optimum quantity of energy supplied to micro-grid m by prosumer n .

Theorem 1. *Given the optimal price $p_m^{n*}(t)$ and fixed energy requirement of micro-grid m , we prove that there exists at least one Stackelberg equilibrium in SmartPrice using variational inequality.*

²Please note that if $e_n(t)$ is positive, $d_n^m(t) = 0$. On the other hand, if $e_n(t) = 0$, $d_n^m(t)$ is a non-negative variable.

Proof. In SmartPrice, each micro-grid m aim to maximize its payoff by maximizing the utility function $\mathcal{U}_m(\cdot)$ while obtaining an optimal value of $d_n^m(t)$. Hence, we get that the cumulative objective of the micro-grids is to maximize $\sum_{m \in \mathcal{M}} \mathcal{U}_m(\cdot)$. Hence, using Lagrangian multiplier with the Karush-KuhnTucker (KKT) condition, we get:

$$\mathcal{L} = \sum_{m \in \mathcal{M}} \mathcal{U}_m(\cdot) - \lambda_1 \sum_m (\sum_n s_n(t) d_n^m(t) - S_m(t)) - \sum_n \lambda_2^n (\sum_m d_n^m(t) - (g_n(t) - x_n(t))) \quad (20)$$

where λ_1 and $\lambda_2^n, \forall n$ are Lagrangian multiplier. Hence, we have the following KKT conditions:

Stationarity: $\nabla_{d_n^m(t)} \mathcal{L} = 0$

Primal feasibility: $(\sum_n s_n(t) d_n^m(t) - S_m(t)) \leq 0$ and $(\sum_m d_n^m(t) - (g_n(t) - x_n(t))) \leq 0$

Dual feasibility: $\lambda_1, \lambda_2^n \geq 0$

Complementary slackness: $\lambda_1 \sum_m (\sum_n s_n(t) d_n^m(t) - S_m(t)) = 0$ and $\lambda_2^n (\sum_m d_n^m(t) - (g_n(t) - x_n(t))) = 0$

By using the property of variational inequality, we get the Jacobian matrix of \mathcal{L} , as follows:

$$\nabla_{d_n^m(t)} \mathcal{L} = \begin{bmatrix} -2 \frac{\psi_1 d_1^m(t)}{S_m(t)} e^{\frac{\pi}{r_1(t)+\delta}} \\ \vdots \\ -2 \frac{\psi_m d_n^m(t)}{S_m(t)} e^{\frac{\pi}{r_n(t)+\delta}} \\ \vdots \\ -2 \frac{\psi_m d_{|N|}^m(t)}{S_m(t)} e^{\frac{\pi}{r_{|N|}(t)+\delta}} \end{bmatrix} \quad (21)$$

Additionally, we obtain the Hessian matrix of \mathcal{L} , as mentioned in Equation (22). From Equation (22), we observe that the Hessian matrix of \mathcal{L} is a diagonal matrix having negative values. Hence, we conclude that there exists at least one Stackelberg equilibrium in SmartPrice. \square

Algorithm 1 SmartPrice-I

INPUTS: $g_n(t), x_n(t)$

OUTPUT: $e_n(t)$

PROCEDURE:

- 1: $e_n(t) = x_n(t) - g_n(t)$
- 2: **return** $e_n(t)$

E. Proposed Algorithms

In SmartPrice, initially, each prosumer is considered to be cooperative, and the price for the unit quantity of energy, i.e.,




Fig. 2: Flowchart of SmartPrice

$p_m^n(t)$ and $c_m^n(t)$, is the same for each prosumer. However, the price for the unit quantity of energy changes over the iterations based on the strategies of the prosumers. The presence of selfish prosumers leads to an oligopolistic market. However, in SmartPrice, the micro-grid motivates the prosumers to behave cooperatively by deciding an optimal price for the unit quantity of energy. We argue that the proposed scheme, SmartPrice, ensures cooperation among the prosumers by executing Algorithms 1, 2, and 3, sequentially. The flowchart of the SmartPrice is presented in Figure 2. Initially, each prosumer n executes Algorithm 1 in order to determine $e_n(t)$. Thereafter, using Algorithm 2, each micro-grid m determines $p_m^n(t)$ and evaluates if it needs to procure energy from the prosumers having surplus energy. In case of having a deficient

$$\nabla_{d_n^m(t)}^2 \mathcal{L} = \begin{bmatrix} -2 \frac{\psi_m}{S_m(t)} e^{\frac{\pi}{r_1(t)+\delta}} & \dots & 0 & \dots & 0 \\ \vdots & \ddots & \vdots & \ddots & \vdots \\ 0 & \dots & -2 \frac{\psi_m}{S_m(t)} e^{\frac{\pi}{r_n(t)+\delta}} & \dots & 0 \\ \vdots & \ddots & \vdots & \ddots & \vdots \\ 0 & \dots & 0 & \dots & -2 \frac{\psi_m}{S_m(t)} e^{\frac{\pi}{r_{|N|}(t)+\delta}} \end{bmatrix} \quad (22)$$

quantity of energy, each micro-grid m requests the prosumers to supply $S_m(t)$ quantity of energy, and determines $c_m^n(t)$ using Algorithm 2. Thereafter, each prosumer n executes Algorithm 3 in order to determine $d_n^m(t)$. At the end of an iteration, using Algorithm 2, each micro-grid m updates the reward factor for each prosumer, to be used in the next iteration.

Algorithm 2 SmartPrice-II

INPUTS: $e_n(t)$, $s_n(t)$, $r_n(t-1)$, $G_m(t)$ and constants

OUTPUT: $r_n(t)$, $p_m^{n*}(t)$, $c_m^{n*}(t)$

PROCEDURE:

```

1: Calculate  $p_m^b(t)$ 
2: for each  $n \in \mathcal{N}_m$  do
3:   Calculate  $p_m^{v,n}(t)$ 
4:    $p_m^{n*}(t) = p_m^b(t) + p_m^{v,n}(t)$ 
5: end for
6:  $S_m(t) = X_m(t) - G_m(t)$ 
7: if  $S_m(t) > 0$  then
8:   for each  $n \in \mathcal{N}_m$  and  $s_n(t) = 1$  do
9:     Calculate  $c_m^{n*}(t)$ 
10:     $d_n(t) \leftarrow \text{SmartPrice-III}(S_m(t), c_m^{n*}(t))$ 
11:    Calculate  $\mathcal{U}_m(\cdot)$ 
12:    Calculate  $r_n(t)$ 
13:   end for
14:   for each  $n \in \mathcal{N}_m$  and  $s_n(t) = 1$  do
15:      $d_n^{m*}(t) \leftarrow 0$ 
16:     do
17:        $\mathcal{U}_m^{prev} = \mathcal{U}_m(\cdot)$ 
18:       Calculate  $d_n^m(t)$  while satisfying constraint in
Equation 12 and  $d_n^m(t) \leq d_n(t)$ 
19:       while  $\mathcal{U}_m(p_m^{n*}(t), c_m^{n*}(t), d_n^{m*}(t)) \geq \mathcal{U}_m^{prev}$ 
20:       end for
21:     end if
22:   return  $r_n(t)$ ,  $p_m^{n*}(t)$ ,  $c_m^{n*}(t)$ 

```

F. Complexity Analysis

In SmartPrice, the aforementioned three algorithms need to be executed sequentially. Using Algorithm 1, each prosumer decides the amount of energy to consumed from the micro-grid. The time complexity of Lines 1-2 of Algorithm 1 is $O(1)$. Therefore, we observe that the time complexity to Algorithm 1 is $O(1)$. Thereafter, Algorithm 2 is executed by each micro-grid. The time complexity of Lines 1 and 6 of Algorithm 2 is $O(1)$, however, the time complexity for Lines 2-5, 8-13, and 14-20 is $O(|\mathcal{N}_m|)$. Therefore, we observed that the time complexity for Algorithm 2 is $O(|\mathcal{N}_m|)$. On the other hand, the time complexity for Algorithm 3 is $O(K)$, where K is a finite value and depends on the constant ρ_n decided by each prosumer n . Hence, the overall complexity of SmartPrice is $O(|\mathcal{N}_m| + K)$.

V. PERFORMANCE EVALUATION

A. Simulation Parameters

To evaluate the performance of SmartPrice, we perform simulations using MATLAB. Generic test-bed information

Algorithm 3 SmartPrice-III

INPUTS: $g_n(t)$, $x_n(t)$, $S_m(t)$, $c_m^n(t)$, ρ

OUTPUT: $d_n^m(t)$

PROCEDURE:

```

1:  $d_n^m(t) \leftarrow 0$ 
2: Calculate  $\mathcal{B}_n(\cdot)$ 
3: do
4:    $\mathcal{B}_n^{prev} = \mathcal{B}_n(\cdot)$ 
5:    $d_n^m(t) = d_n^m(t) + \rho$ 
6: while  $\mathcal{B}_n^{prev} < \mathcal{B}_n(\cdot)$ 
7: return  $d_n^m(t)$ 

```

for SmartPrice is given in Table II. We consider a random deployment of micro-grids and prosumers over a geographical area. Within each region [9] of the area, the prosumers are served by a single micro-grid as mentioned earlier. The energy profile of the entities, i.e., micro-grids and the prosumers, are randomly initialized. Additionally, we consider that each prosumer determines her/his energy requirement individually, as shown in Table III. Based on this information, each micro-grid determines the price for the unit quantity of energy to be charged and paid.

TABLE II: System Specification

Parameter	Value
Processor	Intel(R) Core(TM) i5-2500 CPU @ 3.30 GHz
RAM	4 GB DDR3
Disk Space	500 GB
Operating System	Ubuntu 16.04 LTS
Application Software	MATLAB 2015b

TABLE III: Simulation Parameters

Parameter	Value
Simulation area	20×20 km^2
Number of micro-grids	10
Number of Prosumers	1000
Required energy per prosumer	90-100 MWh
Generated energy per prosumer	50-120 MWh
Prosumer's storage capacity	35-65 MWh
Energy generated by micro-grid	500-650 MWh
Generation cost	10-20 USD/MWh

B. Benchmarks

We used three different existing schemes as benchmarks – *home energy management with storage (HoMeS)* [3], *Dynamic Pricing for PHEV (D2P)* [6], *price taking user (PTU)* [41], and *sustainable energy distribution scheme (SEED)* [29].

In HoMeS, Mondal *et al.* [3] used a game-theoretic analysis to study the nature of energy utilization of the prosumers. Here, the authors considered the presence of storage devices at the user end. On the other hand, in D2P [6], Misra *et al.* studied pricing mechanisms for PHEVs, in which both types




Fig. 3: Performance Comparison of non-cooperative prosumers, and average revenue earned and price charged by the prosumers




Fig. 4: Performance Comparison of served prosumers, and profit earned and price charged by the micro-grids

of pricing schemes - local and roaming - are explored by the authors. In PTU, Samadi *et al.* [41] studied attempted to reduce the energy generation cost of the prosumers and the power consumption to shift load to off-peak hours. On the other hand, Misra *et al.* [29] proposed an evolutionary game-based energy distribution scheme while ensuring that the energy load is optimally distributed among the micro-grids. They considered the players are non-cooperative. However, these works do not consider the situation where the micro-grid may request the prosumers for energy supply. Additionally, none of these works aimed to enforce cooperation among the prosumers which improves the QoS of the energy supplied. Using the proposed scheme, SmartPrice, the micro-grids ensure that the prosumers evolve over the iteration and behave cooperatively. On the other hand, SmartPrice ensures high QoS in the cloud-enabled smart grid. Thus, while taking advantage of the oligopolistic market scenario, in SmartPrice, we propose a dynamic pricing scheme to enforce cooperation among the prosumers.

C. Performance Metrics

We evaluated the performance of SmartPrice using the following metrics.

- 1) **Percentage of Cooperative Prosumers:** In smart grid, we aim to reduce the load on the main grid by serving the prosumers using the renewable energy generated by the micro-grids and other prosumers. Therefore, with the increase in the number of cooperative prosumers, the load on the main grid reduces significantly, thereby improving the QoS.
- 2) **Percentage of Prosumers Served:** The percentage of prosumers served indicates the number of prosumers whose energy request is served successfully by the micro-grids. The increase in the number of prosumers whose energy requirements are satisfied by consuming energy

from the micro-grids is, therefore, an indicator of the improvement of the system performance.

- 3) **Price Charged by Micro-Grids:** In smart grid, each prosumer aims to procure energy by paying less price to the micro-grids. The higher quantity of energy procured by a prosumer increases the price charged to the prosumer, for a fixed per unit rate. Thus, each prosumer aims to ensure that they pay less price for unit energy consumption.
- 4) **Price Charged to the Micro-grids:** Each micro-grid can serve energy, which equals the quantity of energy generated by that micro-grid. If the energy demanded by the prosumers higher than the quantity of energy generated, the micro-grids need to rely on the prosumers having surplus energy. Eventually, the prosumers earn revenue by supplying the excess quantity of energy to the micro-grids.
- 5) **Profit of Micro-grids:** Each micro-grid tries to maximize its earnings to maximize its revenue or profit. The surplus earned by the micro-grids by selling energy after covering its total generation cost determines the profit of the micro-grid.
- 6) **Profit of Prosumers:** In SmartPrice, the prosumers having surplus energy get a chance to earn revenue by supplying the excess quantity of generated energy to the micro-grids having deficient energy. On the contrary, the prosumers may behave non-cooperatively and chose to store the excess quantity of energy for future use.

D. Results and Discussions

Figure 3(a) shows the variation of the number of cooperative prosumers in the system over time using the schemes — SmartPrice, HoMeS, D2P, PTU, and SEED. We consider that, initially, every prosumer in the system is cooperative. Over time, an increasing percentage of prosumers, driven by their self-interests, determine to store their excess energy for future




Fig. 5: Performance Comparison of served prosumers, and profit earned and price charged by the micro-grids with 50% cooperative prosumers.

use instead of selling their energy to micro-grids. This results in the observed initial dip in the percentage of cooperative prosumers. However, after a few iterations, the percentage of cooperative prosumers begins to increase using SmartPrice unlike the other schemes in the existing literature. This is because, as a result of the initial decrease in the percentage of cooperative prosumers, the average price charged to the prosumers by the micro-grids increases. When the price increase becomes significant, the prosumers are motivated to behave cooperatively to facilitate the reduction of the cost of purchasing unit energy from the micro-grids. Thus, the percentage of cooperative prosumers in the system increases with time. However, this is not the case for the other existing schemes as using those schemes, the behavior of the prosumers does not influence the market price of energy. Hence, we argue that SmartPrice enforces cooperation among the prosumers in the cloud-enabled smart grid. From Figure 4(a), we yield that with the increase in the number of cooperative prosumers, the QoS, i.e., the number of served prosumers increases. On the other hand, we observe that with the increase in the number of prosumers, the served prosumers increases initially. However, the number of served prosumers gets saturated due to having a limited amount of energy generated by the micro-grids and the prosumers. Moreover, it is to be noted that using SmartPrice, the remaining prosumers are served from the main grid. We did include them in the Figure 5(a).

Figures 3(b) and 3(c) depicts the variation in the average price for the unit quantity of energy charged by each micro-grid to the prosumers with the increase in the percentage of cooperative prosumers in the system. From Figure 3(b), we observe that using the proposed scheme, SmartPrice, the price for the unit quantity of energy charged to the prosumers decreases by 23.37-35.63% with the increase in the percentage of cooperative prosumers, unlike the existing schemes — HoMeS, D2P, PTU, and SEED. This is because using SmartPrice, the cooperative behavior of prosumers is rewarded by reducing the cost per unit of energy. Thus, the cooperative prosumers pay less price for the unit quantity of energy, thereby reducing the average price charged to the prosumers by the micro-grids. On the other hand, using the existing schemes, the price charged to the prosumers is independent of their behavior. Thus, the average price charged continues to remain higher irrespective of the increase in the cooperation by the prosumers. Additionally, it is to be noted that the existing works do not consider the situation where the micro-grid may request the prosumers for energy

supply. Therefore, from Figures 3(b) and 3(c), we observe zero contribution in the revenue earned and the price charged by the prosumers using the existing schemes — HoMeS, D2P, PTU, and SEED. Moreover, we observe that, with the increase in the number of prosumers in the system, the average price charged to the prosumers decreases further using SmartPrice. On the other hand, as shown in Figure 4(c), SmartPrice ensures high revenue for the micro-grids, as the prosumers served by the micro-grids increases by 38.19-53.14%. We also observed the similar trend in Figure 5(b). Additionally, we observe that using SmartPrice, the profit of the micro-grids is always higher than the existing schemes, as SmartPrice ensures a high number of prosumers are served and high utilization of the generated energy.

Similarly, in Figure 4(b), we observe the variation of the price charged to the micro-grids by the prosumers with the increase in the percentage of cooperative prosumers in the cloud-enabled smart grid. We yield that the price charged to the micro-grid by the prosumers for unit energy increases with the increase in the percentage of cooperative prosumers using the proposed scheme, SmartPrice. However, the revenue earned by the prosumers using other existing schemes is significantly low, as these schemes do not consider the involvement of the prosumers in energy supply along with the micro-grids. This is also because using SmartPrice, prosumers are encouraged to sell their excess energy to the micro-grids by paying them a higher price for the unit quantity of energy. Moreover, with the increase in cooperative prosumers, each micro-grid is presented with the option of purchasing energy from a higher number of prosumers. Thus, the average revenue of prosumers increases as depicted in Figure 4(c). On the other hand, with the increase in the number of prosumers, the average price charged by the micro-grids increases, as depicted in Figure 5(c). This is because the energy demand increases with the increase in the number of prosumers, however, the amount of generated energy remains fixed. Therefore, we argue that the proposed scheme, SmartPrice, enhances the performance of energy management, i.e., enhances the QoS of energy supply, while ensuring high revenue earned by the micro-grids and the prosumers. Additionally, SmartPrice ensures cooperation among the prosumers, which also eventually enhances the QoS of the energy supply.

Therefore, we yield that SmartPrice enforces cooperation among the prosumers by introducing the reward to be awarded by the micro-grids and ensures high revenue of the micro-grids. We also observed that the percentage of cooperative

prosumers in the system increases with time using SmartPrice, which in turn reduces the price to be paid by the prosumers as well as the micro-grids, which results in high QoS using SmartPrice than using the existing schemes.

VI. CONCLUSION

In this paper, we studied the problem of cloud-enabled efficient energy management in the presence of energy generation capacity at the prosumer-end using the single-leader-multiple-followers Stackelberg game. Using the proposed scheme, SmartPrice, we observe that the micro-grids ensure cooperation among the prosumers. In SmartPrice, using the cloud infrastructure, the micro-grids determine the optimal price for the unit quantity of energy to be charged from the prosumers and paid to the prosumers, respectively. On the other hand, we observe that the prosumers, who are non-cooperative by virtue, are motivated by the micro-grids to act cooperatively, thereby ensuring the high QoS. The simulation results indicate that the proposed scheme, SmartPrice, performs superior compared to existing benchmark schemes.

This work can be extended in the future by studying the nature of the energy distribution while introducing a bidding strategy so that the prosumers also have active participation in deciding the price for the unit quantity of energy. This work also can be extended while introducing a broker in between the micro-grids and the prosumers. This broker may act as a third-party entity that ensures the anonymity of the prosumers.

REFERENCES

- [1] G. Strbac, "Demand side management: Benefits and challenges," *Energy Policy*, vol. 36, no. 12, pp. 4419–4426, 2008.
- [2] S. Bera, S. Misra, and J. J. Rodrigues, "Cloud Computing Applications for Smart Grid: A Survey," *IEEE Transactions on Parallel and Distributed Systems*, vol. 26, no. 5, pp. 1477–1494, 2015.
- [3] A. Mondal, S. Misra, and M. S. Obaidat, "Distributed Home Energy Management System With Storage in Smart Grid Using Game Theory," *IEEE Syst. J.*, pp. 1–10, 2015, DOI: 10.1109/JSYST.2015.2421941.
- [4] M. Such and C. Hill, "Battery energy storage and wind energy integrated into the Smart Grid," in *Proc. of IEEE PES on Inn. Smart Grid Tech.*, Washington, DC, Jan 2012, pp. 1–4.
- [5] V. Bakker, M. G. C. Bosman, A. Molderink, J. L. Hurink, and G. J. M. Smit, "Demand Side Load Management Using a Three Step Optimization Methodology," in *Proc. of IEEE Int. Conf. on Smart Grid Comm.*, Gaithersburg, MD, Oct 2010, pp. 431–436.
- [6] S. Misra, S. Bera, and T. Ojha, "D2P: Distributed Dynamic Pricing Policy in Smart Grid for PHEVs Management," *IEEE Trans. on Parallel and Dist. Syst.*, vol. 26, no. 3, pp. 702–712, Mar 2015.
- [7] A. Molderink, V. Bakker, M. G. C. Bosman, J. L. Hurink, and G. J. M. Smit, "Management and Control of Domestic Smart Grid Technology," *IEEE Trans. on Smart Grid*, vol. 1, no. 2, pp. 109–119, Aug 2010.
- [8] M. Erol-Kantarci and H. T. Mouftah, "TOU-Aware Energy Management and Wireless Sensor Networks for Reducing Peak Load in Smart Grids," in *Proc. of IEEE Vehicular Tech. Conf. Fall*, Ottawa, ON, Sept 2010, pp. 1–5.
- [9] A. Mondal and S. Misra, "Dynamic Coalition Formation in a Smart Grid: A Game Theoretic Approach," in *Proc. of IEEE Int. Wrkshp on Smart Comm. Protocols and Algo. in conjunction with IEEE ICC*, Budapest, Hungary, Jun 2013, pp. 1067–1071.
- [10] F. Farzan, F. Farzan, M. A. Jafari, and J. Gong, "Integration of Demand Dynamics and Investment Decisions on Distributed Energy Resources," *IEEE Trans. on Smart Grid*, vol. 7, no. 4, pp. 1886–1895, Jul 2016.
- [11] F. Kamyab, M. Amini, S. Sheykha, M. Hasanpour, and M. M. Jalali, "Demand Response Program in Smart Grid Using Supply Function Bidding Mechanism," *IEEE Trans. on Smart Grid*, vol. 7, no. 3, pp. 1277–1284, May 2016.
- [12] P. Samadi, V. W. S. Wong, and R. Schober, "Load Scheduling and Power Trading in Systems With High Penetration of Renewable Energy Resources," *IEEE Trans. on Smart Grid*, vol. 7, no. 4, pp. 1802–1812, Jul 2016.
- [13] C. P. Mediawathe, E. R. Stephens, D. B. Smith, and A. Mahanti, "A Dynamic Game for Electricity Load Management in Neighborhood Area Networks," *IEEE Trans. on Smart Grid*, vol. 7, no. 3, pp. 1329–1336, May 2016.
- [14] F. Zaman, S. M. Elsayed, T. Ray, and R. A. Sarker, "Evolutionary Algorithms for Finding Nash Equilibria in Electricity Markets," *IEEE Trans. on Evo. Comp.*, pp. 1–14, 2017, DOI: 10.1109/TEVC.2017.2742502.
- [15] B. Barabadi and M. H. Yaghmaee, "A new pricing mechanism for optimal load scheduling in smart grid," *IEEE Syst. J.*, vol. 13, no. 2, pp. 1737–1746, June 2019.
- [16] N. Kumar, S. Misra, J. Rodrigues, J.-H. Lee, M. S. Obaidat, and N. Chilamkurti, "Playing the Smart Grid Game: Performance Analysis of Intelligent Energy Harvesting and Traffic Flow Forecasting for Plug-In Electric Vehicles," *IEEE Vehicular Technology Magazine*, vol. 10, no. 4, pp. 81–92, 2015.
- [17] Y. Jiang, K. Zhou, X. Lu, and S. Yang, "Electricity trading pricing among prosumers with game theory-based model in energy blockchain environment," *Applied Energy*, vol. 271, p. 115239, 2020.
- [18] N. Irtija, F. Sangoleye, and E. E. Tsiropoulou, "Contract-Theoretic Demand Response Management in Smart Grid Systems," *IEEE Access*, vol. 8, pp. 184976–184987, 2020.
- [19] G. S. Aujla, M. Singh, N. Kumar, and A. Y. Zomaya, "Stackelberg Game for Energy-Aware Resource Allocation to Sustain Data Centers Using RES," *IEEE Transactions on Cloud Computing*, vol. 7, no. 4, pp. 1109–1123, 2019.
- [20] A. Ali and H. S. Hassanein, "Time-Series Prediction for Sensing in Smart Greenhouses," in *Proc. of IEEE Global Communications Conference*, 2020, pp. 1–6.
- [21] P. Vamvakas, E. E. Tsiropoulou, and S. Papavassiliou, "Dynamic provider selection & power resource management in competitive wireless communication markets," *Mobile Networks and Applications*, vol. 23, no. 1, pp. 86–99, 2018.
- [22] X.-L. Huang, X. Ma, and F. Hu, "Machine learning and intelligent communications," *Mobile Networks and Applications*, vol. 23, no. 1, pp. 68–70, 2018.
- [23] S. Chen, N. B. Shroff, and P. Sinha, "Heterogeneous Delay Tolerant Task Scheduling and Energy Management in the Smart Grid with Renewable Energy," *IEEE J. on Selected Areas in Comm.*, vol. 31, no. 7, pp. 1258–1267, July 2013.
- [24] M. A. Abido, "Multiobjective Evolutionary Algorithms for Electric Power Dispatch Problem," *IEEE Trans. on Evo. Comp.*, vol. 10, no. 3, pp. 315–329, Jun. 2006.
- [25] D. W. Bunn and F. S. Oliveira, "Agent-based simulation—an application to the new electricity trading arrangements of England and Wales," *IEEE Trans. on Evo. Comp.*, vol. 5, no. 5, pp. 493–503, Oct 2001.
- [26] Z. Sun, Y. Spyridis, T. Lagkas, A. Sesis, G. Efsthopoulos, and P. Sarigiannidis, "End-to-End Deep Graph Convolutional Neural Network Approach for Intentional Islanding in Power Systems Considering Load-Generation Balance," *Sensors*, vol. 21, no. 5, 2021.
- [27] J. Baek, Q. H. Vu, J. K. Liu, X. Huang, and Y. Xiang, "A Secure Cloud Computing Based Framework for Big Data Information Management of Smart Grid," *IEEE Transactions on Cloud Computing*, vol. 3, no. 2, pp. 233–244, 2015.
- [28] A. Paudel, K. Chaudhari, C. Long, and H. B. Gooi, "Peer-to-Peer Energy Trading in a Prosumer-Based Community Microgrid: A Game-Theoretic Model," *IEEE Transactions on Industrial Electronics*, vol. 66, no. 8, pp. 6087–6097, 2019.
- [29] S. Misra, A. Mondal, P. V. S. Kumar, and S. K. Pal, "SEED: QoS-Aware Sustainable Energy Distribution in Smart Grid," *IEEE Transactions on Sustainable Computing*, pp. 1–11, 2021, DOI: 10.1109/TSUSC.2021.3049132.
- [30] H. Huang, S. Nie, J. Lin, Y. Wang, and J. Dong, "Optimization of Peer-to-Peer Power Trading in a Microgrid with Distributed PV and Battery Energy Storage Systems," *Sustainability*, vol. 12, no. 3, 2020.
- [31] K. Anoh, S. Maharjan, A. Ikpehai, Y. Zhang, and B. Adebisi, "Energy Peer-to-Peer Trading in Virtual Microgrids in Smart Grids: A Game-Theoretic Approach," *IEEE Transactions on Smart Grid*, vol. 11, no. 2, pp. 1264–1275, 2020.
- [32] W. Tushar, T. K. Saha, C. Yuen, T. Morstyn, M. D. McCulloch, H. V. Poor, and K. L. Wood, "A motivational game-theoretic approach for peer-to-peer energy trading in the smart grid," *Applied Energy*, vol. 243, pp. 10–20, 2019. [Online]. Available: <https://www.sciencedirect.com/science/article/pii/S0306261919305185>

- [33] L. Han, T. Morstyn, and M. McCulloch, "Estimation of the Shapley Value of a Peer-to-peer Energy Sharing Game Using Multi-Step Coalitional Stratified Sampling," *International Journal of Control, Automation and Systems*, pp. 1–10, 2021.
- [34] R. W. R. de Souza, L. R. Moreira, J. J. P. C. Rodrigues, R. R. Moreira, and V. H. C. de Albuquerque, "Deploying Wireless Sensor Networks-based Smart Grid for Smart Meters Monitoring and Control," *International Journal of Communication Systems*, vol. 31, no. 10, p. e3557, 2018.
- [35] D. B. Avancini, J. J. P. C. Rodrigues, R. A. L. Rabêlo, A. K. Das, S. Kozlov, and P. Solic, "A New IoT-based Smart Energy Meter for Smart Grids," *International Journal of Energy Research*, vol. 45, no. 1, pp. 189–202, 2021.
- [36] K. Wang, H. Li, S. Maharjan, Y. Zhang, and S. Guo, "Green Energy Scheduling for Demand Side Management in the Smart Grid," *IEEE Transactions on Green Communications and Networking*, vol. 2, no. 2, pp. 596–611, 2018.
- [37] B. Lokeshgupta and S. Sivasubramani, "Cooperative game theory approach for multi-objective home energy management with renewable energy integration," *IET Smart Grid*, vol. 2, pp. 34–41, March 2019.
- [38] A. Mondal, S. Misra, L. S. Patel, S. K. Pal, and M. S. Obaidat, "DEMANDS: Distributed Energy Management Using Noncooperative Scheduling in Smart Grid," *IEEE Syst. J.*, vol. 12, no. 3, pp. 2645–2653, September 2018.
- [39] A. Chakraborty, S. Misra, and A. Mondal, "QoS-Aware Dynamic Cost Management Scheme for Sensors-as-a-Service," *IEEE Transactions on Services Computing*, pp. 1–1, 2020, DOI: 10.1109/TSC.2020.3011495.
- [40] A. Chakraborty, A. Mondal, A. Roy, and S. Misra, "Dynamic Trust Enforcing Pricing Scheme for Sensors-as-a-Service in Sensor-Cloud Infrastructure," *IEEE Trans. on Serv. Comp.*, pp. 1–12, October 2018, DOI: 10.1109/TSC.2018.2873763.
- [41] P. Samadi, H. Mohsenian-Rad, R. Schober, and V. W. S. Wong, "Advanced Demand Side Management for the Future Smart Grid Using Mechanism Design," *IEEE Trans. on Smart Grid*, vol. 3, no. 3, pp. 1170–1180, Sept 2012.



Ayan Mondal (S'13-M'21) is a Postdoctoral Researcher at Univ Rennes, Inria, CNRS, IRISA, Rennes, France. He completed his Ph.D. degree from the Department of Computer Science and Engineering, Indian Institute of Technology (IIT) Kharagpur, India in 2020. He is a former TCS Fellow. He also received his M.S. and B.Tech. degree from IIT Kharagpur in 2015 and West Bengal University of Technology in 2012, respectively. His current research interests include algorithm design for data center networks, software-defined networks, sensor-

cloud, edge/fog networks, smart grid, and wireless sensor networks. He is also a member of ACM. For more details, please visit <https://ayanmondal.github.io>



Sudip Misra (SM'11) is a Professor at IIT Kharagpur. He received his Ph.D. degree from Carleton University, Ottawa, Canada. Prof. Misra is the author of over 350 scholarly research papers. He has won several national and international awards including the IEEE ComSoc Asia Pacific Young Researcher Award during IEEE GLOBECOM 2012. He was also the recipient of several academic awards and fellowships such as the INSA NASI Fellow Award (National Academy of Sciences, India), the Young Scientist Award (National Academy of Sciences, India), Young Systems Scientist Award (Systems Society of India), and Young Engineers Award (Institution of Engineers, India). He has also been serving as the Associate Editor of the IEEE TRANSACTIONS ON MOBILE COMPUTING, the IEEE TRANSACTIONS ON VEHICULAR TECHNOLOGY, the IEEE TRANSACTIONS ON SUSTAINABLE COMPUTING, the IEEE SYSTEMS JOURNAL, and the INTERNATIONAL JOURNAL OF COMMUNICATION SYSTEMS (Wiley). He is a Guest Editor of the IEEE NETWORK Magazine. He is also an Editor/Editorial Board Member/Editorial Review Board Member of the IET NETWORKS and the IET WIRELESS SENSOR SYSTEMS. Dr. Misra has 11 books published by Springer, Wiley, and World Scientific. He was invited to chair several international conference/workshop programs and sessions. Dr. Misra was also invited to deliver keynote/invited lectures in over 30 international conferences in USA, Canada, Europe, Asia, and Africa. For more details, please visit <http://cse.iitkgp.ac.in/~smisra>



Aishwariya Chakraborty (S'17) is presently pursuing her Ph.D. degree from the Advanced Technology Development Centre, Indian Institute of Technology Kharagpur, India. She received the prestigious Google PhD Fellowship in 2021. Her current research interests include algorithm design for sensor-cloud, service-oriented architecture, and wireless sensor networks. She received her M.S. and B.Tech. degree from the Department of Computer Science and Engineering, Indian Institute of Technology Kharagpur in 2019 and West Bengal University of

Technology in 2015, respectively. She is a student member of IEEE and ACM. For more details, please visit <https://cse.iitkgp.ac.in/~aishchak>.