APPENDIX - XI

BUILDING SAFETY CERTIFICATE

No.

Dated:22.07.2024

Certified that the existing building **VELS VIDYASHRAM** at **P.V.Vaithiyalingam Road, Velan Nagar, Old Pallavaram, Chennai – 600 117** comprised of one basement (s) and two floors owned/occupied by **Vels Vidyashram** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of PUBLIC WORKS DEPARTMENT (Name of Department/ Govt.) on 07/12/2023.....(date of inspection)in the presence of Mr. Srinivasan, Manager, Velan nagar, Pallavaram (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII with effect from 08/12/23 for a period of 07/12/2023 years in accordance with rule and subject to compliance of the specific conditions as appended.

1. The period of validity of the License shall be from 08.12.2023 to 07.12.2026.

2. The Building shall be used for the school purpose as per Form D

3.The number of persons to be accommodated should not exceed the number specified in Form D

4. Subject to conditions that No Objection certificate from Fire and Rescue Department and Sanitary certificate should be renewed every year.

Issued on ..... at ..... by

Signature with Seal : 26/07/2024

Name : V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Designation Intending Engineer PWD (Retd)
Government Registered
Name & Address of Department/Office: Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Mougambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083

VELS VIDYASHRAM P.V. Vaithyalingam Road, Pallavaram CHENNAI-600 117

Scanned with OKEN Scanner

©
GOVERNMENT OF TAMIL NADU
2021

CHENGALPATTU DISTRICT GAZETTE

PUBLISHED BY AUTHORITY

CHENGALPATTU, OCTOBER 3, 2021

132C Purattasi 17, Pilava, Thiruvalluvar Aandu-2052 [No. 5

NOTIFICATION BY THE COLLECTOR

PROCEEDINGS OF THE DISTRICT COLLECTOR, CHENGALPATTU DISTRICT

PRESENT: Thiru A.R. RAHUL NADH, I.A.S.,

(RC.No.1029/2020/M1, Dt. 14.07.2021)

SUB: Tamil Nadu Public Building (Licensing) Act 1965 and rules 1966–Chengalpattu District - Inclusion of Thiru V.Ramachandran in the panel of private practicing Engineers under Class IA in Chengalpattu district- Orders issued.

READ:

1. Representation from Thiru V.Ramachadran Superintending Engineer (retd), No.7/8, Moogambikai Street, Jaibalaji Nagar, Nesapakkam, Chennai-78. Dated 24.01.2020.
2. This office Letter Rc No. 1029/2020/M1 Dated 18.3.2019.
3. Superintending Engineer, P.W.D., Buildings (Construction and Maintenance) Circle, Chennai-5 Letter No. DB/DOI/F.A-Panel of Engineers 63M/2019 Dated 8.7.2020
4. This office Letter Rc No.1029/2020/M1 Dated 04.09.2020.
5. Engineer - in - Chief (Buildings) & Chief Engineer (Buildings), Public Works Department letter No. AEE/TI0/003943/2020. Dated: 04.03.2021.

****

ORDER:

In the reference 1st cited, one Er. (Thiru) V.Ramachandran residing at Plot No.7/8,Moogambikai Street, Jaibalaji Nagar, Nesapakkam, Chennai-78 has applied for inclusion of his name in the panel of Private Practicing Engineer under Class IA category in Chengalpattu district in the prescribed format and the same was forwarded to the Superintending Engineer, P.W.D., Buildings (Construction and Maintenance) Circle, Chennai-5 for taking appropriate action vide this office reference 2nd cited.

In the reference 2nd cited, the Superintending Engineer, P.W.D., Buildings (Construction and Maintenance) Circle, Chennai-5 has recommended for inclusion of the name of Er. V.Ramachandran in the Panel of Private Practicing Engineers under Class IA in Chengalpattu district and the same was forwarded to the Engineer-in- Chief (Buildings) and Chief Engineer (Buildings), P.W.D., Chennai-5 vide this office reference 4th cited, for taking further action.

VEL'S VIDYASHRAM P.V. Vaithyalingam Road, Pallavaram CHENNAI-600 117

In the reference 5th cited, the Engineer-in-Chief (Buildings) & Chief Engineer (Buildings), Public Works Department, Chennai-5 has informed that the Board of Engineers in their 537th meeting held on 26.02.2021 have discussed the proposal of the petitioner and after elaborate deliberations, the Board has resolved to recommend the name of Thiru V.Ramachandran (D.O.B. 18.08.1955) residing at New No. 7, Old No.8, Moogambigai Street, Jaibalaji Nagar, Nesapakkam, Chennai-78 for inclusion in the panel of private practicing Engineers under Class IA Category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per G.O. Ms. No. 43, Municipal Administration and Water Supply (MA4), Department, dated 17.2.2011) in Chengalpattu district.

Based on the recommendation of the Engineer-in-Chief, (Buildings) and Chief Engineer (Buildings), Public Works Department, Chennai-5, it is hereby ordered that the name of Thiru V. Ramachandran be included in the panel of private practicing Engineers under Class 1A Category (Buildings, the cost of which exceeds Rs.50.00 lakhs as per G.O. Ms. No. 43, Municipal Administration and Water Supply (MA4), Department, dated 17-2-2011) in Chengalpattu district.

Chengalpattu,
14th July 2021.

A.R. RAHUL NADH,
District Collector.

VEL'S VIDYASHRAM
P.V. Vaithyalingam Road,
Pallavaram
CHENNAI-500 117

PRINTED BY THE COMMISSIONER OF STATIONERY AND PRINTING AT THE GOVERNMENT CENTRAL PRESS, CHENNAI AND PUBLISHED BY THE COLLECTOR OF THE DISTRICT.

STATEMENT ACCOMPANYING FORM - A

1. Name of the building : VELS VIDYASHRAM

2. Location/ Street No, Name of place : SF NO 192/2,193/1,2,3,4,5,6,7,8&193/18
Velan nagar ,P.V.Vaithiyalingam Road,
Pallavaram
Chengalpattu District CHENNAI-600117

3. Year of construction : Vide Annexure 1

Area details vide annexure 1	:	plinth area (Sq m)	carpet area (Sqm)
a) BLOCK I		2490	2117
b) BLOCK II		2847	2420
c) BLOCK III		2112	1795
d) BLOCK IV		2006	1705
		9455	8037

4) Approximate cost of construction at current rates : Rs 2269 lakhs

5) Purpose for which building is used : Educational purpose

6) Purpose for which building has hitherto been used : Educational purpose

7) Details of construction of the building (particulars of the foundation,soil specification of various parts under)

a) foundation : isolated column foundation , with plinth beam.

b) basement/ superstructure : brick work in cement mortar, in masonry works

c) superstructure, floor and roof : brick work in cement mortar, RCC Beam RCC roof, tiles flooring, etc,

VEL'S VIDYASHRAM
P.V. Vaithiyalingam Road, Pallavaram
CHENNAI-600 117

8) Period for which the license is required : 01-11-2023 to 31 -10-2026 (Three years)

9) Number of persons to be accommodated : 4000 Students

SIGNATURE OF OWNER OF BUILDING : SIGNATURE OF ENGINEER 11/10/2023

DESIGNATION

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

Certified that no thatched roof buildings are used for conducting classes in school premises. If any thatched buildings are constructed after the issue of this license, we are held responsible for any fire accident that occurs later and that I /We are aware that our license will be cancelled

SIGNATURE OF THE OWNER OF THE BUILDING

VEL'S VIDYASHRAM
P.V. Vaithyalingam Road, Pallavaram
CHENNAI-600 117

V. RAMACHANDRAN
B.E., (Civil), M.E., (Structures), M.Sc., (REV), F.I.V
Govt. Registered Valuer
Registered Panel Engineer Class IA
Chennai, Kancheepuram, Thiruvallur &
Chengalpattu Districts.

Superintending Engineer PWD (Retd.)
Govt. of Tamilnadu
No.7/8, Moogambigai Street, Jai Balaji Nagar,
Nesapakkam, Chennai - 600 078.
Cell : 94865 01083.
E-mail : r.chandran47@rediffmail.com

Date : .....

FORM -B

11-09-2023

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLICBUILDING (LICENSING) ACT 1965(TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966

CERTIFICATE OF STRUCTURAL SOUNDNESS

I certify that I have inspected the school building named VELS VIDYASHRAM, located at S.F.no 192/2,193/1,2,3,4,5,6,7,8&193/18, VelanNagar,P.V.Vaithiyalingam Road,Pallavaram,Chennai -600117 on 08-09-2023. I have satisfied myself that the building structurally sound to be used as a public building for the purposes noted in the statement. The structural soundness of the building has been verified taking into account the loading s per the latest Indian Standards IS:875.The scope of this stability certificate is limited only to the structural soundness of the building as per IS : 456-2000.This does not include the eventualities caused by natural calamities like cyclone , earthquake ,high gales & storms, lightening , floods, fire etc. A license may be granted for the period from 01-11-2023 to 31- 10- 2026 (Three Years) Certified that no thatched buildings are there for conducting classes in the school premises as on date of inspection.

11/9/2023

V. RAMACHANDRAN
B.E.(Civil), M.E.(Structural Engg.),F.I.V
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No. 7/8, Moogambigai Street,
Nesapakkam,
Chennai - 600 078.
Mobile: 94865 01083.

Signature of Engineer

A copy of approved plan, for K.G BLOCK, BLOCK 1 and SHIVALAYABlocks, was produced for inspection.
This certificate is issued based on the physical site inspection of the building.

VEL'S VIDYASHRAM
P.V. Vaithyalingam Road, Pallavaram
CHENNAI-600 117

6

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 1966

FOR NORTH SIDE END BLOCK IV

I Certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	hard gravelly soil & soft disintegrated rock.
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most critical section of masonry and concrete	:	Masonry 1.00 Kg/ sq.cm
	:	Concrete 40 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe permissible stress	:	Masonry 5 Kg / sq cm
	:	Concrete 70Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

11/09/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
7 / 8, Moogambigai Street,
Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083

VEL'S VIDYASHRAM
N.K. Vaidyalingam Road, Pallavaram
CHENNAI-600 117

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 196

FOR SOUTH SIDE END BLOCK IV

I certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	Hardgravelly soil & sdr
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most Critical ection of	:	Masonry 1.00 Kg/ sq.cm
masonry and concrete	:	Concrete 35 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe	:	Masonry 5 Kg / sq cm
permissible stress	:	Concrete 70Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

11/09/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
R.K. Vidyalaya Road, Pallavaram
CHENNAI-600 117

6

FORM-C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 1966

FOR SOUTH SIDE K.G. BLOCK

I Certify that I have inspected the building in the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	hard gravelly soil & soft disintegrated rock.
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most Critical section of masonry and concrete	:	Masonry 1.00 Kg/ sq.cm
	:	Concrete 40 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe permissible stress	:	Masonry 5 Kg / sq cm
	:	Concrete 70Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in statement. A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

11/9/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
P.V. Vallyammai Road, Pallavaram
CHENNAI-600 117

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 1966

FOR WEST SIDE K.G. BLOCK

I Certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	Hardgravelly soil & sdr.
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most Critical section of masonry and concrete	:	Masonry 0.75 Kg/ sq.cm
	:	Concrete 35 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe permissible stress	:	Masonry 5 Kg / sq cm
	:	Concrete 70Kg/sqcm

The structural soundness of the building has been verified by me with reference ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

11/09/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),F.I.V
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nasapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
N.K. Vittiplagam Road, Pallavaram
CHENNAI-600 117

10

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 1966

FOR NORTH SIDE K.G. BLOCK

I Certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	Hard gravelly soil &sdr.
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most critical section of masonry and concrete	:	Masonry 1.00 Kg/ sq.cm
	:	Concrete 40 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe permissible stress	:	Masonry 5 Kg / sq cm
	:	Concrete 70Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

11/09/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
P.V. Vittalapuram Road, Pallavaram
CHENNAI-600 117

11

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 1966

SHIVALAYA BLOCK

I Certify that I have inspected the building mentioned In the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	Hardgravelly soil & sdr.
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most critical section of masonry and concrete	:	Masonry 1.20 Kg/ sq.cm
	:	Concrete 40 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe permissible stress	:	Masonry 5 Kg / sq cm
	:	Concrete 70Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

11/9/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
P.V. Vaithiyalingam Road, Pallavaram
CHENNAI-600 117

12

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 1966

FOR NORTH SIDE END BLOCK I

I Certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	Hardgravelly soil & sdr
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most critical section of masonry and concrete	: Masonry	1.00 Kg/ sq.cm
	: Concrete	40 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe permissible stress	: Masonry	5 Kg / sq cm
	: Concrete	70Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

11/09/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),F.I.V
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
P.V. Vallyapuram Road, Pallavaram
CHENNAI-600 117

13

FORM - C

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB -SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING)ACT 1965 (TAMILNADU ACT13 OF1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDING (LICENSING) RULES 1966

FOR SOUTH SIDE END BLOCK I

I Certify that I have inspected the building mentioned in the statement and furnished below the salient technical features.

1. Foundation

i) Depth below ground level	:	6 ft
ii) Nature of soil met in the foundation level	:	hard gravelly soil & soft disintegrated rock.
iii) Pressure at foundation	:	within allowable limits.
iv) Probable safe bearing capacity of the strata met with at foundation	:	20 .00 tonnes/ Sq m

2. Superstructure

i) Maximum stress in the most critical section of masonry and concrete	:	Masonry 1.00 Kg/ sq.cm
	:	Concrete 40 Kg/ sq cm
ii) Nature of masonry and concrete and it's safe permissible stress	:	Masonry 5 Kg / sq cm
	:	Concrete 70Kg/sq cm

The structural soundness of the building has been verified by me with reference to ISI loading standards 875(latest version) and other relevant Indian standard code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A License may be granted for a period from 01-11-2023 to 31-10-2026 (Three Years)

Place: Chennai

Date: 11-09-2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),F.I.V
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nasrpakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
P.K. Vallyappan Road, Pallavaram
CHENNAI-600 117

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, door no, street name, & name of the place (1)	Age of building (2)	Value of the building (3)	no of storeys (4)	Short description RCC framed, or load bearing masonry (5)
VELS VIDYASHRAM Velan nagar, P.V.Vaithiyalingam Road,Pallavaram Chennai- 600117.	BLOCK I 25 years BLOCK II 19Years BLOCK III 27Years BLOCK IV 16Years	RS 2269akhs	G+ 2 G+ 2 G+2 G+2	Framed structure, column foundation, brick walls, RCC Beams, RCC Roof, tiles flooring etc

Purpose for which the building is certified for use (6)	The period for which the building will be structurally sound (7)	NO of persons to be accommodated (8)	Remarks
Educational purpose	01-11-2023 to 31-10-2026 (Three years)	4000 students	Building is structurally sound .

01/11/2023

SIGNATURE OF THE ENGINEER

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),F.I.V
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer. Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
P.V. Vaithiyalingam Road, Pallavaram
CHENNAI-600 117

form D

FORM - D

FORM OF LICENCE UNDER SUB-SECTION (1) OF SECTION 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) ACT, 1965 (TAMIL NADU ACT 13 OF 1965) REFERRED TO IN RULE 6 OF THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966

LICENCE

Licence No. **45/2020** **Date: 08-12-2023**

Public Building Licence is hereby granted to **Thiru Vels Vidyashram** care of Dr Ishari K Ganesh now residing at 1, P v vaithiyalingam road velan nagar JAMEEN PALLAVARAM Revenue Village, PALLAVARAM Taluk, Chengalpattu District - 600117 of Tamil Nadu State for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned hereunder,

STATEMENT TO ACCOMPANY THE LICENCE

Location of the Building (Door number, Street Number & Name of the Place)	Purpose for which the building is licensed to be used as public building	Number of persons to be accommodated
1 P v vaithiyalingam road velan nagar JAMEEN PALLAVARAM,PALLAVARAM, Chengalpattu,Tamil Nadu,600117	School(including tutorial school)	4000

Fee paid Rs. 1000.0 vide Challan No: 20231011010909, Dated: 11-10-2023

The Period of validity of the licence shall be from the 08-12-2023 to the 07-12-2026 inclusive

Signature valid
Digitally signed by T ARUMUGAM
Date: 08/12/2023 10:18:55 IST

District : Chengalpattu

LICENCE ISSUING AUTHORITY

This certificate is digitally signed and does not require any seal / signature in original.

Genuineness of the certificate can be verified by.

(a) Keying in the unique certificate number 45/2020 in the URL https://tnedistrict.tn.gov.in/tneda/VerifyCerti.xhtml .

(or)

(b) Reading the 2D barcode with mobile barcode reader and verify through online.

Certificate validity period : 08-12-2023 to 07-12-2026

S. Subha

15

FORM - E

FORM OF REPORT TO BE MADETO THE COMPETENT AUTHORITY BY THE INSPECTING AUTHORITIES OR OFFICERS APPOINTED UNDER OTHER ACT UNDER SECTION 28 TAMILNADU PUBLICBUILDINGS LICENSING ACT 1965 (TAMILNADU ACT13 OF 1965) REFERRED TO RULE 7 OF TAMILNADU PUBLIC BUILDINGS LICENSING RULES 1966

1. Name and designation of inspecting Authority	:	V.RAMACHANDRAN
or officer appointed or having jurisdiction	:	B.E (CIVIL) , M.E(STRUCTURALENGG)
any other act or law	:	F.I.V
	:	Superintending EngineerPWD(Retd)
	:	Government Registered
	:	Panel Engineer Class-1A
	:	CHENGALPATTU DISTRICT
	:	NO7/8 Moogambigai street,
	:	Jai Balaji Nagar, Nesapakkam,
	:	Chennai -600078,
	:	Mobile no - 9486501083
2. Location of the building inspected	:	VELS VIDYASHRAM
D.NO, Street No, name of place	:	Velan Nagar, P.V.Vaithiyalingam Road
i.e Municipal corporation/Municipality/ panchayat/	:	Pallavaram
Panchayat union/ township/ cantonment	:	Chennai - 600117
3. Date of inspection	:	08-09-2023
4. Purpose for which the building is used	:	Educational Purpose
5. Nature of defects noticed	:	Refer annex 2
6. Suggestion for rectifying defect	:	during maintenance should be taken care. by suitable plastering methods
7. If in a dangerous condition immediate action	:	No
Recommended to be taken.		

15/8/2023

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),F.I.V
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083

VELS VIDYASHRAM
P.V. Vaithiyalingam Road, Pallavaram
CHENNAI-600 117

16

Annexure -1

SL NO	NAME OF BUILDING			YEAR OF CONSTRUSTION	AGE OF BUILDING
1	BLOCK I SENIOR SECONDARY SCHOOL				
		Plinth area sq m	carpet area sq m		
	Ground floor (RCC Roof)	830	705.66	1998	25 years
	First floor(RCC Roof)	830	705.66	1999	
	Second floor (RCC Roof	830	705.66	2000	
		2490	2117		
2	BLOCK II SHIVALAYA BLOCK				
	Ground floor (RCCRoof)	949	806.66	2004	19 years
	First Floor (Rcc Roof)	949	806.66	2005	
	Second Floor (Rcc roof)	949	806.66	2006	
		2847	2420		
3	BLOCK III -K.G.BLOCK				
	Ground Floor (Rcc roof)	704	598.33	1996	
	First Floor (Rcc Roof)	704	598.33	1997	27 Years
	Second floor (Rcc roof)	704	598.33	1998	
		2112	1795		
4	BLOCK IV				
	Ground floor (Rccroof)	668.66	568.33	2007	16 years
	First floor (Rccroof)	668.66	568.33	2008	
	second floor (Rcc Roof)	668.66	568.33	2009	
		2006	1705		

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
24, Vittalapuram Road, Pallavaram
CHENNAI-600 117

17

ANNEXURE -2

Defects noticed during inspection of building

I) K.G BLOCK

1) In the Room no S 11 of second Floor north side the entire RCC beam has dampness. This should be attended in next maintenance work

V. RAMACHANDRAN
B.E.(Civil),M.E.(Structural Engg.),FIV
Superintending Engineer PWD (Retd)
Government Registered
Panel Engineer, Class - 1A,
Chennai & Kancheepuram District
No: 7 / 8, Moogambigai Street,
Jai Balaji Nagar, Nesapakkam,
Chennai - 600 078.
Mobile: 9486501083.

VEL'S VIDYASHRAM
CHENNAI-600 117