

Feasibility of Hybrid Renewable Energy Water Pumping System for a Small Farm in Egypt

N. M. Khattab^a, M. A. Badr^b, E. T. El Shenawy^{a*}, H. H. Sharawy^c and M. S. Shalaby^c

^a Solar Energy Department, National Research Centre, Egypt.

^b Mechanical Engineering Department, National Research Centre, Egypt.

^c Chemical Engineering & Pilot Plant Department, National Research Centre, Egypt.

Abstract

The design and evaluation of a stand-alone hybrid renewable energy system for pumping underground water for small farm irrigation is presented. Given environmental conditions, system specifications and daily load demand data, the optimal size of main system components are obtained using a sizing algorithm. Different renewable energy systems are compared using yearly simulations, on hourly base via specialized commercial software simulation packages PVSYST and HOMER to simulate the system performance and to reach the optimum configurations based on the objective criteria. The criteria used in economic optimization are the net present cost and the cost of energy, with the percent of the capacity shortage. The compared water pumping systems are; PV only, PV with horizontal axis wind turbine, PV with vertical axis wind turbine, PV with horizontal axis wind turbine and diesel generator and diesel generator only. The simulation also was carried out for different load patterns for optimum operation. The study was illustrated for climatic conditions of an isolated area in El-Tour City, Sinai, Egypt. The installed 3.42 kW PV water pumping system for irrigation purposes in the same site was also described.

Keywords: Solar water pumping; stand alone photovoltaic; wind turbine; renewable hybrid system; diesel generator.

INTRODUCTION

Egyptian Government has embarked an ambitious plan to develop new villages in the desert far from Nile River and Delta by reclaiming and cultivating five million acres over five years. The main challenge facing the government efforts is the inability of the current energy sources to provide those communities with the main infrastructures from energy and water to fulfill agriculture requirements. This is because these communities are small, scattered and located in the desert far from the electricity grid.

Hence, the Egyptian Government strategies targeted providing agriculture water requirements (pumping and irrigation) for new rural areas by applying renewable energy systems. Clean, renewable energies such as solar and wind are considered fast solutions to provide such communities with the energy necessities. The adopted approach has been motivated mainly by Egypt's location that is endowed with abundant solar energy, adequate average wind speed besides long sea shores and underground water.

Among the renewable energy options that are currently in wide use are solar photovoltaic (PV) and small wind turbines (WT) for water pumping and irrigation. Pumping water by

mechanical wind mills in remote areas is an old technology, [1, 2], and by renewable energy for the last few decades [3, 4]. Recently, many users of the water pumping have switched to solar energy via photovoltaic pumping for small systems, while for larger systems the diesel generations are still predominant for pumping water in Egypt, [5]. Compared to PV systems and mechanical wind mills, small wind turbines are still in limited uses for water pumping systems in remote areas. Using hybrid photovoltaic/wind turbine (PV/WT) improves the water pumping reliability and increases the daily volume of the pumped water.

Different studies concerning the individual PV water pumping (PVWP) and wind turbine water pumping (WTWP) systems focused on the dynamic performance of these systems, in particular the match between water demand and water supply [6]. Benghanem et al. [7] compared the performances of different PVWP configurations for different hydraulic heads. Kelley et al. [8] studied the feasibility of PVWP systems for irrigation as a function of location, while Rehman and Sahin, [9] investigated the technical and economic performances of several small WTs to provide water in Saudi Arabia.

The performances of PVWP and WTWP systems have also been compared. Kumar and Kandpal [10] assessed the potential of PVWP and WTWP systems for irrigation in India. Diaz-Mendez et al. [11] presented a simple methodology to compare PVWP and WTWP for irrigation of commercial greenhouses in Spain, Cuba and Pakistan. The study mainly focused on the economic comparison between PVWP and WTWP systems for irrigation for three specific locations with no indication to the match between water demand and water supply and the effect of water supply on the crop yield.

One of the most important limitation facing applications of renewable energies is that no individual source of solar or wind energies is capable of supplying both reliability and cost-effective due to the intermittent nature of them. Moreover, fluctuations in production and time-dependent are other challenges for renewable energy utilization. Flexible demand management, [12-14], and smart energy management, [15, 16], are useful, but they do not fully suffice in maintaining the balance between production and demand of electricity.

Hybrid PV/WT systems which optimize the contribution of solar and wind energy sources generation to provide continuous base requirements are the better solution of this problem. Using a hybrid solar/wind system helps to use solar energy in case of small wind speed and use wind energy in case of low solar radiation levels. Brian et al. [17] analyzed the operation of solar PV and wind turbine as individual systems as well as a PV/WT hybrid system as off-grid system

for pumping water. It was found that the hybrid system delivered more energy than only PV or wind by an amount of 28%. An additional buck/boost converter was also used as a controller to improve hybrid PV/WT water pumping system. Research developments in the field of renewable energy-water pumping systems are reviewed by Gopal et al. [18]. They briefly reviewed hundred of articles published in the water pumping systems and investigated five different system configurations with various types of energy; solar, wind, biomass, thermal and hybrid PV/WT. They concluded that using renewable energy (solar or wind or hybrid) highly reduces the dependence of conventional energy with good environmental impact. According to the meteorological data measured for the city of Xanthi, Greece and their systematic design approach for three different systems for water pumping which are; PV, WT and hybrid PV/WT, Skretas and Papadopoulos [19] concluded that the performance of hybrid system was better than that of solar or wind only.

Tao et al. [20] introduced a new solution of the problem concerning the energy storage in the renewable energy systems, especially in standalone systems. In that work, an important and most traditional storage technology was used, this is the pumped hydro storage (PHS) with a standalone renewable energy system (solar-wind). They developed a mathematical model for the hybrid solar-wind system and applied according to the operating parameters on a case study to feed the required energy to a remote area in Hong Kong and examined its technical feasibility. Time dependent simulation results showed that the inherent fluctuations nature of the renewable energy sources can be effectively compensated by applying the PHS technology. This can provided a reliable and clean energy source power supply. They concluded that hundred percent of the energy autonomy in remote and rural areas can be achieved by pumped hydro storage based hybrid renewable energy.

Many researchers used two public models for optimizing the hybrid renewable energy systems [21-23]. The first model was Hybrid Optimization Model of Electric Renewable (HOMER) and the second was Hybrid Solar-Wind System Optimization model (HSWSO) [24]. The second model mainly used when using a storage battery bank in the hybrid system. The optimization process of the hybrid systems concluded that using a storage tank for water storage is more cost effective than using a storage battery bank in hybrid solar-wind system, due to the higher maintenance and operation costs of the batteries and vice versa for the water storage.

Imene Yahyaoui et al. [25] optimized the design of a hybrid solar-wind-pumped storage system in standalone mode for an isolated area. The initial design process of the system's major components was presented, and optimized based on a techno-economic evaluation. The proposed design was evaluated using yearly simulations, on hourly base, performed by specialized commercial software, PVSYST.

A methodology for optimal sizing design and strategy control based on differential flatness approach was applied to the hybrid stand-alone PV/WT systems by Tégnia, et al [26]. The aim was to find, according to life time of the system provided that the required load energy is completely supplied by the system, the optimal design of the system components that ensure minimum system costs. The problem formulation

and the generic algorithm are used in optimization methodology to optimally configure the system and the results are obtained using Matlab/Simulink.

Therefore, the hybrid PV/WT system is usually installed to supply water in remote areas with considerably less costs and more reliable operation in case of inherent fluctuations of the renewable energy sources. The present study describes the main components of the installed stand-alone 3.42 kW PV water pumping system for irrigation purposes in El-Tour city, Sinai, Egypt. To investigate the feasibility of small, decentralized hybrid PV/WT system for water required for irrigation purposes, a theoretical comparison between different renewable energy systems for water pumping is carried out in the selected site based on using yearly simulations, on hourly base via specialized commercial software simulation packages PVSYST and HOMER, for optimum operation. The compared systems are; i) PV only, ii) PV with horizontal axis wind turbine (PV/HAWT), iii) PV with vertical axis wind turbine (PV/VAWT), iv) PV with horizontal axis wind turbine and diesel generator (PV/HAWT/D) and v) diesel generator only. The criteria used in economic optimization are the net present cost, the cost of energy with the amount of unmet load or percent of energy shortage. The optimization process was carried out for different load patterns.

INSTALLED PV WATER PUMPING SYSTEM

The installed small water pumping system is used to deliver water from a well for agriculture purposes in El-Tour city, Sinai, Egypt (latitude of 28.22° N and longitude of 33.61° E). The system consists of; the PV arrays, mechanical structure, pump controller and water pump. Figure 1 shows an overview of the installed water pumping system.

Table 1 shows the site parameters; air temperature, wind speed and solar radiation levels. From the table it is clear that the site has an annual average air temperature of 20.9 °C with low values of wind speed reaches maximum value of 7 m/s which can be considered considerably low levels of wind speed. Figure 2 shows irradiation levels on a horizontal and an optimally tilted surface (30 degree) in El-Tour, Sinai [27]. From table 1 and figure 2, it is clear that the location has highly irradiation levels all over the year with an annual average of 6.86 kWh/m²/day on an optimally tilted surface. This average value can be considered one of the highest irradiation levels all over the world.



Figure 1: Over view of the water pumping system.

Table 1: Air temperature, wind speed and solar radiation levels in El-Tour, Sinai.

Month	Air temperature °C	ir radiation on optimally tilted surface Wh/m ² /day	Wind speed m/s
January	11.8	5650	4.70
February	12.7	6520	5.00
March	16.2	7760	4.70
April	21.0	7190	6.00
May	24.7	7200	6.50
June	26.8	7350	6.00
July	28.2	7320	5.90
August	28.1	7430	7.00
September	26.4	7290	6.00
October	22.8	7010	5.30
November	18.1	6100	4.90
December	13.4	5510	4.30
Annual	20.9	6860	5.53




Figure 2: Irradiation levels on a horizontal and an optimally tilted surface in El-Tour, Sinai.

PV arrays

The PV system which is to drive the water pump motor, consists of 3.42 kW-PV power (18 PV modules) arranged in two parallel strings, each of them has 9 modules connected in series. According to this arrangement, the PV system gives operating voltage about 216 V and 16 A at standard test conditions (STCs; 1000 w/m² of irradiance, 25° of module temperature and 1.5 AM). Table 2 exhibits the characteristics of the used PV modules at STC, while Figure 3 shows the installation of these modules.

Table 2: Characteristics of the PV system.

Item	Specifications
Module power	190 W
Module cells	48 Cells
Number of modules	18 Modules
V _{OC}	29.76 V
I _{SC}	8.47 A
V _{MP}	24 V
I _{MP}	8.02 A

Mechanical structure

The mechanical structure is used to fix the PV system facing south at tilt angle of 30 degree on the horizontal surface for optimum irradiation collection over the year. The mechanical structure is made of galvanized aluminum rods fitted via aluminum joints supported on 8 concrete bases in order to ensure a stable and secure operation and to avoid vibrations or falling (figure 3). The mechanical structure must withstand the environmental conditions of higher temperatures, humidity and wind loads up to 15 m/s.



Figure 3: PV arrays of the water pumping system.

Pump controller

The pump controller is used to drive the pump electric motor via converting the input DC power from the PV arrays to the required AC power, voltages and currents suitable for the pump operation. The controller has many indicators to fully monitor the system operation. There are many protection features in the controller to safely start the pump at very low irradiation levels and protect it from vibrations and over load. Figures 4, 5 show the pump controller and the wiring diagram, respectively, while table 3 illustrates the controller's parameter specifications.




Figure 4: Pump controller.

Table 3: Parameters of the pump controller.

Parameter	Power kW	Input voltage V	Optimum voltage V	Motor current A	Efficiency %	Ambient temperature °C	Enclosure class	Weight kg
Specification	4	Max 375	238	Max 15	98	-30 to 50	IP54	9




Figure 5: Wiring diagram of the pump controller.

Water pump

The water pump is solar-operated submersible pump with maximum flow rate of 7 m³/h and maximum head of 140 m. The pump has maintenance-free brushless DC motor, has no electronics in the motor. The electrical parameters of the pump motor are given in table 4 while figure 6 illustrates the pump chart.

Table 4: Electrical parameters of the pump motor.

Parameter	Specification
Rated power	3.5 kW
Efficiency	92 %
Motor speed	900-3300 rpm
Enclosure class	IP 68
Submersion	max 250 m
Weight of motor and pump	18 kg




Figure 6: Solar pump chart.

OPTIMIZATION OF HYBRID PV/WT PUMPING SYSTEM

To reach optimum system configurations, alternative configurations supplying the estimated daily load pattern are used to simulate the system performance. The optimum system fulfills the load requirements within the acceptable percentage of unmet load which is one of the decision variables. Optimality condition is based on the objective minimum cost which is defined by two criteria; the first is the minimum net present cost (NPC) and the second is the cost of energy (COE) generated from the system.

Hourly load curve estimation

The daily quantity of water required for irrigation is about 50 m³ in summer and 42 m³ in winter. Water is pumped for seven hour on average. Thus the hourly pumped quantity is 7m³/hr for summer and 6m³/hr for winter. The submersed pump is installed at a distance 41 m from ground level, assuming that the tank is at 2 m above the ground, and then the total elevating head is 43 m. Then the electrical power required for water pumping for summer is about 1.5 kW and for winter 1.3 kW. The estimated hourly electrical load is shown in table 5.

Table 5: Hourly electric load of water pumping system.

Time (Hour)	Winter		Summer	
	Q (M ³ /hr)	K.W	Q (M ³ /hr)	K.W
10	3	0.65	3	0.65
11	6	1.3	7	1.5
12	8	1.7	10	2.14
13	8	1.7	10	2.14
14	8	1.7	10	2.14
15	6	1.3	7	1.5
16	3	0.65	3	0.65

For economic comparison purposes of the hybrid PV/WT pumping systems, 5 cases of the different investigated system configurations are simulated and analyzed using software packages PVSYST and HOMER. The proposed systems are as follows; i) PV system, ii) PV/HAWT, iii) PV/VAWT, iv) PV/VAWT/D and v) diesel only system. The simulation is also carried out for different load patterns.

RESULTS AND DISCUSSION

Case 1: PV only

In this case, the system used the PV arrays only to drive the pump via a converter. Four batteries (12 volts, 200 AH each) were included in the system simulation to control the energy shortage. The NPC and COE resulted from system simulation over 25 years are shown in table 6.

Table 6: NPC and COE of PV system for water pumping.

	PV (kW)	6FM200D	Conv. (kW)	Disp. Strgy	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Capacity Shortage
	3.3	4	5	CC	\$ 8,300	1,332	\$ 22,523	0.614	1.00	0.08
	3.3	4	5	LF	\$ 8,300	1,332	\$ 22,523	0.614	1.00	0.08

From table 6, the total NPC of the PV system is 22,523\$ and COE is 0.614\$/kWh. The capacity shortage is about 8% of the total load, although 4 batteries are included in the system simulation. Figures 7, 8 illustrate the cash flow and energy flow summaries of PV pumping system.




Figure 7: Cash flow summary of PV pumping system.

The cash flow summary shows that the capital cost of the PV modules is 5,000\$ and the O&M costs over 25 years lifetime is 5,337\$, this means that the total PV costs over the simulation period is 10,337\$. The batteries capital 1,800\$, replacement cost over system lifetime is 4,903\$ and batteries O&M cost is 2,135\$. Hence the total batteries cost is 8,711\$. This means that batteries total cost is about 38.7% of system total NPC. The energy summary (Figure 8) shows that although 4.7 % of the load is not supported (unmet load) about 31.6 % of the generated electricity is wasted (excess energy).




Figure 8: Energy summary of PV pumping system.

Case 2: PV/HAWT

The second case used hybrid PV arrays with 1 kW horizontal axis wind turbine to drive the pumping system via controller in addition to the 4 batteries used in case 1. The simulation was carried out for two cases according to the life time of the PV array (25 years) and lifetime of the wind turbine (15 years). The power curve of the used wind turbine is shown in figure 9. It is clear that the monthly average wind speed on site are 5.53 m/s (table 1) which is much lower than the

turbine rated wind speed about 10 m/s (figure 9), which is greatly affect to the performance of the used wind turbine and hence over all system economics.




Figure 9: Wind turbine power curve.

Tables 7, 8 show the simulation results of the PV/HAWT pumping system over 25 and 15 years, respectively. It is clear that the NPC of the system are 31,988\$ and 25,019\$ while the COE are 0.855\$/kWh and 0.834\$/kWh for both cases, which are higher than case of PV only (table 6). In other words, the PV system is more economic than PV/HAWT, due to the lower values of the monthly average wind speed on site than the turbine rated wind speed.

Table 7: Optimization results of hybrid PV/HAWT pumping system (25 years).

	PV (kW)	XL1	6FM2000	Conv. (kW)	Disp. Strgy	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Capacity Shortage
	3.3		4	5	CC	\$ 8,600	1,349	\$ 23,004	0.627	1.00	0.06
	3.3		4	5	LF	\$ 8,600	1,349	\$ 23,004	0.627	1.00	0.06
	3.3	1	4	5	CC	\$ 14,600	1,629	\$ 31,988	0.855	1.00	0.04
	3.3	1	4	5	LF	\$ 14,600	1,629	\$ 31,988	0.855	1.00	0.04

Table 8: Optimization results of hybrid PV/HAWT pumping system (15 years).

	PV (kW)	XL1	6FM2000	Conv. (kW)	Disp. Strgy	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Capacity Shortage
	3.3		4	5	CC	\$ 8,600	1,203	\$ 18,897	0.643	1.00	0.06
	3.3		4	5	LF	\$ 8,600	1,203	\$ 18,897	0.643	1.00	0.06
	3.3	1	4	5	CC	\$ 13,600	1,334	\$ 25,019	0.834	1.00	0.04
	3.3	1	4	5	LF	\$ 13,600	1,334	\$ 25,019	0.834	1.00	0.04

Figures 10,11 present the cash flow summary of the system simulation over 25 and 15 years while figure 12 illustrates the PV/HAWT system energy summary (25 years). It is clear that the operation of 15 years only saves the replacement of the wind turbine and reduces the system O&M costs. Figure 12 shows that about 44.2 % of the generated electricity is not used (excess energy) which may explain the increase in the COE while only 3.9% of capacity shortage of the load is not supported, which is less than that of PV system only (8.3%, figure 8).




Figure 10: Cash flow summary of PV/HAWT pumping system (25 years).




Figure 11: Cash flow summary of PV/HAWT pumping system (15 years).




Figure 12: Energy summary of PV/HAWT pumping system.

Case 3: PV/VAWT

For comparison between horizontal and vertical axis wind turbines, case 3 represented the water pumping system derived by PV arrays with vertical axis wind turbine via pump converter with the pre-described storage batteries. The system was simulated for 15 years. Table 9 exhibits the optimization results of system and figures 13,14 present the system cash flow summary and energy summary, respectively.

Table 9: Optimization results of PV/VAWT pumping system.

	PV (kW)	AS	6FM2000	Conv. (kW)	Disp. Strgy	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Capacity Shortage
	3.3		4	5	CC	\$ 8,600	1,203	\$ 18,897	0.643	1.00	0.06
	3.3		4	5	LF	\$ 8,600	1,203	\$ 18,897	0.643	1.00	0.06
	3.3	1	4	5	CC	\$ 13,600	1,195	\$ 23,825	0.790	1.00	0.03
	3.3	1	4	5	LF	\$ 13,600	1,195	\$ 23,825	0.790	1.00	0.03




Figure 13: Cash flow summary of PV/VAWT pumping system.




Figure 14: Energy summary of PV/VAWT pumping system.

Table 9 shows that the NPC of PV/VAWT is 23,285\$ and the COE is 0.790\$/kWh. The energy summary (figure 14) shows that the excess energy recorded in this case is about 49.6% (compared to 31.6% in case of PV system and 44.2% in case of PV/HAWT). In fact, the amount of increase in excess energy is almost equal to the energy generated from the wind turbine. Hence it is recommended to use this abandoned energy in elevating more water that could be used for irrigation or domestic use. In this case the COE generated from the PV/VAWT will be reduced. From figures 12, 14 it is clear that the capacity shortage are almost equals for both types of wind turbines (PV/HAWT, 3.9 and PV/VAWT, 3.1).

Case 4: PV/ HAWT/Diesel

Case 4 represents a PV array with HAWT with diesel generator to supply the required electrical energy for the water pumping system with the required pump converter with batteries. Table 10 shows the simulation results of the

proposed system for 15 years, while figures 15, 16 present the system cash flow summary and energy summary.

Table 10: Optimization results of PV/VAWT/Diesel pumping system.

	PV (kW)	XL1 (kW)	Label (kW)	6FM2000 (kW)	Conv. (kW)	Disp. Strgy	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Capacity Shortage	Diesel (L)	Label (hrs)
	3.3			4	5	CC	\$ 8,600	1,203	\$ 18,897	0.643	1.00	0.06		
	3.3			4	5	LF	\$ 8,600	1,203	\$ 18,897	0.643	1.00	0.06		
	3.3	1		4	5	LF	\$ 9,100	1,381	\$ 20,920	0.681	0.95	0.01	60	199
	3.3		1	4	5	CC	\$ 9,100	1,763	\$ 24,192	0.786	0.85	0.00	174	527
	3.3	1		4	5	CC	\$ 13,600	1,334	\$ 25,019	0.834	1.00	0.04		
	3.3		1	4	5	LF	\$ 13,600	1,334	\$ 25,019	0.834	1.00	0.04		
	3.3	1	1	4	5	LF	\$ 14,100	1,435	\$ 26,383	0.857	0.97	0.00	38	130
	3.3	1	1	4	5	CC	\$ 14,100	1,701	\$ 28,658	0.930	0.90	0.00	119	361




Figure 15: Cash flow summary of PV/HAWT/Diesel pumping system.




Figure 16: Energy summary of PV/HAWT/Diesel pumping system.

Table 10 showed that the NPC for PV/HAWT/Diesel system is 26,383\$ and COE is 0.857\$/kWh, which is slightly more than that of PV/VAWT or PV/HAWT and more high than that of PV system only (0.643\$/kWh). The energy summary (figure 16) also shows that the excess energy is about 43.9% of the generated electricity; hence the same recommendation of energy management applies. The great advantage of this system configuration is the smallest capacity shortage (0.4%).

Case 5: Diesel alone

For the sake of comparison, it was assumed that the required electrical energy for water pumping is supplied by a diesel

generator only. The length of the simulation run is 15 years. Table 11 presents the NPC and COE based on fuel price of 0.4\$/L. In fact, this case will differ as the price is expected to rise. Also the external cost (cost of CO₂ emissions) is not taken into consideration. Thus, the COE should be higher than the simulated values. Figures 17 and 18 present the system cash flow summary and energy summary.

Table 11: Optimization results of Diesel water pumping system.

Label (kW)	Disp. Strgy	Initial Capital	Operating Cost (\$/yr)	Total NPC	COE (\$/kWh)	Ren. Frac.	Capacity Shortage	Diesel (L)	Label (hrs)
4	CC	\$ 2,000	2,924	\$ 27,026	0.876	0.00	0.00	1,836	2,555




Figure 17: Cash flow summary of Diesel pumping system.




Figure 18: Energy summary of Diesel pumping system.

The total NPC of the diesel system is 27,026\$ which is considered the highest NPC of all previous systems. Comparing the COE in table 11 by COE generated by PV system and PV/WT systems (Tables 6-10), it is clear that the cost of electricity generated from diesel generator (\$0.876, table 11) is higher than PV alone (\$0.643, table 9) or PV/VAWT system (\$0.79, table 9). Figure 18 shows that although the diesel system has the highest NPC, the system satisfies zero shortage capacity.

Case 6: PV/HAWT for modified load pattern:

As it is clear from the above applied PV/WT systems, the excess energy represents a large amount of generated electricity that reached about 50% in one of the cases

(PV/VAWT). This should be handled through applying a load management policy. Hence the load pattern is modified and increased by 3.24 kWh/day distributed over 6 hours per day. The new load profile is presented in table 12 while the results of this run are illustrated in table 13 and figure 17.

Table 12: New load pattern.

Time (Hour)	Winter		Summer	
	Q (M ³ /hr)	K.W	Q (M ³ /hr)	K.W
7	3	0.65	3	0.65
8	3	0.65	4	0.86
9	3	0.65	4	0.86
10	6	1.3	4	0.86
11	7	1.5	7	1.5
12	8	1.7	10	2.14
13	8	1.7	10	2.14
14	8	1.7	10	2.14
15	6	1.3	7	1.5
16	3	0.65	4	0.86
17	0	0	3	0.65

Table 13: Optimization results of hybrid PV/VAWT pumping system for modified load pattern.




Figure 17: Cash flow summary of PV/HAWT pumping system with modified load pattern.

It could be seen in table 13 that COE is decreased from 0.834 \$/kWh (table 8) to 0.758 \$/kWh, NPC is 25,984. Table 13 shows that the peak load is 12 kWh/day; with peak of 3.8 kW. The excess energy decreased to 35.8% (was 44.2%) which is the cause of the decreased COE. Increasing the load another time by 0.1 kW the COE will be 0.678 \$/kWh with NPC is 25,883\$. Figure 18 illustrates the relation between the daily load in kWh and the cost of energy in \$/kWh.




Figure 18: Relation between daily load and cost of energy (COE)

CONCLUSIONS

The present paper illustrated the specifications of an installed PV water pumping system for agriculture purposes in El-Tour city, Sinai, Egypt. For economic comparison, the paper theoretically analyzed different renewable energy water pumping systems with different load patterns using commercial software. The systems using only PV power, PV/WT vertical and horizontal types with and without diesel generator. The systems contain storage batteries. The economical analysis was carried out based on the NPC and COE with system capacity shortage. The result of the analysis showed the following conclusions;

- The NPC and COE is lower in case of PV only and increased by using WT with PV system due to the lower wind speed rates in the specified location. The COE was 0.614\$/kWh for PV only, 0.834\$/kWh for PV/HAWT, 0.790\$/kWh for PV/VAWT, 0.857\$/kWh for PV/HAWT/Diesel and 0.876\$/kWh for diesel generator only. The external cost of CO₂ emissions is not taken into consideration which will raise the cost of energy generated from diesel alone system.
- The capacity shortage percent decreased with using diesel generator in the system, although the NPC increased. The capacity shortage was 8.3% for PV only, 3.9% for PV/HAWT, 3.1% for PV/VAWT, 0.4% for PV/HAWT/Diesel and zero for diesel system only.
- Monthly average wind speeds on the location are much lower than the turbine rated wind speed which leads to non optimal operation of the PV/WT. This leads to higher NPC and COE values. Also high percentage of excess energy is noticed in cases of PV/WT system which causes the increase of COE.
- Increasing the load during the periods of excess energy decreases the COE. Thus it is recommended to use abandoned energy in other optional loads.

REFERENCES

- [1] Nelson, V., 2009, "Wind Energy: Renewable Energy and the Environment". CRC Press, Publisher.

- [2] Nelson, V., Clark, R., Foster, R., 2004, "Wind Water Pumping". West Texas, A&M University-Alternative Energy Institute.
- [3] Foster, R., 2009, "Solar Energy: Renewable Energy and the Environment". CRC Press, Publisher.
- [4] Odeh, I., Yohanis, Y., Norton, B., 2006, "Influence of Pumping Head, Insolation and PV Array Size on PV Water Pumping System Performance", *Solar Energy*, 80, pp. 51-64.
- [5] Kamel, K., Dahl, C., 2005, "The Economics of Hybrid Power Systems for Sustainable Desert Agriculture in Egypt", *Energy*, 30, pp. 1271-1281.
- [6] Campana PE, Li H, Yan J., 2013, "Dynamic Modeling of a PV Pumping System with Special Consideration on Water Demand", *Applied Energy*, 112, pp. 635-645.
- [7] Benghanem M, Daffallah KO, Alamri SN, Joraid AA., 2014, "Effect of Pumping Head on Solar Water Pumping System", *Energy Conversion and Management*, 77, pp. 334-339.
- [8] Kelley LC, Gilbertson E, Sheikh A, Eppinger SD, Dubowsky S., 2010, "On the Feasibility of Solar-Powered Irrigation", *Renewable and Sustainable Energy Review*, 14, pp. 2669-2682.
- [9] Rehman S, Sahin AZ., 2012, "Wind Power Utilization for Water Pumping using Small Wind Turbines in Saudi Arabia: a Techno-Economical Review", *Renewable and Sustainable Energy Review*, 16, pp. 4470-4478.
- [10] Kumar A, Kandpal TC., 2007, "Renewable Energy Technologies for Irrigation Water Pumping in India: a Preliminary Attempt Towards Potential Estimation", *Energy*, 32, pp. 861-70.
- [11] Diaz-Mendez R, Rasheed A, Peillon M, Perdignes A, Sanchez R, Tarquis AM, 2014, "Wind Pumps for Irrigating Greenhouse Crops: Comparison in Different Socio-Economical Frameworks", *Biosystem Eng.*, 128, pp. 21-28.
- [12] Alberg Ostergaard P, Mathiesen BV, Moller B, Lund H., 2010, "A Renewable Energy Scenario for Aalborg Municipality Based on Low-Temperature Geothermal Heat, Wind Power and Biomass", *Energy*, 35, pp.4892-4901.
- [13] Lund H, Munster E., 2003, "Management of Surplus Electricity-Production from a Fluctuating Renewable-Energy Source", *Applied Energy*, 76, pp. 65-74.
- [14] Droste-Franke B, Paal B, Rehtanz C, Sauer D, Schneider J-P, Schreurs M, 2012, "Demand for Balancing Electrical Energy and Power: Balancing Renewable Electricity", Berlin, Heidelberg: Springer.
- [15] Ostergaard PA, Lund H. 2011, "A Renewable Energy System in Frederikshavn using Low-Temperature Geothermal Energy for District Heating", *Applied Energy*, 88, pp. 479-487.
- [16] Fraunhofer-Gesellschaft, 2014, "Managing Renewable Energy Intelligently", ScienceDaily. www.sciencedaily.com/releases/2014/03/140325094814.htm.
- [17] Brian D. Vick, Byron A. Neal, 2012, "Analysis of Off-Grid Hybrid Wind Turbine/Solar PV Water Pumping Systems", *Solar Energy*, 86(5), pp. 1197-1207.
- [18] Gopal C., Mohanraj M., Chandramohan P., Chandrasekar P., 2013, "Renewable Energy Source Water Pumping Systems: A Literature Review", *Renewable and Sustainable Energy Reviews*, 25, pp. 351-370.
- [19] Skretas SB, Papadopoulos DP. 2008, "Systematic Procedure for Efficient Design of Electric Water Pumping Systems Fed by PV or/and WECS: Application using Measured Meteorological Data for the City of Xanthi/Thrace, Greece", *Energy Conversion and Management*, 49, pp. 596-607.
- [20] Tao Ma, Hongxing Yang, Lin Lu, Jinqing Peng, 2014, "Technical Feasibility Study on a Standalone Hybrid Solar-Wind System with Pumped Hydro Storage for a Remote Island in Hong Kong", *Renewable Energy*, 69, pp. 7-15.
- [21] Zhou, W., Lou, Chengzhi, Li, Zhongshi, Lu, Lin, Yang, Hongxing, 2010, "Current Status of Research on Optimum Sizing of Stand-Alone Hybrid Solar-Wind Power Generation Systems". *Applied Energy*, 87, pp. 380-389.
- [22] Lilienthal P., 2005, "HOMER Micropower Optimization Model". NREL/CP-710-37606. 2005. <<http://www.homerenergy.com/>>.
- [23] Baring-Gould, I., 1998, "Hybrid2: The Hybrid System Simulation Model Version 1.1". Users Manual. NREL/TP-440-21272. DE96007901. <http://www.umass.edu/windenergy/research.topics.to ols.software.hybrid2.php>.
- [24] Yang H., Lu L., Zhou W., 2007, "A Novel Optimization Sizing Model for Hybrid Solar-Wind Power Generation System", *Solar Energy*, 81, pp. 76-84.
- [25] Imene Yahyaoui, Giuseppe Tina, Maher Chaabene, Fernando Tadeo, 2015, "Design and Evaluation of a Renewable Water Pumping System", *IFAC-Papers On Line* 48-30: 462-467.
- [26] Tégnia I., Abouboua A., Ayad M.Y., Becherifc M., Saadia R. and Kraaa O., 2014, "Optimal Sizing Design and Energy Management of Stand-Alone Photovoltaic/Wind Generator Systems", *Energy Procedia*, 50, pp. 163-170.
- [27] <http://re.jrc.ec.europa.eu/pvgis/apps4/pvest.php?map=africa>.