



BETTER NEPAL

🔍 Search incidents, reports, teams...



R. Adhikari (Admin) - NEA Lalitpur ▾

INCIDENT MEDIA: EL-2026-00482



Source: Citizen Report | Date: 2026-10-26 | Location: Ward 8, Patan, Lalitpur

TRANSFORMER FAILURE - LALITPUR
(EL-2026-00482)

Type: Infrastructure Failure (Power) **Status:** Ajarola
Status: In Progress **Priority:** NisA Lalitmara
Assigned: NEA Lalitpur Division **Priority:** High



Citizen report

Reported 09:30 AM



AI-assisted classification

Classified as Equipment Failure
09:35 AM

Authority verification

Verified by NEA Lalitpur
10:15 AM

Repair in progress

Dispatched Team Alpha-04 10:30 AM
Estimated Completion 18:00 PM

AI-ASSISTED ANALYSIS



87%

CONFIDENCE RATING
Classification accuracy

ASSESSMENT

Insulator failure causing short circuit.

Recommended Action: Replace unit and insulators.**Priority:** HIGH

FIELD TEAM MANAGEMENT

Team Alpha-04

STATUS: ON SITE

ETA:

Est. Completed by
18:00 PM

MEMBERS:

Rajesh Sharma (Lead)
Sita Tamang (Technician)
Hari Thapa (Electrician)