

REPORT OF EXAMINATION OR TEST OF PRESSURE VESSELS OR PLANT

Registration Number: EKM/03/485/06

NIC Code Number : 15495

(As given in the licence): -----

1. Occupier (or owner) of premises : The Director
2. Address : M/s Symega Savoury Technologies
Pancode, Vadavacod P.O, Puthen Cruz,
Ernakulam
3. Name , description and distinctive number of Pressure Vessel or Plant : S.S vertical olive resin tank (SS304) maximum working pressure of 5 Kg/cm² tank capacity 50 liters, blender,(No. BL 6).
4. Name and address of Manufacturer : M/s Axel.
5. Nature of process (Including temperature and Pressure Parameters) : Used for transferring resins to the blender BL-6 at a pressure of 5 Kg/cm².
6. Particulars of pressure vessel or plant
 - a) Date of construction 2018
 - b) Thickness of Walls 5.2 mm
 - c) Date on which it was first taken in to use 2018
 - d) Safe working pressure recommended by the manufacturer 5 Kg/cm²
7. Date of
 - a) Last external examination 2018
 - b) Last internal examination 2018
 - c) Last hydraulic examination 2018
 - d) Last ultra-sonic or other non-destructive test 2018
8. Whether lagging was removed for purposes of examination N.A
9. Description of examinations carried out and findings
 - a) External examination (give reasons if it is not carried out six monthly) Conducted external examination and found satisfactory.
 - b) Internal examination (give reasons if it is not carried out annually) - Conducted and found satisfactory
 - c) Hydraulic test (give reasons if this is not carried out at interval of 2 or 4 years) Conducted on 7-3-2019 at a pressure of 12 Kg/cm²
 - d) Ultrasonic or other non-destructive test Conducted NDT and found the wall thickness 5 mm.

(Contd...2)

10. Condition of pressure plants

- a) Vessel
- b) Piping

11. Condition of fittings and appliances-

- a) Pressure gauges
- b) Safety valve
- c) Stop Valve
- d) Reducing Valve (give reasons if not necessary)
- e) Additional safety valve (required in case reducing valve is necessary)
- f) Other devices (please specify particularly in case of jacketed vessels)

12. Safe working pressure recommended after examination (specify the Allowances made for conditions of working such as heat, corrosion etc.)

13. a) Repairs (if any) required

b) Period within which the repairs should be executed

c) Any other condition which the person making the examination thinks if necessary for securing

14. Specify reduced working pressure pending repairs

15. Safe working pressure calculated as per methods given in sub rule 8 for thin walled pressure vessel or plant.

16. Other Observations

Satisfactory.
Satisfactory

Working condition
Satisfactory
Working condition

Not exceed the pressure of 5 Kg/cm².

Not now, only preventive maintenance is recommended.

Recommended to check the pipe joint, safety valve periodically.

Conducted hydrostatic pressure test on 7-3-2019 at a pressure of 12 Kg/cm².

I/we certify that on 7-3-2019, the Pressure Vessel or Plant described above was thoroughly cleaned and (so far its construction permits) made accessible for thorough examination and for such tests as were necessary for thorough examination and that the above is a true report of my examination. The validity of this certificate is for one year from the date of inspection.

ER. G.S. Kamath BSc
(Engg)
Chief Executive
Mastec Engineers

Date: 10-3-2019

Er. S. Madhusoodhanan (B.Tech,
MIE, FIV) Chartered Engineer,
Senior Mechanical Engineer &
Executive Officer
Mastec Engineers

Er. K.Narayana Kurup, (B.Tech,
(Mech), MIE, FIV) Signature &
Name of the Competent Person
(Approved Competent Person for
inspection, testing of Pressure
Vessels/ Plant and Lifting Tackles)

Number & date of the Competency Certificate Registration No. 27/I/M/DF&B, Date :06-12-2018.
Issued by : Govt. OF KERALA (Dept : of Factories & Boilers). Valid from 05-11-2018 to 04-11-2019

MASTEC ENGINEERS
147-CURZON NAGAR
KACHERI WARD, KOLLAM-691013
KERALA STATE

Office Ph : 0474-2741309
Mobile : 09895994192
09447230244
Res:-0474-2796919
Email:-mastecklm@gmail.com