



CYRUSTM ELECTRONICS PVT. LTD.

SERVICE REPORT

A-190860

Lucknow Office

Regd. Off : Cyrus House, B-44/69 Sector Q,
Aliganj, Lucknow -24

Ph. : (0522)2746916, 4026916

Fax : (0522) 4075916

e-mail : admin@cyruselectronics.co.in

Code - CEP **56621** A

Alarm/AD/BACS/

Fire Division

Gorakhpur Office:

Works : Opp. Old Parcel Office, Station Road,
Gorakhpur -09

Ph. (0551)2200916, 201916

Arrival Time **03:00 PM**

Departure Time **4:00 PM**

M/s **Canara Bank** Date **25 Oct 22**

Phone **0522134 @ Canara Bank, Gm** Mobile **9878802134**

GADGET : Alarm ☒ AD ☒ Access ☒ Fire ☒

Control Pane Make **DI Guard MC**

Alarm/ AD

Switches No. **07** Magnetic Switches **X**

PIR **01** LDR **X**

BACS

REX Switch **X** EML **X**


Fire

Optical **X** Heat **X** MCP **X**

Others (Name, Qty)

Mandatory Service (Compulsory)

1. Checked Equipment from all switches/Sensors
2. Checked equipment on Battery mode
3. Checked Voice Recording
4. Updated Sticker with numbers stored



Problem Found

New Equipment ~~Installed~~ **Revised** Qty.

12 Volt Battery Qty. **01R**

Service/Work Done

Security Alarm System
Found working when check
the system. But Battery
is faulty. new Battery
Revised

Pending Work

Old Equipment Removed

Qty.

SYSTEM OK YES ☒ NO ☒

- Please put time of arrival, departure and date of visit at the time of signing.
- All Payments Should be made by Demand Draft

Branch Remark

PLEASE DO NOT PAY IN CASH

Satisfactory **REDMI NOTE 9 PRO MAX**

AI QUAD CAMERA

Signature Technician

Date

Verified and found the system working



Signature with rubber stamp