



# CYRUS<sup>TM</sup> ELECTRONICS PVT. LTD.

## SERVICE REPORT

Lucknow Office

Regd. Off : Cyrus House, B -44/69 Sector Q,

Aliganj, Lucknow -24

Ph. : (0522)2746916, 4026916

Fax : (0522) 4075916

e-mail : admin@cyruselectronics.co.in

Code - CEP **57266**

A

Gorakhpur Office:

Works : Opp. Old Parcel Office, Station Road,

Gorakhpur -09

Ph. (0551)2200916, 201916

**Alarm/AD/BACS/**

**Fire Division**

Arrival Time **1:15 PM**

Departure Time **2:15 PM**

Ws **Bank of maharashtra** Date **14/12/2021**  
**Rajendra Prasad**  
 Phone **9953109066** Mobile **9953109066**

GADGET : Alarm ☒ AD ☒ Access ☒ Fire ☒  
 Control Pane Make **FALCON**  
 Alarm/ AD  
 Switches No. **1** Magnetic Switches **2**  
 PIR **2** LDR **X**  
 BACS  
 REX Switch **X** EML **X**  
 Fire  
 Optical **X** Heat **X** MCP **X**  
 Others (Name, Qty)

### Mandatory Service (Compulsory)

1. Checked Equipment from all switches/Sensors ☒
2. Checked equipment on Battery mode ☒
3. Checked Voice Recording ☒
4. Updated Sticker with numbers stored ☒

### Problem Found

**5 Panic switch not ok**

### New Equipment Installed

Qty.

### Service/Work Done

**आग का बुझाना**  
**Alarm system check किया**  
**आग है Alarm system के 5**  
**Panic switch not ok है आग**  
**आग के 5 Panic Switches की**

### Pending Work

**Gomti wiring की**  
**जाता है**

### Old Equipment Removed

Qty.

SYSTEM OK YES ☒ NO ☒

- Please put time of arrival, departure and date of visit at the time of signing.
- All Payments Should be made by Demand Draft

Branch Remark

PLEASE DO NOT PAY IN CASH  
 Satisfactorily **Signature**

Signature Technician

Verified and found the system working

Date **14/12/21**

Signature with rubber stamp

**9953109066**

