



CYRUSTM ELECTRONICS PVT. LTD.

SERVICE REPORT

C-89958

Lucknow Office

Regd. Off : Cyrus House, B-44/69 Sector Q,

Aliganj, Lucknow -24

Ph. : (0522)2746916, 4026916

Fax : (0522) 4075916

e-mail : admin@cyruselectronics.co.in

Code - CEP 56531 A

Alarm/AD/BACS/

Fire Division

Gorakhpur Office:

Works : Opp. Old Parcel Office, Station Road,

Gorakhpur -09

Ph. (0551)2200916, 201916

Arrival Time

Departure Time

M/s <u>Cyralpa Bank</u> Date <u>10/11/2021</u>	
Phone <u>Mithrajyadhi</u> Mobile <u>9815002108</u>	
GADGET : Alarm <input checked="" type="checkbox"/> AD <input checked="" type="checkbox"/> Access <input checked="" type="checkbox"/> Fire <input checked="" type="checkbox"/>	
Control Pane Make <u>N.S.E</u>	
Alarm/ AD	
Switches No. <u>5</u>	Magnetic Switches <u>X</u>
PIR <u>1</u>	LDR <u>X</u>
BACS	
REX Switch <u>X</u>	EML <u>X</u>
Fire	
Optical <u>X</u>	Heat <u>X</u> MCP <u>X</u>
Others (Name, Qty)	
Service/Work Done	
<u>At the n carpenter at</u>	
<u>door of shop suitably</u>	
<u>of wiring check and</u>	
<u>all the wires are okay</u>	
Pending Work	
Old Equipment Removed	
Qty.	
New Equipment Installed	
Qty.	
Mandatory Service (Compulsory)	
1. Checked Equipment from all switches/Sensors <input checked="" type="checkbox"/>	
2. Checked equipment on Battery mode <input checked="" type="checkbox"/>	
3. Checked Voice Recording <input checked="" type="checkbox"/>	
4. Updated Sticker with numbers stored <input checked="" type="checkbox"/>	
Problem Found	
<u>Wiring was cutted due</u>	
<u>to carpenter work</u>	
Branch Remark	
<u>one person's name</u>	
<u>has been found the system working</u>	

SYSTEM OK

YES

☒

NO

☒

• Please put time of arrival, departure and date of visit at the time of signing.

• All Payments Should be made by Demand Draft

Verified and found the system working

PLEASE DO NOT PAY IN CASH

Satisfactorily