REQUEST FOR INFORMATION

RFI-014

Project: Project Alpha - Harbor View Clinic Fit-Out
Raised by: Tomas Reyes (Contractor)
Date raised: 2026-07-28

Question

Drawing A-102 Rev B shows the Level 2 store-room partitions as standard walls, but the store rooms hold oxygen cylinders. Please confirm the required fire rating.

Response (Design consultant)

Provide 1-hour fire-rated partitions to the store rooms (40 m2). See A-102 Rev C to be issued 5 Aug 2026.

Date of response: 2026-08-04

SYNTHETIC TEST DATA - fictional parties and amounts - Foreman hackathon testing only