REQUEST FOR INFORMATION

RFI-017

Project: Project Alpha - Harbor View Clinic Fit-Out
Raised by: Tomas Reyes (Contractor)
Date raised: 2026-09-21

Question

Relocated corridor lighting on E-301 Rev C clashes with the Level 1 ceiling ducts on M-201 Rev B. Please advise.

Response (Design consultant)

Re-route ducts as shown on M-201 Rev C (to be issued 25 Sep 2026). Submit any cost as a Change Order.

Date of response: 2026-09-25

SYNTHETIC TEST DATA - fictional parties and amounts - Foreman hackathon testing only