

BEAM REINFORCEMENT CHECK REPORT

Input Parameters:

Concrete Strength f_c' = 28 MPa
Rebar Strength f_y = 420 MPa
Framing System: Intermediate Moment Resisting Frame (IMRF)

FB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (ρ) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
7a-7a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206
7b-7b	102 (Passed)	128	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2962 Right: N/A (Passed)	1220	102 (Passed)	277	Passed $M_n,l+ \geq M_n,l-/3$: 768 $\geq$ 256 sq. mm $M_n,r+ \geq M_n,r-/3$: 768 $\geq$ 256 sq. mm min $M_n- \geq$ max $A_s/5$: 568 $\geq$ 154 sq. mm min $M_n+ \geq$ max $A_s/5$: 768 $\geq$ 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1193 (Failed)	1220	102 (Passed)	277	Passed $M_n,l+ \geq M_n,l-/3$: 768 $\geq$ 256 sq. mm $M_n,r+ \geq M_n,r-/3$: 768 $\geq$ 256 sq. mm min $M_n- \geq$ max $A_s/5$: 568 $\geq$ 154 sq. mm min $M_n+ \geq$ max $A_s/5$: 768 $\geq$ 154 sq. mm

3	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
---	-----------------------------------	----	---------------------------------------	------	-----------------	-----	--

FB2(12" x 24") ALONG GRID-A Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
8a-8a	102 (Passed)	128	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206
8b-8b	152 (Failed)	128	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 189 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1195 Right: 1195 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 189 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

FB2(12" x 24") ALONG GRID-B Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
9a-9a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206
9b-9b	152 (Failed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 3156 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

FB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
10a-10a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206
10b-10b	102 (Passed)	128	Top: 0.00413 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 256 sq. mm min Mn- >= max As/5: 1168 >= 154 sq. mm min Mn+ >= max As/5: 1000 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 1000 >= 154 sq. mm

FB2(12" x 24") ALONG GRID-D Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
11a-11a	102 (Passed)	128	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206
11b-11b	152 (Failed)	128	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 768 >= 170 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 2250 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 768 >= 170 sq. mm

FB2(12" x 24") IN BETWEEN GRID 4~6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
12a-12a	102 (Passed)	128	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1825 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

FB2(12" x 24") IN BETWEEN GRID 3~4 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
13a-13a	102 (Passed)	128	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2250 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

FB1(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	As Per BNBC
14a-14a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)		0.00333 ~ 0.0206
14b-14b	152 (Failed)	128	Top: 0.00305 Bottom: 0.00413 (Failed)		0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

3	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
4	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

GB1(14" x 26") ALONG GRID-1 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00255 Bottom: 0.00170 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1320	102 (Passed)	290	Passed Mn,l+ >= Mn,l-/3: 400 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 400 >= 200 sq. mm min Mn- >= max As/5: 400 >= 120 sq. mm min Mn+ >= max As/5: 400 >= 120 sq. mm

GB1(14" x 26") ALONG GRID-2 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00255 Bottom: 0.00170 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1320	102 (Passed)	290	Passed Mn,l+ >= Mn,l-/3: 400 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 400 >= 200 sq. mm min Mn- >= max As/5: 400 >= 120 sq. mm min Mn+ >= max As/5: 400 >= 120 sq. mm

GB1(14" x 26") ALONG GRID-3 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
3a-3a	102 (Passed)	144	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1320	102 (Passed)	288	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

GB1(14" x 26") ALONG GRID-4 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	
3a-3a	102 (Passed)	144	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0206	

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	-	-	Left: N/A Right: N/A (N/A)	1320	102 (Passed)	288	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

GB1(14" x 26") ALONG GRID-5 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
4a-4a	102 (Passed)	128	Top: 0.00327 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0206
4b-4b	152 (Failed)	128	Top: 0.00242 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2212 Right: N/A (Passed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 852 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 256 sq. mm min Mn- >= max As/5: 568 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1297 Right: 1297 (Failed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 852 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 256 sq. mm min Mn- >= max As/5: 568 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

GB1(14" x 26") ALONG GRID-6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
5a-5a	102 (Passed)	128	Top: 0.00363 Bottom: 0.00363 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1320	102 (Passed)	288	Passed Mn,l+ >= Mn,l-/3: 852 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

GB1(14" x 26") ALONG GRID-7 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
6a-6a	102 (Passed)	144	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2962 Right: N/A (Passed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1193 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm
3	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

GB2(14" x 26") ALONG GRID-A Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
7a-7a	102 (Passed)	144	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	

1	Left: 50 Right: 50 (Passed)	50	Left: 1309 Right: 1309 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

GB2(14" x 26") ALONG GRID-B Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
8a-8a	102 (Passed)	128	Top: 0.00363 Bottom: 0.00363 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1309 Right: 1309 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 852 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 3156 Right: N/A (Passed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 852 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

GB2(14" x 26") ALONG GRID-D Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
10a-10a	102 (Passed)	128	Top: 0.00327 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0206
10b-10b	152 (Failed)	128	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 568 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 568 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 568 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 568 >= 154 sq. mm

GB2(14" x 26") ALONG GRID-E Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
11a-11a	102 (Passed)	128	Top: 0.00327 Bottom: 0.00327 (Failed)	0.00333 ~ 0.0206
11b-11b	152 (Failed)	128	Top: 0.00327 Bottom: 0.00327 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
3	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
4	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

FB1(12"X24") ALONG GRID-1 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 852 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

FB1(12" x 24") ALONG GRID-2 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 852 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

FB1(12" x 24") IN BETWEEN GRID-B~C Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
3a-3a	102 (Passed)	128	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 852 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 284 sq. mm min Mn- >= max As/5: 1252 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

FB1(12"X24") ALONG GRID-3 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
3a-3a	102 (Passed)	128	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 852 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 284 sq. mm min Mn- >= max As/5: 1252 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

FB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
4a-4a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206
4b-4b	152 (Failed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 1000 >= 120 sq. mm

FB1(12" x 24") ALONG GRID-5 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	
5a-5a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00458 (Passed)	0.00333 ~ 0.0206	

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2212 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 852 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 256 sq. mm min Mn- >= max As/5: 768 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

FB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
6a-6a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r/3: 768 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
7a-7a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206
7b-7b	102 (Passed)	128	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2962 Right: N/A (Passed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1193 (Failed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
3	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB2(12" x 24") ALONG GRID-A Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
8a-8a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0206
8b-8b	152 (Failed)	128	Top: 0.00322 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 568 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 1336 >= 120 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1195 Right: 1195 (Failed)	1220	152 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 568 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 1336 >= 120 sq. mm

2FB2(12" x 24") ALONG GRID-B Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
9a-9a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206
9b-9b	152 (Failed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2	Left: 50 Right: 50 (Passed)	50	Left: 3156 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
---	-----------------------------------	----	--------------------------------------	------	-----------------	-----	--

2FB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
10a-10a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206
10b-10b	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 1000 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB2(12" x 24") ALONG GRID-D Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
11a-11a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206
11b-11b	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 2250 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB2(12" x 24") IN BETWEEN GRID 4~6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
12a-12a	102 (Passed)	128	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1825 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

2FB2(12" x 24") IN BETWEEN GRID 3~4 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
13a-13a	102 (Passed)	128	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: N/A Right: N/A (N/A)	1220	102 (Passed)	275	Failed Mn,l+ >= Mn,l-/3: ? >= ? sq. mm Mn,r+ >= Mn,r-/3: ? >= ? sq. mm min Mn- >= max As/5: ? >= ? sq. mm min Mn+ >= max As/5: ? >= ? sq. mm
2	-	-	Left: 2250 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/3: 568 >= 189 sq. mm Mn,r+ >= Mn,r-/3: 568 >= 189 sq. mm min Mn- >= max As/5: 568 >= 114 sq. mm min Mn+ >= max As/5: 568 >= 114 sq. mm

2FB1(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
14a-14a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206
14b-14b	152 (Failed)	128	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
3	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm
4	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB1(12"X24") ALONG GRID-1 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB1(12" x 24") ALONG GRID-2 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB1(12" x 24") IN BETWEEN GRID-B~C Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
3a-3a	102 (Passed)	128	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 768 >= 170 sq. mm

2FB1(12"X24") ALONG GRID-3 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	
3a-3a	102 (Passed)	128	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206	

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 284 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 284 sq. mm min Mn- >= max As/5: 852 >= 170 sq. mm min Mn+ >= max As/5: 768 >= 170 sq. mm

2FB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
4a-4a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0206
4b-4b	152 (Failed)	128	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 256 sq. mm min Mn- >= max As/5: 568 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB1(12" x 24") ALONG GRID-5 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
5a-5a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2212 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 768 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 768 >= 200 sq. mm min Mn- >= max As/5: 600 >= 154 sq. mm min Mn+ >= max As/5: 768 >= 154 sq. mm

2FB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	
6a-6a	102 (Passed)	128	Top: 0.00413 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206	

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 256 sq. mm min Mn- >= max As/5: 768 >= 154 sq. mm min Mn+ >= max As/5: 600 >= 154 sq. mm

GB2(14" x 26") ALONG GRID-C Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
9a-9a	102 (Passed)	128	Top: 0.00327 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0206
9b-9b	102 (Passed)	128	Top: 0.00242 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1694 Right: N/A (Passed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 852 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 256 sq. mm min Mn- >= max As/5: 568 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 1102 Right: N/A (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/3: 852 >= 256 sq. mm Mn,r+ >= Mn,r-/3: 852 >= 256 sq. mm min Mn- >= max As/5: 568 >= 170 sq. mm min Mn+ >= max As/5: 852 >= 170 sq. mm

LB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1150 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

LB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	-	-	Left: N/A Right: N/A (N/A)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

LB1(12" x 24") ALONG GRID-E & IN BETWEEN GRID 4~6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)		0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1815 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

SB2(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

SB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

SB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206	

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

SB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

WB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

WB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)		0.00333 ~ 0.0206

Span Checks:

Span	Max 1st StIRRup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan StIRRup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

WB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	-	-	Left: N/A Right: N/A (N/A)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

WB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

WB2(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Max Hoop Spacing at Support Check (BNBC 8.3.10.4(b))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))		
	Provided (mm)	As Per BNBC (mm)	Provided	As Per BNBC	As Per BNBC
1a-1a	102 (Passed)	128	Top: 0.00322 Bottom: 0.00322 (Failed)		0.00333 ~ 0.0206

Span Checks:

Span	Max 1st Stirrup Position from Support (BNBC 8.3.10.4(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.10.4(b))		Max MidSpan Stirrup Spacing (BNBC 8.3.10.4(c))		Moment Strength Check (BNBC 8.3.10.4(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm
2	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/3: 600 >= 200 sq. mm Mn,r+ >= Mn,r-/3: 600 >= 200 sq. mm min Mn- >= max As/5: 600 >= 120 sq. mm min Mn+ >= max As/5: 600 >= 120 sq. mm

Parsing Notes (162)

- FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-B | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-D | Stirrup zone length < 2h (1220mm)
- FB1(12" x 24") ALONG GRID-E | Stirrup zone length < 2h (1220mm)
- GB1(14" x 26") ALONG GRID-5 | Stirrup zone length < 2h (1320mm)
- GB1(14" x 26") ALONG GRID-7 | Stirrup zone length < 2h (1320mm)
- GB1(14" x 26") ALONG GRID-7 | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-A | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-A | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-B | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-D | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-E | Stirrup zone length < 2h (1320mm)
- FB1(12" x 24") ALONG GRID-4 | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-B | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-D | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-E | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-4 | Stirrup zone length < 2h (1220mm)
- GB2(14" x 26") ALONG GRID-C | Stirrup zone length < 2h (1320mm)
- LB1(12" x 24") ALONG GRID-6 | Stirrup zone length < 2h (1220mm)
- SB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- SB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- WB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- WB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- sec A1-A1 | No rebar circles found
- sec A-A | No rebar circles found
- sec C-C | No rebar circles found
- sec 1a-1a | Top reinforcement ratio is outside permitted limits
- sec 1a-1a | Bottom reinforcement ratio is outside permitted limits
- sec 1b-1b | Top reinforcement ratio is outside permitted limits
- sec 1b-1b | Bottom reinforcement ratio is outside permitted limits
- sec 2a-2a | Bottom reinforcement ratio is outside permitted limits
- sec 2b-2b | Stirrup spacing exceeds maximum allowed (support/end section)
- sec 2b-2b | Top reinforcement ratio is outside permitted limits
- sec 2b-2b | Bottom reinforcement ratio is outside permitted limits
- sec 3a-3a | Top reinforcement ratio is outside permitted limits
- sec 3a-3a | Bottom reinforcement ratio is outside permitted limits
- sec 4a-4a | Top reinforcement ratio is outside permitted limits
- sec 4b-4b | Stirrup spacing exceeds maximum allowed (support/end section)
- sec 4b-4b | Top reinforcement ratio is outside permitted limits
- sec 6a-6a | Top reinforcement ratio is outside permitted limits
- sec 6a-6a | Bottom reinforcement ratio is outside permitted limits

- sec 7a-7a | Top reinforcement ratio is outside permitted limits
- sec 7a-7a | Bottom reinforcement ratio is outside permitted limits
- sec 9a-9a | Top reinforcement ratio is outside permitted limits
- sec 9b-9b | Top reinforcement ratio is outside permitted limits
- sec 10a-10a | Top reinforcement ratio is outside permitted limits
- sec 10a-10a | Bottom reinforcement ratio is outside permitted limits
- sec 10b-10b | Stirrup spacing exceeds maximum allowed (support/end section)
- sec 10b-10b | Top reinforcement ratio is outside permitted limits