

BEAM REINFORCEMENT CHECK REPORT

Input Parameters:

Concrete Strength $f_c' = 28$ MPa
Rebar Strength $f_y = 420$ MPa
Framing System: Special Moment Resisting Frame (SMRF)

FB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
7a-7a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250
7b-7b	305 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2962 (Passed)	2218	Left: 50 Right: 50 (Passed)	50	Left: 2962 Right: N/A (Passed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	3564 (Passed)	2218	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1193 (Failed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

3	3668 (Passed)	2218	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
---	------------------	------	-----------------------------------	----	---------------------------------------	------	-----------------	-----	--

FB2(12" x 24") ALONG GRID-A Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
8a-8a	305 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 – 0.0250
8b-8b	305 (Passed)	250	152 (Failed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4587 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 284 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	3706 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1195 Right: 1195 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 284 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

FB2(12" x 24") ALONG GRID-B Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
9a-9a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250
9b-9b	305 (Passed)	250	152 (Failed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4587 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	3156 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 3156 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

FB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
10a-10a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250
10b-10b	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1579 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 384 sq. mm min Mn- >= max As/4: 1168 >= 192 sq. mm min Mn+ >= max As/4: 1000 >= 192 sq. mm
2	1105 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 1000 >= 192 sq. mm

FB2(12" x 24") ALONG GRID-D Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
11a-11a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250
11b-11b	305 (Passed)	250	152 (Failed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4612 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 768 >= 213 sq. mm
2	2250 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2250 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 768 >= 213 sq. mm

FB2(12" x 24") IN BETWEEN GRID 4~6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
12a-12a	305 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1825 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1825 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

FB2(12" x 24") IN BETWEEN GRID 3~4 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
13a-13a	305 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2250 (Passed)	2202	Left: 50 Right: 50 (Passed)	50	Left: 2250 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

FB1(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
14a-14a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 – 0.0250
14b-14b	305 (Passed)	250	152 (Failed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4612 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	2258 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

3	1829 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
4	2502 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

GB1(14" x 26") ALONG GRID-1 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 2 (Passed)	2 each face	Top: 0.00255 Bottom: 0.00170 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1977 (Failed)	2318	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1320	102 (Passed)	290	Passed Mn,l+ >= Mn,l-/2: 400 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 400 >= 300 sq. mm min Mn- >= max As/4: 400 >= 150 sq. mm min Mn+ >= max As/4: 400 >= 150 sq. mm

GB1(14" x 26") ALONG GRID-2 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 2 (Passed)	2 each face	Top: 0.00255 Bottom: 0.00170 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1977 (Failed)	2318	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1320	102 (Passed)	290	Passed Mn,l+ >= Mn,l-/2: 400 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 400 >= 300 sq. mm min Mn- >= max As/4: 400 >= 150 sq. mm min Mn+ >= max As/4: 400 >= 150 sq. mm

GB1(14" x 26") ALONG GRID-3 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
3a-3a	356 (Passed)	250	102 (Passed)	144	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1335 (Failed)	2302	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1320	102 (Passed)	288	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

GB1(14" x 26") ALONG GRID-4 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
3a-3a	356 (Passed)	250	102 (Passed)	144	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2343 (Passed)	2302	-	-	Left: N/A Right: N/A (N/A)	1320	102 (Passed)	288	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

GB1(14" x 26") ALONG GRID-5 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
4a-4a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00327 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0250
4b-4b	356 (Passed)	250	152 (Failed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00242 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2212 (Failed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 2212 Right: N/A (Passed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 852 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 384 sq. mm min Mn- >= max As/4: 568 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm
2	4206 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1297 Right: 1297 (Failed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 852 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 384 sq. mm min Mn- >= max As/4: 568 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

GB1(14" x 26") ALONG GRID-6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
5a-5a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00363 Bottom: 0.00363 (Passed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3269 (Passed)	2302	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1320	102 (Passed)	288	Passed Mn,l+ >= Mn,l-/2: 852 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

GB1(14" x 26") ALONG GRID-7 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
6a-6a	356 (Passed)	250	102 (Passed)	144	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2962 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 2962 Right: N/A (Passed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm
2	3564 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1193 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm
3	3668 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

GB2(14" x 26") ALONG GRID-A Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
7a-7a	356 (Passed)	250	102 (Passed)	144	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	

1	4587 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1309 Right: 1309 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm
2	3706 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

GB2(14" x 26") ALONG GRID-B Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
8a-8a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00363 Bottom: 0.00363 (Passed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4587 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1309 Right: 1309 (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 852 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm
2	3156 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 3156 Right: N/A (Passed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 852 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

GB2(14" x 26") ALONG GRID-D Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
10a-10a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 2 (Passed)	2 each face	Top: 0.00327 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0250
10b-10b	356 (Passed)	250	152 (Failed)	128	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00242 Bottom: 0.00242 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4612 (Passed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 568 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 568 >= 192 sq. mm
2	2258 (Failed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1320	152 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 568 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 568 >= 192 sq. mm

GB2(14" x 26") ALONG GRID-E Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
11a-11a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00327 Bottom: 0.00327 (Failed)	0.00333 ~ 0.0250
11b-11b	356 (Passed)	250	152 (Failed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00327 Bottom: 0.00327 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4612 (Passed)	2318	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	2258 (Failed)	2318	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
3	1829 (Failed)	2318	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
4	2502 (Passed)	2318	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1320	152 (Passed)	290	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

FB1(12"X24") ALONG GRID-1 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1977 (Failed)	2202	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 852 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

FB1(12" x 24") ALONG GRID-2 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1977 (Failed)	2202	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 852 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

FB1(12" x 24") IN BETWEEN GRID-B~C Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
3a-3a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1335 (Failed)	2202	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 852 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 426 sq. mm min Mn- >= max As/4: 1252 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

FB1(12"X24") ALONG GRID-3 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
3a-3a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00458 (Passed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1335 (Failed)	2202	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 852 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 426 sq. mm min Mn- >= max As/4: 1252 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

FB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
4a-4a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 – 0.0250
4b-4b	305 (Passed)	250	152 (Failed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3564 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 1000 >= 150 sq. mm

FB1(12" x 24") ALONG GRID-5 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
5a-5a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00458 (Passed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2212 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2212 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 852 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 384 sq. mm min Mn- >= max As/4: 768 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

FB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
6a-6a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3269 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
7a-7a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250
7b-7b	305 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2962 (Passed)	2218	Left: 50 Right: 50 (Passed)	50	Left: 2962 Right: N/A (Passed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	3564 (Passed)	2218	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1193 (Failed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
3	3668 (Passed)	2218	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	277	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB2(12" x 24") ALONG GRID-A Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
8a-8a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 2 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00305 (Failed)	0.00333 – 0.0250
8b-8b	305 (Passed)	250	152 (Failed)	128	Top: 3 Bottom: 2 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00305 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4587 (Passed)	2202	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 568 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 1336 >= 150 sq. mm
2	3706 (Passed)	2202	Left: 50 Right: 50 (Passed)	50	Left: 1195 Right: 1195 (Failed)	1220	152 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 568 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 1336 >= 150 sq. mm

2FB2(12" x 24") ALONG GRID-B Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
9a-9a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250
9b-9b	305 (Passed)	250	152 (Failed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4587 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2	3156 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 3156 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
---	------------------	------	-----------------------------------	----	--------------------------------------	------	-----------------	-----	--

2FB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
10a-10a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 – 0.0250
10b-10b	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1579 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 1000 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	1105 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB2(12" x 24") ALONG GRID-D Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
11a-11a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250
11b-11b	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4612 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
2	2250 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2250 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB2(12" x 24") IN BETWEEN GRID 4~6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
12a-12a	305 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1825 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1825 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

2FB2(12" x 24") IN BETWEEN GRID 3~4 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
13a-13a	305 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 2 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00305 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1534 (Failed)	2202	Left: 50 Right: 50 (Passed)	50	Left: N/A Right: N/A (N/A)	1220	102 (Passed)	275	Failed Mn,l+ >= Mn,l-/2: ? >= ? sq. mm Mn,r+ >= Mn,r-/2: ? >= ? sq. mm min Mn- >= max As/4: ? >= ? sq. mm min Mn+ >= max As/4: ? >= ? sq. mm
2	2250 (Passed)	2202	-	-	Left: 2250 Right: N/A (Passed)	1220	102 (Passed)	275	Passed Mn,l+ >= Mn,l-/2: 568 >= 284 sq. mm Mn,r+ >= Mn,r-/2: 568 >= 284 sq. mm min Mn- >= max As/4: 568 >= 142 sq. mm min Mn+ >= max As/4: 568 >= 142 sq. mm

2FB1(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
14a-14a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 – 0.0250
14b-14b	305 (Passed)	250	152 (Failed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	4612 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2	2258 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2258 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
3	1829 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm
4	2502 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	152 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB1(12"X24") ALONG GRID-1 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1977 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB1(12" x 24") ALONG GRID-2 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1977 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1977 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB1(12" x 24") IN BETWEEN GRID-B~C Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
3a-3a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1335 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 768 >= 213 sq. mm

2FB1(12"X24") ALONG GRID-3 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
3a-3a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00458 Bottom: 0.00413 (Passed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1335 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1335 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 426 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 426 sq. mm min Mn- >= max As/4: 852 >= 213 sq. mm min Mn+ >= max As/4: 768 >= 213 sq. mm

2FB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
4a-4a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00413 (Passed)	0.00333 ~ 0.0250
4b-4b	305 (Passed)	250	152 (Failed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00305 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3564 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1209 Right: 1209 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 384 sq. mm min Mn- >= max As/4: 568 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB1(12" x 24") ALONG GRID-5 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
5a-5a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00413 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2212 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2212 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 768 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 768 >= 300 sq. mm min Mn- >= max As/4: 600 >= 192 sq. mm min Mn+ >= max As/4: 768 >= 192 sq. mm

2FB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
6a-6a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00413 Bottom: 0.00322 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3269 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 384 sq. mm min Mn- >= max As/4: 768 >= 192 sq. mm min Mn+ >= max As/4: 600 >= 192 sq. mm

GB2(14" x 26") ALONG GRID-C Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
9a-9a	356 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00327 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0250
9b-9b	356 (Passed)	250	102 (Passed)	128	Top: 2 Bottom: 3 (Passed)	2 each face	Top: 0.00242 Bottom: 0.00363 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1695 (Failed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1694 Right: N/A (Passed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 852 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 384 sq. mm min Mn- >= max As/4: 568 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm
2	1102 (Failed)	2310	Left: 50 Right: 50 (Passed)	50	Left: 1102 Right: N/A (Failed)	1320	102 (Passed)	289	Passed Mn,l+ >= Mn,l-/2: 852 >= 384 sq. mm Mn,r+ >= Mn,r-/2: 852 >= 384 sq. mm min Mn- >= max As/4: 568 >= 213 sq. mm min Mn+ >= max As/4: 852 >= 213 sq. mm

LB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1150 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1150 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

LB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2343 (Passed)	2210	-	-	Left: N/A Right: N/A (N/A)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

LB1(12" x 24") ALONG GRID-E & IN BETWEEN GRID 4~6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1815 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1815 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

SB2(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2502 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

SB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1105 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

SB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3668 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

SB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3269 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

WB1(12" x 24") ALONG GRID-7 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3668 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1200 Right: 1200 (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

WB1(12" x 24") ALONG GRID-6 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	3269 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 3269 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

WB1(12" x 24") ALONG GRID-4 Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st Stirrup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan Stirrup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	2343 (Passed)	2210	-	-	Left: N/A Right: N/A (N/A)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

WB2(12" x 24") ALONG GRID-C Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 ~ 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1105 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1105 Right: N/A (Failed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

WB2(12" x 24") ALONG GRID-E Results:

Section Checks:

Location	Min Width Check (BNBC 8.3.4.1(c), BNBC 8.3.4.1(d))		Max Hoop Spacing at Support Check (BNBC 8.3.4.3(b))		Min No of Bars Check (BNBC 8.3.4.2(a))		Longitudinal Rebar Ratio (rho) Check (BNBC 8.3.4.2(a))	
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (nos.)	As Per BNBC (nos.)	Provided	As Per BNBC
1a-1a	305 (Passed)	250	102 (Passed)	128	Top: 3 Bottom: 3 (Passed)	2 each face	Top: 0.00322 Bottom: 0.00322 (Failed)	0.00333 – 0.0250

Span Checks:

Span	Min Clear Span Check (BNBC 8.3.4.1(b))		Max 1st StIRRup Position from Support (BNBC 8.3.4.3(b))		Hoop Bar at Support Length Left & Right (BNBC 8.3.4.3(a))		Max MidSpan StIRRup Spacing (BNBC 8.3.4.3(c))		Moment Strength Check (BNBC 8.3.4.2(a))
	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	Provided (mm)	As Per BNBC (mm)	
1	1829 (Failed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 1829 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm
2	2502 (Passed)	2210	Left: 50 Right: 50 (Passed)	50	Left: 2502 Right: N/A (Passed)	1220	102 (Passed)	276	Passed Mn,l+ >= Mn,l-/2: 600 >= 300 sq. mm Mn,r+ >= Mn,r-/2: 600 >= 300 sq. mm min Mn- >= max As/4: 600 >= 150 sq. mm min Mn+ >= max As/4: 600 >= 150 sq. mm

Parsing Notes (162)

- FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-B | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- FB2(12" x 24") ALONG GRID-D | Stirrup zone length < 2h (1220mm)
- FB1(12" x 24") ALONG GRID-E | Stirrup zone length < 2h (1220mm)
- GB1(14" x 26") ALONG GRID-5 | Stirrup zone length < 2h (1320mm)
- GB1(14" x 26") ALONG GRID-7 | Stirrup zone length < 2h (1320mm)
- GB1(14" x 26") ALONG GRID-7 | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-A | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-A | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-B | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-D | Stirrup zone length < 2h (1320mm)
- GB2(14" x 26") ALONG GRID-E | Stirrup zone length < 2h (1320mm)
- FB1(12" x 24") ALONG GRID-4 | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-A | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-B | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- 2FB2(12" x 24") ALONG GRID-D | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-E | Stirrup zone length < 2h (1220mm)
- 2FB1(12" x 24") ALONG GRID-4 | Stirrup zone length < 2h (1220mm)
- GB2(14" x 26") ALONG GRID-C | Stirrup zone length < 2h (1320mm)
- LB1(12" x 24") ALONG GRID-6 | Stirrup zone length < 2h (1220mm)
- SB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- SB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- WB1(12" x 24") ALONG GRID-7 | Stirrup zone length < 2h (1220mm)
- WB2(12" x 24") ALONG GRID-C | Stirrup zone length < 2h (1220mm)
- sec A1-A1 | No rebar circles found
- sec A-A | No rebar circles found
- sec C-C | No rebar circles found
- sec 1a-1a | Top reinforcement ratio is outside permitted limits
- sec 1a-1a | Bottom reinforcement ratio is outside permitted limits
- sec 1b-1b | Top reinforcement ratio is outside permitted limits
- sec 1b-1b | Bottom reinforcement ratio is outside permitted limits
- sec 2a-2a | Bottom reinforcement ratio is outside permitted limits
- sec 2b-2b | Stirrup spacing exceeds maximum allowed (support/end section)
- sec 2b-2b | Top reinforcement ratio is outside permitted limits
- sec 2b-2b | Bottom reinforcement ratio is outside permitted limits
- sec 3a-3a | Top reinforcement ratio is outside permitted limits
- sec 3a-3a | Bottom reinforcement ratio is outside permitted limits
- sec 4a-4a | Top reinforcement ratio is outside permitted limits
- sec 4b-4b | Stirrup spacing exceeds maximum allowed (support/end section)
- sec 4b-4b | Top reinforcement ratio is outside permitted limits
- sec 6a-6a | Top reinforcement ratio is outside permitted limits
- sec 6a-6a | Bottom reinforcement ratio is outside permitted limits

- sec 7a-7a | Top reinforcement ratio is outside permitted limits
- sec 7a-7a | Bottom reinforcement ratio is outside permitted limits
- sec 9a-9a | Top reinforcement ratio is outside permitted limits
- sec 9b-9b | Top reinforcement ratio is outside permitted limits
- sec 10a-10a | Top reinforcement ratio is outside permitted limits
- sec 10a-10a | Bottom reinforcement ratio is outside permitted limits
- sec 10b-10b | Stirrup spacing exceeds maximum allowed (support/end section)
- sec 10b-10b | Top reinforcement ratio is outside permitted limits