

# Power-Aware Scheduling with Dynamic Priorities

**Raj Rajkumar**  
Lecture #11

## Outline

- Static voltage scaling with EDF
- Cycle-conserving Dynamic Voltage Scaling
- Look-Ahead Dynamic Voltage Scaling

## Quiz 2 Statistics

Average	65.49
Std. Deviation	9.85
Max	77
Min	40

## Static Voltage Scaling w/ EDF: Motivation

$\tau$

Pre-run schedule with holes

$C_i$  = worst case computation time @  $F_{\max}$

Next arrival  
of  $\tau_i$



Holes in the pre-run schedule imply:


EDF Test:

$$\sum (C_i/T_i) < 1 \text{ at frequency} = F_{\max}$$


In other words, whenever  $\sum (C_i/T_i) < 1$  there are holes in the EDF schedule

## Static Voltage Scaling w/ EDF: Exploiting “Holes”

“Holes” in the schedule correspond to idle times on the processor.




## Static Voltage Scaling w/ EDF




## Static Voltage Scaling: Example Taskset

- Taskset:  $\tau_1 = (1, 4)$  and  $\tau_2 = (2, 8)$
- $U = 1/4 + 2/8 = 0.5 @ F_{\max}$
- What is the value of scaling factor  $k$  at which the taskset is still schedulable @  $(F_{\max} / k)$ ?
  - $U = (1k)/4 + (2k)/8 = k(1/4 + 2/8) = 1$
  - Solving for  $k$ ,
    - $k = 2$
  - Therefore, we should operate at  $f = F_{\max} / 2$  in order to meet all task deadlines.


## Static Voltage Scaling: Example (1 of 2)




## Static Voltage Scaling: Example (2 of 2)




## What if $(c_i < C_i)$ ? (1 of 3)



## What if ( $c_i < C_i$ )? (2 of 3)



## What if ( $c_i < C_i$ )? (3 of 3)



## Cycle-Conserving EDF

- **Idea:** When a task instance is released, we know its worst-case execution time but not its actual execution time. Let's assume worst-case execution on arrival.
- When the task instance completes, the actual cycles used are compared against the worst case, and cycles saved are given to run other remaining tasks at lower frequency.

***select\_frequency():***

use lowest frequency such that  $U^1 + U^2 + \dots U^n \leq 1$

***upon task\_release ( $\tau_i$ ):***

set  $U^i$  to  $C_i / T_i$

select\_frequency()

***upon task\_completion( $\tau_i$ ):***

set  $U^i$  to  $c_i / T_i$  //  $c_i$  is the actual cycles used in this invocation


select\_frequency()

## Cycle-Conserving EDF Example

Task	$C_i$	Period	$U_i$
1	3	8	0.375
2	3	10	0.300
3	1	14	0.071

Actual Execution Times at  $f_{\max}$


Task	Instance #1 $c_i$	Instance #2 $c_i$
1	2	1
2	1	1
3	1	1



## Look-Ahead EDF

- Defers as much work as possible.
- Sets the operating frequency to meet the minimum work that must be done now to ensure all future deadlines to be met.

## Relative Performance





## Conclusions

- RT-DVS schemes are designed to ensure
  - predictability while saving as much energy as possible in real-time systems.