

VERIFICATION OF CONFORMITY

No.: IN-SH-CP-5627-23255

Applicant: ZHEJIANG MSD GROUP SHARE CO., LTD.

Address: NO.11 HONGQI RD. CHINA WARP KNITTING SCIENTIFIC&TECHNICAL PARK OF HAINING, ZHEJIANG, CHINA

Manufacturer: ZHEJIANG MSD GROUP SHARE CO., LTD.

Address: NO.11 HONGQI RD. CHINA WARP KNITTING SCIENTIFIC&TECHNICAL PARK OF HAINING, ZHEJIANG, CHINA

It has been verified that

Product(s): MSD PVC STRETCH CEILING FILM

Description: Whit plastic film

Main component: PVC

was submitted by the applicant to the testing of the product in accordance with ISO 16000-3 & ISO 16000-6 & ISO 16000-9 & ISO 16000-11.

Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class on basis of the test report of CANPC23003541001.



This verification is valid from 25 July 2023 until 24 July 2026 and remains valid as long as the manufacturing conditions in the plant and the factory production control itself are not modified significantly.

Issue 1. This verification was first issued on 25 July 2023

Authorised by

scan to see the report



IN-SH-CP-5627-23255



Lisa Liang

Manager

Industries Service - CP Certification

SGS-CSTC Standards Technical Services Co., Ltd.

16F Century Yuhui Mansion, No.73 Fucheng Road, Haidian District, Beijing, China 100142

email CN.CONSTProdcert@sgs.com website www.sgs.com



Disclaimer: Neither SGS-CSTC, any of it affiliated SGS sister organizations nor the SGS Group can be held responsibly for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

VERIFICATION OF CONFORMITY

No.: IN-SH-CP-5627-23255

..continued..

Results of examinations are as following:

Compound Name	CAS NO.	28 days Result µg/m³	Classes requirements			
			C	B	A	A+
Toluene	108-88-3	Not detected	> 600	< 600	< 450	< 300
Tetrachloroethylene	127-18-4	Not detected	> 500	< 500	< 350	< 250
Xylene	108-38-3&106-42-3&95-47-6	Not detected	> 400	< 400	< 300	< 200
1,2,4-Trimethylbenzene	95-63-6	Not detected	> 2000	< 2000	< 1500	< 1000
1,4-Dichlorobenzene	106-46-7	Not detected	> 120	< 120	< 90	< 60
Ethylbenzene	100-41-4	Not detected	> 1500	< 1500	< 1000	< 750
2-Butoxyethanol	111-76-2	Not detected	> 2000	< 2000	< 1500	< 1000
Styrene	100-42-5	Not detected	> 500	< 500	< 350	< 250
TVOC	/	Not detected	> 2000	< 2000	< 1500	< 1000
Formaldehyde	50-00-0	Not detected	> 120	< 120	< 60	< 10
Acetaldehyde	75-07-0	Not detected	> 400	< 400	< 300	< 200

Conclusion: Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class.

Statement: Unless otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

Issue 1. This verification was first issued on **25 July 2023**

Authorised by



Lisa Liang
Manager
Industries Service - CP Certification