


Sumida

F O M	NAME & TITLE	George L. Winfield, Director	CITY of BALTIMORE MEMO	
	AGENCY NAME & ADDRESS	Department of Public Works 600 Abel Wolman Municipal Building		
	SUBJECT	Directive 02-1 Fats, Oils, Grease Limitation		


TO

DATE: May 10, 2002

Bureau Heads & Division Chiefs

The Department of Public Works is implementing a sewer discharge limitation for Fats, Oils, Grease (FOG) which will be applied to Dietz and Watson, Inc. located at 3330 Henry G. Parks Circle Drive. An evaluation of historical wastewater data was conducted in order to develop a technically based limit.

Federal General Pretreatment Regulations (40 CFR Part 403.5) require the development and enforcement of local discharge limits to protect the wastewater treatment systems, sludge quality, and effluent quality. Therefore in accordance with Section 28 (Legal Authority) of Article 25 of the Baltimore City Code as amended by Ordinance 775 of 1991, I am directing the Pollution Control Section to incorporate a FOG limit of 200 mg/l into the Wastewater Discharge Permit of Dietz and Watson. The FOG analyses must be performed in accordance with 40 CFR 136.


GEORGE L. WINFIELD
DIRECTOR

GLW:JS:pb

- Cc: Mayor's Office
Honorable Board of Estimates
Comptroller's Office
Fire Department
Police Department
Department of Housing and Community Development
Department of Finance
Legislative Reference