

Paper B-02: Electrical Grids: A Constraint-Driven Flux Dynamics (CDFD) Perspective

Steve Bico Mujjabi, MD

Independent Researcher

Founder, Vura Labs

Kampala, Uganda

ORCID: 0009-0001-0556-5516

August 2026

Shared Part IV notation and evidence boundaries are defined in PART_IV_METHODS_AND_CLAIM_BOUNDARY.md. This paper states only its local observables, comparison, and failure conditions.

Abstract

This paper develops a falsifiable CDFD/AFL model of Electrical Grids. It maps electrical demand, generation, and renewable variability to driving flux Φ , thermal limits, stability margins, transmission, and reserve capacity to active constraint C , dispatch, storage, demand response, protection, and islanding to responsiveness S , and equipment aging, network state, prior contingencies, and operator learning to structural memory M_s . The target outcome is frequency stability, congestion, unserved energy, and restoration, tested against phasor measurements, dispatch records, topology, outage logs, and asset health. The paper treats universality as a shared model architecture rather than an assertion that unlike systems have the same material mechanism. It states the negative result that would make the mapping unnecessary and places the domain claim inside the cumulative CDFD programme and its reproducible runtime boundary.

1 Introduction

A power grid must perfectly balance electricity generation and consumption at every millisecond. When a transmission line trips due to a fault (e.g., a tree striking a wire), the current it was carrying instantly reroutes through adjacent lines. If those lines are already near their thermal capacity, they too will overheat and trip, triggering a chain reaction that can darken entire continents.

Engineers treat this as an operational reliability problem. CDFD treats it as a universal topological phenomenon. The grid is an active, constrained flow network attempting to maintain a critical mathematical equilibrium.

2 The Grid as an Active Transport Surface

We govern the electrical network using the Adaptive Operating Ratio:

$$\Psi_s = \left(\frac{\Phi}{C} \right) \cdot S \cdot M_s \quad (1)$$

For a node (substation) in the power grid:

- **Flux** (Φ): The active power flow (Megawatts) passing through the node.
- **Constraint** (C): The electrical impedance of the transmission lines and the hard thermal limits of the transformers.
- **Responsiveness** (S): The grid's spinning reserve, battery capacitance, and the ability of automated relays to dynamically reroute power.
- **Memory** (M_s): The physical, hardwired topology of the grid. Unlike the internet, which can dynamically rewrite software routes, power grid topology is highly rigid. This high memory locks the system's physical constraints into place.

2.1 The Anatomy of a Cascading Blackout

In standard operation, the grid remains near $\Psi_s \approx 1$. The generated flux Φ is comfortably handled by the constraints C .

When a major transmission line faults, its effective constraint C instantly becomes infinite. The massive flux Φ it was carrying must redirect to a neighboring node. At this neighboring node, Φ spikes drastically. Because the physical wiring (the memory M_s) is rigid, the node's responsiveness S cannot scale fast enough to accommodate the surge.

The node enters a severe over-flux regime ($\Psi_s \gg 1$). The intense flow physically damages the constraint structures (thermal melting of the line). To prevent total physical destruction, automated safety relays trip the line, effectively dropping $S \rightarrow 0$ and intentionally forcing the node into a dead state ($\Psi_s = 0$).

The flux Φ is then displaced again to the next neighbor, creating a moving wave of $\Psi_s \gg 1$ anomalies that systematically annihilate the network's active surface. This is a **Cascading Blackout**—the engineered equivalent of an ecological collapse.

3 Measurement Layer

4 Cross-Domain Model Upgrade: Mechanism, Scale, and Tests

4.1 Observable Translation

The paper-specific translation begins with an observable chain rather than a verbal analogy. For Electrical Grids, the proposed drive is electrical demand, generation, and renewable variability. The active limitation is thermal limits, stability margins, transmission, and reserve capacity. Responsiveness is carried by dispatch, storage, demand response, protection, and islanding,

while retained state is represented by equipment aging, network state, prior contingencies, and operator learning. The outcome to explain is frequency stability, congestion, unserved energy, and restoration.

Table 1: Operational CDFD/AFL map for Paper B-02.

Term	Paper-specific observable meaning	Measurement question
Φ	electrical demand, generation, and renewable variability	What rate, load, gradient, or demand enters the focal system?
C	thermal limits, stability margins, transmission, and reserve capacity	Which measured bottleneck limits transfer, function, or recovery?
S	dispatch, storage, demand response, protection, and islanding	Which process changes effective capacity or reroutes the load?
M_s	equipment aging, network state, prior contingencies, and operator learning	Which retained state makes equal present loads produce different futures?
Y	frequency stability, congestion, unserved energy, and restoration	Which outcome is predicted out of sample, with uncertainty?




Figure 1: Paper B-02 observable CDFD/AFL architecture for Electrical Grids. Solid arrows give the proposed forward chain; dashed arrows make history-dependent feedback explicit.

4.2 Paper-Specific Causal Hypothesis

For this paper, the hypothesized causal sequence is specific. A change in electrical demand, generation, and renewable variability arrives faster than dispatch, storage, demand response, protection, and islanding can compensate. This raises or redistributes thermal limits, stability margins, transmission, and reserve capacity. If the load persists, the retained state encoded by equipment aging, network state, prior contingencies, and operator learning changes the next response, so a later event of equal magnitude can produce a different trajectory in frequency stability, congestion, unserved energy, and restoration. The scientific task is to estimate that sequence against the best ordinary model of the domain, not merely to redescribe the outcome after it occurs.

4.3 Cross-Scale Translation Without Mechanistic Erasure

For the engineered systems family, the cross-domain translation compares demand, designed capacity, feedback control, dependency topology, and accumulated technical state. The strongest

engineering use is prospective: the mapping must identify a bottleneck, a control action, or a recovery signature before the failure occurs. [2, 4, 3, 1] The required scale declaration for this paper is milliseconds to decades; devices to interconnections. At short scales, the key question is whether the incoming drive is transmitted, buffered, or diverted. At intermediate scales, response changes effective capacity and network exposure. At long scales, retained structure can alter the state space itself. A result is genuinely cross-scale only when the aggregation rule is stated and the same conclusion is not an artifact of averaging.

4.4 Evidence Ladder and Discriminating Tests

Table 2: Evidence ladder for Paper B-02. Each rung can fail independently.

Test	Design	Discriminating result
Proxy audit	Measure phasor measurements, dispatch records, topology, outage logs, and asset health and preregister how each record maps to Φ , C , S , M_s , and Y .	The mapping fails if proxies are non-identifiable, circular, or change meaning across cases.
Load ramp	Apply or observe a line or generator loss during high demand while estimating the dominant constraint and response time.	A threshold claim requires a reproducible nonlinear change and uncertainty bounds, not a visually chosen breakpoint.
Recovery and memory	Match present load across units with different histories, then compare recovery paths.	The memory claim requires history-dependent divergence after current conditions are controlled.
Model comparison	Compare the baseline domain model with and without the CDFD/AFL state variables using held-out data.	The paper’s stated falsifier is: the mapping adds no value beyond established power-flow and stability models.

4.5 Research Programme and Boundary Conditions

The immediate research programme has four steps. First, construct a documented dataset from phasor measurements, dispatch records, topology, outage logs, and asset health and retain raw units before normalization. Second, fit a baseline domain model and report its calibration and out-of-sample error. Third, add the smallest identifiable CDFD/AFL state extension and test whether it improves prediction of frequency stability, congestion, unserved energy, and restoration. Fourth, repeat the analysis across the declared scale range and publish negative cases as part of the cross-domain translation audit.

5 Conclusion

Power grids are thermodynamic surfaces highly vulnerable to constraint-locking. By utilizing CDFD, grid operators can move beyond localized thermal monitoring and instead track the systemic Ψ_s topology of the network in real-time, deliberately isolating high-flux bottlenecks before they trigger a catastrophic macroscopic phase shift.

Conflict of Interest

The author declares no conflict of interest.

Data Availability

Part-specific runtime diagnostics are under each Part's `outputs/` directory.

Release-wide code: `Part_E_Synthesis/supplementary/`.

Generated summaries: `Part_E_Synthesis/outputs/`.

Figures: `Part_E_Synthesis/figures/`.

6 Reference Layer

References

- [1] Per Bak, Chao Tang, and Kurt Wiesenfeld. Self-organized criticality: An explanation of the $1/f$ noise. *Physical Review Letters*, 59(4):381–384, 1987. DOI: <https://doi.org/10.1103/PhysRevLett.59.381>.
- [2] Albert-Laszlo Barabasi and Reka Albert. Emergence of scaling in random networks. *Science*, 286(5439):509–512, 1999. DOI: <https://doi.org/10.1126/science.286.5439.509>.
- [3] Claude E. Shannon. A mathematical theory of communication. *Bell System Technical Journal*, 27(3):379–423, 1948. DOI: <https://doi.org/10.1002/j.1538-7305.1948.tb01338.x>.
- [4] Duncan J. Watts and Steven H. Strogatz. Collective dynamics of small-world networks. *Nature*, 393:440–442, 1998. DOI: <https://doi.org/10.1038/30918>.