



ANSI/NETA ATS-2025

2025 ATS

STANDARD FOR

ACCEPTANCE
TESTING SPECIFICATIONS

FOR ELECTRICAL POWER EQUIPMENT & SYSTEMS

NETA®

ANSI/NETA ATS-2025

AMERICAN NATIONAL STANDARD

STANDARD FOR
ACCEPTANCE TESTING SPECIFICATIONS
for Electrical Power Equipment
& Systems

Secretariat
InterNational Electrical Testing Association



Approved by
American National Standards Institute



American National Standard

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by
InterNational Electrical Testing Association
3050 Old Centre Ave., Suite 101
Portage, MI 49024
269.488.6382
www.netaworld.org
neta@netaworld.org
E. Bryant Phillips Executive Director

InterNational Electrical Testing Association
Copyright© 2025
InterNational Electrical Testing Association
All rights reserved
Printed in the United States of America

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher, or in accordance with the Copyright information and Alteration of Content contained herein.



Copyright Information and Alteration of Content

ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems, 2025 edition, (ANSI/NETA ATS-2025) is protected under the copyright laws of the United States, and all rights are reserved. Further, the ANSI/NETA ATS-2025 may not be copied, modified, sold, or used except in accordance with such laws and as follows:

Purchasers may reproduce and use all or a portion of the ANSI/NETA ATS-2025 provided *ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems* are clearly identified in writing as the source of all such uses or reproduction.

Section 7 of the *ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems* may be reproduced and used on a “cut and paste” basis for the particular type of equipment to be tested.

The following sections of the *ANSI/NETA Standard for Acceptance Testing Specifications for Electrical Power Equipment and Systems* must be incorporated by reference as part of any subsection:

3. Qualifications of Testing Organization and Personnel

3.1 Testing Organization

3.2 Testing Personnel

4. Division of Responsibility

4.1 The Owner’s Representative

4.2 The Testing Organization

5. General

5.1 Safety and Precautions

5.2 Suitability of Test Equipment

5.3 Test Instrument Calibration

5.4 Test Report

5.5 Test Decal

The purchaser is required to include the above sections with any section(s) of 7.

InterNational Electrical Testing Association© **Copyright 2025**

InterNational Electrical Testing Association

3050 Old Centre Road, Suite 101

Portage, MI 49024

Voice: 888.300.6382

E-mail: neta@netaworld.org • Web: www.netaworld.org

STANDARDS REVIEW COUNCIL

The following persons were members of the NETA Standards Review Council which approved this document.

Eric J. Beckman
James G. Cialdea
Lorne J. Gara
Wyatt P. Hamrick
Leif W. Hoegberg
Daniel D. Hook
David G. Huffman
E. Bryant Phillips
Chasen C. Tedder, Sr.
Ron A. Widup

Acceptance Testing Specifications Ballot Pool Members

The following persons were members of the Ballot Pool which balloted on this document for submission to the NETA Standards Review Council.

John Ankoviak	Steve Park
Ken Bassett	Lee Perry
Tom Bishop	Mose Ramieh
Scott Blizzard	Scott Reed
Daren Buettner	Dr. Diego Robalino
Guy Carpino	Randall Sagan
Michel Castonguay	Tom Sandri
Tim Cotter	Brandon Sedgwick
Jeffery Gobeli	Charles Sweetser
Craig Goodwin	Dr. Panuwat Teansri
Ahmer Hansa	Howard Trinkowsky
Paul Hartman	Robert Trulock
Kerry Heid	Alan Turpen
Bibek Karki	Matt Wallace
Dave Kreger	Gary Walls
Ben Lanz	Drew Welton
Jeremy Nichols	Jean-Pierre Wolff

Battery Energy Storage System (BESS) Working Group

Ahmer Hansa
Leif W. Hoegberg
Brandon Schuler
Chasen C. Tedder, Sr.

NOTICE

In no event shall the InterNational Electrical Testing Association be liable to anyone for special, collateral, incidental, or consequential damages in connection with or arising out of the use of these materials.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. Comments and suggestions are invited from all users for consideration by the Association in connection with such review. Any such suggestions will be fully reviewed by the Association after giving the commenter, upon request, a reasonable opportunity to be heard.

This document should not be confused with federal, state, or municipal specifications or regulations, insurance requirements, or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, use of this document is purely voluntary and not binding.

InterNational Electrical Testing Association
3050 Old Centre Road Suite 101 • Portage, MI 49024
Voice: 888.300.6382 • Facsimile: 269.488.6383
Email: neta@netaworld.org • Web: www.netaworld.org
E. Bryant Phillips – Executive Director

FOREWORD

(This Foreword is not part of American National Standard ANSI/NETA ATS-2025)

The InterNational Electrical Testing Association (NETA) was formed in 1972 to establish uniform testing procedures for electrical equipment and apparatus. NETA developed specifications for the acceptance of new electrical apparatus prior to energization and for the maintenance of existing apparatus to determine its suitability to remain in service. The first NETA *Acceptance Testing Specifications for Electrical Power Equipment and Systems* was produced in 1972. Upon completion of this project, the NETA Technical Committee began work on a maintenance document, and *Maintenance Testing Specifications for Electrical Power Equipment and Systems* was published in 1975.

NETA has been an Accredited Standards Developer for the American National Standards Institute since 1996. NETA's scope of standards activity is different from that of the IEEE, NECA, NEMA, and UL. In matters of testing electrical equipment and systems NETA continues to reference other standards developers' documents where applicable. NETA's review and updating of presently published standards takes into account both national and international standards. NETA's standards may be used internationally as well as in the United States. NETA firmly endorses a global standardization. IEC standards as well as American consensus standards are taken into consideration by NETA's Section Panels and reviewing committees.

The *NETA Acceptance Testing Specifications* was developed for use by those responsible for assessing the suitability for initial energization of electrical power equipment and systems and to specify field tests and inspections that ensure these systems and apparatus perform satisfactorily, minimizing downtime and maximizing life expectancy.

Since 1972, several revisions of the *Acceptance Testing Specifications* have been published; in 1989 the NETA Technical Committee, with approval of the Board of Directors, set a four-year review and revision schedule. Unless it involves a significant safety or urgent technical issue, each comment and suggestion for change is held until the appropriate review period. Each edition includes new and completely revised sections. The document uses the standard numbering system of ANSI and IEEE. Since 1989, revised editions of the *Acceptance Testing Specifications* have been published in 1991, 1995, 1999, 2003, 2007, 2009, 2013, 2017, and 2021.

On February 20, 2025, the American National Standards Institute approved the 2025 NETA, *Acceptance Testing Specifications for Electrical Power Equipment and Systems* as an American National Standard. ANSI first approved the NETA *Acceptance Testing Specifications for Electrical Power Equipment and Systems* in 1991.

Suggestions for improvement of this standard are welcome. They should be sent to the InterNational Electrical Testing Association, 3050 Old Centre Road, Suite 101, Portage, MI 49024, or emailed to neta@netaworld.org.

PREFACE

(This Foreword is not part of American National Standard ANSI/NETA ATS-2025)

It is recognized by the Association that the needs for acceptance testing of commercial, industrial, governmental, and other electrical power systems vary widely. Many criteria are used in determining what equipment is to be tested and to what extent.

To help the user better understand and navigate more efficiently through this document, we offer the following information:

Notation of Changes

Material included in this edition of the document but not part of the 2021 edition is marked with a black vertical line next to the insertion of text, deletion of text, or alteration of text.

The Document Structure

The document is divided into thirteen separate and defined sections:

Section	Description
Section 1	General Scope
Section 2	Applicable References
Section 3	Qualifications of Testing Organization and Personnel
Section 4	Division of Responsibility
Section 5	General
Section 6	Power System Studies
Section 7	Inspection and Test Procedures
Section 8	System Function Tests and Commissioning
Section 9	Thermographic Survey
Section 10	Electromagnetic Field Testing
Section 11	Online Partial Discharge Survey
Tables	Reference Tables
Appendices	Informational Documents

Section 7 Structure

Section 7 is the main body of the document with specific information on what to do relative to the inspection and acceptance testing of electrical power distribution equipment and systems. It is not intended that this document explain how to test specific pieces of equipment or systems.

Sequence of Tests and Inspections

The tests and inspections specified in this document are not necessarily presented in chronological order and may be performed in a different sequence.

Expected Test Results

Section 7 consists of sections specific to each particular type of equipment. Within those sections there are, typically, four main bodies of information:

- A. Visual and Mechanical Inspection
- B. Electrical Tests
- C. Test Values – Visual and Mechanical
- D. Test Values – Electrical

PREFACE

(This Foreword is not part of American National Standard ANSI/NETA ATS-2025)

Results of Visual and Mechanical Inspections

Some, but not all, visual and mechanical inspections have an associated test value or result. Those items with an expected result are referenced under Section C., *Test Values – Visual and Mechanical*. For example, Section 7.1.1 *Switchgear and Switchboard Assemblies*, item 7.1.1.A.9 calls for verifying tightness of connections using a calibrated torque wrench method. Under the *Test Values – Visual and Mechanical* Section 7.1.1.C.1, the expected results for that particular task are listed within Section C., with reference back to the original task description on item 7.1.1.A.9.

7.	INSPECTION AND TEST PROCEDURES
7.1.1	Switchgear and Switchboard Assemblies
7.1.1	Switchgear and Switchboard Assemblies
A.	Visual and Mechanical Inspection
1.	Compare equipment nameplate data with drawings.
2.	Inspect physical, electrical, and mechanical condition.
3.	Inspect anchorage, alignment, grounding, and required area clearances.
4.	Verify the unit is clean and all shipping bracing, loose parts, and documentation shipped inside cubicles have been removed.
5.	Compare mimic diagram and device labeling with drawings.
6.	Verify that fuse and circuit breaker sizes and types correspond to drawings and coordination study as well as to the circuit breaker address for microprocessor-communication packages.
7.	Verify that current and voltage transformer ratios correspond to drawings.
8.	Verify that wiring connections are tight and that wiring is secure to prevent damage during routine operation of moving parts.
9.	Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.1.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
10.	Confirm correct operation and sequencing of electrical and mechanical interlock systems.
1.	Attempt closure on locked-open devices. Attempt to open locked-closed devices.
2.	Make key exchange with all devices included in the interlock scheme.
11.	Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
12.	Inspect insulators for evidence of physical damage or contaminated surfaces.
13.	Verify correct barrier and shutter installation and operation.
14.	Exercise all active components.
15.	Inspect mechanical indicating devices for correct operation.
16.	Verify that filters are in place and vents are clear.

NETA
Page 35
NETA ATS-2025

7.	INSPECTION AND TEST PROCEDURES
7.1.1	Switchgear and Switchboard Assemblies
15.	*Perform online partial-discharge survey in accordance with Section 11.
C.	Test Values – Visual and Mechanical
1.	Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.1.1.A.9)
2.	Results of the thermographic survey shall be in accordance with Section 9. (7.1.1.A.20)
D.	Test Values – Electrical
1.	Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2.	Insulation-resistance values of bus insulation shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests shall not proceed until insulation-resistance levels are raised above minimum values.
3.	If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
4.	Minimum insulation resistance values of control wiring shall not be less than two megohms.
5.	Results of electrical tests on instrument transformers shall be in accordance with Section 7.10.
6.	Results of ground resistance tests shall be in accordance with Section 7.13.
7.	Accuracy of metering devices shall be in accordance with Section 7.11.
8.	Control Power Transformers
1.	Insulation-resistance values of control power transformers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
2.	Turns-ratio test results shall not deviate by more than one-half percent from either the adjacent coils or the calculated ratio.
3.	Secondary wiring shall be in accordance with design drawings and specifications.

NETA
Page 38
NETA ATS-2025

PREFACE

(This Foreword is not part of American National Standard ANSI/NETA ATS-2025)

Results of Electrical Tests

Each electrical test has a corresponding expected result, and the test and the result have identical numbers. If the electrical test is item four, the expected result under the *Test Values* section is also item four. For example, under Section 7.15.1 *Rotating Machinery, AC Induction Motors and Generators*, item 7.15.1.B.2 (item 2 within the *Electrical Tests* section) calls for performing an insulation-resistance test in accordance with IEEE Standard 43. In section D, *Test Values – Electrical*, the expected results for that particular task are listed in the *Test Values* section under item 2.

7.	INSPECTION AND TEST PROCEDURES
7.15.1	Rotating Machinery, AC Induction Motors and Generators
7.15.1 Rotating Machinery, AC Induction Motors and Generators	
A.	Visual and Mechanical Inspection
1.	Compare equipment nameplate data with drawings.
2.	Inspect physical and mechanical condition.
3.	Inspect anchorage, alignment, and grounding.
4.	Inspect air baffles, filter media, stator winding, stator core, rotor, cooling fans, slip rings, brushes, brush rigging, and bearings.
5.	Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.15.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6.	*Perform special tests such as air-gap spacing and machine alignment.
7.	*Manually rotate the rotor and check for problems with the bearings or shaft.
8.	*Rotate the shaft and measure and record the shaft extension runout.
9.	Verify the application of appropriate lubrication and lubrication systems.
10.	Verify that resistance temperature detector (RTD) circuits conform to drawings.
11.	*Perform thermographic survey in accordance with Section 9.
B.	Electrical Tests
1.	Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2.	Perform insulation-resistance tests in accordance with IEEE Standard 43.
1.	Machines larger than 200 horsepower (150 kilowatts): Test duration shall be ten minutes. Calculate polarization index.
2.	Machines 200 horsepower (150 kilowatts) and less: Test duration shall be one minute. Calculate dielectric-absorption ratio for 60/30 second periods.
3.	On machines rated at 2300 volts and greater, perform dielectric withstand voltage tests in accordance with:
NETA Page 157 NETA ATS-2025	

7.	INSPECTION AND TEST PROCEDURES
7.15.1	Rotating Machinery, AC Induction Motors and Generators
6.	Cooling fans shall operate, not be loose on the rotor shaft, and have no cracks.
7.	Slip ring alignment shall be within manufacturer's published tolerances.
8.	Brush alignment shall be within manufacturer's published tolerances.
9.	Brush rigging shall be in accordance with manufacturer's published data.
10.	Bearings shall be inspected for evidence of overheating, rubs, rolling element damage contamination, electrical damage, and lack of lubrication.
2.	Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.15.1.A.5)
3.	Results of the thermographic survey shall be in accordance with Section 9. (7.15.1.A.11)
4.	Air-gap spacing and machine alignment shall be in accordance with manufacturer's published data. (7.15.1.A.6)
D.	Test Values – Electrical
1.	Compare bolted connection resistance values to values of similar connections. Investigate any values that deviate from similar bolted connections by more than 50 percent of the lowest value.
2.	The recommended minimum insulation resistance (IR_{1min}) test results in megohms shall be in accordance with Table 100.11.
1.	The polarization index value shall not be less than 2.0.
2.	The dielectric absorption ratio shall not be less than 1.4.
3.	If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
4.	Investigate phase-to-phase stator resistance values that deviate by more than five percent.
5.	Power-factor or dissipation-factor values shall be compared to manufacturer's published data. In the absence of manufacturer's data these values will be compared with previous values of similar machines.
6.	Tip-up values shall indicate no significant increase in power factor.
NETA Page 159 NETA ATS-2025	

PREFACE

(This Foreword is not part of American National Standard ANSI/NETA ATS-2025)

Optional Tests

The purpose of these specifications is to assure that all tested electrical equipment and systems supplied by either contractor or owner are operational and within applicable standards and manufacturer's published tolerances and that equipment and systems are installed in accordance with design specifications.

Certain tests are assigned an optional classification. The following considerations are used in determining the use of the optional classification:

1. Does another listed test provide similar information?
2. How does the cost of the test compare to the cost of other tests providing similar information?
3. How commonplace is the test procedure? Is it new technology?

Optional Tests are denoted by an asterisk (*) at the beginning of the item that contains the optional test.

If/When Applicable

The phrases "if applicable", "when applicable", and any variation thereof do not occur in this standard. This standard assumes that if devices or pieces of equipment are not present, they will not be subject to testing or verification. In addition, it is not expected this specification will apply to those devices where a test is not practical or not physically possible to be performed in the field, or there exists no consensus industry standard or practice for performing a given test, or where test equipment manufacturers do not provide guidance to perform the test.

Manufacturer's Instruction Manuals

It is important to follow the recommendations contained in the manufacturer's published data. Many of the details of a complete and effective testing procedure can be obtained from this source.

Summary

The guidance of an experienced testing professional should be sought when making decisions concerning the extent of testing. It is necessary to make an informed judgment for each particular system regarding how extensive a procedure is justified. The approach taken in these specifications is to present a comprehensive series of tests applicable to most industrial and larger commercial systems. In smaller systems, some of the tests can be deleted. In other cases, a number of the tests indicated as optional should be performed.

Likewise, guidance of an experienced testing professional should also be sought when making decisions concerning the results of test data and their significance to the overall analysis of the device or system under test. Careful consideration of all aspects of test and calibration data, including manufacturer's published data and recommendations, must be included in the overall assessment of the device or system under test.

CONTENTS

1. GENERAL SCOPE	1
2. APPLICABLE REFERENCES.....	3
2.1 Codes, Standards, and Specifications.....	4
2.2 Other References	12
2.3 Contact Information	13
3. QUALIFICATIONS OF TESTING ORGANIZATION AND PERSONNEL	14
3.1 Testing Organization	15
3.2 Testing Personnel	16
4. DIVISION OF RESPONSIBILITY	17
4.1 The Owner's Representative	18
4.2 The Testing Organization.....	19
5. GENERAL.....	20
5.1 Safety and Precautions	21
5.2 Suitability of Test Equipment	22
5.3 Test Instrument Calibration.....	23
5.4 Test Report	24
5.5 Test Decal.....	25
6. POWER SYSTEM STUDIES.....	26
6.1 Short-Circuit Studies	27
6.2 Coordination Studies	28
6.3 Incident Energy Analysis	29
6.4 Load-Flow Studies	31
6.5 Stability Studies.....	32
6.6 Harmonic-Analysis Studies.....	33
7. INSPECTION AND TEST PROCEDURES	34
7.1.1 Switchgear and Switchboard Assemblies	35
7.1.2 Panelboard Assemblies	40
7.2.1.1 Transformers, Dry-Type, Air-Cooled, Low-Voltage, Small.....	42
7.2.1.2 Transformers, Dry-Type, Air-Cooled, Large	44
7.2.2 Transformers, Liquid-Filled	47
7.3.1 Cables, Low-Voltage, Low-Energy.....	52
7.3.2 Cables, Low-Voltage, 600-Volt Maximum.....	53
7.3.3 Cables, Medium- and High-Voltage	55
7.4 Metal-Enclosed Busways	59
7.5.1.1 Switches, Air, Low-Voltage.....	62
7.5.1.2 Switches, Air, Medium-Voltage, Metal-Enclosed	64
7.5.1.3 Switches, Air, Medium- and High-Voltage, Open.....	67
7.5.2 Switches, Oil, Medium-Voltage.....	70
7.5.3 Switches, Vacuum, Medium-Voltage	73
7.5.4 Switches, SF6, Medium-Voltage	76
7.5.5 Switches, Cutouts	79
7.6.1.1.1 Circuit Breakers, Low-Voltage, Molded-Case.....	81
7.6.1.1.2 Circuit Breakers, Low-Voltage, Insulated Case.....	83
7.6.1.2 Circuit Breakers, Low-Voltage, Power	86

CONTENTS

7.6.1.3	Circuit Breakers, Air, Medium-Voltage.....	89
7.6.2	Circuit Breakers, Oil, Medium- and High-Voltage.....	93
7.6.3	Circuit Breakers, Vacuum, Medium-Voltage	98
7.6.4	Circuit Breakers, SF ₆	102
7.7	Circuit Switchers	106
7.8	Network Protectors, 600-Volt Class.....	109
7.9.1	Protective Relays, Electromechanical and Solid-State.....	113
7.9.2	Protective Relays, Microprocessor-Based.....	121
7.10.1	Instrument Transformers, Current Transformer.....	124
7.10.2	Instrument Transformers, Voltage Transformers.....	126
7.10.3	Instrument Transformers, Coupling-Capacitor Voltage Transformers	129
7.10.4	Instrument Transformers, High-Accuracy Instrument Transformers	132
7.11.1	Metering Devices, Electromechanical and Solid-State	133
7.11.2	Metering Devices, Microprocessor-Based	134
7.12.1.1	Regulating Apparatus, Voltage, Step Voltage Regulators	136
7.12.1.2	Regulating Apparatus, Voltage, Induction Regulators.....	141
7.12.2	Regulating Apparatus, Current.....	142
7.12.3	Regulating Apparatus, Load Tap-Changers	143
7.13	Grounding Systems	146
7.14	Ground-Fault Protection Systems, Low-Voltage	147
7.15.1	Rotating Machinery, AC Induction Motors and Generators	150
7.15.2	Rotating Machinery, Synchronous Motors and Generators	154
7.15.3	Rotating Machinery, DC Motors and Generators	160
7.16.1.1	Motor Control, Motor Starters, Low-Voltage	163
7.16.1.2	Motor Control, Motor Starters, Medium-Voltage.....	165
7.16.2.1	Motor Control, Motor Control Centers, Low-Voltage.....	169
7.16.2.2	Motor Control, Motor Control Centers, Medium-Voltage.....	170
7.17	Adjustable Speed Drive Systems	171
7.18.1.1	Direct-Current Systems, Batteries, Flooded Lead-Acid.....	174
7.18.1.2	Direct-Current Systems, Batteries, Vented Nickel-Cadmium.....	176
7.18.1.3	Direct-Current Systems, Batteries, Valve-Regulated Lead-Acid.....	178
7.18.2	Direct-Current Systems, Chargers.....	180
7.18.3	Direct-Current Systems, Rectifiers	182
7.19.1	Surge Protective Devices, Low-Voltage	183
7.19.2	Surge Arresters, Medium- and High-Voltage	184
7.20.1	Capacitors.....	186
7.20.2	Capacitor Control Devices	188
7.20.3.1	Reactors (Shunt and Current-Limiting) Dry-Type.....	189
7.20.3.2	Reactors (Shunt and Current-Limiting) Liquid-Filled	191
7.20.4	Resistors	194
7.21	Outdoor Bus Structures	196
7.22.1	Emergency Systems, Engine Generator	198
7.22.2	Emergency Systems, Uninterruptible Power Systems	200
7.22.3	Emergency Systems, Automatic Transfer Switches	202
7.23	Automation Systems and Communications	205

CONTENTS

7.24.1	Automatic Circuit Reclosers and Line Sectionalizers, Automatic Circuit Reclosers, Oil/Vacuum	207
7.24.2	Automatic Circuit Reclosers and Line Sectionalizers, Automatic Line Sectionalizers, Oil.....	211
7.25	Fiber-Optic Cables	214
7.26	Electric Vehicle Charging Systems.....	216
7.27	Arc Energy Reduction Systems.....	218
7.28	Battery Energy Storage Systems (BESS).....	219
7.29	Solar Photovoltaic (PV) Systems	221
7.30	Wind Turbine Systems	223
8.	SYSTEM FUNCTION TESTS AND COMMISSIONING	224
9.	THERMOGRAPHIC SURVEY	226
10.	ELECTROMAGNETIC FIELD TESTING	228
11.	ONLINE PARTIAL DISCHARGE SURVEY	230

TABLES

Table 100.1	Insulation Resistance Test Values, Electrical Apparatus and Systems Other Than Rotating Machinery.....	234
Table 100.2	Switchgear Withstand Test Voltages	235
Table 100.3	Recommended Dissipation Factor/Power Factor at 20° C Liquid-Filled Transformers, Regulators, and Reactors.....	236
Table 100.4	Insulating Fluid Limits	237
Table 100.4.1	Test Limits for New Insulating Oil Received in New Equipment	237
Table 100.4.2	Test Limits for Silicone Insulating Liquid in New Transformers	238
Table 100.4.3	Typical Values for Less-Flammable Hydrocarbon Insulating Liquid Received in New Equipment	239
Table 100.5	Transformer Insulation Resistance Acceptance Testing.....	240
Table 100.6	Medium-Voltage Cables Acceptance Test Values	241
Table 100.6.1	Extruded Dielectric Shielded Power Cables, DC Test Voltages	241
Table 100.6.2	Laminated Dielectric Shielded Power Cable, DC Test Voltages	242
Table 100.6.3	Shielded Power Cable VLF (0.1 Hz) Test Voltages	243
Table 100.6.4	Shielded Power Cables, DAC Test Voltages for Offline PD Tests	244
Table 100.6.5	Shielded Power Cable, AC (20 Hz-300 Hz) Test Voltages	245
Table 100.6.6	VLF Tan Delta (TD), MV/HV Cable Test Voltages.....	246
Table 100.6.7.1	Evaluation of TD Results, PE-based Insulations	247
Table 100.6.7.2	Evaluation of Tan Delta Test Results, EPR Cable	247
Table 100.7	Inverse Time Trip Test at 300% of Rated Continuous Current of Circuit Breakers, Molded-Case Circuit Breakers.....	248
Table 100.8	Instantaneous Trip Tolerances for Field Testing of Circuit Breakers.....	249
Table 100.9	Instrument Transformer Dielectric Tests, Field Acceptance	250
Table 100.10	Unfiltered Housing Vibration Limits	251
Table 100.11	Insulation Resistance Test Values, Rotating Machinery for One Minute at 40° C	252
Table 100.12	US Standard Fasteners, Bolt Torque Values for Electrical Connections.....	253

CONTENTS

Table 100.12.1	Bolt-Torque Values for Electrical Connections, US Standard Fasteners ¹ , Heat-Treated Steel – Cadmium or Zinc Plated ²	253
Table 100.12.2	US Standard Fasteners ¹ , Silicon Bronze Fasteners ^{2 3} , Torque (Pound-Feet)	254
Table 100.12.3	US Standard Fasteners ¹ , Aluminum Alloy Fasteners ^{2 3} , Torque (Pound-Feet)	255
Table 100.12.4	US Standard Fasteners ¹ , Stainless Steel Fasteners ^{2 3} , Torque (Pound-Feet)	256
Table 100.13	SF ₆ Gas Tests.....	257
Table 100.14	Insulation Resistance Conversion Factors	258
Table 100.14.1	Insulation Resistance Conversion Factors (20° C)	258
Table 100.14.2	Insulation Resistance Conversion Factors (40° C)	259
Table 100.15	High-Potential Test Voltage for Automatic Circuit Reclosers.....	260
Table 100.16	High-Potential Test Voltage for Acceptance Testing of Line Sectionalizers.....	261
Table 100.17	Dielectric Withstand Test Voltages Metal-Enclosed Bus.....	262
Table 100.18	Thermographic Survey, Suggested Actions Based on Temperature Rise	263
Table 100.19	Dielectric Withstand Test Voltages for Electrical Apparatus Other than Inductive Equipment	264
Table 100.20	Rated Control Voltages and their Ranges for Circuit Breakers.....	265
Table 100.20.1	Rated Control Voltages and Their Ranges for Circuit Breakers	265
Table 100.20.2	Rated Control Voltages and Their Ranges for Circuit Breakers Solenoid-Operated Devices	267
Table 100.22	Minimum Bending Radius for Medium Voltage Power Cables, Single and Multiple Conductor	268
Table 100.23	Online Partial Discharge Survey.....	270
Table 100.23.1	Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (TEV)	270
Table 100.23.2	Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (HFCT).....	270
Table 100.23.3	Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (UHF)	270
Table 100.23.4	Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (VIS).....	271
Table 100.23.5	Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (Contact/Airborne Acoustic).....	271
	Circuit Reliability Requirement	276

APPENDICES

Appendix A - Definitions	272
Appendix B - Guidance for Circuit Reliability Considerations for Medium and High Voltage Cable Methods of Test.....	275
Appendix C - About the InterNational Electrical Testing Association	278
Appendix D - Form for Comments	280
Appendix E - Form for Proposals	281

1. GENERAL SCOPE

1. GENERAL SCOPE

1. These specifications cover the suggested field tests and inspections that are available to assess the suitability for initial energization and final acceptance of electrical power equipment and systems.
2. The purpose of these specifications is to assure that tested electrical equipment and systems are suitable for initial energization, are, reliable, operational, in conformance with applicable standards and manufacturer's tolerances, and are installed in accordance with design and project specifications.
3. The work specified in these specifications may involve hazardous voltages, materials, operations, and equipment. These specifications do not purport to address all of the safety issues associated with their use. It is the responsibility of the user to review all applicable regulatory limitations prior to the use of these specifications.

2. APPLICABLE REFERENCES

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

2.1 Codes, Standards, and Specifications

All inspections and field tests shall be in accordance with the latest edition of the following codes, standards, and specifications except as provided otherwise herein.

1. American National Standards Institute – ANSI

2. ASTM International – ASTM

ASTM D92 *Standard Test Method for Flash and Fire Points by Cleveland Open Cup Tester*

ASTM D445 *Standard Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (the Calculation of Dynamic Viscosity)*

ASTM D664 *Standard Test Method for Acid Number of Petroleum Products by Potentiometric Titration*

ASTM D877 *Standard Test Method for Dielectric Breakdown Voltage of Insulating Liquids using Disk Electrodes*

ASTM D923 *Standard Practices for Sampling Electrical Insulating Liquids*

ASTM D924 *Standard Test Method for Dissipation Factor (or Power Factor) and Relative Permittivity (Dielectric Constant) of Electrical Insulating Liquids*

ASTM D971 *Standard Test Method for Interfacial Tension of Oil against Water by the Ring Method*

ASTM D974 *Standard Test Method for Acid and Base Number by Color Indicator Titration*

ASTM D1298 *Standard Test Method for Density, Relative Density, or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method*

ASTM D1500 *Standard Test Method for ASTM Color of Petroleum Products (ASTM Color Scale)*

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

ASTM D1524	<i>Standard Test Method for Visual Examination of Used Electrical Insulating Liquids in the Field</i>
ASTM D1533	<i>Standard Test Methods for Water in Insulating Liquids by Coulometric Karl Fischer Titration</i>
ASTM D1816	<i>Standard Test Method for Dielectric Breakdown Voltage of Insulating Liquids Using VDE Electrodes</i>
ASTM D2029	<i>Standard Test Methods for Water Vapor Content of Electrical Insulating Gases by Measurement of Dew Point</i>
ASTM D2129	<i>Standard Test Method for Color of Clear Electrical Insulating Liquids (Platinum-Cobalt Scale)</i>
ASTM D2284	<i>Standard Test Method of Acidity of Sulfur Hexafluoride</i>
ASTM D2472	<i>Standard Specification for Sulfur Hexafluoride</i>
ASTM D2477	<i>Standard Test Method for Dielectric Breakdown Voltage and Dielectric Strength of Insulating Gases at Commercial Power Frequencies</i>
ASTM D2685	<i>Standard Test Method for Air and Carbon Tetrafluoride in Sulfur Hexafluoride by Gas Chromatography</i>
ASTM D2759	<i>Standard Practice for Sampling Gas from a Transformer under Positive Pressure</i>
ASTM D3284	<i>Standard Practice for Combustible Gases in the Gas Space of Electrical Apparatus Using Portable Meters</i>
ASTM D3612	<i>Standard Test Method for Analysis of Gases Dissolved in Electrical Insulating Oil by Gas Chromatography</i>
ASTM D4052	<i>Standard Test Method for Density, Relative Density, and API Gravity of Liquids by Digital Density Meter</i>
ASTM D5837	<i>Standard Test Method for Furanic Compounds in Electrical Insulating Liquids by High Performance Liquid Chromatography (HPLC)</i>

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

3. Association of Edison Illuminating Companies – AEIC
4. Canadian Standards Association – CSA
 - CSA Z462 *Workplace Electrical Safety Standard*
 - CSA Z463 *Maintenance of Electrical Equipment*
5. Electrical Apparatus Service Association - EASA
 - EASA AR100 *Recommended Practice for the Repair of Rotating Electrical Apparatus*
6. International Electrotechnical Commission - IEC
 - IEC 62446-1 *Photovoltaic (PV) Systems - Requirements for Testing, Documentation, and Maintenance - Part 1: Grid Connected Systems - Documentation, Commissioning Tests and Inspection*
7. Institute of Electrical and Electronic Engineers – IEEE
 - IEEE C2 *National Electrical Safety Code*
 - IEEE C37 Compilation *Guides and Standards for Circuit Breakers, Switchgear, Relays, Substations, and Fuses*
 - IEEE C57 Compilation *Distribution, Power, and Regulating Transformers*
 - IEEE C62 Compilation *Surge Protection*
 - IEEE C93.1 *Requirements for Power-Line Carrier Coupling Capacitors and Coupling Capacitor Voltage Transformers (CCVT)*
 - IEEE 43 *IEEE Recommended Practice for Testing Insulation Resistance of Electric Machinery*
 - IEEE 48 *IEEE Standard for Test Procedures and Requirements for Alternating Current Cable Terminations Used on Shielded Cables Having Laminated Insulation Rated 2.5 kV through 765 kV or Extruded Insulation Rated 2.5 kV through 500 kV*

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

IEEE 81	<i>IEEE Guide for Measuring Earth Resistivity, Ground Impedance, and Earth Surface Potentials of a Grounding System</i>
IEEE 95	<i>IEEE Recommended Practice for Insulation Testing of Large AC Rotating Machinery with High Direct Voltage</i>
IEEE 141	<i>IEEE Recommended Practice for Electrical Power Distribution for Industrial Plants (Red Book)</i>
IEEE 142	<i>IEEE Recommended Practice for Grounding of Industrial and Commercial Power Systems (Green Book)</i>
IEEE 241	<i>IEEE Recommended Practice for Electric Power Systems in Commercial Buildings (Gray Book)</i>
IEEE 242	<i>IEEE Recommended Practice for Protection and Coordination of Industrial and Commercial Power Systems (Buff Book)</i>
IEEE 386	<i>IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems above 600 V</i>
IEEE 399	<i>IEEE Recommended Practice for Power Systems Analysis (Brown Book)</i>
IEEE 400	<i>IEEE Guide for Field Testing and Evaluation of the Insulation of Shielded Power Cable Systems Rated 5 kV and Above</i>
IEEE 400.1	<i>IEEE Guide for Field Testing of Laminated Dielectric , Shielded AC Power Cable Systems Rated 5 kV to 500 kV Using High Voltage Direct Current (HVDC)</i>
IEEE 400.2	<i>IEEE Guide for Field Testing of Shielded Power Cable Systems Using Very Low Frequency (VLF)(less than 1 Hz)</i>
IEEE 400.3	<i>IEEE Guide for Partial Discharge Field Diagnostic Testing of Shielded Power Cable Systems</i>

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

IEEE 400.4	<i>IEEE Guide for Field Testing of Shielded Power Cable Systems Rated 5 kV and Above with Damped Alternating Current (DAC) Voltage</i>
IEEE 400.5	<i>IEEE Guide for Field Testing of DC Shielded Power Cable Systems Rated 5 kV and Above with High Direct Current Test Voltages</i>
IEEE 421.3	<i>IEEE Standard for High Potential Test Requirements for Excitation Systems for Synchronous Machines</i>
IEEE 446	<i>IEEE Recommended Practice for Emergency and Standby Power Systems for Industrial and Commercial Applications (Orange Book)</i>
IEEE 450	<i>IEEE Recommended Practice for Maintenance, Testing, and Replacement of Vented Lead-Acid Batteries for Stationary Applications</i>
IEEE 493	<i>IEEE Recommended Practice for the Design of Reliable Industrial and Commercial Power Systems (Gold Book)</i>
IEEE 519	<i>IEEE Standard for Harmonic Control in Electric Power Systems</i>
IEEE 551	<i>Recommended Practice for Calculating AC Short-Circuit Currents in Industrial and Commercial Power Systems</i>
IEEE 602	<i>IEEE Recommended Practice for Electric Systems in Health Care Facilities (White Book)</i>
IEEE 637	<i>IEEE Guide for the Reclamation of Mineral Insulating Oil and Criteria for Its Use</i>
IEEE 644	<i>Procedures for Measurement of Power Frequency Electric and Magnetic Fields from AC Power Lines</i>
IEEE 739	<i>IEEE Recommended Practice for Energy Management in Commercial and Industrial Facilities (Bronze Book)</i>

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

IEEE 1015	<i>IEEE Recommended Practice for Applying Low-Voltage Circuit Breakers Used in Industrial and Commercial Power Systems (Blue Book)</i>
IEEE 1100	<i>IEEE Recommended Practice for Powering and Grounding Electronic Equipment (Emerald Book)</i>
IEEE 1106	<i>IEEE Recommended Practice for Maintenance, Testing, and Replacement of Nickel-Cadmium Batteries for Stationary Applications</i>
IEEE 1159	<i>IEEE Recommended Practice on Monitoring Electrical Power Quality</i>
IEEE 1188	<i>IEEE Recommended Practice for Maintenance, Testing, and Replacement of Valve-Regulated Lead-Acid (VRLA) Batteries for Stationary Applications</i>
IEEE 1526	<i>IEEE Recommended Practice for Testing the Performance of Stand-Alone Photovoltaic Systems</i>
IEEE 1547	<i>IEEE Standard for Interconnection and Interoperability of Distributed Energy Resources with Associated Electric Power Systems Interfaces</i>
IEEE 1584	<i>IEEE Guide for Arc Flash Hazard Calculations</i>
IEEE 3007.3	<i>Recommended Practice for Electrical Safety in Industrial and Commercial Power Systems</i>
8.	Insulated Cable Engineers Association - ICEA
ICEA S-93-639/NEMA WC 74	<i>5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy</i>
ICEA S-94-649	<i>Standard for Concentric Neutral Cables Rated 5,000 – 46,000 Volts</i>
ICEA S-97-682	<i>Standard for Utility Shielded Power Cables Rated 5,000 – 46,000 Volts</i>

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

9. InterNational Electrical Testing Association - NETA

ANSI/NETA ECS	<i>Standard for Electrical Commissioning of Electrical Power Equipment and Systems</i>
ANSI/NETA ETT	<i>Standard for Certification of Electrical Testing Technicians</i>
ANSI/NETA MTS	<i>Maintenance Testing Specifications for Electrical Power Equipment and Systems</i>

10. National Electrical Manufacturers Association – NEMA

NEMA AB4	<i>Guidelines for Inspection and Preventive Maintenance of Molded-Case Circuit Breakers Used in Commercial and Industrial Applications</i>
NEMA C84.1	<i>American National Standard for Electric Power Systems and Equipment - Voltage Ratings (60 Hertz)</i>
NEMA MG1	<i>Motors and Generators</i>

11. National Fire Protection Association – NFPA

NFPA 70	<i>National Electrical Code</i>
NFPA 70B	<i>Standard for Electrical Equipment Maintenance</i>
NFPA 70E	<i>Standard for Electrical Safety in the Workplace</i>
NFPA 99	<i>Health Care Facilities Code</i>
NFPA 101	<i>Life Safety Code</i>
NFPA 110	<i>Emergency and Standby Power Systems</i>
NFPA 111	<i>Standard on Stored Electrical Energy Emergency Systems and Standby Power Systems</i>
NFPA 780	<i>Installation of Lightning Protection Systems</i>

2. APPLICABLE REFERENCES

2.1 Codes, Standards, and Specifications

12. Occupational Safety and Health Administration – OSHA
13. State and local codes and ordinances
14. Underwriters Laboratories, Inc. – UL
UL 1449 *Surge Protective Devices*

2. APPLICABLE REFERENCES

2.2 Other References

2.2 Other References

Manufacturers instruction manuals for the equipment to be tested.

2. APPLICABLE REFERENCES

2.3 Contact Information

2.3 Contact Information

ASTM International – ASTM

www.astm.org

Association of Edison Illuminating Companies – AEIC

www.aeic.org

Canadian Standards Association – CSA

www.csa.ca

Electrical Apparatus Service Association – EASA

www.easa.com

Institute of Electrical and Electronic Engineers – IEEE

www.ieee.org

Insulated Cable Engineers Association – ICEA

c/o Global Document Engineers

www.icea.net

International Electrotechnical Commission – IEC

Contact through American National Standards Institute

InterNational Electrical Testing Association – NETA

3050 Old Centre Road, Suite 101

Portage, MI 49024

(269) 488-6382 or (888) 300-NETA (6382)

www.netaworld.org

National Electrical Manufacturers Association – NEMA

www.nema.org

National Fire Protection Association – NFPA

www.nfpa.org

Occupational Safety and Health Administration – OSHA

U.S. Department of Labor

Occupational Safety and Health Administration

www.osha.gov

Underwriters Laboratories, Inc. – UL

www.ul.com

3. QUALIFICATIONS OF TESTING ORGANIZATION AND PERSONNEL

3. QUALIFICATIONS OF TESTING ORGANIZATION AND PERSONNEL

3.1 Testing Organization

3.1 Testing Organization

1. The testing organization shall be an independent, third-party entity which can function as an unbiased testing authority, professionally independent of the manufacturers, suppliers, and installers of equipment or systems being evaluated.
2. The testing organization shall be regularly engaged in the testing of electrical equipment devices, installations, and systems.
3. The testing organization shall use technicians who are regularly employed for testing services.
4. The testing organization shall submit appropriate documentation to demonstrate that it satisfactorily complies with these requirements.

3. QUALIFICATIONS OF TESTING ORGANIZATION AND PERSONNEL

3.2 Testing Personnel

3.2 Testing Personnel

1. Technicians performing these electrical tests and inspections shall be trained and experienced concerning the apparatus and systems being evaluated. These individuals shall be capable of conducting the tests in a safe manner and with complete knowledge of the hazards involved. They must evaluate the test data and make a judgment on the serviceability of the specific equipment.
2. Technicians shall be certified in accordance with ANSI/NETA ETT, *Standard for Certification of Electrical Testing Technicians*. Each on-site crew leader shall hold a current certification, Level 3 or higher, in electrical testing.

4. DIVISION OF RESPONSIBILITY

4. DIVISION OF RESPONSIBILITY

4.1 The Owner's Representative

4.1 The Owner's Representative

The owner's representative shall provide the testing organization with the following:

1. A short-circuit analysis, a coordination study, and a protective device setting sheet as described in Section 6.
2. A complete set of electrical plans and specifications, including all change orders.
3. Drawings and instruction manuals applicable to the scope of work.
4. An itemized description of equipment to be inspected and tested.
5. A determination of who shall provide a suitable and stable source of electrical power to each test site.
6. A determination of who shall perform certain preliminary low-voltage insulation-resistance, continuity, and low-voltage motor rotation tests prior to and in addition to tests specified herein.
7. Notification of when equipment becomes available for acceptance tests. Work shall be coordinated to expedite project scheduling.
8. Site-specific hazard notification and safety training.

4. DIVISION OF RESPONSIBILITY

4.2 The Testing Organization

4.2 The Testing Organization

The testing organization shall provide the following:

1. All field technical services, tooling, equipment, instrumentation, and technical supervision to perform such tests and inspections.
2. Specific power requirements for test equipment.
3. Notification to the owner's representative prior to commencement of any testing.
4. A timely notification of any system, material, or workmanship that is found deficient based on the results of the acceptance tests.
5. A written record of all tests and a final report.

5. GENERAL

5. GENERAL

5.1 Safety and Precautions

5.1 Safety and Precautions

All parties involved must be cognizant of industry-standard safety procedures. This document does not contain any procedures including specific safety procedures. It is recognized that an overwhelming majority of the tests and inspections recommended in these specifications are potentially hazardous. Individuals performing these tests shall be qualified and capable of conducting the tests in a safe manner and with complete knowledge of the hazards involved.

1. Safety practices shall include, but are not limited to, the following requirements:
 1. All applicable provisions of the Occupational Safety and Health Act, particularly OSHA 29 CFR Part 1910 and 29 CFR Part 1926.
 2. NFPA 70E, *Standard for Electrical Safety in the Workplace*.
 3. Applicable state and local safety operating procedures.
 4. Owner's safety practices.
2. A safety lead person shall be identified prior to commencement of work.
3. A safety briefing shall be conducted prior to the commencement of work.
4. All tests shall be performed with the apparatus de-energized and temporary protective ground applied except where otherwise specifically required to be ungrounded or energized for certain tests.
5. The testing organization shall have a designated safety representative on the project to supervise operations with respect to safety. This individual may be the same person described in 5.1.2.

5. GENERAL

5.2 Suitability of Test Equipment

5.2 Suitability of Test Equipment

1. All test equipment shall meet the requirements in Section 5.3 and be in good mechanical and electrical condition.
2. Field test metering used to check power system meter calibration must be more accurate than the instrument being tested.
3. Accuracy of metering in test equipment shall be appropriate for the test being performed.
4. Waveshape and frequency of test equipment output waveforms shall be appropriate for the test and the tested equipment.

5. GENERAL

5.3 Test Instrument Calibration

5.3 Test Instrument Calibration

1. The testing organization shall have a calibration program which assures that all applicable test instruments are maintained within rated accuracy for each test instrument calibrated.
2. The firm providing calibration service shall maintain up-to-date instrument calibration instructions and procedures for each test instrument calibrated.
3. The accuracy shall be directly traceable to the National Institute of Standards and Technology (NIST) or ISO/IEC 17025, *General Requirements for the Competence of Testing and Calibration Laboratories*.
4. All test instruments shall be calibrated within 12 months of the date of test.
5. Dated calibration labels shall be visible on all test equipment.
6. Records which show date and results of instruments calibrated or tested must be kept up to date.
7. Calibrating standard shall be of higher accuracy than that of the instrument tested.

5. GENERAL

5.4 Test Report

5.4 Test Report

1. The test report shall include the following:
 1. Summary of project.
 2. Description of equipment tested.
 3. Description of tests.
 4. Device settings.
 5. Inspection and test data.
 6. Analysis and recommendations.
2. Test data records shall include the following minimum requirements:
 1. Identification of the testing organization.
 2. Equipment identification.
 3. Nameplate data.
 4. Conditions that may affect the results of the tests/calibrations such as humidity, temperature, and other conditions.
 5. Date of inspections, tests, maintenance, and/or calibrations.
 6. Identification of the testing technician.
 7. Indication of inspections, tests, maintenance, and/or calibrations to be performed and recorded.
 8. Indication of expected results when calibrations are to be performed.
 9. Indication of as-found and as-left results.
 10. Identification of all test results outside of specified tolerances.
 11. Sufficient spaces to allow all results and comments to be indicated.
3. The testing organization shall furnish a copy or copies of the complete report as specified in the acceptance testing contract.

5. GENERAL

5.5 Test Decal

5.5 Test Decal

1. The testing organization shall affix a test decal on the exterior of equipment or equipment enclosure of protective devices after performing electrical tests.
2. The test decal shall be color-coded to communicate the condition of maintenance for the protective device. Color scheme for condition of maintenance of overcurrent protective device shall be:
 1. White: electrically and mechanically acceptable.
 2. Yellow: minor deficiency not affecting fault detection and operation, but minor electrical or mechanical condition exists.
 3. Red: deficiency exists affecting performance, not suitable for service.
3. The decal shall include:
 1. Testing organization
 2. Project identifier
 3. Test date
 4. Technician identifier

6. POWER SYSTEM STUDIES

6. POWER SYSTEM STUDIES

6.1 Short-Circuit Studies

6.1 Short-Circuit Studies

1. Scope of Study

Determine the short-circuit current available at each component of the electrical system and the ability of the component to withstand and/or interrupt the current. Provide an analysis of all possible operating scenarios which will be or have been influenced by the proposed or completed additions or changes to the subject system.

2. Procedure

The short-circuit study shall be performed in accordance with the recommended practices and procedures set forth in IEEE 399 and the step-by-step procedures outlined in the short-circuit calculation chapters of IEEE 141, IEEE 242, and IEEE 551.

3. Study Report

Results of the short-circuit study shall be summarized in a final report containing the following items:

1. Basis, description, purpose, and scope of the study.
2. Tabulations of the data used to model the system components and a corresponding one-line diagram.
3. Descriptions of the scenarios evaluated and identification of the scenario used to evaluate equipment short-circuit current ratings.
4. Tabulations of equipment short-circuit current ratings versus available fault duties. The tabulation shall identify percentage of rated short circuit current and clearly note equipment with insufficient ratings.
5. Conclusions and recommendations.

6. POWER SYSTEM STUDIES

6.2 Coordination Studies

6.2 Coordination Studies

1. Scope of Study

1. Determine the extent of overcurrent protective device coordination for the scope:
 1. Selective coordination: determine the protective device types, characteristics, settings, or ampere ratings which provide selective coordination, equipment protection, and correct interrupting ratings for the full range of available short circuit currents at points of application for each overcurrent protective device.
 2. Compromised coordination: determine protective device types, characteristics, settings, or ampere ratings which permit ranges of non-coordination of overcurrent protective devices.
2. Provide an analysis of possible operating scenarios which will be or have been influenced by the proposed or completed additions or changes to the subject system.

2. Procedure

The coordination study shall be performed in accordance with the recommended practices and procedures set forth in IEEE 399 and IEEE 242. Protective device selection and settings shall comply with requirements of NFPA 70 *National Electrical Code*.

3. Study Report

Results of the coordination study shall be summarized in a final report containing the following items:

1. Basis, description, purpose, and scope of the study and a corresponding one-line diagram.
2. Time-current curves, selective coordination ratios of fuses, or selective coordination tables of circuit breakers demonstrating the coordination of overcurrent protective devices to the scope.
3. Tabulations of protective devices identifying circuit location, manufacturer, type, range of adjustment, IEEE device number, current transformer ratios, recommended settings or device size, and referenced time-current curve.
4. Conclusions and recommendations.

6. POWER SYSTEM STUDIES

6.3 Incident Energy Analysis

6.3 Incident Energy Analysis

1. Scope of Study

Determine arc-flash incident energy levels and flash-protection boundary distances based on the results of the short-circuit and coordination studies. Perform the analysis under worst-case arc-flash conditions for all modes of operation. Provide an analysis of all possible operating scenarios which will be or have been influenced by the proposed or completed additions to the subject system.

2. Procedure

Identify all locations and equipment to be included in the incident energy analysis.

1. Prepare a one-line diagram of the power system.
2. Perform a short-circuit study in accordance with Section 6.1.
3. Perform a coordination study in accordance with Section 6.2.
4. Identify the possible system operating modes including tie-breaker positions, and parallel generation.
5. Calculate the arcing fault current flowing through each branch for each fault location in accordance with NFPA 70E, IEEE 1584, OSHA 1910.269, or other applicable standards.
6. Determine the time required to clear the arcing fault current using the protective device settings and associated trip curves.
7. Select the working distances based on system voltage and equipment class.
8. Calculate the incident energy at each fault location at the prescribed working distance.
9. Determine the arc-flash PPE for the calculated incident energy level.
10. Calculate the flash protection boundary at each fault location.
11. Document the assessment in reports and one-line diagrams.
12. Place appropriate labels on the equipment.

6. POWER SYSTEM STUDIES

6.3 Incident Energy Analysis

3. Study Report

Results of the arc-flash study shall be summarized in a final report containing the following items:

1. Basis, method of hazard assessment, description, purpose, scope, and date of the study.
2. Tabulations of the data used to model the system components and a corresponding one-line diagram.
3. Descriptions of the scenarios evaluated and identification of the scenario used to develop incident-energy levels and arc-flash boundaries.
4. Tabulations of equipment incident energies and arc-flash boundaries.
5. List of required arc-flash labels and locations.
6. Conclusions and recommendations.

6. POWER SYSTEM STUDIES

6.4 Load-Flow Studies

6.4 Load-Flow Studies

1. Scope of Study

Determine active and reactive power, voltage, current, and power factor throughout the electrical system. Provide an analysis of all possible operating scenarios.

2. Procedure

The load-flow study shall be performed in accordance with the recommended practices and procedures set forth in IEEE 399.

3. Study Report

Results of the load-flow study shall be summarized in a final report containing the following items:

1. Basis, description, purpose, and scope of the study.
2. Tabulations of the data used to model the system components and a corresponding one-line diagram.
3. Descriptions of the scenarios evaluated and the basis for each.
4. Tabulations of power and current flow versus equipment ratings. The tabulation shall identify percentage of rated load and the scenario for which the percentage is based. Overloaded equipment shall be clearly noted.
5. Tabulations of system voltages versus equipment ratings. The tabulation shall identify percentage of rated voltage and the scenario for which the percentage is based. Voltage levels outside the ranges recommended by equipment manufacturers, NEMA C84.1, or other appropriate standards shall be clearly noted.
6. Tabulations of system real and reactive power losses with areas of concern clearly noted.
7. Conclusions and recommendations.

6. POWER SYSTEM STUDIES

6.5 Stability Studies

6.5 Stability Studies

1. Scope of Study

Determine the ability of the electrical system's synchronous machines to remain in step with one another following a disturbance. Provide an analysis of disturbances for all possible operating scenarios which will be or have been influenced by the proposed or completed additions or changes to the subject system.

2. Procedure

The stability study shall be performed in accordance with the recommended practices and procedures set forth in IEEE 399.

3. Study Report

Results of the stability study shall be summarized in a final report containing the following items:

1. Basis, description, purpose, and scope of the study.
2. Tabulations of the data used to model the system components and a corresponding one-line diagram.
3. Descriptions of the scenarios evaluated and tabulations or graphs showing the calculation results.
4. Conclusions and recommendations.

6. POWER SYSTEM STUDIES

6.6 Harmonic-Analysis Studies

6.6 Harmonic-Analysis Studies

1. Scope of Study

Determine the impact of nonlinear loads and their associated harmonic contributions on the voltage and currents throughout the electrical system. Provide an analysis of all possible operating scenarios which will be or have been influenced by the proposed or completed additions or changes to the subject system.

2. Procedure

The harmonic-analysis study shall be performed in accordance with the recommended practices and procedures set forth in IEEE 399.

3. Study Report

Results of the harmonic-analysis study shall be summarized in a final report containing the following items:

1. Basis, description, purpose, and scope of the study.
2. Tabulations of the data used to model the system components and a corresponding one-line diagram.
3. Descriptions of the scenarios evaluated and the basis for each.
4. Tabulations of rms voltages, peak voltages, rms currents, and total capacitor bank loading versus associated equipment ratings. Equipment with insufficient ratings shall be clearly identified for each of the scenarios evaluated.
5. Tabulations of calculated voltage-distortion factors, current-distortion factors, and individual harmonics versus the limits specified by IEEE 519. Calculated values exceeding the limits specified in the standard shall be clearly noted.
6. Plots of impedance versus frequency showing resonant frequencies to be avoided.
7. Tabulations of the system transformer capabilities based on the calculated nonsinusoidal load current and the procedures set forth in IEEE C57.110. Overloaded transformers shall be clearly noted.
8. Conclusions and recommendations.

7. INSPECTION AND TEST PROCEDURES

7. INSPECTION AND TEST PROCEDURES

7.1.1 Switchgear and Switchboard Assemblies

7.1.1 Switchgear and Switchboard Assemblies

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical, electrical, and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required area clearances.
4. Verify the unit is clean and all shipping bracing, loose parts, and documentation shipped inside cubicles have been removed.
5. Compare mimic diagram and device labeling with drawings.
6. Verify that fuse and circuit breaker sizes and types correspond to drawings and coordination study as well as to the circuit breaker address for microprocessor-communication packages.
7. Verify that current and voltage transformer ratios correspond to drawings.
8. Verify that wiring connections are tight and that wiring is secure to prevent damage during routine operation of moving parts.
9. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.1.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
10. Confirm correct operation and sequencing of electrical and mechanical interlock systems.
 1. Attempt closure on locked-open devices. Attempt to open locked-closed devices.
 2. Make key exchange with all devices included in the interlock scheme.
11. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
12. Inspect insulators for evidence of physical damage or contaminated surfaces.
13. Verify correct barrier and shutter installation and operation.
14. Exercise all active components.
15. Inspect mechanical indicating devices for correct operation.
16. Verify that filters are in place and vents are clear.

7. INSPECTION AND TEST PROCEDURES

7.1.1 Switchgear and Switchboard Assemblies

17. Perform visual and mechanical inspection of instrument transformers in accordance with Section 7.10.
18. Perform visual and mechanical inspection of surge arresters in accordance with Section 7.19.
19. Inspect control power transformers.
 1. Inspect for physical damage, cracked insulation, broken leads, tightness of connections, defective wiring, and overall general condition.
 2. Verify that primary and secondary fuse or circuit breaker ratings match drawings.
 3. Verify correct functioning of drawout disconnecting contacts, grounding contacts, and interlocks.
20. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted electrical connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests for one minute on each bus section, phase-to-phase and phase-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
3. Perform a dielectric withstand voltage test on each bus section, each phase-to-ground with phases not under test grounded, in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.2. The test voltage shall be applied for one minute. Refer to Section 7.13 before performing tests.
4. *Perform insulation-resistance tests on control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components or control devices that cannot tolerate the applied voltage, follow the manufacturer's recommendation.
5. Perform electrical tests on instrument transformers in accordance with Section 7.10.
6. Perform ground-resistance tests in accordance with Section 7.13.
7. Test metering devices in accordance with Section 7.11.
8. Control Power Transformers

7. INSPECTION AND TEST PROCEDURES

7.1.1 Switchgear and Switchboard Assemblies

1. Perform insulation-resistance tests. Perform measurements from winding-to-winding and each winding-to-ground. Test voltages shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
 2. Perform a turns-ratio test on all tap positions.
 3. Perform secondary wiring integrity test. Disconnect transformer at secondary terminals and connect secondary wiring to a rated secondary voltage source. Verify correct potential at all devices.
 4. Verify correct secondary voltage by energizing the primary winding with system voltage. Measure secondary voltage with the secondary wiring disconnected.
 5. Verify correct function of control transfer relays located in the switchgear with multiple control power sources.
9. Voltage Transformers
1. Perform secondary wiring integrity test. Verify correct potential at all devices.
 2. Verify secondary voltages by energizing the primary winding with system voltage.
10. Perform current-injection tests on the entire current circuit in each section of switchgear.
1. Perform current tests by secondary injection with magnitudes such that a minimum current of 1.0 ampere flows in the secondary circuit. Verify correct magnitude of current at each device in the circuit.
 2. *Perform current tests by primary injection with magnitudes such that a minimum of 1.0 ampere flows in the secondary circuit. Verify correct magnitude of current at each device in the circuit.
11. Perform system function tests in accordance with ANSI/NETA ECS *Standard for Electrical Commissioning Specifications for Electrical Power Equipment and Systems*.
12. Verify operation of cubicle switchgear/switchboard space heaters and their controller.
13. Perform phasing checks on double-ended or dual-source switchgear to ensure correct bus phasing from each source.
14. Perform electrical tests of surge arresters in accordance with Section 7.19.
15. *Perform online partial-discharge survey in accordance with Section 11.

7. INSPECTION AND TEST PROCEDURES

7.1.1 Switchgear and Switchboard Assemblies

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.1.1.A.9)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.1.1.A.20)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values of bus insulation shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests shall not proceed until insulation-resistance levels are raised above minimum values.
3. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
4. Minimum insulation resistance values of control wiring shall not be less than two megohms.
5. Results of electrical tests on instrument transformers shall be in accordance with Section 7.10.
6. Results of ground resistance tests shall be in accordance with Section 7.13.
7. Accuracy of metering devices shall be in accordance with Section 7.11.
8. Control Power Transformers
 1. Insulation-resistance values of control power transformers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
 2. Turns-ratio test results shall not deviate by more than one-half percent from either the adjacent coils or the calculated ratio.
 3. Secondary wiring shall be in accordance with design drawings and specifications.
 4. Secondary voltage shall be in accordance with design specifications.

7. INSPECTION AND TEST PROCEDURES

7.1.1 Switchgear and Switchboard Assemblies

5. Control transfer relays shall perform as designed.
9. Voltage transformers
 1. Secondary wiring shall be in accordance with design drawings and specifications.
 2. Secondary voltage shall be in accordance with design specifications
10. Current-injection tests shall prove current wiring is in accordance with design specifications.
11. Results of system function tests shall be in accordance with ANSI/NETA ECS.
12. Heaters shall be operational.
13. Phasing checks shall prove the switchgear or switchboard phasing is correct and in accordance with the system design.
14. Results of electrical tests on surge arresters shall be in accordance with Section 7.19.
15. Results of online partial-discharge survey should be in accordance with manufacturer's published data. In the absence of manufacturer's data, refer to Table 100.23.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.1.2 Panelboard Assemblies

7.1.2 Panelboard Assemblies

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical, electrical, and mechanical condition.
3. Inspect anchorage, alignment, grounding, bonding, and required area clearances.
4. Verify the unit is clean and all shipping bracing and loose parts have been removed.
5. Verify that fuse and circuit breaker sizes and types correspond to drawings and coordination study.
6. Verify that wiring connections are tight, and that wiring is secure to prevent damage during routine operation of moving parts.
7. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
8. Inspect insulators for evidence of physical damage or contaminated surfaces.
9. Verify correct barrier installation.
10. Perform visual and mechanical inspection on surge protective devices.
11. Exercise all active components.
12. *Perform thermographic survey in accordance with Section 9

B. Electrical Tests

1. Perform insulation-resistance tests for one minute on each bus section, phase-to-phase and phase-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
2. Perform ground-resistance tests in accordance with Section 7.13.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.1.2.A.7)

7. INSPECTION AND TEST PROCEDURES

7.1.2 Panelboard Assemblies

D. Test Values – Electrical

1. Insulation-resistance values of bus insulation shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests shall not proceed until insulation-resistance levels are raised above minimum values.
2. Results of ground resistance tests shall be in accordance with Section 7.13.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.2.1.1 Transformers, Dry-Type, Air-Cooled, Low-Voltage, Small

7.2.1.1 Transformers, Dry-Type, Air-Cooled, Low-Voltage, Small

NOTE: This category consists of power transformers with windings rated 600 volts or less and sizes equal to or less than 167 kVA single-phase or 500 kVA three phase.

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify that resilient mounts are free and that any shipping brackets have been removed.
5. Verify the unit is clean.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.2.1.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify that as-left tap connections are as specified.
8. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests winding-to-winding and each winding-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Calculate the dielectric absorption ratio or polarization index.
3. Verify correct turns ratio at the designated tap position using one or more of the following methods:
 1. Perform turns-ratio tests at the designated tap position.
 2. Verify correct secondary voltage phase-to-phase and phase-to-neutral after energization and prior to loading.

7. INSPECTION AND TEST PROCEDURES

7.2.1.1 Transformers, Dry-Type, Air-Cooled, Low-Voltage, Small

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.2.1.1.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.2.1.1.A.8)
3. Tap connections are left as found unless otherwise specified. (7.2.1.1.A.7)

D. Test Values – Electrical

1. Compare bolted electrical connection resistances to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Minimum insulation-resistance values of transformer insulation shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. The dielectric absorption ratio or polarization index shall not be less than 1.0.
3. Turns-ratio Test and Phase-to-Phase:
 1. Turns-ratio test results shall not deviate by more than one-half percent from either the adjacent coils or the calculated ratio.
 2. Phase-to-phase and phase-to-neutral secondary voltages shall be in agreement with nameplate data.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.2.1.2 Transformers, Dry-Type, Air-Cooled, Large

7.2.1.2 Transformers, Dry-Type, Air-Cooled, Large

NOTE: This category consists of power transformers with windings rated higher than 600 volts and low-voltage transformers larger than 167 kVA single-phase or 500 kVA three-phase.

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify that resilient mounts are free and that any shipping brackets have been removed.
5. Verify the unit is clean.
6. *Verify that control and alarm settings on temperature indicators are as specified.
7. Verify that cooling fans operate and that fan motors have correct overcurrent protection.
8. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.2.1.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
9. Perform specific inspections and mechanical tests as recommended by the manufacturer.
10. Verify that as-left tap connections are as specified.
11. Verify the presence of surge arresters.
12. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests winding-to-winding and each winding-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data use Table 100.5. Calculate dielectric absorption ratio and polarization index.
3. *Perform power-factor or dissipation-factor tests on all windings in accordance with the test equipment manufacturer's published data.

7. INSPECTION AND TEST PROCEDURES

7.2.1.2 Transformers, Dry-Type, Air-Cooled, Large

4. *Perform a power-factor or dissipation-factor tip-up test on windings rated greater than 2.5 kV.
5. Perform turns-ratio tests at all tap positions.
6. *Perform an excitation-current test on each phase.
7. Measure the resistance of each winding at each tap connection. The test current should not exceed 10% of rated current.
8. Measure core insulation resistance at 500 volts dc if the core is insulated and the core ground strap is removable.
9. *Perform an applied voltage test on all high- and low-voltage windings-to-ground. See IEEE C57.12.91.
10. *Verify correct secondary voltage, phase-to-phase and phase-to-neutral, after energization and prior to loading.
11. Test surge arresters in accordance with Section 7.19.
12. *Perform online partial-discharge survey on windings rated higher than 1000 volts in accordance with Section 11.

C. Test Values – Visual and Mechanical

1. Control and alarm settings on temperature indicators shall operate within manufacturer's recommendations for specified settings. (7.2.1.2.A.6)
2. Cooling fans shall operate. (7.2.1.2.A.7)
3. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.2.1.2.A.8)
4. Results of the thermographic survey shall be in accordance with Section 9. (7.2.1.2.A.12)
5. Tap connections shall be left as found unless otherwise specified. (7.2.1.2.A.10)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.2.1.2 Transformers, Dry-Type, Air-Cooled, Large

2. Minimum insulation-resistance values of transformer insulation shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. The dielectric absorption ratio and polarization index shall not be less than 1.0.
3. The following values are typical for insulation power factor tests:
 1. C_{HL} Power transformers: 2.0 percent or less.
 2. C_{HL} Distribution transformers: 5.0 percent or less
 3. C_H and C_L power-factor or dissipation-factor values will vary due to support insulators and bus work utilized on dry transformers. Consult transformer manufacturer's or test equipment manufacturer's data for additional information.
4. Power-factor or dissipation-factor tip-up exceeding 1.0 percent shall be investigated.
5. Turns-ratio test results shall not deviate more than one-half percent from either the adjacent coils or the calculated ratio.
6. The typical excitation current test data pattern for a three-legged core transformer is two similar current readings and one lower current reading. The test should produce a pattern typical for the specific transformer type and configuration.
7. Temperature-corrected winding-resistance values shall compare within one percent of previously obtained results.
8. Core insulation-resistance values shall not be less than one megohm at 500 volts dc.
9. AC dielectric withstand test voltage shall not exceed 75 percent of factory test voltage for one minute duration. DC dielectric withstand test voltage shall not exceed 100 percent of the ac rms test voltage specified in IEEE C57.12.91. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
10. Phase-to-phase and phase-to-neutral secondary voltages shall be in agreement with nameplate data.
11. Test results for surge arresters shall be in accordance with Section 7.19.
12. Results of online partial-discharge survey should be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.23.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.2.2 Transformers, Liquid-Filled

7.2.2 Transformers, Liquid-Filled

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect impact recorder prior to unloading.
4. *Test dew point of tank gases.
5. Inspect anchorage, alignment, and grounding.
6. Verify the presence of PCB content labeling.
7. Verify removal of any shipping bracing after placement.
8. Verify the bushings are clean.
9. Verify that alarm, control, and trip settings on temperature and level indicators are as specified.
10. Verify operation of alarm, control, and trip circuits from temperature and level indicators, pressure relief device, gas accumulator, and fault pressure relay.
11. Verify that cooling fans and pumps operate correctly and have appropriate overcurrent protection.
12. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.2.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
13. Verify correct liquid level in tanks and bushings.
14. Verify valves are in the correct operating position.
15. Verify that positive pressure is maintained on gas-blanketed transformers.
16. Perform inspections and mechanical tests as recommended by the manufacturer.
17. Test load tap-changer in accordance with Section 7.12.3.
18. Verify presence of transformer surge arresters.
19. Verify de-energized tap-changer position is left as specified.

7. INSPECTION AND TEST PROCEDURES

7.2.2 Transformers, Liquid-Filled

20. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests, winding-to-winding and each winding-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Calculate dielectric absorption ratio and polarization index.
3. Perform turns-ratio tests at all tap positions.
4. Perform insulation power-factor or dissipation-factor tests on all windings in accordance with test equipment manufacturer's published data.
5. Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/ capacitance tap. In the absence of a power-factor/capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
6. Perform excitation-current tests in accordance with test equipment manufacturer's published data.
7. *Perform sweep frequency response analysis tests.
8. Measure the resistance of each winding at each tap connection. Test current not to exceed 10 percent rated current according to IEEE C57.152.
9. *Perform dynamic resistance measurement for load tap changer.
10. *Perform leakage reactance three phase equivalent and per phase tests.
11. *If core ground strap is accessible, remove and measure core insulation resistance at 500 volts dc.
12. *Measure the percentage of oxygen in the gas blanket.
13. *Perform dielectric frequency response test in accordance with test equipment manufacturer's published data.
14. Remove a sample of insulating liquid in accordance with ASTM D923. Sample shall be tested for the following:
 1. Dielectric breakdown voltage: ASTM D1816

7. INSPECTION AND TEST PROCEDURES

7.2.2 Transformers, Liquid-Filled

2. Acid neutralization number: ASTM D974
3. Specific gravity: ASTM D1298
4. Interfacial tension: ASTM D971
5. Color: ASTM D1500
6. Visual Condition: ASTM D1524
7. Water in insulating liquids: ASTM D1533.
8. Power factor or dissipation factor in accordance with ASTM D924.
15. Remove a sample of insulating liquid in accordance with ASTM D923 and perform dissolved-gas analysis (DGA) in accordance with IEEE C57.104 or ASTM D3612.
16. Test instrument transformers in accordance with Section 7.10.
17. Test surge arresters in accordance with Section 7.19.
18. Test transformer neutral grounding impedance device.
19. Verify operation of cubicle or air terminal compartment space heaters.

C. Test Values – Visual and Mechanical

1. Alarm, control, and trip circuits from temperature and level indicators as well as pressure relief device and fault pressure relay shall operate within manufacturer's recommendations for their specified settings. (7.2.2.A.10)
2. Cooling fans and pumps shall operate. (7.2.2.A.11)
3. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.2.2.A.12)
4. Results of the thermographic survey shall be in accordance with Section 9. (7.2.2.A.20)
5. Liquid levels in the transformer tanks and bushings shall be within indicated tolerances. (7.2.2.A.13)
6. Positive pressure shall be indicated on pressure gauge for gas-blanketed transformers. (7.2.2.A.15)

7. INSPECTION AND TEST PROCEDURES

7.2.2 Transformers, Liquid-Filled

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Minimum insulation-resistance values of transformer insulation shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. The polarization index shall not be less than 1.0.
3. Turns-ratio test results shall not deviate by more than one-half percent from either the adjacent coils or the calculated ratio.
4. Maximum insulation power-factor/dissipation-factor values of liquid-filled transformers corrected to 20°C shall be in accordance with the manufacturer's published data. In the absence of manufacturer's data, use Table 100.3. Distribution transformer power factor results shall compare to previously obtained results.
5. Investigate bushing power-factor values that vary from nameplate values by more than 50 percent. Investigate bushing capacitance values that vary from nameplate values by more than five percent. Investigate bushing hot-collar test values that exceed 0.1 Watts.
6. The typical excitation-current test data pattern for a three-legged core transformer is two similar current readings and one lower current reading. The test should produce a pattern typical for the specific transformer type and configuration.
7. Sweep frequency response analysis test results should compare to factory and previous test results.
8. Temperature corrected winding-resistance values shall compare within two percent of previously obtained results or between adjacent phases.
9. Dynamic resistance measurements results shall compare to previous test results.
10. Investigate leakage reactance three phase equivalent test results that deviate from the nameplate by more than 3%. The per phase test results serve as a benchmark for future tests and should not deviate from the average of the three readings by more than 3%.
11. Core insulation resistance values shall be comparable to the factory test value but not less than 500 megohms at 500 volts dc.
12. Investigate the presence of oxygen in the nitrogen gas blanket.

7. INSPECTION AND TEST PROCEDURES

7.2.2 Transformers, Liquid-Filled

13. Dielectric frequency response analysis should compare to previous test results and published moisture limits for solid insulation.
14. Insulating liquid values shall be in accordance with Table 100.4.
15. Evaluate results of dissolved-gas analysis in accordance with IEEE C57.104.
16. Results of electrical tests on instrument transformers shall be in accordance with Section 7.10.
17. Results of surge arrester tests shall be in accordance with Section 7.19.
18. Compare grounding impedance device values to manufacturer's published data.
19. Heaters shall be operational.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.3.1 Cables, Low-Voltage, Low-Energy

7.3.1 Cables, Low-Voltage, Low-Energy

—RESERVED—

7. INSPECTION AND TEST PROCEDURES

7.3.2 Cables, Low-Voltage, 1,000-Volt Maximum

7.3.2 Cables, Low-Voltage, 1,000-Volt Maximum

A. Visual and Mechanical Inspection

1. Compare cable data with drawings and specifications.
2. Inspect exposed sections of cables and connectors for physical damage, proper termination, and correct connection in accordance with the single-line diagram.
3. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
4. Inspect compression-applied connectors for correct cable match and indentation.
5. Inspect for correct identification and arrangements.
6. Inspect cable jacket insulation and condition.
7. If cables are terminated through window-type current transformers, inspect to verify that neutral and ground conductors are correctly placed for operation of protective devices.
8. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform an insulation-resistance test on each phase/conductor with all other phase/conductors grounded. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute.
2. Perform continuity tests to ensure correct cable connection.
3. *Verify uniform resistance of parallel conductors.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.3.2.A.3)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.3.2.A.8)

D. Test Values – Electrical

1. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated.

7. INSPECTION AND TEST PROCEDURES

7.3.2 Cables, Low-Voltage, 1,000-Volt Maximum

2. Cable shall exhibit continuity.
3. Deviations in resistance between parallel conductors shall be investigated.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.3.3 Shielded Cables, Medium- and High-Voltage

7.3.3 Shielded Cables, Medium- and High-Voltage

Note: In accordance with ICEA, IEC, IEEE and other power cable consensus standards, testing can be performed by means of direct current, power frequency alternating current, very low frequency alternating current, or damped alternating current. These sources may be used to perform insulation-withstand tests, and baseline diagnostic tests such as partial discharge analysis, and power factor or dissipation factor. The selection shall be made after an evaluation of the available test methods and a review of the installed cable system. Some of the available test methods are listed below.

A. Visual and Mechanical Inspection

1. Compare cable data with drawings and specifications.
2. Inspect terminations, splices, and exposed sections of cables for physical damage.
3. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
4. Inspect compression-applied connectors for correct cable match and indentation.
5. Inspect shield grounding and cable supports.
6. Verify that visible cable bends are not less than ICEA and/or manufacturer's minimum allowable bending radius.
7. *Inspect fireproofing in common cable areas.
8. If cables are terminated through window-type current transformers, inspect to verify that neutral and ground conductors are correctly placed and that shields are correctly terminated for operation of protective devices.
9. Inspect for correct identification and arrangements.
10. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform an insulation-resistance test individually between each phase/conductor and its shield with all other phase/conductors and shields grounded. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1.
2. Perform a shield-continuity test on each power cable by ohmmeter method.

7. INSPECTION AND TEST PROCEDURES

7.3.3 Shielded Cables, Medium- and High-Voltage

3. *Perform cable time domain reflectometer (TDR) measurements on each conductor.
4. *Perform a jacket integrity test for one minute. Use voltage in accordance with manufacturer's published data. In the absence of manufacturer's data use a minimum of 2 kV for cables up to 35 kV and minimum of 5 kV for cables rated higher than 35 kV.
5. Perform a dielectric withstand test using one or more of the following methods. Note the voltage may need to be limited due to power supply chosen and cable terminations, splices, and accessories.
 1. Direct current (DC) dielectric withstand test at maximum voltage on individual conductors with all shields and all conductors not under test grounded. Follow manufacturer's published data. In the absence of cable and accessory manufacturers' data see Table 100.6.1 for extruded dielectric insulation less than 5 years in service (DC potential testing is not recommended for extruded dielectric cables. Check cable and accessory manufacturers' published data) and Table 100.6.2 for laminated dielectric insulation.
 2. Very low frequency (VLF) dielectric withstand test - minimum 30-minute test on individual or grouped conductors with all shields and all conductors not under test grounded. Follow cable and accessory manufacturers' published data for voltage level. Should the circuit be considered of critical importance, longer time is recommend (see Appendix B). Follow cable and accessory manufacturers' published data. In the absence of cable and accessory manufacturers' published data see Table 100.6.3.
 3. Power frequency (20 Hz – 300 Hz) dielectric withstand test -60 minutes at maximum voltage on individual or grouped cables in accordance with cable and accessory manufacturers' published data. In the absence of cable and accessory manufacturers' published data see Table 100.6.5.
6. *Perform a tan-delta (insulation power factor/dissipation factor) test on each individual conductor with all shields and all conductors not under test grounded. In the absence of cable and accessory manufacturers' published data see Table 100.6.6 and Table 100.6.7. Record stability and mean tan-delta values at each step.
7. *Perform an online partial discharge (PD) test. Record ambient noise floor, waveform, and phase-resolved PD pattern of any PD detected.

7. INSPECTION AND TEST PROCEDURES

7.3.3 Shielded Cables, Medium- and High-Voltage

8. *Perform an offline partial discharge (PD) test. Record average or peak ambient background noise floor, PD calibration pulse, and any relevant PD, noting location, amplitude, repetition, PD inception, PD extinction voltage thresholds for cable and accessories, and phase resolved pattern. Follow cables and accessory manufacturers' published data for cable accessories, any connected equipment, and test equipment. In the absence of cable and accessory manufacturers' published data see Table 100.6.3, 100.6.4, and 100.6.5 for maximum voltage levels.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels should be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.3.3.A.3)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.3.3.A.10)
3. Cable bends should not be less than ICEA and/or manufacturer's minimum allowable bending radius. In the absence of manufacturer's data refer to Table 100.22. The minimum bend radius to which insulated cables may be bent for permanent training shall be in accordance with Table 100.22. (7.3.3.A.6)

D. Test Values – Electrical

1. Insulation-resistance values should be in accordance with manufacturer's published data. Conductor and insulation geometry, temperature, and overall cable length need to be taken into account in accordance with manufacturer's published data for definitive minimum insulation resistance criteria.
2. Shielding shall exhibit continuity. Investigate resistance values in excess of ten ohms per 1000 feet of cable.
3. TDR graphical measurements shall clearly identify the cable length and characteristic should be consistent with other phases.
4. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the test, the test specimen is considered to have passed the test.
5. If no evidence of distress (distortion of applied waveform, overload/trip) or insulation failure is observed by the end of the total time of voltage application during the test, the test specimen is considered to have passed the test.
6. For evaluation of tan-delta results see Table 100.6.7 or IEEE 400.2.

7. INSPECTION AND TEST PROCEDURES

7.3.3 Shielded Cables, Medium- and High-Voltage

7. There should be no evidence of partial discharge during online testing. Any environmental background noise should be filtered out or eliminated from the reported PD measurements. Record any PD originating from the cable, including amplitude, repetition, and phase pattern of PD relative to the system voltage, to help determine internal, surface, and corona type PD.
8. There shall be no evidence of offline partial discharge at or below the PD voltage threshold limits in accordance with manufacturer's published data or IEEE 400.3.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.4 Metal-Enclosed Busways

7.4 Metal-Enclosed Busways

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify correct connection in accordance with single-line diagram.
5. Verify tightness of accessible bolted electrical connections and bus joints by calibrated torque-wrench method or in accordance with 7.4.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Confirm physical orientation in accordance with manufacturer's labels to ensure adequate cooling.
7. Verify weep or drain plugs are in accordance with manufacturer's published data.
8. Verify correct installation of joint shield.
9. Verify ventilating openings are clean.
10. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections and bus joints with a low-resistance ohmmeter.
2. Perform insulation resistance tests on each busway for one minute, phase-to-phase and phase-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
3. Perform a dielectric withstand voltage test on each busway, phase-to-ground with phases not under test grounded, in accordance with manufacturer's published data. If manufacturer has no recommendation for this test, it shall be in accordance with Table 100.17. Where no dc test value is shown in Table 100.17, an ac value shall be used.
4. Measure connection resistance of assembled busway with a low-resistance ohmmeter.
5. Perform phasing test on each busway tie section energized by separate sources. Tests must be performed from their permanent sources.

7. INSPECTION AND TEST PROCEDURES

7.4 Metal-Enclosed Busways

6. Verify operation of busway space heaters.
7. *Perform online partial-discharge survey in accordance with Section 11.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels should be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.4.A.5)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.4.A.10)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Metal-Enclosed Busways
 - a. Low-Voltage Metal-Enclosed Busways - Insulation-resistance test voltages and minimum insulation resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, insulation resistance values are to be corrected to a nominal 100-foot busway run. Use the following formula to determine the minimum insulation resistance value, in Megohms, to a 100-foot nominal value:

$$\text{Minimum Megohm Value} = 100 \div [\text{busway length in feet}]$$

Converted values of insulation resistance less than manufacturer's minimum or less than the corrected minimum Megohm value should be investigated. Dielectric withstand voltage tests should not proceed until insulation-resistance levels are raised above minimum values.
 - b. Medium-Voltage Metal-Enclosed Busways – Insulation-resistance test voltages and resistance values shall be in accordance with the manufacturer's published data or Table 100.1.
3. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
4. Connection-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values which deviate from those of similar bus connections and sections by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.4 Metal-Enclosed Busways

5. Phasing test results shall indicate the phase relationships are in accordance with system design.
6. Heaters shall be operational.
7. Results of online partial-discharge survey should be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.23.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.5.1.1 Switches, Air, Low-Voltage

7.5.1.1 Switches, Air, Low-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Verify correct blade alignment, blade penetration, travel stops, and mechanical operation.
6. Verify that fuse sizes and types are in accordance with drawings, short-circuit studies, and coordination study.
7. Verify that each fuse has adequate mechanical support and contact integrity.
8. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.5.1.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
9. Verify operation and sequencing of interlocking systems.
10. Verify correct phase barrier installation.
11. Verify correct operation of all indicating and control devices.
12. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
13. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Measure contact resistance across each switchblade and fuseholder.
3. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.

7. INSPECTION AND TEST PROCEDURES

7.5.1.1 Switches, Air, Low-Voltage

4. Measure fuse resistance.
5. Verify cubicle space heater operation.
6. Perform ground fault test in accordance with Section 7.14.
7. Perform tests on other protective devices in accordance with Section 7.9.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.5.1.1.A.8)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.5.1.1.A.13)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.
3. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated.
4. Investigate fuse-resistance values that deviate from each other by more than 15 percent.
5. Heaters shall be operational.
6. Ground fault tests shall be in accordance with Section 7.14.
7. Results of protective device tests shall be in accordance with Section 7.9.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.5.1.2 Switches, Air, Medium-Voltage, Metal-Enclosed

7.5.1.2 Switches, Air, Medium-Voltage, Metal-Enclosed

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Verify correct blade alignment, blade penetration, travel stops, arc interrupter operation, and mechanical operation.
6. Verify that fuse sizes and types are in accordance with drawings, short-circuit study, and coordination study.
7. Verify that expulsion-limiting devices are in place on all fuses having expulsion-type elements.
8. Verify that each fuseholder has adequate mechanical support and contact integrity.
9. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.5.1.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
10. Verify operation and sequencing of interlocking systems.
11. Verify correct phase barrier installation.
12. Verify correct operation of all indicating and control devices.
13. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
14. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Measure contact resistance across each switchblade assembly and fuseholder.

7. INSPECTION AND TEST PROCEDURES

7.5.1.2 Switches, Air, Medium-Voltage, Metal-Enclosed

3. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
4. Perform a dielectric withstand voltage test on each pole with switch closed. Test each pole-to-ground with all other poles grounded. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.2.
5. Measure fuse resistance.
6. Verify cubicle space heater operation.
7. *Perform online partial-discharge survey in accordance with Section 11.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.5.1.2.A.9)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.5.1.2.A.14)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.
3. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests shall not proceed until insulation-resistance levels are raised above minimum values.
4. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
5. Investigate fuse resistance values that deviate from each other by more than 15 percent.
6. Heaters shall be operational.

7. INSPECTION AND TEST PROCEDURES

7.5.1.2 Switches, Air, Medium-Voltage, Metal-Enclosed

7. Results of online partial-discharge survey shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, refer to Table 100.23.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.5.1.3 Switches, Air, Medium- and High-Voltage, Open

7.5.1.3 Switches, Air, Medium- and High-Voltage, Open

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Perform mechanical operator tests in accordance with manufacturer's published data.
6. Verify correct operation and adjustment of motor operator limit switches and mechanical interlocks.
7. Verify correct blade alignment, blade penetration, travel stops, arc interrupter operation, and mechanical operation.
8. Verify operation and sequencing of interlocking systems.
9. Verify that each fuse has adequate mechanical support and contact integrity.
10. Verify that fuse sizes and types are in accordance with drawings, short-circuit study, and coordination study.
11. Verify tightness of accessible-bolted electrical connections by calibrated torque-wrench method or in accordance with 7.5.1.3.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
12. Verify correct operation of all indicating and control devices.
13. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
14. Record as-found and as-left operation counter readings.
15. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low resistance ohmmeter.
2. Perform contact-resistance test across each switchblade and fuseholder.

7. INSPECTION AND TEST PROCEDURES

7.5.1.3 Switches, Air, Medium- and High-Voltage, Open

3. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
4. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components or control devices that cannot tolerate the applied voltage, follow manufacturer's recommendation.
5. Perform a dielectric withstand voltage test on each pole with switch closed. Test each pole-to-ground with all other poles grounded. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.19.
6. Measure fuse resistance.
7. *Perform power-factor or dissipation-factor tests on each pole with the switch open and each phase with the switch closed.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.5.1.3.A.11)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.5.1.3.A.15)
3. Operation counter should advance one digit per close-open cycle. (7.5.1.3.A.14)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.
3. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests should not proceed until insulation-resistance levels are raised above minimum values.

7. INSPECTION AND TEST PROCEDURES

7.5.1.3 Switches, Air, Medium- and High-Voltage, Open

4. Minimum insulation-resistance values of control wiring shall not be less than two megohms.
5. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
6. Investigate fuse resistance values that deviate from each other by more than 15 percent.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.5.2 Switches, Oil, Medium-Voltage

7.5.2 Switches, Oil, Medium-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Perform mechanical operator tests in accordance with manufacturer's published data.
6. Verify correct operation and adjustment of motor operator limit switches and mechanical interlocks.
7. Test all electrical and mechanical interlock systems for correct operation and sequencing.
8. Verify that each fuse has adequate mechanical support and contact integrity.
9. Verify that fuse sizes and types are in accordance with drawings, short-circuit study, and coordination study.
10. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.5.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
11. Verify that insulating oil level is correct.
12. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
13. Record as-found and as-left operation counter readings.
14. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform a contact/pole-resistance test.

7. INSPECTION AND TEST PROCEDURES

7.5.2 Switches, Oil, Medium-Voltage

3. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
4. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components or control devices that cannot tolerate the applied voltage, follow manufacturer's recommendation.
5. Perform a dielectric withstand voltage test on each pole with switch closed. Test each pole-to-ground with all other poles grounded. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.19.
6. *Remove a sample of insulating liquid in accordance with ASTM D 923. Sample shall be tested in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D 877.
 2. Color: ASTM D 1500
 3. Visual condition: ASTM D 1524
7. Measure fuse resistance.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.5.2.A.10)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.5.2.A.14)
3. Operation counter shall advance one digit per close-open cycle. (7.5.2.A.13)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.5.2 Switches, Oil, Medium-Voltage

3. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated. Dielectric withstand voltage tests should not proceed until insulation-resistance levels are raised above minimum values.
4. Insulation-resistance values of control wiring shall not be less than two megohms.
5. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
6. Insulating liquid test results shall be in accordance with Table 100.4.
7. Investigate fuse resistance values that deviate from each other by more than 15 percent.

| *Optional Test

7. INSPECTION AND TEST PROCEDURES

7.5.3 Switches, Vacuum, Medium-Voltage

7.5.3 Switches, Vacuum, Medium-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Perform mechanical operator tests in accordance with manufacturer's published data.
6. Verify correct operation and adjustment of motor operator limit switches and mechanical interlocks.
7. Verify critical distances on operating mechanism as recommended by the manufacturer.
8. Test all electrical and mechanical interlock systems for correct operation and sequencing.
9. Verify that each fuse has adequate support and contact integrity.
10. Verify that fuse sizes and types are in accordance with drawings, the short-circuit study, and the coordination study.
11. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.5.3.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
12. Verify that insulating oil level is correct.
13. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
14. Record as-left operation counter reading.
15. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted electrical connections with a low resistance ohmmeter.
2. Perform a contact/pole-resistance test.

7. INSPECTION AND TEST PROCEDURES

7.5.3 Switches, Vacuum, Medium-Voltage

3. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
4. *Perform magnetron atmospheric condition (MAC) test on each vacuum interrupter.
5. Perform vacuum bottle integrity test in strict accordance with manufacturer's published data.
6. Remove a sample of insulating liquid, in accordance with ASTM D 923. Sample shall be tested in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D 877
 2. Color: ASTM D 1500
 3. Visual condition: ASTM D 1524
7. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
8. Perform a dielectric withstand voltage test in accordance with manufacturer's published data.
9. Verify open and close operation from control devices.
10. Measure fuse resistance.

C. Test Values – Visual and Mechanical

1. Critical distances of the operating mechanism shall be in accordance with manufacturer's published data. (7.5.3.A.7)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.5.3.A.11)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.5.3.A.15)
4. Operation counter shall advance one digit per close-open cycle. (7.5.3.A.14)

7. INSPECTION AND TEST PROCEDURES

7.5.3 Switches, Vacuum, Medium-Voltage

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.
3. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests shall not proceed until insulation-resistance levels are raised above minimum values.
4. In the absence of manufacturer's published data, each vacuum interrupter pressure shall not be greater than 1×10^{-2} Pa and shall not deviate from adjacent poles by more than two orders of magnitude.
5. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the vacuum bottle integrity test, the test specimen is considered to have passed the test.
6. Insulating liquid test results shall be in accordance with Table 100.4.
7. Insulation-resistance values of control wiring shall not be less than two megohms.
8. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
9. Results of open and close operation from control devices shall be in accordance with system design.
10. Investigate fuse resistance values that deviate from each other by more than 15 percent.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.5.4 Switches, SF₆, Medium-Voltage

7.5.4 Switches, SF₆, Medium-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Inspect and service mechanical operator and SF₆ gas insulated system in accordance with the manufacturer's published data.
6. Verify correct operation of SF₆ gas pressure alarms and limit switches, as recommended by the manufacturer.
7. Measure critical distances as recommended by the manufacturer.
8. Verify operation and sequencing of interlocking systems.
9. Verify that each fuse holder has adequate mechanical support and contact integrity.
10. Verify that fuse sizes and types are in accordance with drawings, short-circuit study, and coordination study.
11. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.5.4.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
12. Verify appropriate lubrication on moving, current-carrying parts and on moving and sliding surfaces.
13. Test for SF₆ gas leaks in accordance with manufacturer's published data.
14. Record as-found and as-left operation counter readings.
15. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through accessible bolted electrical connections with a low-resistance ohmmeter.
2. Perform a contact/pole-resistance test.

7. INSPECTION AND TEST PROCEDURES

7.5.4 Switches, SF6, Medium-Voltage

3. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
4. *Remove a sample of SF6 gas if provisions are made for sampling and test in accordance with Table 100.13.
5. Perform a dielectric withstand voltage test across each gas bottle with the switch in the open position in accordance with manufacturer's published data.
6. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
7. Perform a dielectric withstand voltage test in accordance with manufacturer's published data.
8. Verify open and close operation from control devices.
9. Measure fuse resistance.

C. Test Values – Visual and Mechanical

1. Critical distances of operating mechanism shall be in accordance with manufacturer's published data. (7.5.4.A.7)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.5.4.A.11.)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.5.4.A.15)
4. Operation counter shall advance one digit per close-open cycle. (7.5.4.A.14)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.5.4 Switches, SF6, Medium-Voltage

3. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests shall not proceed until insulation-resistance levels are raised above minimum values.
4. Results of SF6 gas tests shall be in accordance with Table 100.13.
5. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
6. Insulation-resistance values of control wiring shall not be less than two megohms.
7. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
8. Results of open and close operation from control devices shall be in accordance with system design.
9. Investigate fuse resistance values that deviate from each other by more than 15 percent.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.5.5 Switches, Cutouts

7.5.5 Switches, Cutouts

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Verify correct blade alignment, blade penetration, travel stops, latching mechanism, and mechanical operation.
6. Verify that each fuseholder has adequate mechanical support and contact integrity.
7. Verify that fuse size and types are in accordance with drawings, short-circuit study, and coordination study.
8. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.5.5.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
9. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Measure contact resistance across each cutout.
3. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch closed and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
4. Perform a dielectric withstand voltage test on each pole, phase-to-ground with cutout closed. Ground adjacent cutouts. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
5. Measure fuse resistance.

7. INSPECTION AND TEST PROCEDURES

7.5.5 Switches, Cutouts

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.5.5.A.8)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.5.5.A.9)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values which deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.
3. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Dielectric withstand voltage tests shall not proceed until insulation-resistance levels are raised above minimum values.
4. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
5. Investigate fuse resistance values that deviate from each other by more than 15 percent.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.6.1.1.1 Circuit Breakers, Low-Voltage, Molded-Case

7.6.1.1.1 Circuit Breakers, Low-Voltage, Molded-Case

Note: Generally, Molded Case Circuit Breakers have spring assisted, over-center handle operating mechanisms for quick-make and break operation whereas Insulated Case Circuit Breakers have two-step, stored-energy operating mechanisms.

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Verify the unit is clean.
4. Operate the circuit breaker to ensure smooth operation.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Perform adjustments for final protective device settings in accordance with the coordination study.
7. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with the circuit breaker closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
2. Perform a contact/pole-resistance test.
3. Determine long-time pickup and delay by primary current injection.
4. Determine short-time pickup and delay by primary current injection.
5. Determine ground-fault pickup and time delay by primary current injection.
6. Determine instantaneous pickup by primary current injection.
7. *Test functions of the trip unit by means of secondary injection.

7. INSPECTION AND TEST PROCEDURES

7.6.1.1.1 Circuit Breakers, Low-Voltage, Molded-Case

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.6.1.1.A.5)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.6.1.1.A.7)
3. Settings shall comply with coordination study recommendations. (7.6.1.1.A.6)

D. Test Values – Electrical

1. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
2. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
3. Long-time pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current characteristic tolerance band, including adjustment factors. If manufacturer's curves are not available, trip times shall not exceed the value shown in Table 100.7.
4. Short-time pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current tolerance band.
5. Ground fault pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current tolerance band.
6. Instantaneous pickup values shall be as specified and within manufacturer's published tolerances. In the absence of manufacturer's data, refer to Table 100.8.
7. Pickup values and trip characteristics shall be within manufacturer's published tolerances.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.6.1.1.2 Circuit Breakers, Low-Voltage, Insulated Case

7.6.1.1.2 Circuit Breakers, Low-Voltage, Insulated Case

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify that all maintenance devices are available for servicing and operating the breaker.
5. Verify the unit is clean.
6. Verify the arc chutes are intact.
7. Inspect moving and stationary contacts for condition and alignment.
8. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
9. Verify cell fit and element alignment.
10. Verify racking mechanism operation.
11. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
12. Perform adjustments for final protective device settings in accordance with coordination study.
13. Record as-found and as-left operation counter readings.
14. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with the circuit breaker closed, and across each open pole. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
2. Perform a contact/pole-resistance test.
3. Determine long-time pickup and delay by primary current injection.

7. INSPECTION AND TEST PROCEDURES

7.6.1.1.2 Circuit Breakers, Low-Voltage, Insulated Case

4. Determine short-time pickup and delay by primary current injection.
5. Determine ground-fault pickup and delay by primary current injection.
6. Determine instantaneous pickup value by primary current injection.
7. *Test functions of the trip unit by means of secondary injection.
8. Verify correct operation of any auxiliary features such as trip and pickup indicators, zone interlocking, electrical close and trip operation, trip-free, antipump function, and trip unit battery condition. Reset all trip logs and indicators.
9. Verify operation of charging mechanism.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.6.1.2.A.8)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.6.1.2.A.14)
3. Settings shall comply with coordination study recommendations. (7.6.1.2.A.12)
4. Operations counter shall advance one digit per close-open cycle. (7.6.1.2.A.13)

D. Test Values – Electrical

1. Insulation-resistance values of circuit breakers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
2. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. In the absence of manufacturer's data, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
3. Insulation-resistance values of control wiring shall not be less than two megohms.
4. Long-time pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current characteristic tolerance band, including adjustment factors. If manufacturer's curves are not available, trip times shall not exceed the value shown in Table 100.7.

7. INSPECTION AND TEST PROCEDURES

7.6.1.1.2 Circuit Breakers, Low-Voltage, Insulated Case

5. Short-time pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current tolerance band.
6. Ground fault pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current tolerance band.
7. Instantaneous pickup values shall be as specified and within manufacturer's published tolerances. In the absence of manufacturer's data, use Table 100.8.
8. Pickup values and trip characteristic shall be as specified and within manufacturer's published tolerances.
9. Auxiliary features shall operate in accordance with manufacturer's published data.
10. The charging mechanism shall operate in accordance with manufacturer's published data.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.6.1.2 Circuit Breakers, Low-Voltage, Power

7.6.1.2 Circuit Breakers, Low-Voltage, Power

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify that all maintenance devices are available for servicing and operating the breaker.
5. Verify the unit is clean.
6. Verify the arc chutes are intact.
7. Inspect moving and stationary contacts for condition and alignment.
8. Verify the primary and secondary contacts wipe and other dimensions vital to satisfactory operation of the breaker are correct.
9. Perform all mechanical operator and contact alignment tests on both the breaker and its operating mechanism in accordance with manufacturer's published data.
10. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
11. Verify cell fit and element alignment.
12. Verify racking mechanism operation.
13. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
14. Perform adjustments for final protective device settings in accordance with coordination study.
15. Record as-found and as-left operation counter readings.
16. *Perform thermographic survey shall be in accordance with Section 9.

7. INSPECTION AND TEST PROCEDURES

7.6.1.2 Circuit Breakers, Low-Voltage, Power

B. Electrical Tests

1. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with the circuit breaker closed, and across each open pole. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
2. Perform a contact/pole-resistance test.
3. Determine long-time pickup and delay by primary current injection.
4. Determine short-time pickup and delay by primary current injection.
5. Determine ground-fault pickup and delay by primary current injection.
6. Determine instantaneous pickup value by primary current injection.
7. *Test functions of the trip unit by means of secondary injection.
8. Verify correct operation of any auxiliary features such as trip and pickup indicators, zone interlocking, electrical close and trip operation, trip-free, antipump function, and trip unit battery condition. Reset all trip logs and indicators.
9. Verify operation of charging mechanism.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.6.1.2.A.10)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.6.1.2.A.16)
3. Settings shall comply with coordination study recommendations. (7.6.1.2.A.14)
4. Operations counter shall advance one digit per close-open cycle. (7.6.1.2.A.15)

D. Test Values – Electrical

1. Contact-resistance values of circuit breakers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.

7. INSPECTION AND TEST PROCEDURES

7.6.1.2 Circuit Breakers, Low-Voltage, Power

2. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. In the absence of manufacturer's data, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
3. Insulation-resistance values of control wiring shall not be less than two megohms.
4. Long-time pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current characteristic tolerance band, including adjustment factors. If manufacturer's curves are not available, trip times shall not exceed the value shown in Table 100.7.
5. Short-time pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current tolerance band.
6. Ground fault pickup values shall be as specified, and the trip characteristic shall not exceed manufacturer's published time-current tolerance band.
7. Instantaneous pickup values shall be as specified and within manufacturer's published tolerances. In the absence of manufacturer's data, use Table 100.8.
8. Pickup values and trip characteristic shall be as specified and within manufacturer's published tolerances.
9. Auxiliary features shall operate in accordance with manufacturer's published data.
10. The charging mechanism shall operate in accordance with manufacturer's published data.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.6.1.3 Circuit Breakers, Air, Medium-Voltage

7.6.1.3 Circuit Breakers, Air, Medium-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify that all maintenance devices are available for servicing and operating the breaker.
5. Verify the unit is clean.
6. Verify the arc chutes are intact.
7. Inspect moving and stationary contacts for condition and alignment.
8. If recommended by manufacturer, slow close/open breaker and check for binding, friction, contact alignment, and penetration. Verify that contact sequence is in accordance with manufacturer's published data. In the absence of manufacturer's data, use IEEE C37.04.
9. Perform all mechanical operation tests on the operating mechanism in accordance with manufacturer's published data.
10. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
11. Verify cell fit and element alignment.
12. Verify racking mechanism operation.
13. Inspect puffer operation.
14. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
15. Perform contact-timing test.
16. *Perform mechanism-motion analysis.
17. *Perform trip/close coil current signature analysis.
18. Record as-found and as-left operation-counter readings.

7. INSPECTION AND TEST PROCEDURES

7.6.1.3 Circuit Breakers, Air, Medium-Voltage

19. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with circuit breaker closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
2. Perform a contact/pole-resistance test.
3. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be on minute. For units with solid-state components or control devices that cannot tolerate the applied voltage, follow manufacturer's recommendation.
4. With breaker in the test position, make the following tests:
 1. Trip and close breaker with the control switch.
 2. Trip breaker by operating each of its protective relays.
 3. Verify mechanism charge, trip-free, and antipump functions.
5. Perform minimum pickup voltage tests on trip and close coils in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.20.
6. *Perform power-factor or dissipation-factor tests with breaker in both the open and closed positions.
7. *Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/capacitance tap. In the absence of a power-factor/ capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
8. Perform a dielectric withstand voltage test on each phase with the circuit breaker closed and the poles not under test grounded. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.19.
9. Measure blowout coil circuit resistance.
10. Verify operation of heaters.

7. INSPECTION AND TEST PROCEDURES

7.6.1.3 Circuit Breakers, Air, Medium-Voltage

C. Test Values – Visual and Mechanical

1. Mechanical operation and contact alignment shall be in accordance with manufacturer's published data. (7.6.1.3.A.9)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.6.1.3.A.10)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.6.1.3.A.19)
4. Contact timing values shall be in accordance with manufacturer's published data. (7.6.1.3.A.15)
5. Travel and velocity values shall be in accordance with manufacturer's published data. (7.6.1.3.A.16)
6. Trip/close coil current values shall be in accordance with manufacturer's published data. (7.6.1.3.A.17)
7. Operations counter shall advance one digit per close-open cycle. (7.6.1.3.A.18)

D. Test Values – Electrical

1. Insulation-resistance values of circuit breakers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
2. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. In the absence of manufacturer's data, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
3. Insulation-resistance values of control wiring shall not be less than two megohms.
4. Breaker mechanism charge, close, open, trip, trip-free, and antipump features shall function as designed.
5. Minimum pickup voltage of the trip and close coils shall conform to the manufacturer's published data. In the absence of the manufacturer's published data, refer to Table 100.20.
6. Power-factor or dissipation-factor values shall be compared with previous test results of similar breakers or manufacturer's published data.

7. INSPECTION AND TEST PROCEDURES

7.6.1.3 Circuit Breakers, Air, Medium-Voltage

7. Power-factor or dissipation-factor and capacitance values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliampere/milliwatt loss basis, and the results shall be compared to values of similar bushings.
8. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the circuit breaker is considered to have passed the test.
9. The blowout coil circuit shall exhibit continuity.
10. Heaters shall be operational.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.6.2 Circuit Breakers, Oil, Medium- and High-Voltage

7.6.2 Circuit Breakers, Oil, Medium- and High-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify that all maintenance devices such as special tools and gauges specified by the manufacturer are available for servicing and operating the breaker.
5. Verify correct oil level in all tanks and bushings.
6. Verify that breather vents are clear.
7. Verify the unit is clean.
8. Inspect hydraulic system and air compressor in accordance with manufacturer's published data.
9. Test alarms and pressure-limit switches for pneumatic and hydraulic operators as recommended by the manufacturer.
10. Perform mechanical operation tests on the operating mechanism in accordance with manufacturer's published data.
11. *Perform internal inspection:
 1. Remove oil. Lower tanks or remove manhole covers as necessary. Inspect bottom of tank for broken parts and debris.
 2. Inspect lift rod and toggle assemblies, contacts, interrupters, bumpers, dashpots, bushing current transformers, tank liners, and gaskets.
 3. Verify that contact sequence is in accordance with manufacturer's published data. In the absence of manufacturer's data, use IEEE C37.04.
 4. Fill tank(s) with filtered oil.
12. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.6.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
13. Verify racking mechanism operation.

7. INSPECTION AND TEST PROCEDURES

7.6.2 Circuit Breakers, Oil, Medium- and High-Voltage

14. Perform contact-timing test.
15. Perform mechanism-motion analysis.
16. *Perform trip/close coil current signature analysis.
17. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
18. Record as-found and as-left operation counter readings.
19. Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with circuit-breaker closed, and across each open pole. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
3. Perform a static contact/pole resistance test.
4. *Perform a dynamic contact/pole resistance test.
5. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
6. Remove a sample of insulating liquid in accordance with ASTM D 923. Sample shall be tested in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D 877
 2. Color: ASTM D 1500
 3. Power factor: ASTM D 924
 4. Interfacial tension: ASTM D 971
 5. Visual condition: ASTM D 1524
 6. Neutralization number (acidity): ASTM D 974

7. INSPECTION AND TEST PROCEDURES

7.6.2 Circuit Breakers, Oil, Medium- and High-Voltage

7. Water content: ASTM D 1533
7. Perform minimum pickup voltage tests on trip and close coils in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.20.
8. Verify correct operation of any auxiliary features such as electrical close and trip operation, trip-free, antipump function.
9. Trip circuit breaker by operation of each protective device. Reset all trip logs and indicators.
10. Perform power-factor or dissipation-factor tests on each pole with breaker open and each phase with breaker closed. Determine tank loss index.
11. Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/capacitance tap. In the absence of a power-factor/capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
12. *Perform a dielectric withstand voltage test in accordance with manufacturer's published data.
13. Verify operation of heaters.
14. Test instrument transformers in accordance with Section 7.10.

C. Test Values – Visual and Mechanical

1. Settings for alarm, pressure, and limit switches shall be in accordance with owner's specifications. In the absence of owner's specifications use manufacturer's published data. (7.6.2.A.9).
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.6.2.A.12)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.6.2.A.19)
4. Contact timing values shall be in accordance with manufacturer's published data. (7.6.2.A.14).
5. Travel and velocity values shall be in accordance with manufacturer's published data. (7.6.2.A.15)
6. Trip/close coil current values shall be in accordance with manufacturer's published data. (7.6.2.A.16).

7. INSPECTION AND TEST PROCEDURES

7.6.2 Circuit Breakers, Oil, Medium- and High-Voltage

7. Operations counter shall advance one digit per close-open cycle. (7.6.2.A.18)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values of circuit breakers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
3. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
4. Dynamic contact resistance values shall be in accordance with manufacturer's published data.
5. Insulation-resistance values of control wiring shall not be less than two megohms.
6. Insulating liquid test results shall be in accordance with Table 100.4.
7. Minimum pickup voltage of the trip and close coils shall conform to the manufacturer's published data. In the absence of the manufacturer's published data, use Table 100.20.
8. Auxiliary features shall operate in accordance with manufacturer's published data.
9. Protective devices shall operate the breaker per system design.
10. Power-factor or dissipation-factor values and tank loss index shall be compared to manufacturer's published data. In the absence of manufacturer's data, the comparison shall be made to test data from similar breakers or data from test equipment manufacturers.
11. Power-factor or dissipation-factor and capacitance values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliamperes/milliwatt loss basis, and the results should be compared to values of similar bushings.
12. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
13. Heaters shall be operational.

7. INSPECTION AND TEST PROCEDURES

7.6.2 Circuit Breakers, Oil, Medium- and High-Voltage

14. Results of electrical tests on instrument transformers shall be in accordance with Section 7.10.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.6.3 Circuit Breakers, Vacuum, Medium-Voltage

7.6.3 Circuit Breakers, Vacuum, Medium-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify that all maintenance devices such as special tools and gauges specified by the manufacturer are available for servicing and operating the breaker.
5. Verify the unit is clean.
6. Perform all mechanical operation tests on the operating mechanism in accordance with manufacturer's published data.
7. Measure critical distances such as contact gap as recommended by manufacturer.
8. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
9. Verify cell fit and element alignment.
10. Verify racking mechanism operation.
11. Verify appropriate lubrication on moving, current-carrying parts and on moving and sliding surfaces.
12. Perform contact-timing test.
13. *Perform trip/close coil current signature analysis.
14. *Perform mechanism motion analysis.
15. Record as-found and as-left operation counter readings.
16. *Perform thermographic survey in accordance with Section 9.

7. INSPECTION AND TEST PROCEDURES

7.6.3 Circuit Breakers, Vacuum, Medium-Voltage

B. Electrical Tests

1. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with the circuit breaker closed, and across each open pole. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
2. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
3. Perform a contact/pole-resistance test.
4. Perform minimum pickup voltage tests on trip and close coils in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.20.
5. Verify correct operation of any auxiliary features such as electrical close and trip operation, trip-free, and antipump function.
6. Trip circuit breaker by operation of each protective device. Reset all trip logs and indicators.
7. *Perform power-factor or dissipation-factor tests on each pole with the breaker open and each phase with the breaker closed.
8. *Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/capacitance tap. In the absence of a power-factor/capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
9. *Perform magnetron atmospheric condition (MAC) test on each vacuum interrupter.
10. Perform vacuum bottle integrity (dielectric withstand voltage) test across each vacuum bottle with the breaker in the open position in strict accordance with manufacturer's published data.
11. Perform a dielectric withstand voltage test in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.19.
12. Verify operation of heaters.
13. Test instrument transformers in accordance with Section 7.10.

7. INSPECTION AND TEST PROCEDURES

7.6.3 Circuit Breakers, Vacuum, Medium-Voltage

C. Test Values – Visual and Mechanical

1. Critical distance measurements such as contact gap shall be in accordance with the manufacturer's published data. (7.6.3.A.7)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.6.3.A.8)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.6.3.A.16)
4. Contact timing values shall be in accordance with manufacturer's published data. (7.6.3.A.12)
5. Trip/close coil current values shall be in accordance with manufacturer's published data. (7.6.3.A.13)
6. Travel and velocity values shall be in accordance with manufacturer's published data. (7.6.3.A.14)
7. Operation counter shall advance one digit per close-open cycle. (7.6.3.A.15)

D. Test Values – Electrical

1. Insulation-resistance values of circuit breakers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
2. Insulation-resistance values of control wiring shall not be less than two megohms.
3. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. In the absence of manufacturer's data, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
4. Minimum pickup voltage of the trip and close coils shall conform to the manufacturer's published data. In the absence of the manufacturer's published data, refer to Table 100.20.
5. Auxiliary features shall operate in accordance with manufacturer's published data.
6. Protective devices shall operate the breaker per system design.
7. Power-factor or dissipation-factor values shall be compared to manufacturer's published data. In the absence of manufacturer's data the comparison shall be made to similar breakers.

7. INSPECTION AND TEST PROCEDURES

7.6.3 Circuit Breakers, Vacuum, Medium-Voltage

8. Power-factor or dissipation-factor and capacitance values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliampere/milliwatt loss basis, and the results should be compared to values of similar bushings.
9. In the absence of manufacturer's published data, each vacuum interrupter pressure shall not be greater than 1×10^{-2} Pa and shall not deviate from adjacent poles by more than two orders of magnitude.
10. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the vacuum bottle integrity test, the test specimen is considered to have passed the test.
11. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
12. Heaters shall be operational.
13. Results of instrument transformer tests shall be in accordance with Section 7.10.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.6.4 Circuit Breakers, SF₆

7.6.4 Circuit Breakers, SF₆

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify that all maintenance devices such as special tools and gauges specified by the manufacturer are available for servicing and operating the breaker.
5. Verify the unit is clean.
6. When provisions are made for sampling, remove a sample of SF₆ gas and test in accordance with Table 100.13. Do not break seal or distort “sealed-for-life” interrupters.
7. Inspect operating mechanism and/or hydraulic or pneumatic system and SF₆ gas-insulated system in accordance with manufacturer’s published data.
8. Test for SF₆ gas leaks in accordance with manufacturer’s published data.
9. Verify correct operation of alarms and pressure-limit switches for pneumatic, hydraulic, and SF₆ gas pressure in accordance with manufacturer’s published data.
10. If recommended by manufacturer, slow close/open breaker and check for binding, friction, contact alignment, and penetration. Verify that contact sequence is in accordance with manufacturer’s published data. In the absence of manufacturer’s data, refer to IEEE C37.04.
11. Perform all mechanical operation tests on the operating mechanism in accordance with the manufacturer’s published data.
12. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.6.4.B.1. Torque values shall be in accordance with manufacturer’s published data. In the absence of manufacturer’s data, use Table 100.12.
13. Verify the appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
14. Perform contact-timing test.
15. *Perform trip/close coil signature analysis.
16. Perform mechanism motion analysis for breakers rated 38kV and above.

7. INSPECTION AND TEST PROCEDURES

7.6.4 Circuit Breakers, SF6

17. Record as-found and as-left operation counter readings.
18. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through all bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests in accordance with Table 100.1 from each pole-to-ground with breaker closed and across open poles at each phase. For single-tank breakers, perform insulation resistance tests in accordance with Table 100.1 from pole-to-pole.
3. Perform a static contact/resistance test.
4. *Perform a dynamic contact/pole resistance test.
5. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components or for control devices that cannot tolerate the voltage, follow manufacturer's recommendation.
6. Perform minimum pickup voltage tests on trip and close coils in accordance with manufacturer's published data.
7. Verify correct operation of any auxiliary features such as electrical close and trip operation, trip-free, and antipump function. Reset all trip logs and indicators.
8. Trip circuit breaker by operation of each protective device.
9. Perform power-factor or dissipation-factor tests on each pole with the breaker open and on each phase with the breaker closed.
10. Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/capacitance tap. In the absence of a power-factor/capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
11. *Perform a dielectric withstand voltage test in accordance with manufacturer's published data.
12. Verify operation of heaters.
13. Test instrument transformers in accordance with Section 7.10.

7. INSPECTION AND TEST PROCEDURES

7.6.4 Circuit Breakers, SF6

C. Test Values – Visual and Mechanical

1. SF6 gas shall have values in accordance with Table 100.13. (7.6.4.A.6)
2. Results of the SF6 gas leak test shall confirm that no SF6 gas leak exists. (7.6.4.A.8)
3. Settings for alarm, pressure, and limit switches shall be in accordance with manufacturer's published data. (7.6.4.A.9)
4. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.6.4.A.12)
5. Results of the thermographic survey shall be in accordance with Section 9. (7.6.4.A.18)
6. Contact timing values shall be in accordance with manufacturer's published data. (7.6.4.A.14)
7. Trip/close coil current values shall be in accordance with manufacturer's published data. (7.6.4.A.15)
8. Travel and velocity values shall be in accordance with manufacturer's published data. (7.6.4.A.16)
9. Operations counter shall advance one digit per close-open cycle. (7.6.4.A.17)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values of circuit breakers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
3. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. In the absence of manufacturer's data, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
4. Dynamic contact resistance values shall be in accordance with manufacturer's published data.
5. Insulation-resistance values of control wiring shall not be less than two megohms.

7. INSPECTION AND TEST PROCEDURES

7.6.4 Circuit Breakers, SF6

6. Minimum pickup voltage of the trip and close coils shall conform to the manufacturer's published data. In the absence of manufacturer's published data, use Table 100.20.
7. Auxiliary features shall operate in accordance with manufacturer's published data.
8. Protective devices shall operate the breaker per the system design.
9. Power-factor or dissipation-factor values shall be compared to manufacturer's published data. In the absence of manufacturer's data, the comparison shall be made to test data from similar breakers or data from test equipment manufacturers.
10. Power-factor or dissipation-factor and capacitance test values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliamperere/milliwatt loss basis, and the results shall be compared to values of similar bushings.
11. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
12. Heaters shall be operational.
13. Results of electrical tests on instrument transformers shall be in accordance with Section 7.10.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.7 Circuit Switchers

7.7 Circuit Switchers

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the bushings and insulators are clean.
5. Verify both the circuit switcher and its operating mechanism mechanically operate in accordance with the manufacturer's published data.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.7.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify operation of SF₆ interrupters is in accordance with manufacturer's published data.
8. Verify SF₆ pressure is in accordance with manufacturer's published data.
9. Verify operation of isolating switch is in accordance with system design and manufacturer's published data.
10. Verify all interlocking systems operate and sequence per system design and manufacturer's published data.
11. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
12. Record as-found and as-left operation counter readings.
13. *Perform thermographic survey in accordance with Section 9.

B Electrical Tests

1. Perform resistance measurements through all connections with a low-resistance ohmmeter.
2. Perform contact-resistance test of interrupters and isolating switches.
3. Perform insulation-resistance tests on each pole phase-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.

7. INSPECTION AND TEST PROCEDURES

7.7 Circuit Switchers

4. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
5. Perform minimum pickup voltage tests on trip and close-coils in accordance with manufacturer's published data.
6. Verify correct operation of any auxiliary features such as electrical close and trip operation, trip-free, and anti-pump function. Reset all trip logs and indicators.
7. Trip circuit switcher by operation of each protective device.
8. Verify correct operation of electrical trip of interrupters.
9. aPerform a dielectric withstand voltage test in accordance with the manufacturer's published data.
10. *Perform insulation power-factor or dissipation-factor tests on each pole with the circuit switcher open and each phase with the circuit switcher closed.
11. Verify operation of heaters.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.7.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.7.A.13)
3. SF6 interrupters shall operate in accordance with manufacturer's published data. (7.7.A.7)
4. SF6 pressure shall be in accordance with manufacturer's published data. (7.7.A.8)
5. Isolating switch shall operate in accordance with system and manufacturer's design. (7.7.A.9)
6. Interlocking systems shall operate in accordance with system and manufacturer's design. (7.7.A.10)
7. Operation counter shall advance one digit per close-open cycle. (7.7.A.12)

7. INSPECTION AND TEST PROCEDURES

7.7 Circuit Switchers

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. In the absence of manufacturer's data, investigate values that deviate from adjacent poles or similar breakers by more than 50 percent of the lowest value.
3. Insulation-resistance values of circuit switchers shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
4. Insulation-resistance values of control wiring shall not be less than two megohms.
5. Minimum pickup voltage of the trip and close coils shall conform to the manufacturer's published data. In the absence of manufacturer's published data, use Table 100.20.
6. Auxiliary features shall operate in accordance with manufacturer's published data.
7. Protective devices shall operate the circuit switcher in accordance with the system design.
8. Electrical trip interrupters shall function as designed.
9. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the circuit switcher is considered to have passed the test.
10. Power-factor or dissipation-factor values shall be compared to manufacturer's published data. In the absence of manufacturer's data, the comparison shall be made to test data from similar breakers or data from test equipment manufacturers.
11. Heaters shall be operational.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.8 Network Protectors, 600-Volt Class

7.8 Network Protectors, 600-Volt Class

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data of the network protector, network transformer primary switch, and secondary bus isolation switch with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Verify arc chutes are intact.
6. Inspect network transformer primary (open, close, and ground) switch.
7. Perform visual and mechanical inspection on network protector collector bus isolation switch in accordance with Section 7.5.1.1.
8. Inspect moving and stationary contacts for condition and alignment.
9. Verify that maintenance devices are available for servicing and operating the network protector.
10. Verify that primary and secondary contact wipe and other dimensions vital to satisfactory operation of the network protector are correct.
11. Perform mechanical operator and contact alignment tests on both the protector and its operating mechanism.
12. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.8.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
13. Verify cell fit and element alignment.
14. Verify racking mechanism operation.
15. Verify appropriate lubrication on moving current-carrying parts, moving and sliding surfaces.
16. Record as-found and as-left operation counter readings.
17. Perform a leak test on submersible enclosure in accordance with manufacturer's published data.

7. INSPECTION AND TEST PROCEDURES

7.8 Network Protectors, 600-Volt Class

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with network protector closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
3. Perform a contact/pole-resistance test.
4. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components or for control devices that cannot tolerate the voltage, follow manufacturer's recommendation.
5. Verify current transformer ratios in accordance with Section 7.10.
6. Measure the resistance of each network protector power fuse.
7. Measure minimum pickup voltage of the motor control relay.
8. Verify that the motor can charge the closing mechanism at the minimum voltage specified by the manufacturer.
9. Measure minimum pickup voltage of the trip actuator. Verify that the actuator resets correctly.
10. Test and calibrate network protector electro-mechanical master and phasing relay, solid-state or microprocessor relays with a network protector test set, and in accordance with Section 7.9.
11. Perform operational tests.
 1. Verify correct operation of all mechanical and electrical interlocks including network transformer primary (open, close, and ground) switch and collector bus isolation switch.
 2. Verify trip-free operation.
 3. Verify correct operation of the auto-open-close control handle.
 4. Verify the protector will close with voltage on the transformer side only.

7. INSPECTION AND TEST PROCEDURES

7.8 Network Protectors, 600-Volt Class

5. Verify the protector will open when the source feeder breaker is opened.
6. Verify remote trip operation.
12. Verify phase rotation, phasing, and synchronized operation as required by the application.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.8.A.12)
2. Operations counter shall advance one digit per close-open cycle. (7.8.A.16)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation resistance of the network protector shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated.
3. Contact-resistance values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. In the absence of manufacturer's data, investigate values that deviate from adjacent poles or similar protectors by more than 50 percent of the lowest value.
4. Insulation-resistance values of control wiring shall not be less than two megohms.
5. Results of current transformer ratios shall be in accordance with Section 7.10.
6. Investigate fuse resistance values that deviate from each other by more than 15 percent.
7. Minimum pickup voltage of the motor control relay shall be in accordance with manufacturer's published data, but not more than 75 percent of rated control circuit voltage.
8. Minimum acceptable motor closing voltage should not exceed 75 percent of rated control circuit voltage.
9. Trip actuator minimum pickup voltage shall not exceed 75 percent of rated control circuit voltage.
10. Results of network protector relay calibrations shall be in accordance with Section 7.9.

7. INSPECTION AND TEST PROCEDURES

7.8 Network Protectors, 600-Volt Class

11. Network protector operation shall be in accordance with design requirements.
12. Phase rotation, phasing, and synchronizing shall be in accordance with system design requirements.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

7.9.1 Protective Relays, Electromechanical and Solid-State

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect relays and cases for physical damage. Remove shipping restraint material.
3. Verify the unit is clean.
4. Inspect the unit.
 1. Relay Case
 1. Tighten case connections.
 2. Inspect cover for correct gasket seal.
 3. Inspect shorting hardware, connection paddles, and knife switches.
 4. Remove any foreign material from the case.
 5. Verify target reset.
 6. Clean cover glass.
 2. Relay
 1. Inspect relay for foreign material, particularly in disk slots of the damping and electromagnets.
 2. Verify disk clearance throughout its travel. Verify contact follow and spring tension.
 3. Inspect spiral spring convolutions.
 4. Inspect disk and contacts for freedom of movement and correct travel.
 5. Verify tightness of mounting hardware and connections.
 6. Burnish contacts.
 7. Inspect bearings and pivots.
5. Verify that all settings are in accordance with coordination study or setting sheet supplied by owner.

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

B. Electrical Tests

1. Perform an insulation-resistance test on each circuit-to-frame. Procedures for performing insulation-resistance tests on solid-state relays shall be determined from the relay manufacturer's published data.
2. Test targets and indicators.
 1. Determine pickup and dropout of electromechanical targets.
 2. Verify operation of all light-emitting diode indicators.
 3. Set contrast for liquid-crystal display readouts.
3. Protection Elements
 1. 2/62 Timing Relay
 1. Determine time delay.
 2. Verify operation of all contacts used in the control scheme.
 2. 21 Distance Relay
 1. Determine maximum reach.
 2. Determine maximum torque angle and directional characteristic.
 3. Determine offset.
 4. Plot impedance circle.
 3. 24 Volts/Hertz Relay
 1. Determine pickup frequency at rated voltage.
 2. Determine pickup frequency at a second voltage level.
 3. Determine time delay.
 4. 25 Sync Check Relay
 1. Determine closing zone at rated voltage.
 2. Determine maximum voltage differential that permits closing at zero degrees.

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

3. Determine live line, live bus, dead line, and dead bus set points.
 4. Determine time delay.
 5. Determine advanced closing angle.
 6. Verify dead bus/live line, dead line/live bus and dead bus/dead line control functions.
5. 27 Undervoltage Relay
 1. Determine pick up and/or dropout voltage.
 2. Determine time delay.
 3. Determine time delay at a second point on the timing curve for inverse time relays.
6. 32 Directional Power Relay
 1. Determine directional unit maximum torque angle.
 2. Determine directional unit contact closing zone.
 3. Determine directional unit minimum pickup at maximum torque angle.
 4. Determine time delay.
 5. Verify time delay at a second point on the timing curve for inverse time relays.
 6. Plot the operating characteristic.
7. 40 Loss of Field (Impedance) Relay
 1. Determine maximum torque angle.
 2. Determine maximum reach.
 3. Determine offset.
 4. Test for spurious torque.
 5. Plot impedance circle.
8. 46 Current Balance Relay

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

1. Determine pickup of each unit.
 2. Determine percent slope.
 3. Determine time delay with zero restraint.
9. 46N Negative Sequence Current Relay
1. Determine negative sequence alarm level.
 2. Determine negative sequence minimum trip level.
 3. Determine maximum time delay.
 4. Verify two points on the $(I_2)^2t$ curve.
10. 47 Phase Sequence or Phase Balance Voltage Relay
1. Determine positive sequence voltage to close the normally open contact.
 2. Determine positive sequence voltage to open the normally closed contact (undervoltage trip).
 3. Verify negative sequence trip.
 4. Determine time delay to close the normally open contact with sudden application of 120 percent of pickup.
 5. Determine time delay to close the normally closed contact upon removal of voltage when previously set to rated system voltage.
11. 49R Thermal Replica Relay
1. Determine time delay at 300 percent of setting.
 2. Determine a second point on the operating curve.
 3. Determine minimum pickup.
12. 49T Temperature (RTD) Relay
1. Determine trip resistance.
 2. Determine reset resistance.
13. 50 Instantaneous Overcurrent Relay

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

1. Determine pickup.
14. 50BF Breaker Failure
 1. Determine current supervision pickup.
 2. Determine time delays.
 3. Test all initiate inputs and used outputs.
15. 51 Time Overcurrent
 1. Determine minimum pickup.
 2. Determine time delay at two points on the time current curve.
16. 55 Power Factor Relay
 1. Determine tripping lead and lag angle.
 2. Determine enable time delay.
 3. Determine operate time delay.
17. 59 Overvoltage Relay
 1. Determine overvoltage pickup.
 2. Determine time delay to close the contact with sudden application of 120 percent of pickup.
18. 60 Voltage Balance Relay
 1. Determine voltage difference to close the contacts with one source at rated voltage.
 2. Plot the operating curve for the relay.
19. 63 Transformer Sudden Pressure Relay
 1. Determine rate-of-rise or the pickup level of suddenly applied pressure in accordance with manufacturer's published data.
 2. Verify operation of the 63 FPX seal-in circuit.
 3. Verify trip circuit to remote operating device.

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

- 20. 64 Ground Detector Relay
 - 1. Determine maximum impedance to ground causing relay pickup.
- 21. 67 Directional Overcurrent Relay
 - 1. Determine directional unit minimum pickup at maximum torque angle.
 - 2. Determine contact closing zone.
 - 3. Determine maximum torque angle.
 - 4. Plot operating characteristics.
 - 5. Determine overcurrent unit pickup.
 - 6. Determine overcurrent unit time delay at two points on the time current curve.
- 22. 79 Reclosing Relay
 - 1. Determine time delay for each programmed reclosing interval.
 - 2. Verify lockout for unsuccessful reclosing.
 - 3. Determine reset time.
 - 4. Determine close pulse duration.
 - 5. Verify instantaneous overcurrent lockout.
- 23. 81 Frequency Relay
 - 1. Verify frequency set points.
 - 2. Determine time delay.
 - 3. Determine undervoltage cutoff.
- 24. 85 Pilot Wire Monitor
 - 1. Determine overcurrent pickup.
 - 2. Determine undercurrent pickup.
 - 3. Determine pilot wire ground pickup level.

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

25. 87 Differential

1. Determine operating unit pickup.
2. Determine the operation of each restraint unit.
3. Determine slope.
4. Determine harmonic restraint.
5. Determine instantaneous pickup.
6. Plot operating characteristics for each restraint.

4. Control Verification/Functional Tests

Verify that each of the relay contacts performs its intended function in the control scheme including breaker trip tests, close inhibit tests, 86 lockout tests, and alarm functions. Refer to Section 8.

C. Test Values – Visual and Mechanical

1. Relay Case

1. Case connections shall be torqued in accordance with manufacturer's published data. (7.9.1.A.4.1.1)
2. Cover gasket shall be intact and able to prevent foreign matter from entering the case. (7.9.1.A.4.1.2)
3. Cover glass, connection paddles, and/or knife switches shall be clean. (7.9.1.A.4.1.3)
4. Case shall be free of foreign material. (7.9.1.A.4.1.4)
5. The target reset shall be operational. (7.9.1.A.4.1.5)

2. Relay

1. Relay shall be free of foreign material. (7.9.1.A.4.2.1)
2. Relay disc clearance, contact clearance, and spring bias shall operate in accordance with manufacturer's published data. (7.9.1.A.4.2.2)
3. Relay spiral spring shall be concentric. (7.9.1.A.4.2.3)

7. INSPECTION AND TEST PROCEDURES

7.9.1 Protective Relays, Electromechanical and Solid-State

4. Relay discs and contacts shall have freedom of movement and correct travel distance in accordance with manufacturer's published data. (7.9.1.A.4.2.4)
 5. Mounting hardware and connections shall be tightened to the manufacturer's recommended torque values. (7.9.1.A.4.2.5)
 6. Contacts shall be clean and make good contact with each other. (7.9.1.A.4.2.6)
 7. Bearings and pivots shall be clean and allow freedom of movement. (7.9.1.A.4.2.7)
3. Relay settings shall match the coordination study or setting sheet supplied by owner. (7.9.1.A.5)

D. Test Values – Electrical

1. Insulation-resistance values shall be in accordance with manufacturer's published data. Values of insulation resistance less than the manufacturer's recommendations shall be investigated.
2. Targets and Indicators
 1. Pickup and dropout of electromechanical targets shall be in accordance with manufacturer's published data.
3. Light-emitting diodes shall illuminate.
4. Operation of protection elements for devices listed in Section 7.9.1.B, 1 through 25, shall be calibrated using manufacturer's recommended tolerances and at critical test points specified by the setting engineer.
5. Control Verification
 1. Control verification outputs and protection schemes, as listed in Section 7.9.1.B.4, shall operate as per the design. Results shall be within the manufacturer's published tolerances.
 2. When critical test points are specified, the relay shall be calibrated to those points even though other test points may be out of tolerance.

7. INSPECTION AND TEST PROCEDURES

7.9.2 Protective Relays, Microprocessor-Based

7.9.2 Protective Relays, Microprocessor-Based

A. Visual and Mechanical Inspection

1. Record model number, style number, serial number, firmware revision, software revision, and rated control voltage.
2. Verify operation of light-emitting diodes, display, and targets.
3. Record passwords for all access levels.
4. Clean the front panel and remove foreign material from the case.
5. Check tightness of connections.
6. Verify that the frame is grounded in accordance with manufacturer's instructions.
7. Upload owner supplied relay settings file.
8. Download settings and logic from the relay and compare the settings to those specified in the coordination study or setting sheet supplied by owner.
9. Set clock if not controlled externally and verify relay displays the correct date and time.
10. Check with setting engineer for applicable firmware updates and product recalls.
11. Inspect, clean, and verify operation of shorting devices.

B. Electrical Tests

1. Perform insulation-resistance tests from each circuit to the grounded frame in accordance with manufacturer's published data.
2. Apply voltage or current to all analog inputs and verify correct registration of the relay meter functions.
3. *Verify SCADA metering values and digital status points at remote terminals.
4. Protection Elements

Check functional operation of each element used in the protection scheme as described for electromechanical and solid-state relays in 7.9.1.B.3. When not otherwise specified, use manufacturer's recommended tolerances.
5. Control Verification
 1. Check operation of all active digital inputs.

7. INSPECTION AND TEST PROCEDURES

7.9.2 Protective Relays, Microprocessor-Based

2. Check all output contacts or SCRs, preferably by operating the controlled device such as circuit breaker, auxiliary relay, or alarm.
3. Check internal logic functions used in the protection scheme against the owner supplied narrative of each function or logic diagram.
4. For pilot schemes, perform protection system communication tests.
5. Upon completion of testing, reset all min/max records and fault counters. Delete sequence-of-events records and all event records.
6. Arc Energy Reduction Systems
 1. Determine pickup for all overcurrent elements used.
 2. Determine timing for all overcurrent elements used.
 3. Verify zone interlocking logic and timing.
 4. Verify logic for normal and maintenance modes of operation.
 5. Verify communication failure and circuit monitoring alarms.
 6. Verify ambient light for each light sensor and verify relay light sensor pickup values are above maximum ambient values.
 7. Verify each light sensor logic and timing.
 8. Verify current supervision logic and timing.
 9. Verify differential scheme logic and timing. Verify that all current transformers used in the differential zone have been tested in accordance with Section 7.10.1.B of this standard.
7. Verify trip and close coil monitoring functions.
8. *Verify setting change alarm to SCADA.
9. *Verify relay SCADA communication and indications such as protection operate, protection fail, communication fail, fault recorder trigger.
10. Verify all communication links are operational.

C. Test Values – Visual and Mechanical

1. Light-emitting diodes, displays, and targets should illuminate. (7.9.2.A.2)

7. INSPECTION AND TEST PROCEDURES

7.9.2 Protective Relays, Microprocessor-Based

2. Relay should be clean and operational. (7.9.2.A.4)
3. Settings and logic should agree with the most recent engineered setting files. (7.9.2.A.8)
4. Verify relay displays the correct date and time. (7.9.2.A.10)

D. Test Values – Electrical

1. Insulation-resistance values should be in accordance with manufacturer's published data. Values of insulation resistance less than manufacturer's recommendations should be investigated.
2. Voltage and current analog readings should be in accordance with manufacturer's published tolerances.
3. SCADA metering values should function in accordance with the manufacturer's published data.
4. Operation of protection elements for devices as listed in 7.9.1.B, items 1 through 25, should be operational and within manufacturer's recommended tolerances.
5. Control verification inputs, outputs, and protection schemes, as listed in 7.9.2.B.5, items 1 through 9, should operate as per the design. Results should be within the manufacturer's published tolerances.
6. Operation of protection elements for arc energy reduction systems listed in 7.9.2.B.6, items 1 through 9, shall be operational and in accordance with manufacturer's published data.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.10.1 Instrument Transformers, Current Transformer

7.10.1 Instrument Transformers, Current Transformer

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Verify correct connection of transformers with system requirements.
4. Verify that adequate clearances exist between primary and secondary circuit wiring.
5. Verify the unit is clean.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify that all required grounding and shorting connections provide contact.
8. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
9. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests – Current Transformers

1. Perform insulation-resistance test of each current transformer and its secondary wiring with respect to ground at 1000 volts dc for one minute. For units with solid-state components that cannot tolerate the applied voltage, follow manufacturer's recommendations.
2. Perform a polarity test of each current transformer in accordance with IEEE C57.13.1.
3. Perform a ratio-verification test using the voltage or current method in accordance with IEEE C57.13.1.
4. Perform an excitation test on transformers used for relaying applications in accordance with IEEE C57.13.1.
5. Measure current circuit burdens at CT shorting terminal block in accordance with IEEE C57.13.1
6. Perform insulation-resistance tests on the primary winding of bar-type CTs with the secondary grounded. Test voltages shall be in accordance with Table 100.5.

7. INSPECTION AND TEST PROCEDURES

7.10.1 Instrument Transformers, Current Transformer

7. *Perform dielectric withstand tests on the primary winding of bar-type CTs with the secondary grounded. Test voltages shall be in accordance with Table 100.9.
8. Perform insulation power-factor or dissipation-factor tests on bar-type CTs rated 38 kV and above in accordance with manufacturer's published data.
9. Verify that current transformer secondary circuits are grounded and have only one grounding point in accordance with IEEE C57.13.3. That grounding point should be located as specified by the engineer in the project drawings.

C. Test Values – Visual and Mechanical

1. Bolt torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.10.1.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.10.1.A.9)

D. Test Values – Electrical

1. Insulation-resistance values of instrument transformers shall not be less than values shown in Table 100.5.
2. Polarity results shall agree with transformer markings.
3. Ratio errors shall be in accordance with IEEE C57.13.
4. Excitation results shall match the curve supplied by the manufacturer or be in accordance with IEEE C57.13.1.
5. Compare measured burdens to instrument transformer ratings.
6. Insulation-resistance values of instrument transformers shall not be less than values shown in Table 100.5.
7. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the primary winding is considered to have passed the test.
8. Power-factor or dissipation-factor values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use test equipment manufacturer's published data.
9. Test results shall indicate that the circuits have only one grounding point.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.10.2 Instrument Transformers, Voltage Transformers

7.10.2 Instrument Transformers, Voltage Transformers

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Verify correct connection of transformers with system requirements.
4. Verify that adequate clearances exist between primary and secondary circuit wiring.
5. Verify the unit is clean.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify that all required grounding and connections provide contact.
8. Verify correct primary and secondary fuse sizes for voltage transformers.
9. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
10. Perform as-left tests.
11. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform insulation-resistance tests for one minute winding-to-winding and each winding-to-ground. Test voltages shall be applied for one minute in accordance with Table 100.5. For units with solid-state components that cannot tolerate the applied voltage, follow manufacturer's recommendations.
2. Perform a polarity test on each transformer to verify the polarity marks or H1-X1 relationship as applicable.
3. Perform a turns-ratio test on all tap positions.
4. Measure voltage circuit burdens at transformer terminals.

7. INSPECTION AND TEST PROCEDURES

7.10.2 Instrument Transformers, Voltage Transformers

5. *For primary windings rated 15 kV and higher, perform a dielectric withstand test on the primary windings with the secondary windings connected to ground. The dielectric voltage shall be in accordance with Table 100.9. The test voltage shall be applied for one minute.
6. For primary windings rated 15 kV and higher, perform power-factor or dissipation-factor tests in accordance with manufacturer's published data.
7. Verify that voltage transformer secondary circuits are grounded and have only one grounding point in accordance with IEEE C57.13.3. The grounding point should be located as specified by the engineer in the project drawings.

C. Test Values – Visual and Mechanical

1. Bolt torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.10.2.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.10.2.A.11)

D. Test Values – Electrical

1. Insulation-resistance values of instrument transformers shall not be less than values shown in Table 100.5.
2. Polarity results shall agree with transformer markings.
3. In accordance with IEEE C57.13.8.1.1, the ratio error shall be as follows:
 1. Revenue metering applications: equal to or less than ± 0.1 percent for ratio and ± 0.9 mrad (three minutes) for phase angle.
 2. Other applications: equal to or less than $+1.2$ percent for ratio and ± 17.5 mrad (one degree) for phase angle.
4. Compare measured burdens to instrument transformer ratings.
5. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the primary windings are considered to have passed the test.
6. Power-factor or dissipation-factor values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use test equipment manufacturer's published data.
7. Test results shall indicate that the circuits are grounded at only one point.

7. INSPECTION AND TEST PROCEDURES

7.10.2 Instrument Transformers, Voltage Transformers

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.10.3 Instrument Transformers, Coupling-Capacitor Voltage Transformers

7.10.3 Instrument Transformers, Coupling-Capacitor Voltage Transformers

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Verify correct connection of transformers with system requirements.
4. Verify that adequate clearances exist between primary and secondary circuit wiring.
5. Verify the unit is clean.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.10.3.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify that all required grounding and connections provide contact.
8. Verify correct primary and secondary fuse sizes for voltage transformers.
9. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
10. Perform as-left tests.
11. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests for one minute winding-to-winding and each winding-to-ground. Test voltages shall be applied for one minute in accordance with Table 100.5. For units with solid-state components that cannot tolerate the applied voltage, follow manufacturer's recommendations.
3. Perform a polarity test on each transformer to verify the polarity marking. See IEEE C93.1 for standard polarity marking.
4. Perform a ratio test on all tap positions.
5. Measure voltage circuit burdens at transformer terminals.

7. INSPECTION AND TEST PROCEDURES

7.10.3 Instrument Transformers, Coupling-Capacitor Voltage Transformers

6. *Perform a dielectric withstand test on the primary windings with the secondary windings connected to ground. The dielectric withstand voltage shall be in accordance with Table 100.9. The test voltage shall be applied for one minute.
7. Measure capacitance of capacitor sections.
8. Perform power-factor or dissipation-factor tests in accordance with test equipment manufacturer's published data.
9. Verify that the coupling-capacitor voltage transformer circuits are grounded and have only one grounding point in accordance with IEEE C57.13.3. That grounding point should be located as specified by the engineer in the project drawings.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.10.3.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.10.3.A.11)

D. Test Values – Coupling Capacitor Voltage Transformers

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values of instrument transformers shall not be less than values shown in Table 100.5.
3. Polarity results shall agree with transformer markings.
4. In accordance with IEEE C57.13.8.1.1, the ratio error shall be as follows:
 1. Revenue metering applications: equal to or less than ± 0.1 percent for ratio and ± 0.9 mrad (three minutes) for phase angle.
 2. Other applications: equal to or less than $+1.2$ percent for ratio and ± 17.5 mrad (one degree) for phase angle.
5. Measured burdens shall be compared to instrument transformer ratings.
6. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.

7. INSPECTION AND TEST PROCEDURES

7.10.3 Instrument Transformers, Coupling-Capacitor Voltage Transformers

7. Capacitance of capacitor sections of coupling-capacitor voltage transformers shall be in accordance with manufacturer's published data.
8. Power-factor or dissipation-factor values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use test equipment manufacturer's published data.
9. Test results shall indicate that the circuits are grounded at only one point.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.10.4 Instrument Transformers, High-Accuracy Instrument Transformers

7.10.4 Instrument Transformers, High-Accuracy Instrument Transformers

—RESERVED—

7. INSPECTION AND TEST PROCEDURES

7.11.1 Metering Devices, Electromechanical and Solid-State

7.11.1 Metering Devices, Electromechanical and Solid-State

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Verify tightness of electrical connections.
4. Inspect cover gasket, cover glass, condition of spiral spring, disk clearance, contacts, and case-shorting contacts, as applicable.
5. Verify the unit is clean.
6. Verify freedom of movement, end play, and alignment of rotating disk(s).

B. Electrical Tests

1. Verify accuracy of meters per manufacturer's published data.
2. Calibrate meters in accordance with manufacturer's published data.
3. Verify all instrument multipliers.
4. Verify that current transformer and voltage transformer secondary circuits are intact.

C. Test Values – Visual and Mechanical

1. Tightness of electrical connections shall assure a low-resistance connection. (7.11.1.A.3)
2. Display and indicating devices shall operate per the manufacturer's published data.

D. Test Values – Electrical

1. Meter accuracy shall be in accordance with manufacturer's published data.
2. Calibration results shall be within manufacturer's published tolerances.
3. Instrument multipliers shall be in accordance with system design specifications.
4. Test results shall confirm the integrity of the secondary circuits of current and voltage transformers.

7. INSPECTION AND TEST PROCEDURES

7.11.2 Metering Devices, Microprocessor-Based

7.11.2 Metering Devices, Microprocessor-Based

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect meters and cases for physical damage.
3. Verify the unit is clean.
4. Verify tightness of electrical connections.
5. Record model number, serial number, firmware revision, software revision, and rated control voltage.
6. Verify operation of display and indicating devices.
7. Record passwords.
8. Verify unit is grounded in accordance with manufacturer's instructions.
9. Verify unit is connected in accordance with manufacturer's instructions and project drawings.
10. Upload owner supplied settings file.

B. Electrical Tests

1. Apply voltage or current as appropriate to each analog input and verify correct measurement and indication.
2. Confirm correct operation and setting of each auxiliary input/output feature in use, including mechanical relay, digital, and analog.
3. After initial system energization, confirm measurements and indications are consistent with loads present in accordance with ANSI/NETA ECS *Standard for Electrical Commissioning Specifications for Electrical Power Equipment and Systems*.

C. Test Values – Visual and Mechanical

1. Nameplate data shall be per drawings. (7.11.2.A.1)
2. Tightness of electrical connections shall assure a low resistance connection. (7.11.2.A.4)
3. Display and indicating devices shall operate per manufacturer's published data. (7.11.2.A.6)

7. INSPECTION AND TEST PROCEDURES

7.11.2 Metering Devices, Microprocessor-Based

D. Test Values – Electrical

1. Measurement and indication of applied values of voltage and current shall be within manufacturer's published tolerances for accuracy.
2. All auxiliary input/output features shall operate per settings and manufacturer's published data.
3. Measurements and indications shall be consistent with energized system loads.

7. INSPECTION AND TEST PROCEDURES

7.12.1.1 Regulating Apparatus, Voltage, Step Voltage Regulators

7.12.1.1 Regulating Apparatus, Voltage, Step Voltage Regulators

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect impact recorder prior to unloading regulator.
4. Inspect anchorage, alignment, and grounding.
5. Verify removal of any shipping bracing and vent plugs after final placement.
6. *Perform leakage reactance three phase equivalent and per phase tests.
7. Verify the unit is clean.
8. Verify auxiliary device operation.
9. Verify tightness of accessible-bolted electrical connections by calibrated torque-wrench method or in accordance with 7.12.1.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
10. Verify correct operation of motor and drive train and automatic motor cutoff at maximum lower and raise positions.
11. Verify appropriate lubrication on drive motor components.
12. Verify correct liquid level in all tanks and bushings.
13. Perform specific inspections and mechanical tests as recommended by the manufacturer.
14. Record as-found and as-left operation counter readings.
15. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests on each winding-to-ground in any off-neutral position. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Calculate polarization index.

7. INSPECTION AND TEST PROCEDURES

7.12.1.1 Regulating Apparatus, Voltage, Step Voltage Regulators

3. Perform insulation power-factor or dissipation-factor tests on windings in accordance with test equipment manufacturer's published data.
4. Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/ capacitance tap. In the absence of a power-factor/ capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
5. Measure winding resistance of source windings in the neutral position. Measure the resistance of all taps on load windings.
6. *Perform dynamic winding resistance measurement.
7. *Perform leakage reactance three phase equivalent and per phase test.
8. Perform special tests and adjustments as recommended by manufacturer.
9. *If the regulator has a separate tap-changer compartment, test for the presence of oxygen in the gas blanket in the main tank.
10. Perform turns-ratio test on each voltage step position. Verify that the indicator correctly identifies all tap positions.
11. Verify accurate operation of voltage range limiter.
12. Verify operation and accuracy of bandwidth, time delay, voltage, and line-drop compensation functions of regulator control device.
13. Sample insulating liquid in the main tank and tap-changer tank or common tank in accordance with ASTM D923 and perform dissolved-gas analysis in accordance with IEEE C57.104 or ASTM D 3612.
14. Remove a sample of insulating liquid from the main tank or common tank in accordance with ASTM D 923. Sample shall be tested in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D 1816
 2. Acid neutralization number: ASTM D 974
 3. Specific gravity: ASTM D 1298
 4. Interfacial tension: ASTM D 971
 5. Color: ASTM D 1500
 6. Visual condition: ASTM D 1524

7. INSPECTION AND TEST PROCEDURES

7.12.1.1 Regulating Apparatus, Voltage, Step Voltage Regulators

7. *Power factor: ASTM D 924
 Required when the regulator voltage is 46 kV or higher.
8. Water in insulating liquids: ASTM D 1533
15. If the regulator has a separate tap-changer compartment remove a sample of insulating liquid from the tap-changer tank in accordance with ASTM D 923. Sample shall be tested in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D 1816
 2. Color: ASTM D 1500
 3. Visual condition: ASTM D 1524
16. Verify operation of heaters.

C. Test Values – Visual and Mechanical

1. Auxiliary devices should operate in accordance with system design. (7.12.1.1.A.7)
2. Bolt-torque levels should be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.12.1.1.A.10)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.12.1.1.A.16)
4. Motor, drive train, and automatic cutoff should operate in accordance with manufacturer's design. (7.12.1.1.A.11)
5. Liquid level in tanks and bushings should be within indicated tolerances. (7.12.1.1.A.13)
6. The operation counter shall move incrementally for each operation performed. (7.12.1.1.A.13)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.12.1.1 Regulating Apparatus, Voltage, Step Voltage Regulators

2. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. Resistance values shall be temperature corrected in accordance with Table 100.14. The polarization index shall be compared to manufacturer's factory test results. If manufacturer's test results are not available the polarization index value shall not be less than 1.0.
3. Maximum power-factor or dissipation-factor values of liquid-filled regulators shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, compare to test equipment manufacturer's published data. Representative-values are indicated in Table 100.3.
4. Power-factor or dissipation-factor and capacitance values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliamperere/milliwatt loss basis, and the results shall be compared to values of similar bushings.
5. Consult the manufacturer if winding-resistance test values vary by more than two percent from factory test values or between adjacent phases.
6. Dynamic winding resistance measurements results shall compare to factory test results.
7. Investigate leakage reactance three phase equivalent test results that deviate from the nameplate by more than 3%. The per phase test results serve as a benchmark for future tests and should not deviate from the average of the three readings by more than 3%.
8. Special tests and adjustments shall meet manufacturer's published requirements.
9. Investigate presence of oxygen in nitrogen gas blanket.
10. Turns-ratio test results shall maintain a normal deviation between each voltage step and shall not deviate more than one-half percent from the calculated voltage ratio.
11. Voltage range limiter shall operate within manufacturer's recommendations.
12. Operation and accuracy of bandwidth, time-delay, voltage, and live drop compensation functions shall be as specified.
13. Results of dissolved gas analysis shall be evaluated in accordance with IEEE C57.104 or ASTM D 3612.
14. Results of insulating liquid tests on the main tank of regulators having a separate tap-changer compartment or the common tank of single tank voltage regulators shall be in accordance with Table 100.4.
15. Results of insulating liquid tests on the tap-changer tank of regulators having a separate tap-changer compartment shall be in accordance with Table 100.4.

7. INSPECTION AND TEST PROCEDURES

7.12.1.1 Regulating Apparatus, Voltage, Step Voltage Regulators

16. Heaters shall be operational.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.12.1.2 Regulating Apparatus, Voltage, Induction Regulators

7.12.1.2 Regulating Apparatus, Voltage, Induction Regulators

—WITHDRAWN—

7. INSPECTION AND TEST PROCEDURES

7.12.2 Regulating Apparatus, Current

7.12.2 Regulating Apparatus, Current

—RESERVED—

7. INSPECTION AND TEST PROCEDURES

7.12.3 Regulating Apparatus, Load Tap-Changers

7.12.3 Regulating Apparatus, Load Tap-Changers

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Inspect impact recorder.
5. Verify removal of any shipping bracing and vent plugs.
6. Verify the unit is clean.
7. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
8. Verify correct auxiliary device operation.
9. Verify correct operation of motor and drive train and automatic motor cutoff at maximum lower and maximum raise positions.
10. Verify appropriate liquid level in all tanks.
11. Perform specific inspections and mechanical tests as recommended by the manufacturer.
12. Verify appropriate lubrication on motor components.
13. Record as-found and as-left operation counter readings.
14. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform insulation-resistance tests in any off-neutral position in accordance with Section 7.2.2.
2. Perform insulation power-factor or dissipation-factor tests in accordance with Section 7.2.2.
3. *Perform winding-resistance test at each tap position.
4. Perform special tests and adjustments as recommended by the manufacturer.

7. INSPECTION AND TEST PROCEDURES

7.12.3 Regulating Apparatus, Load Tap-Changers

5. Perform dynamic winding resistance measurement.
6. *Perform leakage reactance three phase equivalent and per phase tests.
7. Perform turns-ratio test at all tap positions.
8. Remove a sample of insulating liquid in accordance with ASTM D 923. The sample shall be tested for the following in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D 1816
 2. Color: ASTM D 1500
 3. Visual condition: ASTM D 1524
9. Remove a sample of insulating liquid in accordance with ASTM D923 and perform dissolved gas analysis in accordance with IEEE C57.104 or ASTM D 3612.
10. *Perform magnetron atmospheric condition (MAC) test on each vacuum interrupter.
11. *Perform vacuum bottle integrity tests (dielectric withstand voltage) across each vacuum bottle with the contacts in the open position in strict accordance with manufacturer's published data.
12. * Perform excitation test on all taps and neutral position.
13. Verify operation of heaters.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.12.3.A.7)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.12.3.A.14)
3. Auxiliary device operation shall be in accordance with design intent. (7.12.3.A.8)
4. Motor, drive train, and automatic cutoff shall operate in accordance with manufacturer's design intent and automatic motor cutoff shall operate at maximum lower and maximum raise positions. (7.12.3.A.9)
5. Liquid level in tanks shall be within indicated tolerances. (7.12.3.A.10)
6. Operation counter shall have had an incremental change in accordance with tap-changer operation. (7.12.3.A.13)

7. INSPECTION AND TEST PROCEDURES

7.12.3 Regulating Apparatus, Load Tap-Changers

D. Test Values – Electrical

1. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated.
2. Maximum winding insulation power-factor/dissipation-factor values of liquid-filled transformers shall be in accordance with the transformer manufacturer's published data. In the absence of manufacturer's data, use Table 100.3.
3. Consult the manufacturer if winding-resistance values vary by more than one percent from measurements of adjacent windings.
4. Special tests and adjustments shall be in accordance with manufacturer's published data.
5. Dynamic winding resistance measurements results shall compare to factory test results.
6. Investigate leakage reactance three phase equivalent test results that deviate from the nameplate by more than 3%. The per phase test results serve as a benchmark for future tests and should not deviate from the average of the three readings by more than 3%.
7. Turns-ratio test results shall maintain a normal deviation between each voltage step and shall not deviate more than one-half percent from the calculated voltage ratio.
8. Results of insulating liquid tests shall be in accordance with Table 100.4.
9. Results of dissolved-gas analysis shall be evaluated in accordance with IEEE C57.104.
10. In the absence of manufacturer's published data, each vacuum interrupter pressure shall not be greater than 1×10^{-2} Pa and shall not deviate from adjacent poles by more than two orders of magnitude.
11. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
12. The typical excitation-current test data pattern for a three-legged core transformer is two similar current readings and one lower current reading. The test should produce a pattern typical for the specific transformer type and configuration.
13. Heaters shall be operational.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.13 Grounding Systems

7.13 Grounding Systems

A. Visual and Mechanical Inspection

1. Verify ground system is in compliance with drawings, specifications, and NFPA 70, *National Electrical Code*, Article 250.
2. Inspect physical and mechanical condition.
3. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.13.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform fall-of-potential or alternative test in accordance with IEEE 81 on the main grounding electrode or system.
3. Perform point-to-point tests to determine the resistance between the main grounding system and all major electrical equipment frames, system neutral, and derived neutral points.

C. Test Values – Visual and Mechanical

1. Grounding system electrical and mechanical connections shall be free of corrosion. (7.13.A.2)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.13.A.3)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. The resistance between the main grounding electrode and ground shall be no greater than five ohms for large commercial or industrial systems and one ohm or less for generating or transmission station grounds unless otherwise specified by the owner. (Reference IEEE 142)
3. Investigate point-to-point resistance values that exceed 0.5 ohm.

7. INSPECTION AND TEST PROCEDURES

7.14 Ground-Fault Protection Systems, Low-Voltage

7.14 Ground-Fault Protection Systems, Low-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect the components for damage and errors in polarity or conductor routing.
 1. Verify that the ground connection is made on the source side of the neutral disconnect link and also on the source side of any ground fault sensor.
 2. Verify that the neutral sensors are connected with correct polarity on both primary and secondary.
 3. Verify that all phase conductors and the neutral pass through the sensor in the same direction for zero sequence systems.
 4. Verify that grounding conductors do not pass through the zero sequence sensors.
 5. Verify that the grounded conductor is solidly grounded.
3. Verify the unit is clean.
4. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.14.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
5. Verify correct operation of all functions of the self-test panel.
6. Verify that the control power transformer has adequate capacity for the system.
7. Set pickup and time-delay settings in accordance with the settings provided in the owner's specifications. Record appropriate operation and test sequences as required by NFPA 70, *National Electrical Code*, Article 230.95.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Measure the system neutral-to-ground insulation resistance with the neutral disconnect link temporarily removed. Replace the neutral disconnect link after testing.

7. INSPECTION AND TEST PROCEDURES

7.14 Ground-Fault Protection Systems, Low-Voltage

3. *Perform insulation resistance test on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components or control devices that cannot tolerate the applied voltage, follow manufacturer's recommendation.
4. Perform ground fault protective device pickup tests using primary current injection.
5. For summation type systems utilizing phase and neutral current transformers, verify correct polarities by applying current to each phase-neutral current transformer pair. This test also applies to molded-case breakers utilizing an external neutral current transformer.
6. Measure time delay of the ground fault protective device at a value equal to or greater than 150 percent of the pickup value.
7. Verify reduced control voltage tripping capability is 55 percent for ac systems and 80 percent for dc systems.
8. Verify blocking capability of zone interlock systems.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.14.A.4)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. System neutral-to-ground insulation resistance shall be a minimum of one megohm.
3. Insulation-resistance values of control wiring shall not be less than two megohms.
4. Results of pickup test shall be greater than 90 percent of the ground fault protection device pickup setting and less than 1200 amperes or 125 percent of the pickup setting, whichever is smaller.
5. The ground fault protective device shall operate when current direction is the same relative to polarity marks in the two current transformers. The ground fault protective device shall not operate when current direction is opposite relative to polarity marks in the two current transformers.

7. INSPECTION AND TEST PROCEDURES

7.14 Ground-Fault Protection Systems, Low-Voltage

6. Relay timing shall be in accordance with manufacturer's published data but must be no longer than one second at 3000 amperes in accordance with NFPA 70, *National Electrical Code*, Article 230.95.
7. The circuit interrupting device shall operate when control voltage is 55 percent of nominal voltage for ac circuits and 80 percent of nominal voltage for dc circuits.
8. Results of zone-blocking tests shall be in accordance with manufacturer's published data and design specifications.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.15.1 Rotating Machinery, AC Induction Motors and Generators

7.15.1 Rotating Machinery, AC Induction Motors and Generators

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Inspect air baffles, filter media, stator winding, stator core, rotor, cooling fans, slip rings, brushes, brush rigging, and bearings.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.15.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. *Perform special tests such as air-gap spacing and machine alignment.
7. *Manually rotate the rotor and check for problems with the bearings or shaft.
8. *Rotate the shaft and measure and record the shaft extension runout.
9. Verify the application of appropriate lubrication and lubrication systems.
10. Verify that resistance temperature detector (RTD) circuits conform to drawings.
11. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests in accordance with IEEE Standard 43.
 1. Machines larger than 200 horsepower (150 kilowatts):
Test duration shall be ten minutes. Calculate polarization index.
 2. Machines 200 horsepower (150 kilowatts) and less:
Test duration shall be one minute. Calculate dielectric-absorption ratio for 60/30 second periods.
3. On machines rated at 2300 volts and greater, perform dielectric withstand voltage tests in accordance with:

7. INSPECTION AND TEST PROCEDURES

7.15.1 Rotating Machinery, AC Induction Motors and Generators

1. IEEE Standard 95 for dc dielectric withstand voltage tests.
2. NEMA MG1 for ac dielectric withstand voltage tests.
4. Perform phase-to-phase stator resistance test on machines 2300 volts and greater.
5. *Perform insulation power-factor or dissipation-factor tests.
6. *Perform power-factor or dissipation-factor tip-up tests.
7. *Perform surge comparison tests.
8. Perform insulation-resistance test on insulated bearings in accordance with manufacturer's published data.
9. Test surge protection devices in accordance with Section 7.19 and Section 7.20.
10. Test motor starter in accordance with Section 7.16.
11. Perform resistance tests on resistance temperature detector (RTD) circuits.
12. Verify operation of machine space heater.
13. *Perform vibration test while machine is running under load.
14. *Measure bearing temperatures while machine is running under load.
15. *Perform current signature analysis while machine is running under load.
16. *Perform partial discharge test.

C. Test Values – Visual and Mechanical

1. Inspection (7.15.1.A.4)
 1. Air baffles shall be clean.
 2. Filter media shall be clean.
 3. Stator winding shall be clean and show no evidence of overheating, cracking, tracking, or surface partial discharge activity.
 4. Stator core shall be clean with no ventilation duct blockage, lamination looseness, burning, or rubs from contact with the rotor.
 5. Rotor shall be clean and show no evidence of overheating or cracked bars or end rings and show no evidence of rubs from contact with the stator.

7. INSPECTION AND TEST PROCEDURES

7.15.1 Rotating Machinery, AC Induction Motors and Generators

6. Cooling fans shall operate, not be loose on the rotor shaft, and have no cracks.
 7. Slip ring alignment shall be within manufacturer's published tolerances.
 8. Brush alignment shall be within manufacturer's published tolerances.
 9. Brush rigging shall be in accordance with manufacturer's published data.
 10. Bearings shall be inspected for evidence of overheating, rubs, rolling element damage contamination, electrical damage, and lack of lubrication.
-
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.15.1.A.5)
 3. Results of the thermographic survey shall be in accordance with Section 9. (7.15.1.A.11)
 4. Air-gap spacing and machine alignment shall be in accordance with manufacturer's published data. (7.15.1.A.6)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate any values that deviate from similar bolted connections by more than 50 percent of the lowest value.
2. The recommended minimum insulation resistance ($IR_{1 \text{ min}}$) test results in megohms shall be in accordance with Table 100.11.
 1. The polarization index value shall not be less than 2.0.
 2. The dielectric absorption ratio shall not be less than 1.4.
3. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
4. Investigate phase-to-phase stator resistance values that deviate by more than five percent.
5. Power-factor or dissipation-factor values shall be compared to manufacturer's published data. In the absence of manufacturer's data these values will be compared with previous values of similar machines.
6. Tip-up values shall indicate no significant increase in power factor.

7. INSPECTION AND TEST PROCEDURES

7.15.1 Rotating Machinery, AC Induction Motors and Generators

7. If no evidence of distress, insulation failure, or lack of waveform nesting is observed by the end of the total time of voltage application during the surge comparison test, the test specimen is considered to have passed the test.
8. Bearing insulation-resistance measurements shall be within manufacturer's published tolerances. In the absence of manufacturer's published tolerances, the comparison shall be made to similar machines.
9. Test results of surge protection devices shall be in accordance with Section 7.19 and Section 7.20.
10. Test results of motor starter equipment shall be in accordance with Section 7.16.
11. RTD circuits shall conform to design intent and machine protection device manufacturer's published data.
12. Heaters shall be operational.
13. Vibration amplitudes of the uncoupled and unloaded machine shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, vibration amplitudes shall not exceed values shown in Table 100.10. If values exceed those in Table 100.10, perform complete vibration analysis.
14. Verify bearing RTDs indicate the correct temperature.
15. Investigate cause if current signature analysis tests show evidence of cracks or breaks in squirrel-cage windings, non-uniform air gaps, rolling element bearing defect, etc. Sideband magnitudes less than 40 dB from the power frequency are considered indicators of broken bars, whereas magnitudes less than 60 dB may be a warning of a developing problem. Non-uniform air gaps may be present when the average of the difference between the current magnitudes of the side frequencies from the highest magnitude frequency component are less than 15 dB, and a warning if less than 25 dB.
16. Perform visual inspections and off-line tests on stator windings if partial discharge levels are high based on comparison to previous tests, tests on similar machines, or values suggested by the test instrument manufacturer.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.15.2 Rotating Machinery, Synchronous Motors and Generators

7.15.2 Rotating Machinery, Synchronous Motors and Generators

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Inspect air baffles, filter media, stator windings, stator core, rotor, cooling fans, slip rings, brushes, brush rigging, and bearings.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.15.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Perform special tests such as air-gap spacing and machine alignment.
7. Manually rotate the rotor and check for problems with the bearings or shaft.
8. Rotate the shaft and measure and record the shaft extension runout.
9. Verify the application of appropriate lubrication and lubrication systems.
10. Verify that resistance temperature detector (RTD) circuits conform to drawings.
11. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests in accordance with IEEE Standard 43.
 1. Machines larger than 200 horsepower (150 kilowatts):
Test duration shall be for ten minutes. Calculate polarization index.
 2. Machines 200 horsepower (150 kilowatts) and less:
Test duration shall be for one minute. Calculate dielectric-absorption ratio.
3. On machines rated at 2300 volts and greater perform dielectric withstand voltage tests in accordance with:
 1. IEEE Standard 95 for dc dielectric withstand voltage tests.

7. INSPECTION AND TEST PROCEDURES

7.15.2 Rotating Machinery, Synchronous Motors and Generators

2. NEMA MG1 for ac dielectric withstand voltage tests.
4. Perform phase-to-phase stator resistance test on machines 2300 volts and greater.
5. *Perform insulation power-factor or dissipation-factor tests.
6. *Perform power-factor or dissipation-factor tip-up tests.
7. *Perform surge comparison tests.
8. Perform insulation-resistance test on insulated bearings in accordance with manufacturer's published data.
9. Test surge protection devices in accordance with Section 7.19 and Section 7.20.
10. Test motor starter in accordance with Section 7.16.
11. Perform resistance tests on resistance temperature detector (RTD) circuits.
12. Verify operation of machine space heater.
13. *Perform vibration test while machine is running under load.
14. Perform insulation-resistance tests on the main rotating field winding, the exciter-field winding, and the exciter-armature winding in accordance with IEEE Standard 43.
15. *Perform an ac voltage-drop test on all rotating field poles.
16. *Perform a high-potential test on the excitation system in accordance with IEEE Standard 421.3.
17. Measure resistance of machine-field winding, exciter-stator winding, exciter-rotor windings, and field discharge resistors.
18. *Perform front-to-back resistance tests on diodes and gating tests of silicon-controlled rectifiers for field application semiconductors.
19. Prior to re-energizing, apply voltage to the exciter supply and adjust exciter-field current to nameplate value.
20. Verify that the field application timer and the enable timer for the power-factor relay have been tested and set to the motor drive manufacturer's recommended values.
21. *Record stator current, stator voltage, and field current for the complete acceleration period including stabilization time for a normally loaded starting condition. From the recording determine the following information:

7. INSPECTION AND TEST PROCEDURES

7.15.2 Rotating Machinery, Synchronous Motors and Generators

1. Bus voltage prior to start.
2. Voltage drop at start.
3. Bus voltage at machine full-load.
4. Locked-rotor current.
5. Current after synchronization but before loading.
6. Current at maximum loading.
7. Acceleration time to near synchronous speed.
8. Revolutions per minute (RPM) just prior to synchronization.
9. Field application time.
10. Time to reach stable synchronous operation.
22. *Plot a V-curve of stator current versus excitation current at approximately 50 percent load to check correct exciter operation.
23. *If the range of exciter adjustment and machine loading permit, reduce excitation to cause power factor to fall below the trip value of the power-factor relay. Verify relay operation.
24. Measure bearing temperatures while machine is running under load.
25. *Perform current signature analysis test while machine is running under load.
26. *Perform partial discharge test.

C. Test Values – Visual and Mechanical

1. Inspection (7.15.2.A.4)
 1. Air baffles shall be clean and installed in accordance with manufacturer's published data.
 2. Filter media shall be clean and installed in accordance with manufacturer's published data.
 3. Stator winding shall be clean and show no evidence of overheating, cracking, tracking, or surface partial discharge activity.

7. INSPECTION AND TEST PROCEDURES

7.15.2 Rotating Machinery, Synchronous Motors and Generators

4. Stator core shall be clean with no ventilation duct blockage, lamination looseness, burning, or rubs from contact with the rotor.
 5. Rotor shall be clean and show no evidence of overheating or cracked bars or end rings and should show no evidence of rubs from contact with the stator.
 6. Cooling fans shall operate, not be loose on the rotor shaft, and have no cracks in them.
 7. Slip ring alignment shall be within manufacturer's published tolerances.
 8. Brush alignment shall be within manufacturer's published tolerances.
 9. Brush rigging shall be in accordance with manufacturer's published data.
 10. Bearings shall be inspected for evidence of overheating, rubs, rolling element damage, contamination, electrical damage, and lack of lubrication.
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.15.2.A.5)
 3. Results of thermographic survey shall be in accordance with Section 9. (7.15.2.A.11)
 4. Air-gap spacing and machine alignment shall be in accordance with manufacturer's published data. (7.15.2.A.6)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate any values that deviate from similar bolted connections by more than 50 percent of the lowest value.
2. The recommended minimum insulation resistance ($IR_{1 \text{ min}}$) test results in megohms shall be in accordance with Table 100.11.
 1. The polarization index value shall not be less than 2.0.
 2. The dielectric absorption ratio shall not be less than 1.4.
3. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
4. Investigate phase-to-phase stator resistance values that deviate by more than five percent.

7. INSPECTION AND TEST PROCEDURES

7.15.2 Rotating Machinery, Synchronous Motors and Generators

5. Power-factor or dissipation-factor values shall be compared to manufacturer's published data. In the absence of manufacturer's data shall be compared with previous values of similar machines.
6. Tip-up values shall indicate no significant increase in power factor or dissipation factor.
7. If no evidence of distress, insulation failure, or lack of waveform nesting is observed by the end of the total time of voltage application during the surge comparison test, the test specimen is considered to have passed the test.
8. Insulation resistance of bearings shall be within manufacturer's published tolerances. In the absence of manufacturer's published tolerances, the comparison shall be made to similar machines.
9. Test results of surge protection devices shall be in accordance with Section 7.19 and Section 7.20.
10. Test results of motor starter equipment shall be in accordance with Section 7.16.
11. RTD circuits shall be in accordance with system design intent and machine protection device manufacturer's specifications.
12. Heaters shall be operational.
13. Vibration amplitudes of the uncoupled and unloaded machine shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, vibration amplitudes shall not exceed values shown in Table 100.10. If values exceed those in Table 100.10, perform complete vibration analysis.
14. The recommended minimum insulation resistance ($IR_{1 \text{ min}}$) test results in megohms shall be in accordance with Table 100.11.
15. The pole-to-pole ac voltage drop shall not exceed 10 percent variance between poles.
16. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the winding is considered to have passed the test.
17. The measured resistance values of motor-field windings, exciter-stator windings, exciter-rotor windings, and field-discharge resistors shall be compared to manufacturer's published data. In the absence of manufacturer's data, the comparison shall be made to similar machines.
18. Resistance test results of diodes and gating tests of silicon-controlled rectifiers shall be in accordance with industry standards and system design requirements.

7. INSPECTION AND TEST PROCEDURES

7.15.2 Rotating Machinery, Synchronous Motors and Generators

19. Exciter power supply shall allow exciter-field current to be adjusted to nameplate value.
20. Application timer and enable timer for power-factor relay test results shall comply with manufacturer's recommended values.
21. Recorded values shall be in accordance with system design requirements.
22. Plotted V-curve shall indicate correct exciter operation.
23. When reduced excitation falls below trip value for the power-factor relay, the relay shall operate.
24. Verification that bearing temperature detectors are indicating the correct temperatures.
25. Investigate cause if current signature analysis tests show evidence from non-uniform air gaps, rolling element bearing defect, etc. Sideband magnitudes less than 40 dB from the power frequency are considered indicators of broken bars, whereas, magnitudes of less than 60 dB may be a warning of a developing problem. Non-uniform air gaps may be present when the average of the difference between the current magnitudes of the side frequencies from the highest magnitude frequency component are less than 15 dB, and a warning if less than 25 dB.
26. Perform visual inspections and off-line tests on stator windings if partial discharge levels are high based on comparison to previous tests, tests on similar machines, or values suggested by the test instrument manufacturer.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.15.3 Rotating Machinery, DC Motors and Generators

7.15.3 Rotating Machinery, DC Motors and Generators

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Inspect air baffles, filter media, field poles and yokes, armature, cooling fans, commutator, brushes, brush rigging, and bearings.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.15.3.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Inspect commutator and tachometer generator.
7. *Perform special tests such as air-gap spacing, bar tightness of commutator, and machine alignment.
8. *If the armature can be manually rotated, check for any obvious problems with the bearings or shaft.
9. *If the motor shaft can be rotated, measure and record the shaft extension runout.
10. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests on all windings in accordance with IEEE Standard 43.
 1. Machines larger than 200 horsepower (150 kilowatts):
Test duration shall be for ten minutes. Calculate polarization index.
 2. Machines 200 horsepower (150 kilowatts) and less:
Test duration shall be for one minute. Calculate dielectric absorption ratio for 60/30 second periods.
3. *Perform high-potential test in accordance with NEMA MG 1, Section 3.01.
4. *Perform an ac voltage-drop test on all field poles.

7. INSPECTION AND TEST PROCEDURES

7.15.3 Rotating Machinery, DC Motors and Generators

5. *Perform a surge (impulse) comparison test on the field and armature winding.
6. *Perform armature commutator bar-to-bar resistance test.
7. If the motor has both shunt and series field windings, their relative polarity is to be checked and the leads are to be marked appropriately.
8. Measure armature running current and field current or voltage. Compare to nameplate.
9. *Perform vibration tests while machine is running under load.
10. Verify that all protective devices are in accordance with Section 7.16.

C. Test Values – Visual and Mechanical

1. Inspection (7.15.3.A.4)
 1. Air baffles shall be clean and installed in accordance with manufacturer's published data.
 2. Filter media shall be clean.
 3. Field poles and yokes shall show no evidence of overheating, contamination, or other defects.
 4. The armature and commutator shall show no evidence of overheating, contamination, or other defect.
 5. Cooling fans shall operate.
 6. Commutator runout shall be within manufacturer's published tolerances.
 7. Brush alignment shall be within manufacturer's published tolerances.
 8. Brush rigging shall be in accordance with manufacturer's published data.
 9. Bearings shall be inspected for evidence of overheating, rubs, rolling element damage contamination, electrical damage, and lack of lubrication.
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.15.3.A.5)
3. Results of thermographic survey shall be in accordance with Section 9. (7.15.3.A.10)
4. Commutator and tachometer generator shall be in accordance with manufacturer's published data and system design. (7.15.3.A.6)

7. INSPECTION AND TEST PROCEDURES

7.15.3 Rotating Machinery, DC Motors and Generators

5. Air-gap spacing and machine alignment shall be in accordance with manufacturer's published data. (7.15.3.A.7)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate any values that deviate from similar bolted connections by more than 50 percent of the lowest value.
2. The recommended minimum insulation resistance (IR 1 min) test results in megohms shall be in accordance with Table 100.11.
3. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the winding is considered to have passed the test.
4. The individual pole-to-pole ac voltage drop shall not exceed ten percent variance from the average value (average value = test voltage divided by number of coils) applicable to all of the poles.
5. Measured running current and field current or voltage shall be comparable to nameplate data.
6. Vibration amplitudes of the uncoupled and unloaded machine shall not exceed values shown in Table 100.10. If values exceed those in Table 100.10, perform complete vibration analysis.
7. Test results of motor starter equipment shall be in accordance with Section 7.16.
8. Investigate bar-to-bar resistance values of armature that deviate by more than five percent.

| *Optional Test

7. INSPECTION AND TEST PROCEDURES

7.16.1.1 Motor Control, Motor Starters, Low-Voltage

7.16.1.1 Motor Control, Motor Starters, Low-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Inspect contactors.
 1. Verify mechanical operation.
 2. Verify contact gap, wipe, alignment, and pressure are in accordance with manufacturer's published data.
6. *Motor-Running Protection
 1. Verify overload element rating/motor protection settings are correct for application.
 2. If motor-running protection is provided by fuses, verify correct fuse rating.
7. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
8. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
9. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with starter closed, and across each open pole. Test voltage shall be in accordance with manufacturer's published data or Table 100.1.
2. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.

7. INSPECTION AND TEST PROCEDURES

7.16.1.1 Motor Control, Motor Starters, Low-Voltage

3. Test motor protection devices in accordance with manufacturer's published data. In the absence of manufacturer's data, use Section 7.9.
4. Test circuit breakers in accordance with Section 7.6.1.1.
5. Perform operational tests by initiating control devices.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.16.1.1.A.7)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.16.1.1.A.9)

D. Test Values – Electrical

1. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated.
2. Insulation-resistance values of control wiring shall not be less than two megohms.
3. Motor protection parameters shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Section 7.9.
4. Circuit breaker test results shall be in accordance with Section 7.6.1.1.
5. Control devices shall perform in accordance with system design and/or requirements.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.16.1.2 Motor Control, Motor Starters, Medium-Voltage

7.16.1.2 Motor Control, Motor Starters, Medium-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Test electrical and mechanical interlock systems for correct operation and sequencing.
7. Verify correct barrier and shutter installation and operation.
8. Exercise active components and confirm correct operation of indicating devices.
9. Inspect contactors.
 1. Verify mechanical operation.
 2. Verify contact gap, wipe, alignment, and pressure are in accordance with manufacturer's published data.
10. Verify overload protection rating is correct for its application. Set adjustable or programmable devices according to the protective device coordination study.
11. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
12. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform insulation-resistance tests on contactor(s) for one minute, phase-to-ground and phase-to-phase with the contactor closed, and across each open contact. Test voltage shall be in accordance with manufacturer's published data, or Table 100.1.

7. INSPECTION AND TEST PROCEDURES

7.16.1.2 Motor Control, Motor Starters, Medium-Voltage

2. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
3. *Perform magnetron atmospheric condition (MAC) test on each vacuum interrupter.
4. *Perform a dielectric withstand voltage test in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.9.
5. Perform vacuum bottle integrity test (dielectric withstand voltage) across each vacuum bottle with the contacts in the open position in strict accordance with manufacturer's published data.
6. Perform contact/pole resistance tests.
7. Measure blowout coil circuit resistance.
8. Measure resistance of power fuses.
9. Energize contactor using an auxiliary source. Adjust armature to minimize operating vibration.
10. Test control power transformers in accordance with Section 7.1.B.8.
11. Test starting transformers, in accordance with Section 7.2.1.
12. Test starting reactors, in accordance with 7.20.3.
13. Test motor protection devices in accordance with manufacturer's published data. In the absence of manufacturer's data, test in accordance with Section 7.9.
14. *Perform system function test in accordance with ANSI/NETA ECS Standard for Electrical Commissioning Specifications for Electrical Power Equipment & Systems.
15. Verify operation of cubicle space heater.
16. Test instrument transformers in accordance with Section 7.10.
17. Test metering devices in accordance with Section 7.11.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.16.1.2.A.5)

7. INSPECTION AND TEST PROCEDURES

7.16.1.2 Motor Control, Motor Starters, Medium-Voltage

2. Results of the thermographic survey shall be in accordance with Section 9. (7.16.1.2.A.12)
3. Electrical and mechanical interlocks shall operate in accordance with system design. (7.16.1.2.A.6)
4. Barrier and shutter installation and operation shall be in accordance with manufacturer's design. (7.16.1.2.A.7)
5. Indicating devices shall operate in accordance with system design. (7.16.1.2.A.8)

D. Test Values – Electrical

1. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.5. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
2. Insulation-resistance values of control wiring shall not be less than two megohms.
3. Evaluate each vacuum interrupter in accordance with test equipment manufacturer's instructions. In the absence of manufacturer's published data, each vacuum interrupter pressure shall not be greater than 1×10^{-2} Pa and shall not deviate from adjacent poles by more than two orders of magnitude.
4. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
5. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the vacuum bottle integrity test, the vacuum bottle is considered to have passed the test.
6. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values which deviate from those of similar connections by more than 50 percent of the lowest value.
7. Resistance values of blowout coils shall be in accordance with manufacturer's published data.
8. Resistance values shall not deviate by more than 15 percent between identical fuses.
9. Contactor coil shall operate with minimal vibration and noise.
10. Control power transformer test results shall be in accordance with Section 7.1.D.8.

7. INSPECTION AND TEST PROCEDURES

7.16.1.2 Motor Control, Motor Starters, Medium-Voltage

11. Starting transformer test results shall be in accordance with Section 7.2.1.
12. Starting reactor test results shall be in accordance with Section 7.20.3.
13. Motor protection parameters shall be in accordance with manufacturer's published data.
14. System function test results shall be in accordance with manufacturer's published data and system design.
15. Heaters shall be operational.
16. The results of instrument transformer tests shall be in accordance with Section 7.10.
17. Metering device test results shall be in accordance with Section 7.11.

| *Optional Test

7. INSPECTION AND TEST PROCEDURES

7.16.2.1 Motor Control, Motor Control Centers, Low-Voltage

7.16.2.1 Motor Control, Motor Control Centers, Low-Voltage

1. Refer to Section 7.1 for appropriate inspections and tests of the motor control center bus.
2. Refer to Section 7.5.1.1 for appropriate inspections and tests of the motor control center switches.
3. Refer to Section 7.6 for appropriate inspections and tests of the motor control center circuit breakers.
4. Refer to Section 7.16.1.1 for appropriate inspections and tests of the motor control center starters.

7. INSPECTION AND TEST PROCEDURES

7.16.2.2 Motor Control, Motor Control Centers, Medium-Voltage

7.16.2.2 Motor Control, Motor Control Centers, Medium-Voltage

1. Refer to Section 7.1 for appropriate inspections and tests of the motor control center bus.
2. Refer to Section 7.5.1.2 for appropriate inspections and tests of the motor control center switches.
3. Refer to Section 7.6 for appropriate inspections and tests of the motor control center circuit breakers.
4. Refer to Section 7.16.1.2 for appropriate inspections and tests of the motor control center starters.

7. INSPECTION AND TEST PROCEDURES

7.17 Adjustable Speed Drive Systems

7.17 Adjustable Speed Drive Systems

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Ensure vent path openings are free from debris and that heat transfer surfaces are not contaminated by oil, dust, and dirt.
6. Verify correct connections of circuit boards, wiring, disconnects, and ribbon cables.
7. Motor running protection
 1. Compare drive overcurrent setpoints with motor full-load current rating to verify correct settings.
 2. If drive is used to operate multiple motors, compare individual overload element ratings with motor full-load current ratings.
 3. Apply minimum and maximum speed setpoints. Confirm setpoints are within limitations of the load coupled to the motor.
8. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.17.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
9. Verify correct fuse sizing in accordance with manufacturer's published data.
10. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with low-resistance ohmmeter.
2. Test the motor overload relay elements by injecting primary current through the overload circuit and monitoring trip time of the overload element.
3. Test input circuit breaker by primary injection in accordance with Section 7.6.

7. INSPECTION AND TEST PROCEDURES

7.17 Adjustable Speed Drive Systems

4. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
5. Test for the following parameters in accordance with relay calibration procedures outlined in Section 7.9 or as recommended by the manufacturer:
 1. Input phase loss protection
 2. Input overvoltage protection
 3. Output phase rotation
 4. Overtemperature protection
 5. DC overvoltage protection
 6. Overfrequency protection
 7. Drive overload protection
 8. Fault alarm outputs
6. Perform continuity tests on bonding conductors in accordance with Section 7.13.
7. Perform startup of drive in accordance with manufacturer's published data. Calibrate drive to the system's minimum and maximum speed control signals.
8. Perform operational tests by initiating control devices.
 1. Slowly vary drive speed between minimum and maximum. Observe motor and load for unusual noise or vibration.
 2. Verify operation of drive from remote start/stop and speed control signals.
9. Measure fuse resistance.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.17.A.8)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.17.A.10)

7. INSPECTION AND TEST PROCEDURES

7.17 Adjustable Speed Drive Systems

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Overload test trip times at 300 percent of overload element rating shall be in accordance with manufacturer's published time-current curve.
3. Input circuit breaker test results shall be in accordance with Section 7.6.
4. Insulation-resistance values of control wiring shall not be less than two megohms.
5. Relay calibration test results shall be in accordance with Section 7.9.
6. Continuity of bonding conductors shall be in accordance with Section 7.13.
7. Control devices shall perform in accordance with system requirements.
8. Operational tests shall conform to system design requirements.
9. Investigate fuse resistance values that deviate from each other by more than 15 percent.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.18.1.1 Direct-Current Systems, Batteries, Flooded Lead-Acid

7.18.1.1 Direct-Current Systems, Batteries, Flooded Lead-Acid

A. Visual and Mechanical Inspection

1. Verify that batteries are adequately located.
2. Verify that battery area ventilation system is operable.
3. Verify existence of suitable eyewash equipment.
4. Compare equipment nameplate data with drawings.
5. Inspect physical and mechanical condition.
6. Verify adequacy of battery support racks, mounting, battery spill containment system, anchorage, clearances, alignment, and grounding.
7. Verify electrolyte level. Measure electrolyte specific gravity and temperature levels.
8. Verify presence of flame arresters.
9. Verify the units are clean.
10. Verify application of an oxide inhibitor on battery terminal connections.
11. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
12. Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Measure charger float and equalizing voltage levels. Adjust to battery manufacturer's recommended settings.
2. Verify all charger functions and alarms.
3. Measure each monoblock/cell voltage and total battery voltage with charger energized and in float mode of operation.
4. Measure intercell connection resistances.
5. Perform internal ohmic measurement tests.
6. Perform a load test in accordance with manufacturer's specifications or IEEE 450.

7. INSPECTION AND TEST PROCEDURES

7.18.1.1 Direct-Current Systems, Batteries, Flooded Lead-Acid

7. Measure the battery system voltage from positive-to-ground and negative-to-ground.

C. Test Values – Visual and Mechanical

1. Electrolyte level and specific gravity shall be within normal limits. (7.18.1.1.A.7)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.18.1.1.A.11)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.18.1.1.A.12)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Charger float and equalize voltage levels shall be in accordance with battery manufacturer's published data.
3. The results of charger functions and alarms shall be in accordance with manufacturer's published data.
4. Cell voltages shall be within 0.05 volt of each other or in accordance with manufacturer's published data.
5. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
6. Cell internal ohmic values (resistance, impedance, or conductance) shall not vary by more than 25 percent between identical cells that are in a fully charged state.
7. Results of load tests shall be in accordance with manufacturer's published data or IEEE 450.
8. Voltage measured from positive to ground shall be equal in magnitude to the voltage measured from negative to ground.

7. INSPECTION AND TEST PROCEDURES

7.18.1.2 Direct-Current Systems, Batteries, Vented Nickel-Cadmium

7.18.1.2 Direct-Current Systems, Batteries, Vented Nickel-Cadmium

A. Visual and Mechanical Inspection

1. Verify that batteries are adequately located.
2. Verify that battery area ventilation system is operable.
3. Verify existence of suitable eyewash equipment.
4. Compare equipment nameplate data with drawings.
5. Inspect physical and mechanical condition.
6. Verify adequacy of battery support racks or cabinets, mounting, battery spill containment system, anchorage, alignment, grounding, and clearances.
7. Verify electrolyte level. Measure pilot-cell electrolyte temperature.
8. Verify the units are clean.
9. Verify application of an oxide inhibitor on battery terminal connections.
10. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
11. Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Measure charger float and equalizing voltage levels. Adjust to battery manufacturer's recommended settings.
2. Verify all charger functions and alarms.
3. Measure each monoblock/cell voltage and total battery voltage with charger energized and in float mode of operation.
4. Measure intercell connection resistances.
5. Perform a load test in accordance with manufacturer's published data or IEEE 1106.
6. Measure the battery system voltage from positive to-ground and negative-to-ground.

7. INSPECTION AND TEST PROCEDURES

7.18.1.2 Direct-Current Systems, Batteries, Vented Nickel-Cadmium

C. Test Values – Visual and Mechanical

1. Electrolyte level shall be within normal limits. (7.18.1.2.A.7)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.18.1.2.A.10)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.18.1.2.A.11)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Charger float and equalize voltage levels shall be in accordance with battery manufacturer's published data.
3. The results of charger functions and alarms shall be in accordance with manufacturer's published data.
4. Cell voltages shall be within 0.05 volt of each other or in accordance with manufacturer's published data.
5. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
6. Results of load tests shall be in accordance with manufacturer's published data or IEEE 1106.
7. Voltage measured from positive to ground shall be equal in magnitude to the voltage measured from negative to ground.

7. INSPECTION AND TEST PROCEDURES

7.18.1.3 Direct-Current Systems, Batteries, Valve-Regulated Lead-Acid

7.18.1.3 Direct-Current Systems, Batteries, Valve-Regulated Lead-Acid

A. Visual and Mechanical Inspection

1. Verify that batteries are adequately located.
2. Verify that battery area ventilation system is operable.
3. Verify existence of suitable eyewash equipment.
4. Compare equipment nameplate data with drawings.
5. Inspect physical and mechanical condition.
6. Verify adequacy of battery support racks or cabinets, mounting, anchorage, alignment, grounding, and clearances.
7. Verify the units are clean.
8. Verify the application of an oxide inhibitor on battery terminal connections.
9. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
10. Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Measure negative post temperature.
2. Measure charger float and equalizing voltage levels.
3. Verify all charger functions and alarms.
4. Measure each monoblock/cell voltage and total battery voltage with charger energized and in float mode of operation.
5. Measure intercell connection resistances.
6. Perform internal ohmic measurement tests.
7. Perform a load test in accordance with manufacturer's published data or IEEE 1188.
8. Measure the battery system voltage from positive to ground and negative to ground.

7. INSPECTION AND TEST PROCEDURES

7.18.1.3 Direct-Current Systems, Batteries, Valve-Regulated Lead-Acid

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.18.1.3.A.9)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.18.1.3.A.10)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values that deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Negative post temperature shall be within manufacturer's published data or IEEE 1188.
3. Charger float and equalize voltage levels shall be in accordance with the battery manufacturer's published data.
4. Results of charger functions and alarms shall be in accordance with manufacturer's published data.
5. Monoblock/cell voltages shall be in accordance with manufacturer's published data.
6. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
7. Monoblock/cell internal ohmic values (resistance, impedance, or conductance) shall not vary by more than 25 percent between identical monoblocks/cells that are in a fully charged state.
8. Results of load tests shall be in accordance with manufacturer's published data or IEEE 1188.
9. Voltage measured from positive to ground shall be similar in magnitude to the voltage measured from negative to ground.

7. INSPECTION AND TEST PROCEDURES

7.18.2 Direct-Current Systems, Chargers

7.18.2 Direct-Current Systems, Chargers

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect for physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.18.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Inspect filter and tank capacitors.
7. Verify operation of cooling fans and presence of filters.
8. Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through all bolted connections with a low-resistance ohmmeter.
2. Verify float voltage and equalize voltage.
3. Verify high-voltage shutdown settings.
4. Verify correct load sharing (parallel chargers).
5. Verify calibration of meters in accordance with Section 7.11.
6. Verify operation of alarms.
7. Measure and record input and output voltage and current.
8. Measure and record ac ripple current and voltage imposed on the battery.
9. *Perform full load testing and verify current limit of charger.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.18.2.A.5)

7. INSPECTION AND TEST PROCEDURES

7.18.2 Direct-Current Systems, Chargers

2. Results of the thermographic survey shall be in accordance with Section 9. (7.18.2.A.8)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values that deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Float and equalize voltage settings shall be in accordance with the battery manufacturer's published data.
3. High- voltage shutdown settings shall be in accordance with manufacturer's published data.
4. Results of load sharing between parallel chargers shall be in accordance with system design specifications.
5. Results of meter calibration shall be in accordance with Section 7.11.
6. Results of alarm operation shall be in accordance with manufacturer's published data and system design.
7. Input and output voltage shall be in accordance with manufacturer's published data.
8. AC ripple current and voltage imposed on the battery shall be within the charger manufacturer's specification and in accordance with the battery manufacturer's published data.
9. Charger shall be capable of producing rated full load output and current limit shall be in accordance with the specified settings.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.18.3 Direct-Current Systems, Rectifiers

7.18.3 Direct-Current Systems, Rectifiers

—RESERVED—

7. INSPECTION AND TEST PROCEDURES

7.19.1 Surge Protective Devices, Low-Voltage

7.19.1 Surge Protective Devices, Low-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and clearances.
4. Verify the device is clean.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Verify that the ground lead is attached to ground with the shortest wire length possible.

B. Electrical Tests

1. Verify self-test operation, alarms, counter-indication, and status indicators.
2. Test grounding connection in accordance with Section 7.13.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.19.1.A.5)

D. Test Values – Electrical

1. Self-test operation, alarms, counters, and status indicators shall function in accordance with the manufacturer's published data.
2. Resistance between the arrester ground terminal and the ground system shall be less than 0.5 ohm and in accordance with Section 7.13.

7. INSPECTION AND TEST PROCEDURES

7.19.2 Surge Arresters, Medium- and High-Voltage

7.19.2 Surge Arresters, Medium- and High-Voltage

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and clearances.
4. Verify the arresters are clean.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.19.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Verify that the ground lead on each device is individually attached to ground with the shortest wire length possible.
7. Verify that the stroke counter is correctly mounted and electrically connected.
8. Record the stroke counter reading.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform an insulation-resistance test on each arrester, phase terminal-to-ground. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
3. Test grounding connection in accordance with Section 7.13.
4. Perform a watts-loss test for substation class surge arresters.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.19.2.A.5.2)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.19.2 Surge Arresters, Medium- and High-Voltage

2. Insulation –resistance values shall be in accordance with manufacturer’s published data. In the absence of manufacturer’s data, use Table 100.1. Values of insulation resistance less than this table or manufacturer’s recommendations should be investigated.
3. Resistance between the arrester ground terminal and the ground system shall be less than 0.5 ohm and in accordance with Section 7.13.
4. Watts-loss values are evaluated on a comparison basis with similar units and test equipment manufacturer’s published data.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.20.1 Capacitors

7.20.1 Capacitors

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and clearances.
4. Verify the unit is clean.
5. Verify that capacitors are electrically connected in their specified configuration.
6. Verify tightness of accessible-bolted electrical connections by calibrated torque-wrench method or in accordance with 7.20.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests from phase terminal(s) to case for one minute. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1.
3. Measure the capacitance of all terminal combinations.
4. Measure resistance of the internal discharge resistors.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.20.1.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.20.1.A.7)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.20.1 Capacitors

2. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table for manufacturer's recommendations should be investigated.
3. Investigate capacitance values differing from manufacturer's published data.
4. Investigate discharge resistor values differing from manufacturer's published data. In accordance with NFPA 70, Article 460, residual voltage of a capacitor shall be reduced to 50 volts in the following time intervals after being disconnected from the source of supply:

<u>Rated Voltage</u>	<u>Discharge Time</u>
< 600 volts	1 minute
> 600 volts	5 minutes

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.20.2 Capacitor Control Devices

7.20.2 Capacitor Control Devices

—RESERVED—

7. INSPECTION AND TEST PROCEDURES

7.20.3.1 Reactors (Shunt and Current-Limiting) Dry-Type

7.20.3.1 Reactors (Shunt and Current-Limiting) Dry-Type

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. *Perform insulation power-factor or dissipation-factor tests on all windings in accordance with test equipment manufacturer's published data.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.20.3.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify that tap connections are as specified.
8. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with low-resistance ohmmeter.
2. Perform winding-to-ground insulation-resistance tests. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, refer to Table 100.1.
3. Measure winding resistance.
4. *Perform dielectric withstand voltage tests on each winding to ground.
5. *Perform insulation resistance power-factor or dissipation-factor tests on all windings in accordance with test equipment manufacturer's published data.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12. (7.20.3.1.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.20.3.1.A.8)

7. INSPECTION AND TEST PROCEDURES

7.20.3.1 Reactors (Shunt and Current-Limiting) Dry-Type

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
3. Winding-resistance test results shall be within one percent of factory results.
4. AC dielectric withstand test voltage shall not exceed 75 percent of factory test voltage for one minute duration. DC dielectric withstand test voltage shall not exceed 100 percent of the factory rms test voltage for one minute duration. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
5. Maximum insulation power-factor/dissipation-factor values of reactors corrected to 20°C shall be in accordance with the manufacturer's published data. In the absence of manufacturer's data, use Table 100.3.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.20.3.2 Reactors (Shunt and Current-Limiting) Liquid-Filled

7.20.3.2 Reactors (Shunt and Current-Limiting) Liquid-Filled

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect impact recorder prior to unloading.
4. Verify removal of any shipping bracing after final placement.
5. Inspect anchorage, alignment, and grounding.
6. Verify the unit is clean.
7. Verify settings and operation of all temperature devices.
8. Verify that cooling fans and pumps operate correctly and that fan and pump motors have correct overcurrent protection.
9. Verify operation of all alarm, control, and trip circuits from temperature and level indicators, pressure relief device, and fault pressure relay.
10. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.20.3.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
11. Verify correct liquid level in all tanks and bushings.
12. Verify that positive pressure is maintained on nitrogen-blanketed reactors.
13. Perform specific inspections and mechanical tests as recommended by the manufacturer.
14. Verify that tap connections are as specified.
15. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with low-resistance ohmmeter.
2. Perform winding-to-ground insulation-resistance tests. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Calculate polarization index.

7. INSPECTION AND TEST PROCEDURES

7.20.3.2 Reactors (Shunt and Current-Limiting) Liquid-Filled

3. Perform insulation power-factor or dissipation-factor tests on windings in accordance with the test equipment manufacturer's published data.
4. Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/ capacitance tap. In the absence of a power-factor/ capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
5. Measure winding resistance.
6. Measure the percentage of oxygen in the nitrogen gas blanket.
7. Remove a sample of insulating liquid in accordance with ASTM D923. Sample shall be tested for the following:
 1. Dielectric breakdown voltage: ASTM D1816.
 2. Acid neutralization number: ASTM D974.
 3. Specific gravity: ASTM D1298.
 4. Interfacial tension: ASTM D971.
 5. Color: ASTM D1500.
 6. Visual Condition: ASTM D1524.
 7. Water in insulating liquids: ASTM D1533.
 8. Measure power factor or dissipation factor in accordance with ASTM D924.
8. Remove a sample of insulating liquid in accordance with ASTM D923 and perform dissolved-gas analysis in accordance with IEEE C57.104 or ASTM D-3612.

C. Test Values – Visual and Mechanical

1. Operation of temperature devices shall be in accordance with system requirements. (7.20.3.2.A.7)
2. Operation of pumps and fans shall be in accordance with manufacturer's recommendations and system design. (7.20.3.2.A.8)
3. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.20.3.2.A.10)

7. INSPECTION AND TEST PROCEDURES

7.20.3.2 Reactors (Shunt and Current-Limiting) Liquid-Filled

4. Results of the thermographic survey shall be in accordance with Section 9.
(7.20.3.2.A.15)
5. Liquid levels shall be in accordance with manufacturer's published tolerances.
(7.20.3.2.A.11)
6. Positive pressure shall be indicated on the pressure gauge for gas-blanketed reactors.
(7.20.3.2.A.12)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated. The polarization index shall be greater than 1.0.
3. Maximum power-factor or dissipation-factor values of liquid-filled reactors shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, compare to test equipment manufacturer's published data. Representative values are indicated in Table 100.3.
4. Power-factor or dissipation-factor and capacitance values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliampere/ milliwatt-loss basis, and the results shall be compared to values of similar bushings.
5. Consult the manufacturer if winding-resistance test values vary by more than two percent from factory test values or between adjacent phases.
6. Investigate presence of oxygen in the nitrogen gas blanket.
7. Insulating liquid values shall be in accordance with Table 100.4.
8. Results of dissolved-gas analysis shall be evaluated in accordance with IEEE Standard C57.104.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.20.4 Resistors

7.20.4 Resistors

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Verify proper anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.20.4.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. Verify correct liquid level in all tanks and bushings.
7. Perform mechanical inspections and tests as recommended by the manufacturer.
8. Verify that filters are in place and vents are clear.
9. Perform visual and mechanical inspection of instrument transformers in accordance with Section 7.10.
10. Verify monitoring and auxiliary systems.
11. *Perform a thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with low-resistance ohmmeter.
2. Perform resistor-to-ground insulation-resistance tests. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1.
3. Measure resistance value.
4. Perform electrical tests on instrument transformers in accordance with Section 7.10.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels should be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12 (7.20.4.A.5).

7. INSPECTION AND TEST PROCEDURES

7.20.4 Resistors

2. Results of the thermographic survey shall be in accordance with Section 9. (7.20.4.A.11)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values should be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
3. Consult the manufacturer if resistance values vary more than two percent from factory acceptance tests.
4. Results of electrical tests on instrument transformers shall be in accordance with Section 7.10.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.21 Outdoor Bus Structures

7.21 Outdoor Bus Structures

A. Visual and Mechanical Inspection

1. Compare bus arrangement with drawings and specifications.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the support insulators are clean.
5. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.21.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
6. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Measure insulation resistance of each bus, phase-to-ground with other phases grounded for equipment rated less than 46 kV. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1.
3. Perform dielectric withstand voltage test on each bus phase, phase-to-ground with other phases grounded. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.19. Test duration shall be for one minute.
4. *Perform insulation power-factor or dissipation-factor tests on each bus phase, phase-to-ground with other phases grounded.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.21.A.5)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.21.A.6)

7. INSPECTION AND TEST PROCEDURES

7.21 Outdoor Bus Structures

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1.
3. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
4. Insulation power-factor or dissipation-factor results shall be compared to manufacturer's published data. In absence of manufacturer's published data, the comparison shall be made to previous test results or data from the test equipment manufacturers.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.22.1 Emergency Systems, Engine Generator

7.22.1 Emergency Systems, Engine Generator

NOTE: Other than protective shutdowns, the prime mover is not addressed in these specifications.

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.

B. Electrical and Mechanical Tests

1. Perform insulation-resistance tests in accordance with IEEE 43.
 1. Machines larger than 200 horsepower (150 kilowatts):
Test duration shall be ten minutes. Calculate polarization index.
 2. Machines 200 horsepower (150 kilowatts) and less:
Test duration shall be one minute. Calculate the dielectric-absorption ratio.
2. Test protective relay devices in accordance with Section 7.9.
3. Verify phase rotation, phasing, and synchronized operation as required by the application.
4. Functionally test engine shutdown for low oil pressure, overtemperature, overspeed, and other protection features as applicable.
5. *Perform vibration test for each main bearing cap.
6. Conduct performance test in accordance with NFPA 110.
7. Verify correct functioning of the governor and regulator.

C. Test Values – Visual and Mechanical

1. Anchorage, alignment, and grounding should be in accordance with manufacturer's published data and system design. (7.22.1.A.3)

7. INSPECTION AND TEST PROCEDURES

7.22.1 Emergency Systems, Engine Generator

D. Test Values – Electrical

1. The recommended minimum insulation resistance ($IR_{1 \text{ min}}$) test results in megohms shall be in accordance with Table 100.11.
 - 1.1 The polarization index value shall not be less than 2.0.
 - 1.2 The dielectric absorption ratio shall be greater than 1.0.
2. Protective relay device test results shall be in accordance with Section 7.9.
3. Phase rotation, phasing, and synchronizing shall be in accordance with system design requirements.
4. Low oil pressure, overtemperature, overspeed, and other protection features shall operate in accordance with manufacturer's published data and system design requirements.
5. Vibration levels shall be in accordance with manufacturer's published data and shall be compared to baseline data.
6. Performance tests shall conform to manufacturer's published data and NFPA 110.
7. Governor and regulator shall operate in accordance with manufacturer's published data and system design requirements.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.22.2 Emergency Systems, Uninterruptible Power Systems

7.22.2 Emergency Systems, Uninterruptible Power Systems

NOTE: There are many configurations of uninterruptible power supply installations. Some are as simple as a static switch selecting between two highly reliable sources, while others are complex systems using a combination of rectifiers, batteries, inverters, motor/generators, static switches, and bypass switches. It is the intent of these specifications to list possible tests of the major components of the system and more specifically the system as a whole. It is important that the manufacturer's recommended commissioning tests be performed.

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify that fuse sizes and types correspond to drawings.
5. Verify the unit is clean.
6. Test electrical and mechanical interlock systems for correct operation and sequencing.
7. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.22.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
8. Verify operation of forced ventilation.
9. Verify that filters are in place and/or vents are clear.
10. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Test static transfer from inverter to bypass and back. Use normal load, if possible.
3. Set free running frequency of oscillator.
4. Test dc undervoltage trip level on inverter input breaker. Set according to manufacturer's published data.
5. Test alarm circuits.

7. INSPECTION AND TEST PROCEDURES

7.22.2 Emergency Systems, Uninterruptible Power Systems

6. Verify synchronizing indicators for static switch and bypass switches.
7. Perform electrical tests for UPS system breakers in accordance with Section 7.6.
8. Perform electrical tests for UPS system automatic transfer switches in accordance with Section 7.22.3.
9. Perform electrical tests for UPS system batteries in accordance with Section 7.18.
10. Perform electrical tests for UPS rotating machinery in accordance with Section 7.15.

C. Test Values – Visual and Mechanical

1. Electrical and mechanical interlock systems shall operate in accordance with system design requirements. (7.22.2.A.6)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.22.2.A.7)
3. Results of the thermographic survey shall be in accordance with Section 9. (7.22.2.A.10)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Static transfer shall function in accordance with manufacturer's published data.
3. Oscillator free running frequency shall be within manufacturer's published tolerances.
4. DC undervoltage shall trip inverter input breaker.
5. Alarm circuits shall operate in accordance with design requirements.
6. Synchronizing indicators shall operate in accordance with design requirements.
7. Breaker performance shall be in accordance with Section 7.6.1.
8. Automatic transfer switch performance shall be in accordance with Section 7.22.3.
9. Battery test results shall be in accordance with Section 7.18.
10. Rotating machinery performance shall be in accordance with Section 7.15.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.22.3 Emergency Systems, Automatic Transfer Switches

7.22.3 Emergency Systems, Automatic Transfer Switches

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required clearances.
4. Verify the unit is clean.
5. Verify appropriate lubrication on moving current-carrying parts and on moving and sliding surfaces.
6. Verify that warning labels are attached and visible.
7. Verify tightness of all control connections.
8. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.22.3.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
9. Perform manual transfer operation.
10. Verify positive mechanical interlocking between normal and alternate sources.
11. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with switch in both source positions and across each open pole. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1.
3. *Perform insulation-resistance tests on all control wiring with respect to ground. The applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components or for control devices that cannot tolerate the applied voltage, follow manufacturer's recommendation.
4. Perform a contact/pole-resistance test.

7. INSPECTION AND TEST PROCEDURES

7.22.3 Emergency Systems, Automatic Transfer Switches

5. Verify settings and operation of control devices.
6. Calibrate and set all relays and timers in accordance with Section 7.9
7. Verify phase rotation, phasing, and synchronized operation as required by the application.
8. Verify correct operation and timing of the following functions:
 1. Normal source voltage-sensing and frequency-sensing relays.
 2. Engine start sequence.
 3. Time delay upon transfer.
 4. Alternate source voltage-sensing and frequency-sensing relays.
 5. Automatic transfer operation.
 6. Interlocks and limit switch function.
 7. Time delay and retransfer upon normal power restoration.
 8. Engine cool down and shutdown feature.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.22.3.A.8)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.22.3.A.11)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation resistance values of transfer switches shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated.
3. Insulation-resistance values of control wiring shall not be less than two megohms.

7. INSPECTION AND TEST PROCEDURES

7.22.3 Emergency Systems, Automatic Transfer Switches

4. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.
5. Control devices shall operate in accordance with manufacturer's published data.
6. Relay test results shall be in accordance with Section 7.9.
7. Phase rotation phasing, and synchronization shall be in accordance with system design specifications.
8. Operation and timing shall be in accordance with manufacturer's and system design requirements.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.23 Automation Systems and Communications

7.23 Automation Systems and Communications

A. Visual and Mechanical Inspection

1. Record model numbers, style numbers, serial numbers, firmware revisions, software revisions, and rated control voltage.
2. Inspect the physical and mechanical condition of equipment and wiring.
3. Verify operation of light-emitting diodes, displays, and targets.
4. Verify equipment is clean.
5. Check tightness of all connections.
6. Verify appropriate grounding equipment and circuits.
7. Verify backup batteries are healthy and connected.
8. Check with setting engineer for applicable firmware updates and product recalls.
9. Verify settings and application configurations are in accordance with engineered settings.
10. Verify devices display the correct date and time.
11. Reset and clear events, maintenance data, statistical data, and alarms from the devices after any tests.
12. Download or document settings and logic from the devices.

B. Electrical Tests

1. Perform metering tests on all analog inputs and verify metering values on the human machine interface (HMI) and at remote terminals.
2. Verify operation of all enabled digital inputs.
3. Verify operation of all digital outputs by operating the controlled device.
4. Verify all communication links are operational, error free, and function test failovers of redundant communication links.
5. Verify operation of all internal logic functions including tagging, lockouts, and local/remote control.
6. Verify alarm and status points.

7. INSPECTION AND TEST PROCEDURES

7.23 Automation Systems and Communications

7. Verify deadband and zero deadband settings and operation.
8. Reset and clear events, maintenance data, statistical data, and alarms from the devices after completion of tests.

C. Test Values – Visual and Mechanical

1. Light-emitting diodes, displays, and targets should illuminate.
2. Equipment shall be clean and operational.
3. Settings and logic shall agree with the most recent engineered setting files.
4. Verify equipment displays the correct date and time and events are accurately timestamp.

D. Test Values – Electrical

1. Metering readings shall be in accordance with manufacturer's published tolerances.
2. Inputs shall operate as per the design.
3. Outputs shall operate as per the design.
4. Communication links shall be operational and failover times shall be in accordance with the manufacturer's published data.
5. Internal logic functions shall operate as per the design.
6. Alarms and statuses shall be as per the design.
7. Deadbands shall operate in accordance with manufacturer's published data.
8. Indications and statistical data shall operate in accordance with manufacturer's published data.

7. INSPECTION AND TEST PROCEDURES

7.24.1 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Circuit Reclosers, Oil/Vacuum

7.24.1 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Circuit Reclosers, Oil/Vacuum

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Perform all mechanical operation and contact alignment tests on both the recloser and its operating mechanism in accordance with manufacturer's published data.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.24.1.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12.
7. Verify appropriate insulating liquid level.
8. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with recloser closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1.
3. Perform a contact/pole-resistance test.
4. *Perform insulation-resistance tests on all control wiring with respect to ground. Applied potential shall be 500 volts dc for 300-volt rated cable and 1000 volts dc for 600-volt rated cable. Test duration shall be one minute. For units with solid-state components, follow manufacturer's recommendation.
5. Remove a sample of insulating liquid in accordance with ASTM D 923. Sample shall be tested in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D 877

7. INSPECTION AND TEST PROCEDURES

7.24.1 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Circuit Reclosers, Oil/Vacuum

2. Color: ASTM D 1500
3. Visual condition: ASTM D 1524
6. Perform minimum pickup voltage tests on trip and close coils in accordance with manufacturer's published data.
7. *Perform power-factor or dissipation-factor tests on each pole with the recloser open and each phase with the recloser closed.
8. *Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/capacitance tap. In the absence of a power-factor/capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.
9. *Perform magnetron atmospheric condition (MAC) test on each vacuum interrupter.
10. Perform vacuum bottle integrity test (dielectric withstand voltage) across each vacuum bottle with the contacts in the open position in strict accordance with manufacturer's published data.
11. Perform dielectric withstand voltage test on each phase with the recloser closed and the poles not under test grounded. Test voltage shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.19.
12. Verify operation of heaters.
13. Test all protective functions in accordance with Section 7.9.
14. Test all metering and instrumentation in accordance with Section 7.11.
15. Test instrument transformers in accordance with Section 7.10.

C. Test Values – Visual and Mechanical

1. Mechanical operation and contact alignment shall be in accordance with manufacturer's published data. (7.24.1.A.5)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.24.1.A.6)
3. Insulating liquid level shall be in accordance with manufacturer's recommended tolerances. (7.24.1.A.7)
4. Results of the thermographic survey shall be in accordance with Section 9. (7.24.1.A.8)

7. INSPECTION AND TEST PROCEDURES

7.24.1 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Circuit Reclosers, Oil/Vacuum

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations shall be investigated.
3. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values that deviate from adjacent poles or similar reclosers by more than 50 percent of the lowest value.
4. Insulation-resistance values of control wiring shall not be less than two megohms.
5. Insulating liquid test results shall be in accordance with Table 100.4.
6. Minimum pickup voltage of the trip and close coils shall conform to the manufacturer's published data. In the absence of the manufacturer's published data, use Table 100.20.
7. Power-factor or dissipation-factor values and tank loss-index shall be compared to manufacturer's published data. In the absence of manufacturer's published data, the comparison shall be made to test data from similar circuit reclosers or data from test equipment manufacturers.
8. Power-factor or dissipation-factor and capacitance values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliampere/milliwatt loss basis, and the results shall be compared to values of similar bushings.
9. In the absence of manufacturer's published data, each vacuum interrupter pressure shall not be greater than 1×10^{-2} Pa and shall not deviate from adjacent poles by more than two orders of magnitude.
10. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the vacuum bottle integrity test, the test specimen is considered to have passed the test.
11. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand voltage test, the test specimen is considered to have passed the test.
12. Heaters shall be operational.

7. INSPECTION AND TEST PROCEDURES

7.24.1 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Circuit Reclosers, Oil/Vacuum

13. Protective device function test results shall be in accordance with Section 7.9.
14. Metering and instrumentation test results shall be in accordance with Section 7.11.
15. Instrument transformer test results shall be in accordance with Section 7.10.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.24.2 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Line Sectionalizers, Oil

7.24.2 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Line Sectionalizers, Oil

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition.
3. Inspect anchorage, alignment, and grounding.
4. Verify the unit is clean.
5. Perform all mechanical operation and contact alignment tests on both the sectionalizer and its operating mechanism in accordance with manufacturer's published data.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method or in accordance with 7.24.2.B.1. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify appropriate insulating liquid level.
8. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform resistance measurements through bolted connections with a low-resistance ohmmeter.
2. Perform insulation-resistance tests for one minute on each pole, phase-to-phase and phase-to-ground with sectionalizer closed, and across each open pole. Apply voltage in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1.
3. Perform a contact/pole-resistance test.
4. Remove a sample of insulating liquid in accordance with ASTM D923. The sample shall be tested in accordance with the referenced standard.
 1. Dielectric breakdown voltage: ASTM D877
 2. Color: ASTM D 1500
 3. Visual condition: ASTM D 1524

7. INSPECTION AND TEST PROCEDURES

7.24.2 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Line Sectionalizers, Oil

5. Perform dielectric withstand voltage tests on each pole-to-ground and pole-to-pole with recloser in closed position.
6. Test sectionalizer counting function by application of simulated fault current (greater than 160 percent of continuous current rating).
7. Test sectionalizer lockout function for all counting positions.
8. Test for reset timing on trip actuator.
9. *Perform power-factor or dissipation-factor tests on each pole with the recloser open and each phase with the recloser closed.
10. *Perform power-factor or dissipation-factor tests on each bushing equipped with a power-factor/ capacitance tap. In the absence of a power-factor/capacitance tap, perform hot-collar tests. These tests shall be in accordance with the test equipment manufacturer's published data.

C. Test Values – Visual and Mechanical

1. Mechanical operation and contact alignment shall be in accordance with manufacturer's published data. (7.24.2.A.5)
2. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.24.2.A.6)
3. Insulating liquid level shall be in accordance with manufacturer's recommended tolerances. (7.24.2.A.7)
4. Results of the thermographic survey shall be in accordance with Section 9. (7.24.2.A.8)

D. Test Values – Electrical

1. Compare bolted connection resistance values to values of similar connections. Investigate values which deviate from those of similar bolted connections by more than 50 percent of the lowest value.
2. Insulation-resistance values shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
3. Microhm or dc millivolt drop values shall not exceed the high levels of the normal range as indicated in the manufacturer's published data. If manufacturer's published data is not available, investigate values that deviate from adjacent poles or similar switches by more than 50 percent of the lowest value.

7. INSPECTION AND TEST PROCEDURES

7.24.2 Automatic Circuit Reclosers and Line Sectionalizers, Automatic Line Sectionalizers, Oil

4. Insulating liquid test results shall be in accordance with Table 100.4.
5. If no evidence of distress or insulation failure is observed by the end of the total time of voltage application during the dielectric withstand test, the test specimen is considered to have passed the test.
6. Operations counter shall advance one digit per close-open cycle.
7. Lockout function shall operate in accordance with manufacturer's published data.
8. Reset timing of trip actuator shall operate in accordance with manufacturer's published data.
9. Power-factor or dissipation-factor values and tank loss-index shall be compared to manufacturer's published data. In the absence of manufacturer's published data, the comparison shall be made to test data from similar sectionalizers or data from test equipment manufacturers.
10. Power-factor or dissipation-factor and capacitance values shall be within ten percent of nameplate rating for bushings. Hot collar tests are evaluated on a milliampere/milliwatt loss basis, and the results should be compared to values of similar bushings.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.25 Fiber-Optic Cables

7.25 Fiber-Optic Cables

A. Visual and Mechanical Inspection

1. Compare cable, connector, and splice data with drawings and specifications.
2. Inspect cable and connections for physical and mechanical damage.
3. Verify that all connectors and splices are correctly installed.
4. Verify that visible cable bends are not less than the manufacturer's minimum allowable bending radius.

B. Optical Tests

1. Perform cable length measurement, fiber fracture inspection, and construction defect inspection using an optical time domain reflectometer.
2. Perform connector and splice integrity test using an optical time domain reflectometer.
3. Perform cable attenuation loss measurement with an optical power loss test set.
4. Perform connector and splice attenuation loss measurement from both ends of the optical cable with an optical power loss test set.
5. Perform transmit and receive power measurements from local device and remote device.

C. Test Values – Visual and Mechanical

1. Cable and connections shall not have been subjected to physical or mechanical damage.
(7.25.1.1)
2. Connectors and splices shall be installed in accordance with industry standards.
(7.25.A.2)
3. Cable bends should not be less than the manufacturer's minimum allowable bending radius.

D. Test Values – Optical

1. The optical time domain reflectometer signal shall be analyzed for cable backscatter by viewing the reflected power/distance graph.
2. The optical time domain reflectometer signal shall be analyzed for excessive connection or splice attenuation by viewing the reflected power/distance graph.

7. INSPECTION AND TEST PROCEDURES

7.25 Fiber-Optic Cables

3. Attenuation loss measurement shall be expressed in dB/km. Losses shall be within the manufacturer's recommendations when no local site specifications are available.
4. Connector and splice attenuation loss measurement shall be expressed in dB/km. Losses shall be within the manufacturer's recommendations when no local site specifications are available.
5. Transmit and receive power measurement results shall compare to manufacturer's published data.

7. INSPECTION AND TEST PROCEDURES

7.26 Electric Vehicle Charging Systems

7.26 Electric Vehicle Charging Systems

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical and mechanical condition of cords and connectors.
3. Inspect anchorage, alignment, grounding, and required area clearances.
4. Verify the unit is clean and all shipping bracing, loose parts, and documentation shipped inside cubicles have been removed.
5. Verify that wiring connections are tight and that wiring is secure to prevent damage during routine operation of moving parts.
6. Verify tightness of accessible bolted electrical connections by calibrated torque-wrench method. Torque values shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.12.
7. Verify operation and sequencing of interlocking systems.
8. *Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Perform system function tests in accordance with manufacturer's published data.
2. Perform the following tests:
 - 2.1 Protective Earth (PE) grounding protection.
 - 2.2 Protective conductor resistance measurement.
 - 2.3 Touch voltage measurement.
 - 2.4 Personal protection.
 - 2.5 Nuisance tripping.
 - 2.6 Proximity pilot.
 - 2.7 Control pilot.
 - 2.8 Charger output voltage measurement.
 - 2.9 Charger output frequency (ac only) or ripple measurement.

7. INSPECTION AND TEST PROCEDURES

7.26 Electric Vehicle Charging Systems

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data. In the absence of manufacturer's published data, use Table 100.12. (7.26.A.6)
2. Results of the thermographic survey shall be in accordance with Section 9. (7.26.A.8)

D. Test Values – Electrical

1. Results of system function tests shall be in accordance with manufacturer's published data.
2. Result of the electrical test are as follows:
 - 2.1 Evaluate test results/indications in accordance with test equipment manufacturer's instructions.
 - 2.2 Investigate resistance values that exceed 0.5 ohms.
 - 2.3 Evaluate test results/indications in accordance with manufacturer's published data.
 - 2.4 Personal protection tripping devices shall operate in accordance with manufacturer's published data
 - 2.5 Nuisance tripping devices shall operate in accordance with manufacturer's published data.
 - 2.6 Evaluate test results/indications in accordance with manufacturer's published data.
 - 2.7 Evaluate test results/indications in accordance with manufacturer's published data.
 - 2.8 Evaluate test results/indications in accordance with manufacturer's published data.
 - 2.9 Evaluate test results/indications in accordance with manufacturer's published data.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.27 Arc Energy Reduction Systems

7.27 Arc Energy Reduction Systems

—RESERVED—

7. INSPECTION AND TEST PROCEDURES

7.28 Battery Energy Storage Systems (BESS)

7.28 Battery Energy Storage Systems (BESS)

A. Visual and Mechanical Inspection

1. Verify that batteries are adequately located.
2. Verify that battery area fire suppression equipment is installed.
3. Verify existence of suitable eyewash equipment.
4. Compare equipment nameplate data with drawings.
5. Inspect physical and mechanical condition.
6. Verify mounting, anchorage, alignment, grounding, and clearances.
7. Verify the units are clean.
8. Verify tightness of accessible field installed bolted electrical connections by calibrated torque wrench method in accordance with manufacturer's published data.
9. Perform thermographic survey in accordance with Section 9.

B. Electrical Tests

1. Test transformers in accordance with Section 7.2.
2. Test low voltage circuit breakers in accordance with Sections 7.6.1.1.1, 7.6.1.1.2, and 7.6.1.2.
3. Test field-installed low voltage interconnecting cables in accordance with Section 7.3.2.
4. *Perform a load test in accordance with manufacturer's published data.
5. Verify correct battery system voltage and polarity.
6. *Perform power quality measurement during start up at point of medium voltage inter-connection.

C. Test Values – Visual and Mechanical

1. Bolt-torque levels shall be in accordance with manufacturer's published data.
2. Results of the thermographic survey shall be in accordance with Section 9.

7. INSPECTION AND TEST PROCEDURES

7.28 Battery Energy Storage Systems (BESS)

D. Test Values – Electrical

1. Transformer results shall be in accordance with Section 7.2.
2. Circuit breaker results shall be in accordance with Sections 7.6.1.1.1, 7.6.1.1.2, and 7.6.1.2.
3. Low voltage cable results shall be in accordance with Section 7.3.2.
4. Results of load tests shall be in accordance with manufacturer's published data.
5. Voltage shall meet manufacturer's published data.
6. Results of power quality should be in accordance with IEEE 1547.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.29 Solar Photovoltaic (PV) Systems

7.29 Solar Photovoltaic (PV) Systems

A. Visual and Mechanical Inspection

1. Compare equipment nameplate data with drawings.
2. Inspect physical, electrical, and mechanical condition.
3. Inspect anchorage, alignment, grounding, and required area clearances.
4. Verify the equipment is clean and all shipping bracing, loose parts, and documentation shipped inside cubicles have been removed.
5. *Set the inverters, gateways, and data acquisition system in accordance with the engineered setting files.
6. Verify that wiring connections are tight and that wiring is secure.
7. *Perform thermographic survey.

B. Electrical Tests

1. Perform polarity tests for:
 1. Individual cables.
 2. PV string combiner boxes.
2. Perform blocking diode tests.
3. Perform dry insulation resistance tests for PV arrays or PV strings including modules, junction boxes, and cables in accordance with manufacturer's published data.
4. *Perform wet insulation resistance tests for PV arrays or PV strings including modules, junction boxes, and cables in accordance with manufacturer's published data.
5. Perform open-circuit voltage measurements for each PV string.
6. Perform short-circuit or operational current measurements for each PV string.
7. Performance test (I-V curve measurements) in accordance with manufacturer's published data.
8. Perform system voltage to ground measurements to verify correct system grounding.
9. Perform ground-resistance tests in accordance with Section 7.13.

7. INSPECTION AND TEST PROCEDURES

7.29 Solar Photovoltaic (PV) Systems

10. *Perform data acquisition and communication gateway tests in accordance with Section 7.23.

C. Test Values – Visual and Mechanical

1. Results of the thermographic survey shall be in accordance with manufacturer's published data (7.29.A.7).

D. Test Values – Electrical

1. Polarity checks shall prove the connections of the individual cables and PV string combiner boxes are correct and in accordance with the manufacturer's published data and system design.
2. The blocking diode shall be tested to verify the correct polarity and the diode voltage test results shall be in accordance with the manufacturer's published data.
3. Dry insulation-resistance test results shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
4. Wet insulation-resistance test results shall be in accordance with manufacturer's published data. In the absence of manufacturer's data, use Table 100.1. Values of insulation resistance less than this table or manufacturer's recommendations should be investigated.
5. Results of the open-circuit voltage measurements for each PV string shall be in accordance with manufacturer's published data.
6. Results of the short-circuit or operational current measurements for each PV string shall be in accordance with manufacturer's published data.
7. Results of the performance testing (I-V curve measurements) shall be in accordance with manufacturer's published data.
8. Results of voltage to ground measurements shall be in accordance with manufacturer's published data and the system grounding design.
9. Results of ground resistance tests shall be in accordance with Section 7.13.
10. Results of data acquisition and communication gateway tests shall be in accordance with Section 7.23.

*Optional Test

7. INSPECTION AND TEST PROCEDURES

7.30 Wind Turbine Systems

7.30 Wind Turbine Systems

—RESERVED—

8. SYSTEM FUNCTION TESTS AND COMMISSIONING

8. SYSTEM FUNCTION TESTS AND COMMISSIONING

It is the purpose of system function tests to prove the correct interaction of all sensing, processing, and action devices. Perform system function tests in accordance with ANSI/NETA ECS *Standard for Electrical Commissioning Specifications for Electrical Power Equipment & Systems*.

9. THERMOGRAPHIC SURVEY

9. THERMOGRAPHIC SURVEY

1. Visual and Mechanical Inspection

1. Inspect physical and mechanical condition.
2. Remove panel covers or view the equipment through viewing ports designed to transmit applicable signals being measured.
3. *Perform a follow-up thermographic survey within 12 months of final acceptance by the owner.

2. Thermographic Survey Report

Provide a report which includes the following:

1. Description of equipment tested.
2. Discrepancies.
3. Temperature difference between the area of concern and the reference area.
4. Probable cause of temperature difference.
5. Areas inspected. Identify inaccessible and/or unobservable areas and/or equipment.
6. Identify load conditions at time of inspection.
7. Provide photographs and/or thermograms of the deficient area.
8. Provide recommended action for repair.

3. Test Parameters

1. Inspect distribution systems with imaging equipment capable of detecting a minimum temperature difference of 1° C at 30° C.
2. Equipment shall detect emitted radiation and convert detected radiation to visual signal.
3. Thermographic surveys should be performed at normal circuit loading.

4. Test Results

Suggested actions based on temperature rise can be found in Table 100.18

*Optional Test

10.ELECTROMAGNETIC FIELD TESTING

10. ELECTROMAGNETIC FIELD TESTING

1. Procedure

1. Take detailed measurements of the magnetic flux density, vector direction, and temporal variations at the locations or over the area.
 1. Perform spot measurements of the magnetic fields (40 to 800 hertz) at grid intervals one meter above the floor throughout the office. Record x, y, z, and resultant magnetic flux density values for each measurement point.
 2. Take additional detailed spot measurements directly at floor level and at two meters above the floor at grid point locations directly on the wall surface separating measured area from suspected magnetic field source.
 3. If measured magnetic flux densities at any perimeter wall appear to be above 3.0 mG, take additional spot measurements of the adjoining space utilizing the same measurement grid spacing at one meter above floor.
 4. Take a baseline magnetic flux density reading at a specific point in the immediate area of the suspected magnetic field source.
 5. Determine magnetic field temporal variations as required by positioning the Gaussmeter at or near the location of highest magnetic flux density for 24 to 48 hours.
2. Obtain and record related electrical system information including current measurements.
3. The magnetic field evaluation shall be performed in accordance with the recommended practices and procedures in accordance with IEEE 644.

2. Survey Report

Provide a report which includes the following:

1. Basis, description, purpose, and scope of the survey.
2. Tabulations and or attached graphical representations of the magnetic flux density measurements corresponding to the time and area or space where the measurements were taken.
3. Descriptions of each of the operating conditions evaluated and identification of the condition that resulted in the highest magnetic flux density.
4. Descriptions of equipment performance issues related to measured magnetic flux density.
5. Description of magnetic field test equipment.
6. Conclusions and recommendations.

11.ONLINE PARTIAL DISCHARGE SURVEY

11. ONLINE PARTIAL DISCHARGE SURVEY

1. Inspection

1. Inspect physical and mechanical condition.
 - a. Inspect for audible indications of partial discharge.
 - b. Inspect for indications or ozone.
2. Select sensor technology base on the type of equipment under survey.
 - a. Transient -earth voltage (TEV)
 - b. High-frequency current transformer (HFCT).
 - c. Ultra-High Frequency (UHF).
 - d. Coupler technology on voltage indicator system (VIS) ports.
 - e. Contact acoustic.
 - f. Airborne acoustic.
3. Connect sensor to an instrument that displays the signal intensity and phase relationship of the signal.
4. Record results.
 1. Survey Report
 2. Provide a report that includes the following:
 3. List of equipment surveyed
 4. Discrepancies
 5. Background signal level for baseline reference.
 6. Probably cause of signal difference and nature of activity.
 7. Inaccessible or unobservable equipment.
 8. System voltage and current at time of inspection.
 9. Graphical or color-coded representation of the deficiencies.
 10. Recommended action.
 11. Test results

11. ONLINE PARTIAL DISCHARGE SURVEY

12. Suggested action can be found in Table 100.23.1, according to applicable sensor technology.

TABLES



**Standard for Acceptance Testing Specifications
for
Electrical Power
Equipment and Systems**

TABLES

Table 100.1 Insulation Resistance Test Values, Electrical Apparatus and Systems Other Than Rotating Machinery

Nominal Rating of Equipment (Volts)	Minimum DC Test Voltage (Volts)	Recommended Minimum Insulation Resistance (Megohms) at 20° C
250	500	25
600	1,000	100
1,000	1,000	100
2,500	1,000	500
5,000	2,500	1,500
8,000	2,500	2,500
15,000	2,500	5,000
25,000	5,000	10,000
34,500	5,000	100,000
46,000 and above	5,000	100,000

Notes:

1. In the absence of consensus standards dealing with insulation-resistance tests, the Standards Review Council suggests the above representative values.
2. See Table 100.14 for temperature correction factors.
3. Test results are dependent on the temperature of the insulating material and the humidity of the surrounding environment at the time of the test.
4. Insulation-resistance test data may be used to establish a trending pattern. Deviations from the baseline information permit evaluation of the insulation.
5. For rotating machinery insulation-resistance test values see Table 100.11.
6. For cables, the acceptability for energization should not be determined by the recommended minimum insulation resistance values shown above. Conductor and insulation geometry, temperature, and overall cable length need to be taken into account per manufacturer's published data for definitive minimum insulation resistance criteria.

TABLES

Table 100.2 Switchgear Withstand Test Voltages

Type of Switchgear	Rated Maximum Voltage (kV) (rms)	Maximum Test Voltage kV	DC
		AC	
Low-Voltage Power Circuit Breaker Switchgear	.254/.508/.635	1.6	2.3
	.730/1.058	2.2	3.1
Metal-Clad Switchgear	4.76	14	20
	8.25	27	37.5
	15	27	37.5
	27	45	†
	38	60	†
Station-Type Cubicle Switchgear	15.5	37	†
	38	60	†
	72.5	120	†
Metal Enclosed Interrupter Switchgear	With stress cone type terminations (With IEEE 386 type terminations)	With stress cone type terminations (With IEEE 386 type terminations)	
	4.76 (4.76)	14 (14)	20
	8.25 (8.25)	27 (25)	37
	15.0 (14.4)	27 (25)	37
	27.0 (26.3)	45 (30)	†
	38.0 (36.6)	60 (37)	†

Notes:

1. Derived from IEEE C37.20.1-2015, Paragraph 6.5, *Standard for Metal-Enclosed Low-Voltage Power Circuit-Breaker Switchgear*, C37.20.2-2015, Paragraph 6.5, *Standard for Metal-Clad Switchgear*, C37.20.2-1993, *Standard for Metal-Clad and Station-Type Cubicle Switchgear*, Paragraph 5.5, and C37.20.3-2013, Paragraph 5.2, *Standard for Metal-Enclosed Interrupter Switchgear*, and includes 0.75 multiplier with fraction rounded down.
 2. The column headed “DC” is given as a reference only for those using dc tests to verify the integrity of connected cable installations without disconnecting the cables from the switchgear. It represents values believed to be appropriate and approximately equivalent to the corresponding power frequency withstand test values specified for voltage rating of switchgear. The presence of this column in no way implies any requirement for a dc withstand test on ac equipment or that a dc withstand test represents an acceptable alternative to the low-frequency withstand tests specified in these specifications, either for design tests, production tests, conformance tests, or field tests. When making dc tests, the voltage should be raised to the test value in discrete steps and held for a period of one minute.
- † Because of the variable voltage distribution encountered when making dc withstand tests, the manufacturer should be contacted for recommendations before applying dc withstand tests to the switchgear. Voltage transformers above 34.5 kV should be disconnected when testing with dc. Refer to IEEE C57.13-1993 (*IEEE Standard Requirements for Instrument Transformers*) paragraph 8.8.2.

TABLES

**Table 100.3 Recommended Dissipation Factor/Power Factor at 20° C
Liquid-Filled Transformers, Regulators, and Reactors**

	Mineral Oil Maximum	Natural Ester Fluid
Power Transformers, Regulators, and Reactors	0.5%	1.0%

Notes:

1. In the absence of consensus standards dealing with transformer dissipation/power factor values, the NETA Standards Review Council suggests the above representative values.
2. Distribution transformer power factor results shall compare to previously obtained results.

TABLES

Table 100.4 Insulating Fluid Limits

Table 100.4.1 Test Limits for New Insulating Oil Received in New Equipment

Mineral Oil				
Test	ASTM Method	≤ 69 kV and Below	> 69 kV - < 230 kV	≥ 230 kV
Dielectric breakdown, kV minimum @ 1mm (0.04") gap	D1816	25	30	35
Dielectric breakdown, kV minimum @ 2 mm (0.08") gap	D1816	45	55	60
Interfacial tension mN/m minimum	D971	38	38	38
Neutralization number, mg KOH/g maximum	D974	0.03	0.03	0.03
Water content, ppm maximum	D1533	20	10	10
Power factor at 25° C, %	D924	0.05	0.05	0.05
Power factor at 100° C, %	D924	0.40	0.40	0.5
Color	D1500	0.5	0.5	0.5
Visual condition	D1524	Bright and clear	Bright and clear	Bright and clear

IEEE C57.106-2015, *Guide for Acceptance and Maintenance of Insulating Oil in Equipment*, Table 2.

TABLES

Table 100.4.2 Test Limits for Silicone Insulating Liquid in New Transformers

Test	ASTM Method	Acceptable Values
Dielectric breakdown, kV minimum	D1816	30
Visual	D2129	Clear, free of particles
Water content, ppm maximum	D1533	50
Dissipation/power factor, 60 hertz, % max. @ 25° C	D924	0.01
Viscosity, cSt @ 25° C	D445	47.5 – 52.5
Fire point, ° C, minimum	D92	340
Neutralization number, mg KOH/g max	D974	0.01

IEEE C57.111-1989 (R2009), *Guide for Acceptance of Silicone Insulating Fluid and Its Maintenance in Transformers*, Table 2.

TABLES

Table 100.4.3 Typical Values for Less-Flammable Hydrocarbon Insulating Liquid Received in New Equipment

ASTM Method	Test	Results		
		Minimum		Maximum
D1816	Dielectric breakdown voltage for 0.08 in gap, kV	40	34.5 kV class and below	----
		50	Above 34.5 kV class	
		60	Desirable	
D1816	Dielectric breakdown voltage for 0.04 in gap kV	20	34.5 kV class and below	----
		25	Above 34.5 kV class	
		30	Desirable	
D974	Neutralization number, mg KOH/g	----		0.03
D877	Dielectric breakdown voltage kV	30		----
D924	AC loss characteristic (dissipation factor), % 25° C	----		0.1
	100° C	----		1
D1533B	Water content, ppm	----		25
D1524	Condition-visual	Clear		
D92	Flash point (° C)	275		----
D92	Fire point (° C)	300 ^a		----
D971	Interfacial tension, mN/m, 25° C	38		----
D445	Kinematic viscosity, mm ² /s, (cSt), 40° C	1.0 X 10 ² (100)		1.3 X 10 ² (130)
D1500	Color	----		L2.5

Notes:

1. IEEE C57.121-1998, *IEEE Guide for Acceptance and Maintenance of Less Flammable Hydrocarbon Fluid in Transformers*, Table 3.
2. The test limits shown in this table apply to less-flammable hydrocarbon fluids as a class. Specific typical values for each brand of fluid should be obtained from each fluid manufacturer.
 - a. If the purpose of the High Molecular Weight Hydrocarbons (HMWH) installation is to comply with the NFPA 70 National Electrical Code, this value is the minimum for compliance with NEC Article 450.23.

TABLES

Table 100.5 Transformer Insulation Resistance Acceptance Testing

Transformer Coil Rating Type (Volts)	Minimum DC Test Voltage	Recommended Minimum Insulation Resistance (Megohms)	
		Liquid Filled	Dry
600 and below	1,000	100	500
601 – 5,000	2,500	1,000	5,000
Greater than 5,000	5,000	5,000	25,000

Notes:

1. In the absence of consensus standards, the NETA Standards Review Council suggests the above representative values.
2. See Table 100.14 for temperature correction factors.
3. Since insulation resistance depends on insulation rating (kV) and winding capacity (kVA), values obtained should be compared to manufacturer's published data.
4. Insulation resistance values for transformers filled with natural ester-based fluids typically have a lower insulation resistance compared to transformers filled with mineral oil. Results for ester immersed transformers shall compare to factory or previously obtained results.

TABLES

Table 100.6 Medium-Voltage Cables Acceptance Test Values

Table 100.6.1 Extruded Dielectric Shielded Power Cables, DC Test Voltages

Rated Voltage Phase-to-Phase (V)	100% Insulation Level	133% Insulation Level	173% Insulation Level
2000 - 5000	28	36	36
5001 - 8000	36	44	44
8001 - 15000	56	64	64
15001 - 25000	80	96	100
25001 - 28000	84	100	108
28001 - 35000	100	124	132
35001 - 46000	132	172	180

Notes:

Tables and notes from ANSI/NEMA WC74/ICEA S93-639-2017 *American National Standard for 5-46 KV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy*, Appendix F Table F-1.

1. Apply voltage for 15 consecutive minutes.
2. After 5 years of service, DC Testing is not recommended.
3. Table voltages are intended for cables designed to meet this standard. Consult manufacturers of cables and accessories before applying this test.

TABLES

Table 100.6.2 Laminated Dielectric Shielded Power Cable, DC Test Voltages

System Voltage, kV rms, Phase-to-Phase	System BIL, kV Crest	Acceptance Test, kV dc, Phase-to-Ground
5	75	28
8	95	36
15	110	56
25	150	75
28	170	85
35	200	100
46	250	125
69	350	175
115	450	225
115	550	275
138	650	325
161	750	375
230	1,050	525
345	1,175	585
345	1,300	650
500	1,425	710
500	1,550	775
500	1,675	838

Notes:

1. Maximum test voltage should be maintained for 15 continuous minutes.
2. Voltages higher than those listed, up to 80% of system BIL, may be considered, but the age and operating environment of the system should be taken into account. The user is urged to consult the suppliers of the cable and any/all accessories before applying the high voltage.
3. When older cables or other types/classes of cables or other equipment such as transformers, switchgear, motors, etc. are connected to the cable to be tested, voltages lower than those shown in the table may be necessary to comply with the limitations imposed by such interconnected cables and equipment. See IEEE 95 [B5] and Table 1 of IEEE C37.20.2.
4. If the test voltage exceeds 50% of system BIL, surge protection against excessive overvoltages induced by flashovers at the termination should be provided.
5. It is strongly recommended that the user consult with the manufacturer(s) of all components that will be subjected to such testing before performing any tests on cables and cable accessories rated 115kV and higher.
6. It should be noted that this table and the test procedures suggested in this guide do not necessarily agree with the recommendations of other organizations, such as those of the Association of Edison Illuminating Companies AEIC CS1-12, CS2-14, CS3-16, CS4-18. Where there is concern, a user should consult the supplier of the cable and accessories to ascertain that the components will withstand the test.
7. Reproduction of table 1 from IEEE 400.1-2018 IEEE Guide for Field Testing of Laminated Dielectric, Shielded Power Cable Systems Rated 5 kV and Above with High Direct Current Voltage.

TABLES

Table 100.6.3 Shielded Power Cable VLF (0.1 Hz) Test Voltages

Cable System Rating Phase-to-Phase (kV RMS)	Acceptance Test Voltage Phase-to-Ground (kV RMS)
5	10
8	13
11	16
15	21
20	26
22	28
25	32
28	36
30	38
33	42
35	44
46	57
66	80
69	84
90	110
115	140
132	160
138	168

Notes:

Adaptation of Table 3 for IEEE 400.2 2024 Guide for field testing of shielded power cable systems using very low frequency (VLF).

Recommended duration of test is a minimum of 30 minutes without failure. Should the cable be considered of critical importance, a 60 minute withstand test is recommended. Should a failure occur, the test should be repeated in full, after the repair has been made.

Voltage levels are based on current practice where the relative test voltages decrease as the cable rating increases to compensate for the changes in design stress for HV vs MV cables. Considering typical cable designs, the stresses at test voltages for HV cables are more than twice those for MV cables.

Lower voltage levels may be used upon agreement with the circuit owner for cable systems ratings above 115 kV.

VLF test voltages are for sinusoidal waveforms. For cosine rectangular waveforms, multiply the test voltage by the square root of 2.

TABLES

Table 100.6.4 Shielded Power Cables, DAC Test Voltages for Offline PD Tests

Power Cable Rated Voltage U [kV] Phase-to-Phase	U.[kV]	DAC Test Voltage Level V_t [kV peak] Phase-to-Ground
3	2	6
5	3	8
6	4	12
8	5	14
10	6	17
15	9	26
20	12	34
25	15	43
30	18	51
35	21	60
45-47	26	74
60-69	35	99
110-115	64	181
132-138	77	187
150-161	87	212
220-230	127	254

Notes:

Extracted from IEEE 400.4-2015, Guide for Field Testing of Shielded Power Cable Systems Rated 5 kV and above with Damped Alternating Current (DAC) Voltage, Table A.2.

TABLES

Table 100.6.5 Shielded Power Cable, AC (20 Hz-300 Hz) Test Voltages

Power Cable Voltage Phase-to-Phase (kV RMS)	Test Duration (Minutes)	Maintenance Test Voltage Phase-to-Ground (kV RMS)
3	15	3
5	15	5
6	15	6
8	15	8
10	15	10
15	15	15
20	15	20
25	15	25
30	15	30
35	15	35
45-47	60	52
60-69	60	72
110-115	60	128
132-138	60	132
150-161	60	150

Notes:

1. This table has been adapted from the recommended voltage levels and durations in IEC-60502-2-2014 and IEC-60840-2020. Those standards reference these voltages and durations as AC voltage test of the insulation after installation. The standard further acknowledges installations which have been in use, lower voltages than given in the table above, and / or shorter durations may be used.
2. It is strongly recommended that the user consult with the manufacturer(s) and system owners of all components that will be subjected to such testing before performing any tests on cables and cable accessories on time duration and voltage levels before testing. Duration and voltage levels should be negotiated, taking into account the age, environment, history of breakdowns, and the purpose of carrying out the test.

TABLES

Table 100.6.6 VLF Tan Delta (TD), MV/HV Cable Test Voltages

Step	Voltage	Min# of TD Test Data Points
1	0.5 U _o	6
2	1 U _o	6
3	1.5 U _o	6
*4	Ref table 100.6.3	Duration of withstand

Notes:

1. U_o is defined as the Nominal RMS Rated Voltage, Phase to Ground.
2. For new installations use nameplate voltage rating (ensure all components of circuit have same rating). For existing installations use operating voltage/system voltage. Example to calculate U_o and therefore 0.5 and 1.5 x U_o.
 - 2.1. For a 15 kV rated system the U_o for the new cable would be $15/\sqrt{3}=8.7$ kV.
 - 2.2. For a 15 kV rated system the U_o for an existing cable operating at 13.8 kV use $13.8/\sqrt{3}=8.0$ kV.
3. If performing the optional Monitored Withstand Test with TD at voltage and duration as specified in Table 100.6.3.

TABLES

Table 100.6.7.1 Evaluation of TD Results, PE-based Insulations

Criteria (10 ⁻³)	Acceptable (10 ⁻³)	Further Study (10 ⁻³)	Action Required (10 ⁻³)
Standard Deviation at any voltage step	< 0.1	0.1 – 0.5	> 0.5
Differential / Tip Up (1.5 U _o minus 0.5 U _o)	< 5	5 – 80	> 80
Mean Value at any voltage step	< 4	4 – 50	> 50

Notes:

1. Evaluation criteria are based on IEEE 400.2-2013 Table 4.
2. Evaluation is acceptable if all criteria are good. If any single criteria is in further study or action required, then the cable's evaluation falls into that more severe category.
3. All evaluation criteria is based on using VLF sinusoidal at 0.1 Hz.

Table 100.6.7.2 Evaluation of Tan Delta Test Results, EPR Cable

Criteria (10 ⁻³)	Acceptable (10 ⁻³)	Further Study (10 ⁻³)	Action Required (10 ⁻³)
Standard Deviation at any voltage step	< 0.1	0.1 – 1.3	> 1.3
Differential / Tip Up (1.5 U _o minus 0.5 U _o)	< 5	5 – 100	> 100
Mean Value at any voltage step	< 35	35 – 120	> 120

Notes:

1. Evaluation criteria are based on IEEE 400.2-2013 Table 5.
2. Evaluation is acceptable if all criteria are good. If any single criteria is in further study or action required, then the cable's evaluation falls into that more severe category.
3. All evaluation criteria is based on using VLF sinusoidal at 0.1 Hz.
4. Evaluation criteria for EPR cable are largely dependent on type of fill EPR insulation. Values shown are for unknown filled EPR insulation. For more detailed analysis, review Table 5 of IEEE 400.2.

TABLES

Table 100.7 Inverse Time Trip Test at 300% of Rated Continuous Current of Circuit Breakers, Molded-Case Circuit Breakers

Range of Rated Continuous Current (Amperes)	Maximum Trip Time in Seconds for Each Maximum Frame Rating ^a	
	≤ 250 V	251-600 V
0-30	50	70
31-50	80	100
51-100	140	160
101-150	200	250
151-225	230	275
226-400	300	350
401-600	----	450
601-800	----	500
801-1,000	----	600
1,001-1,200	----	700
1,201-1,600	----	775
1,601-2,000	----	800
2,001-2,500	----	850
2,501-5,000	----	900
6,000	----	1,000

Notes:

1. Derived from Table 3, NEMA Standard AB 4-2017, *Guidelines for Inspection and Preventive Maintenance of Molded-Case Circuit Breakers Used in Commercial and Industrial Applications*.
 - a. Trip times may be substantially longer for integrally-fused circuit breakers if tested with the fuses replaced by solid links (shorting bars).

TABLES

Table 100.8 Instantaneous Trip Tolerances for Field Testing of Circuit Breakers

		Tolerances of Manufacturer's Published Trip Range	
Breaker Type	Tolerance of Settings	High Side	Low Side
Electronic Trip Units ¹	+30% -30%	----	----
Adjustable ¹	+40% -40%	----	----
Nonadjustable ²	----	+25%	-25%

Notes:

NEMA AB4-2017 *Guidelines for Inspection and Preventative Maintenance of Molded Case Circuit Breakers Used in Commercial and Industrial Applications*, Table 4.

1. Tolerances are based on variations from the nominal settings.
2. Tolerances are based on variations from the manufacturer's published trip band (i.e., -25% below the low side of the band; +25% above the high side of the band).

TABLES

Table 100.9 Instrument Transformer Dielectric Tests, Field Acceptance

Nominal System Voltage (kV)	BIL (Full Wave) (kV)	Dielectric Withstand Test Field Test Voltage (kV)
		AC
0.60	10	3.0
1.20	30	7.5
2.40	45	11.25
5.00	60	14.25
8.70	75	19.5
15.00	95	25.5
15.00	110	25.5
25.00	125	30.0
25.00	150	37.5
34.50	200	52.5
46.00	250	71.2
69.00	350	105
115.00	450	138
115.00	550	172
138.00	650	206
161.00	750	243
230.00	900	296
230.00	1050	345
345.00	1175	382
345.00	1300	431
500.00	1675	562
500.00	1800	600
765.00	2050	690

Notes:

1. Table 100.9 is derived from Paragraph 8.5.2 and Table 2 of IEEE C57.13-2016, *Standard Requirements for Instrument Transformers*.

TABLES

Table 100.10 Unfiltered Housing Vibration Limits

NEMA Frame Size		NEMA Frame ≤ 210		NEMA Frame > 210	
Vibration Grade	Mounting	Displacement, mils pk-pk	Velocity in./s pk	Displacement mils pk-pk	Velocity in./s pk
A	Resilient	2.4	0.15	2.4	0.15
	Rigid	N/A	N/A	1.9	0.12 *0.15
B	Resilient	1.0	0.06	1.6	0.10
	Rigid	N/A	N/A	1.3	0.08 *0.10

Notes:

1. Derived from NEMA publication MG 1-2021, Section 7.8., Table 7-11, *Unfiltered Housing Vibration Limits*.
2. The following defines the limits of vibration for machines running at no load, uncoupled, for vibration grades A and B.
3. Grade “A” applies to machines with no special vibration requirements.
4. Grade “B” applies to machines with special vibration requirements. Rigid mounting is not considered acceptable for machines with shaft heights less than NEMA frame size 210.
5. Vibration limits are given in mils peak-to-peak displacement and in./s peak velocity. Vibration at frequencies above 1000 Hz should be filtered out.
6. *This level is the limit when the twice line frequency vibration level is dominant.

TABLES

Table 100.11 Insulation Resistance Test Values, Rotating Machinery for One Minute at 40° C

Winding Rated Voltage ^a (V)	DC Test Voltage	Recommended Minimum Insulation Resistance (Megohms): Windings Before 1970, Field Windings, Others Not listed in Table 100.11 ^b	Recommended Minimum Insulation Resistance (Megohms): AC Windings Built After 1970, (form-wound coils)	Recommended Minimum Insulation Resistance (Megohms): DC Armature, Random-Wound Stator Coils, Form-Wound Coils below 1 kV
< 1,000	500	kV + 1	100	5
1,000 – 2,500	500 – 1,000	kV + 1	100	-
2,501 – 5,000	1,000 – 2,500	kV + 1	100	-
5,001 – 12,000	2,500 – 5,000	kV + 1	100	-
> 12,000	5,000 – 10,000	kV + 1	100	-

Notes:

1. Refer to table 100.14 for temperature correction factors.
- a. Rated line-to-line voltage for three-phase ac machines, line-to-ground voltage for single phase machines, and rated direct voltage for dc machines or field windings.
- b. kV is the rated machine terminal-to-terminal voltage.

TABLES

Table 100.12 US Standard Fasteners, Bolt Torque Values for Electrical Connections

Table 100.12.1 Bolt-Torque Values for Electrical Connections, US Standard Fasteners¹, Heat-Treated Steel – Cadmium or Zinc Plated²

Grade	SAE 1&2	SAE 5	SAE 7	SAE 8
Head Marking				
Minimum Tensile (Strength) (Ibf/in ²)	64K	105K	133K	150K
Bolt Diameter (Inches)	Torque (Pound-Feet)			
1/4	4	6	8	8
5/16	7	11	15	18
3/8	12	20	27	30
7/16	19	32	44	48
1/2	30	48	68	74
9/16	42	70	96	105
5/8	59	96	135	145
3/4	96	160	225	235
7/8	150	240	350	380
1.0	225	370	530	570

Notes:

1. Consult manufacturer for equipment supplied with metric fasteners.
2. Table is based on national coarse thread pitch.

TABLES

**Table 100.12.2 US Standard Fasteners¹, Silicon Bronze Fasteners^{2 3}, Torque
(Pound-Feet)**

Bolt Diameter (Inches)	Nonlubricated	Lubricated
5/16	15	10
3/8	20	15
1/2	40	25
5/8	55	40
3/4	70	60

Notes:

1. Consult manufacturer for equipment supplied with metric fasteners.
2. Table is based on national coarse thread pitch.
3. This table is based on bronze alloy bolts having a minimum tensile strength of 70,000 pounds per square inch.

TABLES

Table 100.12.3 US Standard Fasteners¹, Aluminum Alloy Fasteners^{2 3}, Torque (Pound-Feet)

Bolt Diameter (inches)	Lubricated
5/16	10
3/8	14
1/2	25
5/8	40
3/4	60

Notes:

1. Consult manufacturer for equipment supplied with metric fasteners.
2. Table is based on national coarse thread pitch.
3. This table is based on aluminum alloy bolts having a minimum tensile strength of 55,000 pounds per square inch.

TABLES

**Table 100.12.4 US Standard Fasteners¹, Stainless Steel Fasteners^{2,3}, Torque
(Pound-Feet)**

Bolt Diameter (Inches)	Uncoated
5/16	15
3/8	20
1/2	40
5/8	55
3/4	70

Notes:

1. Tables in 100.12 are compiled from Penn Union Catalogue and Square D Company, Anderson Products Division, *General Catalog: Class 3910 Distribution Technical Data, Class 3930 Reference Data Substation Connector Products*.

Consult manufacturer for equipment supplied with metric fasteners.

2. Table is based on national coarse thread pitch.
3. This table is to be used for the following hardware types:

Bolts, cap screws, nuts, flat washers, locknuts (18-8 alloy)

Belleville washers (302 alloy).

TABLES

Table 100.13 SF₆ Gas Tests

Test	Limits
Water Content	-36° C / 200 ppmv / 25 ppmw
SO ₂ Decomposition Products	< 5 ppmv
Total Decomposition Products	7 ul/l (7 ppmv)
Mineral Oil	10 ppmw
Purity of SF ₆	> 98.5% volume

Notes:

This table is derived from IEC 60376 Specifications of technical grade sulfur hexafluoride (SF₆) and complimentary gases to be used in its mixtures for use in electrical equipment Table 1. The value has been adjusted to reflect common result parameters for 3 in 1 field gas test equipment.

1. If all gas handling equipment is oil-free (compressor, pump), then oil content measurement is not necessary.
2. This table is a guide for field testing and actual results should be compared to manufacturer's literature.
3. The values in the table are for applications using pure SF₆ gas. For mixed gases refer to manufacturer's data.

TABLES

Table 100.14 Insulation Resistance Conversion Factors

Table 100.14.1 Insulation Resistance Conversion Factors (20° C)

Temperature		Multiplier	
° C	° F	Apparatus Containing Immersed Oil Insulation	Apparatus Containing Solid Insulation Other Than Rotating Machinery
-10	14	0.125	0.25
-5	23	0.180	0.32
0	32	0.25	0.40
5	41	0.36	0.50
10	50	0.50	0.63
15	59	0.75	0.81
20	68	1.00	1.00
25	77	1.40	1.25
30	86	1.98	1.58
35	95	2.80	2.00
40	104	3.95	2.50
45	113	5.60	3.15
50	122	7.85	3.98
55	131	11.20	5.00
60	140	15.85	6.30
65	149	22.40	7.90
70	158	31.75	10.00
75	167	44.70	12.60
80	176	63.50	15.80
85	185	89.789	20.00
90	194	127.00	25.20
95	203	180.00	31.60
100	212	245.00	40.00
105	221	359.15	50.40
110	230	509.00	63.20

Notes:

Derived from *Stitch in Time...The Complete Guide to Electrical Insulation Testing*, Megger.

Formula: $R_c = R_a \times K$

Where: R_c is resistance corrected to 20° C

R_a is measured resistance at test temperature

K is applicable multiplier

Example: Resistance test on oil-immersion insulation at 104° F

$R_a = 2$ megohms @ 104° F

$K = 3.95$

$R_c = R_a \times K$

$R_c = 2.0 \times 3.95$

$R_c = 7.90$ megohms @ 20° C

NETA

Page 258

ANSI/NETA ATS-2025

TABLES

Table 100.14.2 Insulation Resistance Conversion Factors (40° C)

Temperature		Multiplier	
° C	° F	Apparatus Containing Immersed Oil Insulation	Apparatus Containing Solid Insulation, Other Than Rotating Machinery
-10	14	0.03	0.10
-5	23	0.04	0.13
0	32	0.06	0.16
5	41	0.09	0.20
10	50	0.13	0.25
15	59	0.18	0.31
20	68	0.25	0.40
25	77	0.35	0.50
30	86	0.50	0.63
35	95	0.71	0.79
40	104	1.00	1.00
45	113	1.41	1.26
50	122	2.00	1.59
55	131	2.83	2.00
60	140	4.00	2.52
65	149	5.66	3.17
70	158	8.00	4.00
75	167	11.31	5.04
80	176	16.00	6.35
85	185	22.63	8.00
90	194	32.00	10.08
95	203	45.25	12.70
100	212	64.00	16.00
105	221	90.51	20.16
110	230	128.00	25.40

Notes:

Derived from Megger's *Stitch in Time...The Complete Guide to Electrical Insulation Testing*.

Notes: The insulation resistance coefficient is based on the halving of the insulation resistance to the change in temperature. Apparatus Containing Immersed Oil Insulation Table uses 10° C change with temperature halving. Apparatus Containing Solid Insulation Table uses 15° C change with temperature halving.

Formula: $R_c = R_a \times K$

Where: R_c is resistance corrected to 40° C

R_a is measured resistance at test temperature

K is applicable multiplier

Example: Resistance test on oil-immersion insulation at 68° F/20° C

$R_a = 2$ megohms @ 68° F/20° C

$K = 0.40$

$R_c = R_a \times K$

$R_c = 2.0 \times 0.40 = 0.8$ megohms @ 40° C

TABLES

Table 100.15 High-Potential Test Voltage for Automatic Circuit Reclosers

Nominal Voltage Class (kV)	Maximum Voltage (kV)	Rated Impulse Withstand Voltage (kV)	Maximum Field Test Voltage, kV, AC
14.4	15.0	95	35
14.4	15.5	110	50
24.9	27.0	150	60
34.5	38.0	150	70
46.0	48.3	250	105
69.0	72.5	350	160

Notes:

1. Derived from IEEE C37.61-1973 (R1992), *Standard Guide for the Application, Operation, and Maintenance of Automatic Circuit Reclosers* and from C37.60-2012, High-voltage switchgear and control gear – Part 111: Automatic circuit reclosers and fault interrupters for alternating current systems up to 38 kV.

TABLES

Table 100.16 High-Potential Test Voltage for Acceptance Testing of Line Sectionalizers

Nominal Voltage Class kV	Maximum Voltage kV	Rated Impulse Withstand Voltage kV	Maximum Field Test Voltage kV, AC	DC 15 Minute Withstand (kV)
14.4 (1 ø)	15.0	95	35	53
24.9 (1 ø)	27.0	125	40	78
34.5 (1 ø)	38.0	150	50	103

Notes:

1. Derived from IEEE C37.63-2013 Table 2 (*Standard Requirements for Overhead, Pad-Mounted, Dry-Vault, and Submersible Automatic Line Sectionalizers for Alternating Current Systems Up to 38 kV*).
2. In the absence of consensus standards, the NETA Standards Review Council suggests the above representative values.
3. NOTE: Values of ac voltage given are dry test one minute factory test values.

TABLES

Table 100.17 Dielectric Withstand Test Voltages Metal-Enclosed Bus

Type of Bus	Rated kV	Maximum Test Voltage, kV	
		AC	DC
Isolated Phase for Generator Leads	24.5	37.0	52.0
	29.5	45.0	----
	34.5	60.0	----
Isolated Phase for Other than Generator Leads	15.5	37.0	----
	27.0	45.0	----
	38.0	60.0	----
Nonsegregated Phase	1.058	2.25	----
	4.76	14.2	----
	8.25	27.0	----
	15.0	27.0	----
	15.5	37.5	----
	27.0	45.0	----
Segregated Phase	38.0	60.0	----
	15.5	37.0	----
	27.0	45.0	----
DC Bus Duct	38.0	60.0	----
	0.3/325	1.6	----
	0.8	2.7	----
	1.2	36.0	----
	1.6	4.0	----
	3.2	6.6	----

Notes:

- Derived from IEEE C37.23-2015, Tables 1, 2, 3, 4 and paragraph 6.4.3. The table includes a 0.75 multiplier with fractions rounded down.
- NOTE:

The presence of the column headed “DC” does not imply any requirement for a dc withstand test on ac equipment. This column is given as a reference only for those using dc tests and represents values believed to be appropriate and approximately equivalent to the corresponding power frequency withstand test values specified for each class of bus.

Direct current withstand tests are recommended for flexible bus to avoid the loss of insulation life that may result from the dielectric heating that occurs with rated frequency withstand testing.

Because of the variable voltage distribution encountered when making dc withstand tests and variances in leakage currents associated with various insulation systems, the manufacturer should be consulted for recommendations before applying dc withstand tests to this equipment.

TABLES

Table 100.18 Thermographic Survey, Suggested Actions Based on Temperature Rise

Temperature difference (ΔT) based on comparisons between similar components under similar loading.	Temperature difference (ΔT) based upon comparisons between component and ambient air temperatures.	Recommended Action
1° C - 3° C	1° C - 10° C	Possible deficiency; warrants investigation
4° C - 15° C	11° C - 20° C	Indicates probable deficiency; repair as time permits
----	21° C - 40° C	Monitor until corrective measures can be accomplished
> 15° C	> 40° C	Major discrepancy; repair immediately

Notes:

1. Temperature specifications vary depending on the exact type of equipment. Even in the same class of equipment (i.e., cables) there are various temperature ratings. Heating is generally related to the square of the current; therefore, the load current will have a major impact on ΔT . In the absence of consensus standards for ΔT , the values in this table will provide reasonable guidelines.
2. An alternative method of evaluation is presented in Chapter 8.10.2.2, Standards-Based Temperature Rating System, *Electrical Power Equipment Maintenance and Testing 2nd Edition*, by Paul Gill, 2008 edition.
3. It is a necessary and valid requirement that the person performing the electrical inspection be thoroughly trained and experienced concerning the apparatus and systems being evaluated as well as knowledgeable of thermographic methodology.

TABLES

Table 100.19 Dielectric Withstand Test Voltages for Electrical Apparatus Other than Inductive Equipment

Nominal System (Line) Voltage ¹ (kV)	Insulation Class	AC Factory Test (kV)	Maximum Field Applied AC Test (kV)	Maximum Field Applied DC Test (kV)
1.2	1.2	10	6.0	8.5
2.4	2.5	15	9.0	12.7
4.8	5.0	19	11.4	16.1
8.3	8.7	26	15.6	22.1
14.4	15.0	34	20.4	28.8
18.0	18.0	40	24.0	33.9
25.0	25.0	50	30.0	42.4
34.5	35.0	70	42.0	59.4
46.0	46.0	95	57.0	80.6
69.0	69.0	140	84.0	118.8

Notes:

1. In the absence of consensus standards, the NETA Standards Review Council suggests the above representative values.
2. Intermediate voltage ratings are placed in the next higher insulation class.

TABLES

Table 100.20 Rated Control Voltages and their Ranges for Circuit Breakers

Operating mechanisms are designed for rated control voltages listed with operational capability throughout the indicated voltage ranges to accommodate variations in source regulation, coupled with low charge levels, as well as high charge levels maintained with floating charges. The maximum voltage is measured at the point of user connection to the circuit breaker [see notes (12) and (13)] with no operating current flowing, and the minimum voltage is measured with maximum operating current flowing.

Table 100.20.1 Rated Control Voltages and Their Ranges for Circuit Breakers

(11) Rated Control Voltage	Direct Current Voltage Ranges (1)(2)(3)(5) Volts, DC (8)(9)		Opening Functions All Types	Rated Control Voltage (60Hz)	Alternating Current Voltage Ranges (1)(2)(3)(4)(8) Closing, Tripping, and Auxiliary Functions
	Closing and Auxiliary Functions				
	Indoor Circuit Breakers	Outdoor Circuit Breakers		Single Phase	Single Phase
24 (6)	----	----	14-28	120	104-127 (7)
48 (6)	38-56	36-56	28-56	240	180Y/104-220Y/127208-254
125	100-140	90-140	70-140	----	----
250	200-280	180-280	140-280	Polyphase	Polyphase
----	----	----	----	208Y/120	----
----	----	----	----	240	208-254 (7)

Derived from Table 8, IEEE C37.06-2009, *AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis – Preferred Ratings and Related Required Capabilities*.

Notes:

- (1) Electrically operated motors, contactors, solenoids, valves, and the like, need not carry a nameplate voltage rating that corresponds to the control voltage rating shown in the table as long as these components perform the intended duty cycle (usually intermittent) in the voltage range specified.
- (2) Relays, motors, or other auxiliary equipment that function as a part of the control for a device shall be subject to the voltage limits imposed by this standard, whether mounted at the device or at a remote location.
- (3) Circuit breaker devices, in some applications, may be exposed to control voltages exceeding those specified here due to abnormal conditions such as abrupt changes in line loading. Such applications require specific study, and the manufacturer should be consulted. Also, application of switchgear devices containing solid-state control exposed continuously to control voltages approaching the upper limits of ranges specified herein, require specific attention and the manufacturer should be consulted before application is made.
- (4) Includes supply for pump or compressor motors. Note that rated voltages for motors and their operating ranges are covered by NEMA MG-1-1978.
- (5) It is recommended that the coils of closing, auxiliary, and tripping devices that are connected continually to one dc potential should be connected to the negative control bus so as to minimize electrolytic deterioration.

TABLES

- (6) 24-volt or 48-volt tripping, closing, and auxiliary functions are recommended only when the device is located near the battery or where special effort is made to ensure the adequacy of conductors between battery and control terminals. 24-volt closing is not recommended.
- (7) Includes heater circuits
- (8) Voltage ranges apply to all closing and auxiliary devices when cold. Breakers utilizing standard auxiliary relays for control functions may not comply at lower extremes of voltage ranges when relay coils are hot, as after repeated or continuous operation.
- (9) Direct current control voltage sources, such as those derived from rectified alternating current, may contain sufficient inherent ripple to modify the operation of control devices to the extent that they may not function over the entire specified voltage ranges
- (10) This table also applies for circuit breakers in gas insulated substation installations.
- (11) In cases where other operational ratings are a function of the specific control voltage applied, tests in C37.09 may refer to the "Rated Control Voltage." In these cases, tests shall be performed at the levels in this column.
- (12) For an outdoor circuit breaker, the point of user connection to the circuit breaker is the secondary terminal block point at which the wires from the circuit breaker operating mechanism components are connected to the user's control circuit wiring.
- (13) For an indoor circuit breaker, the point of user connection to the circuit breaker is either the secondary disconnecting contact (where the control power is connected from the stationary housing to the removable circuit breaker) or the terminal block point in the housing nearest to the secondary disconnecting contact.

TABLES

Table 100.20.2 Rated Control Voltages and Their Ranges for Circuit Breakers Solenoid-Operated Devices

Rated Voltage	Closing Voltage Ranges for Power Supply
125 dc	90 – 115 or 105 – 130
250 dc	180 – 230 or 210 – 260
230 ac	190 – 230 or 210 – 260

Some solenoid operating mechanisms are not capable of satisfactory performance over the range of voltage specified in the standard; moreover, two ranges of voltage may be required for such mechanisms to achieve an acceptable standard of performance.

The preferred method of obtaining the double range of closing voltage is by use of tapped coils. Otherwise it will be necessary to designate one of the two closing voltage ranges listed above as representing the condition existing at the device location due to battery or lead voltage drop or control power transformer regulation. Also, caution should be exercised to ensure that the maximum voltage of the range used is not exceeded.

TABLES

Table 100.22 Minimum Bending Radius for Medium Voltage Power Cables, Single and Multiple Conductor

Cable Type	Overall Diameter of Cable					
	inches 0.75 and less	mm 190 and less	inches 0.76 to 1.50	mm 191 to 381	inches 1.51 and larger	mm 382 and larger
	Minimum Bending Radius as a Multiple of Cable Diameter					
Smooth Aluminum Sheath Single Conductor Nonshielded, Multiple Conductor or Multiplexed, with Individually	10		12		15	
Single Conductor Shielded	12		12		15	
Multiple Conductor or Multiplexed, with Overall Shield	12		12		15	
Interlocked Armor or Corrugated Aluminum Sheath Nonshielded	7		7		7	
Multiple Conductor with Individually Shielded Conductor	12/7 ^a		12/7 ^a		12/7 ^a	
Multiple Conductor with Overall Shield	12		12		12	
Lead Sheath	12		12		12	

12x³ individual shielded conductor diameter, or 7x overall cable diameter, whichever is greater.

Table 100.22 and notes from ANSI/NEMA WC 74/ICEA S-93-639-2017 American National Standard for *5-46 kV Shielded Power Cable for Use in the Transmission and Distribution of Electric Energy, Appendix I*.

NFPA 70 300.34 Conductor Bending Radius – over 1,000 V – single conductor non-shielded 8X overall diameter, shielded 12X multi-conductor 12X individual conductor or 7X entire table.

Notes:

Specific references from Appendix I:

1. Interlocked-Armor and Metallic-Sheathed Cables

1.1 The minimum bending radius for interlocked-armored cables, smooth or corrugated aluminum sheath or lead sheath shall be in accordance with Table 100.22.

2. Flat-Tape Armored or Wire-Armored Cables

2.1 The minimum bending radius for all flat-tape armored and all wire-armored cables is twelve times the overall diameter of cable.

3. Tape-Shielded Cables

3.1 The minimum bending radius for tape-shielded cables given above applies to helically applied flat or corrugated tape or longitudinally applied corrugated tape-shielded cables.

3.2 The minimum bending radius for a single-conductor cable is twelve times the overall diameter.

TABLES

3.3 For multiple-conductor or multiplexed single-conductor cables having individually taped shielded conductors, the minimum bending radius is twelve times the diameter of the individual conductors or seven times the overall diameter, whichever is greater.

3.4 For multiple-conductor cables having an overall tape shield over the assembly, the minimum bending radius is twelve times the overall diameter of the cable.

4. Wire-Shielded Cables

4.1 The minimum bending radius for a single-conductor cable is eight times the overall diameter.

4.2 For multiple-conductor or multiplexed single-conductor cables having wire shielded individual conductors, the minimum bending radius is eight times the diameter of the individual conductors or five times the overall diameter, whichever is greater.

4.3 For multiple-conductor cables having a wire shield over the assembly, the minimum bending radius is eight times the overall diameter of the cable.

TABLES

Table 100.23 Online Partial Discharge Survey

Notes:

1. Any signal level present without a phase-angle related component is not indicative of partial-discharge activity.
2. Compare measured levels to established background readings.
3. Background readings higher than values listed in these tables should be investigated and mitigated.
4. These tables are applicable to switchgear partial discharge test results.

Table 100.23.1 Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (TEV)

dB	Phase-Angle Related Component	Recommended Action
Any ¹	No	Survey in 12 months for trending ²
< 20	Yes	Survey in 6 months for trending
20 – 30	Yes	Locate and repair as soon as practical
> 30	Yes	Locate and repair as soon as possible

Table 100.23.2 Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (HFCT)

pC	dB	Phase Related Component	Recommended Action
Any	Any	No	Survey in 12 months for trending
< 250	< 10	Yes	Survey in 6 months for trending
200 – 500	10 – 20	Yes	Locate and repair as soon as practical
> 500	> 20	Yes	Locate and repair as soon as possible

Table 100.23.3 Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (UHF)

dBmV	Phase Related Component	Recommended Action
Any	No	Survey in 12 months for trending
< 10	Yes	Survey in 6 months for trending
10 – 20	Yes	Locate and repair as soon as practical
> 20	Yes	Locate and repair as soon as possible

TABLES

Table 100.23.4 Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (VIS)

dB	Phase Related Component	Recommended Action
Any	No	Survey in 12 months for trending
20 – 29	Yes	Survey in 6 months for trending
30 – 39	Yes	Locate and repair as soon as practical
> 40	Yes	Locate and repair as soon as possible

Table 100.23.5 Online Partial Discharge Survey, Suggested Actions Based on Nature and Strength of Signal (Contact/Airborne Acoustic)

dB	Phase Related Component	Recommended Action
Any	No	Survey in 12 months for trending
< 3	Yes	Survey in 6 months for trending
3 – 6	Yes	Locate and repair as soon as practical
> 6	Yes	Locate and repair as soon as possible

Appendix A - Definitions

As-found.

Condition of the equipment when taken out of service, prior to testing.

As-left.

Condition of equipment at the completion of inspection and testing. As-left values refer to test values obtained after any corrective action or design change has been performed on the device under test.

Cable, Laminated Dielectric Insulation.

Insulation formed in layers, typically from fluid-impregnated tapes of either cellulose paper, or polypropylene, or a combination of the two. Examples include: paper insulated lead covered (PILC) cable designs, Mass Impregnated Non Draining (MIND) cable designs, high pressure pipe type cable designs, and self-contained cable systems.

Cable, Extruded Dielectric Insulation.

Insulation such as polyethylene (PE), crosslinked polyethylene (XLPE), tree retardant crosslinked polyethylene (TRXLPE), ethylene propylene rubber (EPR), etc. applied using an extrusion process.

Comment.

Suggested revision, addition, or deletion in an existing section of the NETA specifications.

Commissioning, electrical.

The systematic process of documenting and placing into service newly installed or retrofitted electrical power equipment and systems.

Electrical tests.

Electrical tests involve application of electrical signals and observation of the response. It may be, for example, applying a potential across an insulation system and measuring the resultant leakage current magnitude or power factor or dissipation factor. It may also involve application of voltage and/or current to metering and relaying equipment to check for correct response.

Exercise.

To operate equipment in such a manner that it performs all its intended functions to allow observation, testing, measurement, and diagnosis of its operational condition.

Inspection.

Examination or measurement to verify whether an item or activity conforms to specified requirements.

Interim amendment.

An interim amendment is made by NETA's Standards Review Council when there is a potential hazard prior to review by the Section Panel or the public

Maintenance, Condition of.

The state of the electrical equipment considering the manufacturers' instructions, manufacturers' recommendations, and applicable industry codes, standards, and recommended practices.

APPENDIX A - DEFINITIONS

Manufacturer's published data.

Data, instructions, and specifications provided by the manufacturer concerning a specific piece of equipment.

Mechanical inspection.

Observation of the mechanical operation of equipment not requiring electrical stimulation, such as manual operation of circuit breaker trip and close functions. It may also include tightening of hardware, cleaning, and lubricating.

Proposal.

Draft of a section that is currently “reserved” in one of the NETA specifications.

Ready-to-test-condition.

Having the equipment which is to be tested isolated, source and load disconnected, the equipment grounded, and control and operating sources identified.

Shall.

Indicates a mandatory requirement and is used when the testing firm has control over the result.

Should.

Indicates that a provision is not mandatory but is recommended as good practice.

Time-travel analysis.

The measurement of the opening and closing strokes of circuit contacts from the time of an initiating signal to the complete at rest position of the contact. The analysis shall provide the information required to determine distance traveled, velocity of travel, contact insertion, contact bounce, and contact parting time.

System voltage.

The root-mean-square (rms) phase-to-phase voltage of a portion of an alternating-current electric system. Each system voltage pertains to a portion of the system that is bounded by transformers or utilization equipment.

Verify.

To investigate by observation or by test to determine that a particular condition exists.

Visual inspection.

Qualitative observation of physical characteristics, including cleanliness, physical integrity, evidence of overheating, lubrication, etc.

Voltage (as applied to system voltage class):

Note: The following are in accordance with ANSI C84.1, *American National Standard for Electrical Power Systems and Equipment – Voltage Ratings (60Hz)*.

Low voltage (LV).

A class of nominal system voltages 1000 volts or less.

APPENDIX A - DEFINITIONS

Medium voltage (MV).

A class of nominal system voltages greater than 1000 volts and less than 100 kV.

High voltage (HV).

A class of nominal system voltages equal to or greater than 100 kV and equal to or less than 230 kV.

Extra-high voltage (EHV).

A class of nominal system voltages greater than 230 kV but less than 1000 kV.

Ultra-high voltage (UHV).

A class of nominal system voltages equal to or greater than 1000 kV.

Appendix B - Guidance for Circuit Reliability Considerations for Medium and High Voltage Cable Methods of Test

When considering the most effective field-testing method for medium-voltage power cables, consensus standards from standards-making organizations such as ICEA, IEC, IEEE, manufacturer's published data, and other entities often have differing opinions as to the most effective method for performing cable assessment tests. These differing opinions create difficulties for the owners of the cables to make informed maintenance testing decisions.

Only after careful review of all standards, test methods, availability of replacement cable and accessories, and review of the site-specific cable system, can an end-user, engineer, or testing company make an informed decision as to the best value for testing of their medium-voltage cable system.

A key factor to determining the best course of action when performing cable testing is the system reliability requirements, which are different and unique for each facility, and unique to the type and construction of the cable system under test.

In the absence of guidance from existing consensus standards, and to aid in the selection of the appropriate test[s], NETA's Standard Review Council presents the following matrix based on reliability requirements of the cable system and the type of cables to be tested.

These recommendations are primarily a compilation of the current IEEE standards and recommendations from NETA accredited companies' field experience on cost benefit analysis. In the absence of a full evaluation, the following table may be used to determine the most appropriate tests and the time duration.

APPENDIX B - GUIDANCE FOR CIRCUIT RELIABILITY CONSIDERATIONS FOR MEDIUM AND HIGH VOLTAGE CABLE METHODS OF TEST

Circuit Reliability Requirement			
Cable Type	Low	Medium	High
MV Tape Shield	30 min VLF withstand OR - Diagnostic TD with Tip-Up	30 min VLF Monitored withstand and - Diagnostic TD with Tip-Up	60 min VLF Monitored withstand and - Diagnostic TD with Tip-Up
MV Concentric Neutral	30 min VLF withstand OR - Diagnostic TD with Tip-Up	30 min VLF Monitored withstand and - Diagnostic TD with Tip-Up	60 min VLF Monitored withstand and - Diagnostic TD with Tip-Up and Offline PD
HV Concentric Neutral	60 min VLF withstand OR - Diagnostic TD with Tip-Up	30 min VLF Monitored withstand and - Diagnostic TD with Tip-Up and - Offline PD	60 min VLF Monitored withstand and - Diagnostic TD with Tip-Up and - Offline PD
MV / HV PILC	15 min DC withstand	15 min Monitored DC withstand with Voltage Recovery	30 min VLF Monitored withstand and - Diagnostic TD with Tip-Up

Notes:

1. Tape shielding attenuation properties of medium and high-voltage cables can affect the results of offline partial discharge tests, therefore is not a preferred test method for this type of cable.
2. Monitored withstand test is defined as a test in which a test with a predetermined magnitude is applied for predetermined time. During the test, Tan Delta or partial discharge values are monitored and used together with the withstand results to determine the cable condition.
3. Frequencies outside of 0.1 Hz are not recommended for tan-delta analysis.

APPENDIX B - GUIDANCE FOR CIRCUIT RELIABILITY CONSIDERATIONS FOR MEDIUM AND HIGH VOLTAGE CABLE METHODS OF TEST

4. Very Low Frequency (VLF) testing is the most widely accepted and specified cable test due to the lower cost and availability of the test equipment. Power frequency cable testing (20-300 Hz) may be utilized in place of a recommended VLF testing mentioned above.
5. Cable type is identified as medium-voltage or high-voltage and the type of insulation shield present. Depending on the type, different service-aged insulation shields have an impact on the ability to perform tan-delta and partial discharge testing. The IEEE standards reference the above shielding types and have indicated the value of tests for each type of shielding.
6. Low criticality circuits are those that will have little impact to the overall facility, system, personnel, or life safety equipment if they fail.
7. Medium criticality circuits are those that when a failure occurs it can impact the overall facility, but likely will not completely shut it down if they fail. Medium criticality circuits will financially impact the organization if failure occurs, but these circuits will typically be able to be repaired, replaced, or repowered from a different source within a reasonable amount of time.
8. High criticality circuits are those that can affect life safety and/or completely shut down a significant portion of the facility or system if they fail. These circuits will likely have a major impact, both financially and operationally, to the organization. The mitigation of these failures can have a severe impact from a downtime, cost, or environmental perspective.

Appendix C - About the InterNational Electrical Testing Association

(The information contained in this appendix is not part of American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this appendix may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the standard.)

The InterNational Electrical Testing Association (NETA) is an ANSI-accredited standards developer for the American National Standards Institute (ANSI) and defines the standards by which electrical equipment is deemed safe and reliable. NETA Certified Technicians conduct the tests that ensure this equipment meets the Association's stringent specifications. NETA is the leading source of specifications, procedures, testing, and requirements, not only for commissioning new equipment but for testing the reliability and performance of existing equipment.

CERTIFICATION

Certification of competency is particularly important in the electrical testing industry. Inherent in the determination of the equipment's serviceability is the prerequisite that individuals performing the tests be capable of conducting the tests in a safe manner and with complete knowledge of the hazards involved. They must also evaluate the test data and make an informed judgment on the continued serviceability, deterioration, or nonserviceability of the specific equipment. NETA, a nationally recognized certification agency, provides recognition of four levels of competency within the electrical testing industry in accordance with *ANSI/NETA ETT Standard for Certification of Electrical Testing Technicians*.

QUALIFICATIONS OF THE TESTING ORGANIZATION

An independent overview is the only method of determining the long-term usage of electrical apparatus and its suitability for the intended purpose. NETA Accredited Companies best support the interest of the owner, as the objectivity and competency of the testing firm is as important as the competency of the individual technician. NETA Accredited Companies are part of an independent, third-party electrical testing association dedicated to setting world standards in electrical maintenance and acceptance testing. Hiring a NETA Accredited Company assures the customer that:

- The NETA Certified Technician has broad-based knowledge – this person is trained to inspect, test, maintain, and calibrate all types of electrical equipment in all types of industries.
- NETA Technicians meet stringent educational and experience requirements in accordance with *ANSI/NETA ETT Standard for Certification of Electrical Testing Technicians*.
- A Registered Professional Engineer will review all engineering reports.
- All tests will be performed objectively, according to NETA specifications, using calibrated instruments traceable to the National Institute of Science and Technology (NIST).
- The firm is a well-established, full-service electrical testing business.

APPENDIX C - ABOUT THE INTERNATIONAL ELECTRICAL TESTING ASSOCIATION

(This appendix is not part of American National Standard ANSI/NETA ATS-2025)

SPECIFICATIONS AND PUBLICATIONS

As a part of its service to the industry, the InterNational Electrical Testing Association provides nationally recognized publications:

ANSI/NETA ECS	<i>Standard for Electrical Commissioning of Electrical Power Equipment & Systems</i>
ANSI/NETA ETT	<i>Standard for Certification of Electrical Testing Technicians for Electrical Power Equipment & Systems</i>
ANSI/NETA MTS	<i>Standard for Maintenance Testing Specifications for Electrical Power Equipment & Systems</i>
ANSI/NETA ATS	<i>Standard for Acceptance Testing Specifications for Electrical Power Equipment & Systems</i>

The Association also produces a quarterly technical journal, *NETA World*, which features articles of interest to electrical testing and maintenance companies, consultants, engineers, architects, and plant personnel directly involved in electrical testing and maintenance.

EDUCATIONAL PROGRAMS

PowerTest, NETA's annual technical conference, draws hundreds of qualified industry professionals from around the globe. This conference provides a forum for current industry advances, critical informational updates, networking, and more. Regular attendees include technicians from electrical testing and maintenance companies, consultants, engineers, architects, and plant personnel directly involved in electrical testing and maintenance. Paper presentations from field-experienced industry experts share practical knowledge and experience while in-depth seminars offer interactive training. At the Trade Show attendees enjoy the highest-quality gathering of industry-specific suppliers displaying state-of-the-art products and services directly related to the electrical testing industry. PowerTest attendance is the best opportunity for interaction and input in a professional technical environment.

www.powertest.org

Appendix D - Form for Comments

(This appendix is not part of American National Standard ANSI/NETA ATS-2025)

Anyone may comment on this document using this form:

Type of Comment (Check one) ☐ Technical ☐ Editorial

Paragraph Number _____

Recommend (Check One) ☐ *New Text ☐ *Revised Text ☐ *Deleted Text

☐ This Comment is original material (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought, or research and to the best of his/her knowledge is not copied from another source.)

☐ This Comment is not original material; its source (if known) is _____

Please Check One: ☐ User ☐ Producer ☐ General Interest

Date _____

Name (please print) _____

Company _____

Address _____

City/State/Zip _____

Phone with area code _____

Fax _____

Email _____

Organization represented, if any _____

I hereby grant NETA the nonexclusive, royalty-free rights, including nonexclusive, royalty-free rights in copyright, in this material; I understand that I acquire no rights in any publication of NETA in which this proposal in this or another similar analogous form is used.

Signature (required) _____

1. All comments must be relevant to the proposed standard.
2. Suggested changes must include (1) proposed text, including the wording to be added, revised (and how revised), or deleted, (2) a statement of the problem and substantiation for a technical change, and (3) signature of submitter. (Note: State the problem that will be resolved by your recommendation; give the specific reason for your comment, including copies of texts, research papers, testing experience, etc. If more than 200 words, it may be abstracted for publication.)
3. Editorial comments are welcome, but they cannot serve as the sole basis for a suggested change.

A comment that does not include all required information may be rejected by the Standards Review Council for that reason. Must use separate form for each comment. All comments must be typed or printed neatly. Illegible comments will be interpreted to the best of the staff's ability.

This form is available electronically on NETA's website at www.netaworld.org/standards/standards-get-involved under Standards Activities.

Send to: Standards Review Council
3050 Old Centre Road, Suite 101, Portage, MI 49024
Phone: 888.300.6382 Email: neta@netaworld.org

Appendix E - Form for Proposals

(This appendix is not part of American National Standard ANSI/NETA ATS-2025)

Anyone may propose a new section for this document using the following form:

When drafting a proposed section:

1. Use the most recent edition of the specifications as a guideline for format and wording.
2. Remember that NETA specifications are “what to do” documents and do not include “how to do” information.
3. Include references.
4. When applicable, use the standard base format:
 - a. Visual and Mechanical Inspection
 - b. Electrical Tests
 - c. Test Values

Date _____

Name _____ Tel No. _____

Company _____ Fax No. _____

Address _____ E-Mail _____

Please indicate organization represented (if any) _____

NETA document title _____ Year _____

Section/Number _____

Note 1: Type or print legibly in black ink.

Note 2: If supplementary material (photographs, diagrams, reports, etc.) is included, you may be required to submit sufficient copies for all Members and Alternates of the Section Panel.

I hereby grant NETA the nonexclusive, royalty-free rights, including nonexclusive, royalty-free rights in copyright, in this proposal. I understand that I acquire no rights in any publication of NETA in which this proposal in this or another similar analogous form is used.

Signature (required) _____

This form is available electronically on NETA’s website at www.netaworld.org under Standards Activities.

Send to:

Standards Review Council
3050 Old Centre Road, Suite 101
Portage, MI 49024
Phone: 888.300.6382
Email: neta@netaworld.org