



AMP Quality Energy Services,
LLC
AMP Quality Energy Services,
LLC
4220 West Schrimsher SW Site
W1
Huntsville, AL, 35804

Nameplate Data			
Serial Number	24JC264800001	Unit ID	
Equipment Type	Transformer	Manufacturer	ABB
Year Manufactured	2024	Primary KV	15
Gallons	185	KVA Rating	75
Phases	3	Fluid type	Natural Ester
Substation Location	200 Lockheed Martin Way	Breathing Configuration	Sealed

Equipment Information		
Top Valve (in)		Bottom Valve (in)
Hose Length (ft)		Paint Condition
Conservator Tank		Bushings Enclosed
Leaks		Radiators
Service Energized		Compartments

Sample Date		03/26/2025
Barcode Sample Number	00309390	
Job Number	24021	
DGA	ppm	
Hydrogen		71
Methane		3
Ethane		84
Ethylene		3
Acetylene		Trace
Carbon Monoxide		30
Carbon Dioxide		706
Oxygen		317
Nitrogen		32468
TDCG		192
CO2 / CO		23.53
DGA Condition	Condition 1	
DGA Analysis	Duval Pentagon not applicable.	
Barcode Sample Number	00309391	
Moisture (D1533) ppm	72	
Acid (D974) mgKOH/g	0.059	
IFT mM/m	22.2	
Color (D1500)	0.50	
Visual (1524)	Clear and Sparkle - Trace Sediment	
Dielectric (D1816) kV 2 mm	47.3	
Specific Gravity (D1298/D4052)	0.9204	
PF 25C (D924) %	0.161	
Oil Quality	All tests meet recommended levels for in-service natural ester fluids.	