



AMP Quality Energy Services,
LLC
AMP Quality Energy Services,
LLC
4220 West Schrimsher SW Site
W1
Huntsville, AL, 35804

Nameplate Data			
Serial Number	2550015203	Unit ID	
Equipment Type	Transformer	Manufacturer	Eaton
Year Manufactured	2025	Primary KV	12.47
Gallons	137	KVA Rating	300
Phases	3	Fluid type	Natural Ester
Substation Location	CEI Labs	Breathing Configuration	Sealed

Equipment Information			
Top Valve (in)		Bottom Valve (in)	
Hose Length (ft)		Paint Condition	
Conservator Tank		Bushings Enclosed	
Leaks		Radiators	
Service Energized		Compartments	

Sample Date		06/02/2026
Barcode Sample Number		00334739
Job Number		26055
Sample Temp.	°C	29
DGA	ppm	
Hydrogen		78
Methane		2
Ethane		123
Ethylene		2
Acetylene		0
Carbon Monoxide		35
Carbon Dioxide		622
Oxygen		861
Nitrogen		58413
TDCG		240
CO2 / CO		17.77
DGA Condition		Condition 1
DGA Analysis		Duval Pentagon not applicable.
Barcode Sample Number		00334740
Moisture (D1533)	ppm	54
Acid (D974)	mgKOH/g	0.028
IFT	mM/m	16.8
Color (D1500)		0.50
Visual (1524)		Clear and Sparkle - No Sediment
Dielectric (D1816)	kV 2 mm	56.8
Specific Gravity (D1298/D4052)		0.9231
PF 25C (D924)	%	0.225
Oil Quality		All tests meet recommended levels for in-service natural ester fluids.