Accurate Testing Labs, LLC
7950 Meadowlark Way
Coeur d'Alene, ID 83815
Phone (208) 762 8378 Fax (208) 762 9082
info@accuratetesting.com www.accuratetesting.com

Certificate of Analysis

Order No.: **2026080749**

Tom Richardson
H2O Well Service
582 W Hayden Ave
Hayden Lake, ID 83835

Description: Anderson, Anthony
Date Received: 08/26/2026 08:14

Sample: **2**
Location: Well D911540
Sample Type: Construction

Matrix: Drinking Water
D/T Collected: 08/25/2026 14:05
Collected by: Kevin Albriton

Analyte	Result	Unit	Method	PQL	Analysis Date	Analyst
Calcium	26.3	mg/L	EPA 200.7	0.022	08/27/26	WM
Hardness, Total (as CaCO3)	7.10	GPG	SM 2340	0.02	08/27/26	WM
Iron	4.61	mg/L	EPA 200.7	0.0078	08/27/26	WM
Magnesium	13.6	mg/L	EPA 200.7	0.020	08/27/26	WM
Manganese	0.108	mg/L	EPA 200.7	0.0006	08/27/26	WM
pH	8.06	pH Units	EPA 150.1		08/26/26	WM

Water qualtity parameters:

pH: Normal range: 6.5 - 8.5

Iron: Maximum contaminants level: 0.3 mg/L
Sources: Naturally occurring, corrosion of pipe
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Manganese: Maximum contaminants level: 0.05 mg/L
Sources: Naturally occurring
Adverse effects: Objectionable taste and odor, discolors laundry and fixtures

Hardness:				
	1 - 3.5	slightly hard	7.0 -10.5	hard
	3.5 - 7.0	moderately hard	10.5 - over	very hard

If the RESULT is 'ND' (Not Detected) or 'Absent', that means the concentration is less than the PQL (Practical Quantitation Limit for this method).

Walter Mueller

Laboratory Supervisor, Digitally signed by: Walter Mueller Date: 08/29/26