

POINT NUMBER	POINT NAME	EMS					STAT INPUT INTERPOSING RELAY NO.	CONT OUTPUT INTERPOSING RELAY NO.	RTU		EPAC		CASE NO. (NOTE 3)	ELEM DIA DWG.	ANNUNCIATOR WINDOW
		TAB DEC	CONT	NORMAL STATE	1 DSCRPT	0 DSCRPT			DIG CARD NO. INPUT NO.	RM NO. OUTPUT NO.	INPUT MOD-PT	OUTPUT MOD-PT			
161	RESERVED FOR 115KV LINE POS. 4 PROTECTION RELAYS ALARMS	159		1			1E2	—	DI 10-160				—		W129
162		160		1			1E3		DI 11-161				10		W130
163		161		1			1E4		DI 11-162				1A, 2A		W131
164		162		1			—		DI 11-163						W132
165		163		1			—		DI 11-164	RM 9-67/68					—
166	RESERVED FOR 115KV LINE POS. 7 PROTECTION RELAYS ALARMS	F 164		1			1E5		DI 11-165						W133
167		165		1			1E6		DI 11-166						W134
168		166		1			1E7		DI 11-167						W135
169		167		1			1E8		DI 11-168						W136
170		168		1			—		DI 11-169						W137
171	RESERVED FOR 115KV LINE POS. 8 PROTECTION RELAYS ALARMS	169		1			—		DI 11-170	RM 9-69/70					—
172		170		1			1E9		DI 11-171						W138
173		F 171		1			1E10		DI 11-172						W139
174		172		1			1E11		DI 11-173						W140
175		173		1			1E12		DI 11-174						W141
176	RESERVED FOR 115KV LINE POS. 8 PROTECTION RELAYS ALARMS	174		1			—		DI 11-175						W142
177		175		1			—		DI 11-176	RM 9-71/72					—
178		176		1			1E13		DI 12-177						W143
179		177		1			1E14		DI 12-178						W144
180		178		1			1E15		DI 12-179						W145
181	RESERVED FOR 115KV LINE POS. 8 PROTECTION RELAYS ALARMS	179		1			1E16		DI 12-180						W146
182		180		1			—		DI 12-181						W147
183		181		1			—		DI 12-182	RM 10-73/74					—
184		182		1			1E17		DI 12-183						W148
185		183		1			1E18		DI 12-184						W149
186	RESERVED FOR 115KV LINE POS. 8 PROTECTION RELAYS ALARMS	184		1			1E19		DI 12-185						W150
187		F 185		1			1E20		DI 12-186						W151
188		186		1			—		DI 12-187						W152
189		187		1			—		DI 12-188	RM 10-75/76					—
190		F 188		1			1E21		DI 12-189						W153
191	115KV LBFB ARMED	189		1			1F1		DI 12-190				NOTE 4		W154
192	115KV LBFB TRIP	190		1			1F2		DI 12-191				NOTE 4		W155
193	115KV CB 1 LBFB RELAY PS 1/2 FAIL	191		1			1F3		DI 12-192						W156
194	115KV CB 1 LBFB RELAY FAIL	192		1			1F4		DI 13-193						W157
195	115KV CB 2 LBFB RELAY PS 1/2 FAIL	F 193		1			1F5		DI 13-194						W158
196	115KV CB 2 LBFB RELAY FAIL	F 194		1			1F6		DI 13-195						W159
197	115KV CB 3 LBFB RELAY PS 1/2 FAIL	195		1			1F7		DI 13-196				5640022		W160
198	115KV CB 3 LBFB RELAY FAIL	196		1			1F8		DI 13-197				5640022		W161
199	115KV CB 5 LBFB RELAY PS 1/2 FAIL	197		1			1F9		DI 13-198				5640026		W162
200	115KV CB 5 LBFB RELAY FAIL	198		1			1F10		DI 13-199				5640026		W163
201	115KV CB 7 LBFB RELAY PS 1/2 FAIL	199		1			1F11		DI 13-200				5640030		W164
202	115KV CB 7 LBFB RELAY FAIL	200		1			1F12		DI 13-201				5640030		W165
203	115KV CB 9 LBFB RELAY PS 1/2 FAIL	201		1			1F13		DI 13-202				5640034		W166
204	115KV CB 9 LBFB RELAY FAIL	202		1			1F14		DI 13-203				5640034		W167
205	115KV CB 11 LBFB RELAY PS 1/2 FAIL	203		1			1F15		DI 13-204						W168
206	115KV CB 11 LBFB RELAY FAIL	204					1F16		DI 13-205						W169
207	115KV CB 13 LBFB RELAY PS 1/2 FAIL	205		1			1F17		DI 13-206						W170
208	115KV CB 13 LBFB RELAY FAIL	F 206		1			1F18		DI 13-207						W171
209	115KV CB 15 LBFB RELAY PS 1/2 FAIL	207		1			1F19		DI 13-208						W172
210	115KV CB 15 LBFB RELAY FAIL	208		1			1F20		DI 14-209						W173
211	115KV CB 17 LBFB RELAY PS 1/2 FAIL	209		1			1F21		DI 14-210						W174
212	115KV CB 17 LBFB RELAY FAIL	F 210		1			1F22		DI 14-211						W175
213	115KV CB 23 LBFB RELAY PS 1/2 FAIL	211		1			1F23		DI 14-212				5640038		W176
214	115KV CB 23 LBFB RELAY FAIL	212		1			1F24		DI 14-213				5640038		W177
215	SPARE	213					1G1		DI 14-214						W178
216	SPARE	214					1G2		DI 14-215						W179
217	115KV CB 1 TCM	F 215					1G3		DI 14-216						W180
218	115KV CB 2 TCM	216					1G4		DI 14-217						W181
219	115KV CB 3 TCM	217					1G5		DI 14-218						W182
220	115KV CB 5 TCM	218					1G6		DI 14-219						W183
221	115KV CB 7 TCM	219					1G7		DI 14-220						W184
222	115KV CB 9 TCM	220					1G8		DI 14-221						W185
223	115KV CB 11 TCM	F 221					1G9		DI 14-222						W186
224	115KV CB 13 TCM	222					1G10		DI 14-223						W187
225	115KV CB 15 TCM	223					1G11		DI 14-224						W188
226	115KV CB 17 TCM	224					1G12		DI 15-225						W189
227	115KV CB 23 TCM	225					1G13		DI 15-226						W190
228	SEL-2020 COM	226					1G14		DI 15-227						W191
229	HWE-INYOKERN A TGT	227					—								—
230	HWE-INYOKERN B TGT	228					—								—
231	HWE-INYOKERN C TGT	229					—								—
232	HWE-INYOKERN GRD TGT	230					—								—
233	COSO HWE A TGT	231					—								—
234	COSO HWE B TGT	232					—								—
235	COSO HWE C TGT	233					—								—
236	COSO HWE GRD TGT	234					—								—
237	SILVERPEAK C A TGT	F 235					—								—
238	SILVERPEAK C B TGT	236					—								—
239	SILVERPEAK C C TGT	237					—								—
240	SILVERPEAK C GRD TGT	F 238					—								—

POINT NUMBER	POINT NAME	EMS					STAT INPUT INTERPOSING RELAY NO.	CTRL OUTPUT INTERPOSING RELAY NO.	RTU		EPAC		CASE NO. (NOTE 3)	ELEM. DIAG. DWG.	ANNUNCIATOR WINDOW
		TAB DEC	CONT	NORMAL STATE	1 DSCRPT	0 DSCRPT			DIG CARD NO. INPUT NO.	RM NO. OUTPUT NO.	INPUT MOD-PT	OUTPUT MOD-PT			
241	SILVERPEAK A A TGT	239					—								—
242	SILVERPEAK A B TGT	240					—								—
243	SILVERPEAK A C TGT	241					—								—
244	SILVERPEAK A GRD TGT	242				904562788								904562788	
245	HAIWEE-INYOKERN 115KV D60 OPD A/S	243		1	NORMAL	ALARM	1G-15		DI 15-228				6A	5804239	W192
246	HAIWEE-INYOKERN 115KV D60 OPD ALARM	244		1	NORMAL	ALARM	1G-16		DI 15-229				6A	5804239	W193
247	HAIWEE-INYOKERN 115KV D60 OPD TRIP	245		1	NORMAL	ALARM	1G-17		DI 15-230				6A	5804239	W194
248	COSO-HAIWEE-INYOKERN 115KV D60 OPD A/S	246		1	NORMAL	ALARM	1G-18		DI 15-231				6A	5804244	W195
249	COSO-HAIWEE-INYOKERN 115KV D60 OPD ALARM	247		1	NORMAL	ALARM	1G-19		DI 15-232				6A	5804244	W196
250	COSO-HAIWEE-INYOKERN 115KV D60 OPD TRIP	248		1	NORMAL	ALARM	1G-20		DI 15-233				6A	5804244	W197
251	SPARE	249				904562794	1G-21		DI 15-234						W198
252	SPARE	250					1G-22		DI 15-235						W199
253	SPARE	251					1G-23		DI 15-236						W200
254	SPARE	252					1G-24		DI 15-237						W201
255	PMU TROUBLE ALARM	253					—		DI 15-238						W202
256	SPARE	254					—		DI 15-239						—
257	SPARE	255					—		DI 15-240						—
258	SPARE	256					—		DI 16-241						W203
259	SPARE	257					—		DI 16-242						W204
260	SPARE	258					—		DI 16-243						W205
261	SPARE	259					—		DI 16-244						W206
262	SPARE	260					—		DI 16-245						W207
263	SPARE	261					—		DI 16-246						—
264	SPARE	262					—		DI 16-247	RM 10-77/78					—
265	SPARE	263					—		DI 16-248	RM 10-79/80					—
266	SPARE	264					—		DI 16-249	RM 11-81/82					—
267	SPARE	265					—		DI 16-250	RM 11-83/84					—
268	SPARE	266					—		DI 16-251	RM 11-85/86					—
269	SPARE	267					—		DI 16-252	RM 11-87/88					—
270	SPARE	268					—		DI 16-253	RM 12-89/90					—
271	SPARE	269					—		DI 16-254	RM 12-91/92					—
272	SPARE	270					—		DI 16-255	RM 12-93/94					—
273	SPARE	271					—		DI 16-256	RM 12-95/96					—