TECHNICAL DATA SHEET: JOCKEY PUMP

System Component for Low Pressure Zone Maintenance

Equipment Overview

This datasheet outlines the specifications for a high-capacity Jockey Pump deployed in a fire protection or pressure-maintenance system designated for a Low Pressure Zone. The primary function of this unit is to maintain consistent system pressure, compensating for minor leakages without cycling the main fire pump.

Performance & Operational Parameters

Parameter	Specified Value	Engineering Notes / Unit Equivalents
Flow Rate	180 LPM (10.8 m^3/hr)	Converts to 3.0 L/s or ~47.5 GPM.
Pumping Head / Pressure	120 m / 12.00 kg/cm^2	Equivalent to ~11.77 bar or ~170.6 PSI.
Motor Rating	5.0 kW (6.7 HP)	Requires standard 3-phase industrial power supply.
Application Zone	Low Pressure Zone	Configured for targeted zone pressure stabilization.
Pump Type (Typical)	Vertical Multistage Centrifugal	Recommended for high-head, low-to-medium flow duties.

System Integration & Installation Notes

• **Pressure Settings:** The jockey pump cut-in pressure should typically be set 0.3 to 0.5 bar higher than the main fire pump cut-in pressure.

• **Check Valve & Isolation:** Ensure a non-return (check) valve and full-bore isolation valves are installed on the discharge line to prevent backflow.

• **Controller Matching:** The starter panel must feature adequate overload protection, dry-run protection, and an automatic alternating/timer circuit if paired.

• **Vibration Isolation:** Flexible pipe connectors and anti-vibration mounting pads are recommended to protect connected header piping.

Note: Please verify standard unit conversions (e.g., cm/hr parsed as cubic meters per hour: m^3/hr) against physical site pipe dimensions before final plumbing procurement.