SANT VALVES
SINCE 1953

I.B.R

ISO 9001 CERTIFIED COMPANY

CI-18 Cast Iron Ball Valve Class 125, Flanged (ISI Marked)

Product Description

HSN 84818030

Product : 'SANT' Cast Iron Ball Valve
Product Standard : IS:9890 Class 125
Body Material cum Standard : Cast Iron IS:210 Gr.FG220
Description : Three piece design
Type of Seat : Renewable Teflon
Trim : Stem: SS AISI-410 Stainless Steel, Ball: SS AISI-304
Gland Packing : Teflon Rings
End Details : Flanges as per IS:3516-1966 undrilled/B.S.10 Table F



Testing & Certification

Body Test Pressure : 300 Psig. (21 bar g) Hyd.
Seat Test Pressure : 220 Psig. (15.4 bar g) Hyd., 100 Psig. (6.9 bar g) Air

Our Works' Test Certificate is furnished with every supply.

Application


Water	Oil	Gas

Materials of Construction

Components	Materials	Specifications
Body	Cast Iron	IS:210 Gr.FG220
Ball	Stainless Steel	AISI-304
Stem	Stainless Steel	AISI-410
Body Seats & Gland Seals	Teflon	—
Stopper, Gland Nut, Handle & Fasteners	Mild Steel	IS:2062:1992
Hand Sleeve	PVC	—
Gasket	Compressed Asbestos Fibre	—

Dimensions (in mm)

Nominal Size	Nominal Size (Inches)	F	LL (Approx.)
15	1/2	130±2	135
20	3/4	130±2	160
25	1	140±2	170
32	1 1/4	165±2	205
40	1 1/2	165±2	205
50	2	203±2	205
65	2 1/2	222±2	250
80	3	241±2	380
100	4	305±2	380



Notes
1. Product images are for illustration purposes only. Actual product may vary.

Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com

2. Actual dimensions may change over time, due to continual design improvements. Please confirm before placing order.

Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com