SANT VALVES
SINCE 1953

I.B.R

ISO 9001 CERTIFIED COMPANY

CR-21A Cast Iron Butterfly Valve Wafer Type (ISI Marked)

Product Description

HSN 84818030

Product : 'SANT' Cast Iron Butterfly Valve
Type of Pattern : Short Pattern
Product Standard : IS:13095
Pressure / Class / Rating : PN 10/PN 16
Body Material cum Standard : Cast Iron IS:210 Gr.FG200
Description : Wafer Type
Type of Seat : Nitrile / EPDM Lining
Type of Disc : SG Iron
Trim : SS AISI-410
End Details : Suitable insertion between Flanges as per BS 10 Table D/E ANSI B 16.1 Cl-125



Testing & Certification

Ratings:

PN10
Body Test Pressure : 1.5MPa (218 Psig) Hyd
Seat Test Pressure : 1.1MPa (160 Psig) Hyd

PN16
Body Test Pressure : 2.4MPa (348 Psig) Hyd
Seat Test Pressure : 1.8MPa (261 Psig) Hyd

Our Works' Test Certificate is furnished with every supply.

Application

Water

Materials of Construction

Components	Materials	Specifications
Body	Cast Iron	IS:210 Gr.FG260
Disc	S.G. Iron	IS:1865 Gr.SG400/15
Shaft	Stainless Steel	AISI-410/ IS:6603: 12cr12
Seat	Rubber	Nitrile / EPDM Lining
Gear	M.S.	—
Lever / Handwheel	M.S.	—


Dimensions (in mm)

Nominal Size	Nominal Size (Inches)	F	ØD	LL (Approx.)	H (Approx.)
40	1.1/2	33±2	82	175	132
50	2	43±2	95	175	132
65	2.1/2	46±2	106	175	145
80	3	46±2	124	260	170
100	4	52±2	150	260	189
125	5	56±2	173	260	207
150	6	56±2	210	260	232

Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com



Notes
1. Product images are for illustration purposes only. Actual product may vary.
2. Actual dimensions may change over time, due to continual design improvements. Please confirm before placing order.

Sant Valves Pvt. Ltd.
G.T.Road Bye Pass,
Jalandhar – 144012. Punjab. INDIA

https://www.santvalves.com

Phone : +91 181 5084693
Fax: +91 181 5062270
Email : info@santvalves.com