

Open-FDD Documentation

Generated by scripts/build_docs_pdf.py

June 12, 2026

- 1 Home
- 2 Open-FDD
 - 2.1 Who it is for
 - 2.2 Start here
 - 2.3 v3 edge stack
 - 2.4 Distribution
 - 2.5 License
- 3 Open-FDD Central / Portfolio / RCx reports
- 4 Open-FDD Central / Portfolio / RCx reports
 - 4.1 Boundary
 - 4.2 Incremental build order
 - 4.3 RCx report content (normalized roles)
 - 4.4 Prerequisites
 - 4.5 Safety
- 5 Run with Docker images
- 6 Run with Docker images
 - 6.1 Images
 - 6.2 1. Install and validate Docker
 - 6.3 2. Bootstrap the site (one script)
 - 6.3.1 Manual start (optional)
 - 6.4 Long-term operation
 - 6.4.1 Survive power cycles
 - 6.4.2 Start / stop / restart
 - 6.4.3 LAN access
 - 6.5 Deployment choices
 - 6.6 Next steps
- 7 First login and health check
- 8 First login and health check
 - 8.1 Public health
 - 8.2 Login
 - 8.3 Smoke checklist
 - 8.4 Stack detail (authenticated)
 - 8.5 Troubleshooting
- 9 Quick Start
- 10 Quick Start
- 11 Updating the stack

- 12 Updating the stack
 - 12.1 Before you start
 - 12.2 Fetch helper scripts (no git clone)
 - 12.3 One-command upgrade (recommended)
 - 12.4 Step by step
 - 12.4.1 1. Backup site state
 - 12.4.2 2. Verify images (optional)
 - 12.4.3 3. Pull and recreate
 - 12.4.4 4. Verify
 - 12.5 Dashboard UI updates
 - 12.6 Rollback
 - 12.7 Safe cleanup
 - 12.8 Next steps
- 13 Local development
- 14 Local development
 - 14.1 Clone and auth
 - 14.2 Start stack
 - 14.3 BACnet bench overlay (optional)
 - 14.4 Production-like local stack (Caddy, LAN scans)
 - 14.5 Docs preview
- 15 Build Docker images
- 16 Build Docker images
 - 16.1 Local build
 - 16.2 Publish to GHCR (maintainers)
- 17 Developer Guide
- 18 Developer Guide
- 19 Tests and CI
- 20 Tests and CI
 - 20.1 Local tests
 - 20.2 CI (GitHub Actions)
 - 20.3 Docs build (same as CI)
 - 20.4 Security-related CI
- 21 Contributing
- 22 Contributing
 - 22.1 Expectations
 - 22.2 Pull request checklist
 - 22.3 Repository layout (short)
 - 22.4 Docs links (GitHub Pages)
 - 22.5 Security issues
 - 22.6 Agent-assisted development
- 23 Health checks (developer)
- 24 Health checks (developer)
 - 24.1 Clone and local stack
 - 24.2 Stack health script
 - 24.3 Compose overlays
 - 24.4 BACnet poll pipeline
 - 24.5 pytest (bridge security / BACnet)
 - 24.6 Pentest production stack (LAN ZAP)
 - 24.7 Post-deploy insurance (inventory hosts)
- 25 Security testing cycle
- 26 Security testing cycle
 - 26.1 Who owns what

- 26.2 Per-revision workflow
 - 26.2.1 1. Local functional tests
 - 26.2.2 2. Pentest production stack (on Open-FDD host)
 - 26.2.3 3. Host + exposure checks (on edge VM)
 - 26.2.4 4. LAN security scan (from laptop)
 - 26.2.5 5. Pull request + automated review
 - 26.2.6 6. Release
 - 26.2.7 7. Lab edge validation
 - 26.2.8 8. Next cycle
- 26.3 What each scan layer covers
- 26.4 Open-source contributors
- 27 Python recipes (full Arrow library)
- 28 Python recipes — full Arrow library
 - 28.1 Shared helpers (paste once per rule file)
 - 28.2 GL36 AHU Rules A-M
 - 28.2.1 Rule A — duct static low at full fan speed (AHU-A)
 - 28.2.2 Rules B & C — blended air outside OAT/RAT band (AHU-D)
 - 28.2.3 Rule D — discharge cold when heating commanded (AHU-B)
 - 28.2.4 Rule E — SAT too low with full heating (AHU-C)
 - 28.2.5 Rule F — SAT/MAT mismatch in economizer mode (AHU-E)
 - 28.2.6 Rule G — ambient too warm for free cooling (AHU-E)
 - 28.2.7 Rule H — OAT/MAT mismatch (econ + mech cooling) (AHU-E)
 - 28.2.8 Rule I — OAT/MAT mismatch (economizer only) (AHU-E)
 - 28.2.9 Rule J — discharge above blended in cooling (AHU-B)
 - 28.2.10 Rule K — discharge above setpoint in full cooling (AHU-C)
 - 28.2.11 Rule L — cooling coil ΔT when inactive (CH-C)
 - 28.2.12 Rule M — heating coil ΔT when inactive (AHU-B)
 - 28.3 Starter pack (VAV / AHU baseline)
 - 28.3.1 01_vav_zone_temp_bounds_occupied (VAV-C)
 - 28.3.2 02_vav_zone_temp_flatline_occupied (VAV-C)
 - 28.3.3 03_vav_damper_command_extreme_flatline (VAV-D)
 - 28.3.4 04_ahu_runtime_outside_schedule (BLD-C)
 - 28.3.5 05 / 06 / 07 — see Rules A, sensor_bounds_mask on sa-t / sensor_flatline_mask on sa-t
 - 28.4 Economizer starters
 - 28.4.1 ahu_econ_100oa_temp_tracking_fault (AHU-E)
 - 28.4.2 ahu_mech_cooling_when_free_cooling_available (AHU-E)
 - 28.4.3 ahu_oa_damper_excess_open_extreme_ambient (AHU-E)
 - 28.5 VAV zones
 - 28.5.1 zone_reheat_warm_ambient (VAV-A)
 - 28.5.2 zone_damper_valve_full_open (VAV-D)
 - 28.5.3 Zone / IAQ bounds
 - 28.6 Central plant
 - 28.6.1 dp_below_sp_pump_max (CH-E)
 - 28.6.2 flow_high_pump_max (CH-B)
 - 28.6.3 plant_supply_temp_deadband (CH-D)
 - 28.6.4 chiller_excessive_runtime (CH-F)

- 28.7 Heat pumps
 - 28.7.1 hp_discharge_cold_when_heating (HP-D)
- 28.8 Opportunistic / ventilation
 - 28.8.1 econ_active_warm_ambient (AHU-E)
 - 28.8.2 mech_cool_when_econ_available (AHU-E)
 - 28.8.3 low_oa_fraction_estimated (VAV-B)
 - 28.8.4 preheat_excess_temp (AHU-B)
- 28.9 Weather station
 - 28.9.1 weather_temp_spike (BLD-B)
 - 28.9.2 weather_gust_lt_wind (BLD-B)
 - 28.9.3 RH bounds
- 28.10 Schedule + weather gating (occupied hours)
- 28.11 Next steps
- 29 System overview
- 30 System overview
 - 30.1 Docker edge stack (production)
 - 30.2 Components
 - 30.3 Deployment
 - 30.4 Optional PyPI-only path
- 31 Expression cookbook (Arrow-native)
- 32 Expression cookbook (Arrow-native)
 - 32.1 Legacy → modern translation
 - 32.2 How Arrow rules are structured
 - 32.2.1 Command scaling (0-1 vs 0-100 %)
 - 32.2.2 Occupied hours (schedule gating)
 - 32.3 Sensor validation (bounds, flatline, rate of change)
 - 32.3.1 Bounds (out of range) — oob_rolling
 - 32.3.2 Flatline (stuck sensor) — flatline_1h
 - 32.3.3 Rate of change (spike) — rate_of_change
 - 32.3.4 Mixing envelope (MAT vs OAT/RAT) — mixing_envelope
 - 32.4 GL36-inspired AHU rules (legacy expression → fault code)
 - 32.5 Starter pack (VAV / AHU baseline)
 - 32.5.1 Economizer starters
 - 32.6 VAV, central plant, heat pump
 - 32.7 Opportunistic / ventilation
 - 32.8 Data quality vs equipment faults
 - 32.9 Metric (°C) equivalents
 - 32.10 Binding rules to the fault catalog
 - 32.11 Pandas YAML → Arrow checklist (commissioning)
- 33 Deployment modes
- 34 Deployment modes
 - 34.1 Mode summary
 - 34.2 v3 container stack (all edge modes)
 - 34.3 Caddy HTTP (typical edge)
 - 34.4 Caddy TLS (OT LAN)
 - 34.5 BACnet data path
 - 34.6 What not to do on production edges
 - 34.7 Related
- 35 Arrow recipes
- 36 Arrow recipes (default)
 - 36.1 Simple threshold
 - 36.2 Supply air temp high

- 36.3 Fan commanded but no airflow
- 36.4 Flatline (1 h rolling window)
- 36.5 Sensor out of range (catalog defaults)
- 36.6 Sensor flatline + spike (catalog)
- 37 Python recipes (Arrow)
- 38 Python recipes (Arrow)
- 39 Containers
- 40 Containers
 - 40.1 GHCR images
 - 40.2 Stack diagram
 - 40.3 Responsibilities
 - 40.4 Network and ports (typical edge)
 - 40.5 Long-lived deployment
 - 40.6 Persistent data
 - 40.7 Optional host services
- 41 Lookback window helper
- 42 Lookback window helper
 - 42.1 Recommended pattern (copy into rule.py)
 - 42.2 Why not hide this behind a library call yet?
 - 42.3 Lookback vs rolling samples
 - 42.4 Batch intervals
- 43 Data flow
- 44 Data flow
 - 44.1 Telemetry ingest
 - 44.1.1 BACnet
 - 44.1.2 Modbus TCP
 - 44.1.3 JSON API (HTTP/HTTPS)
 - 44.2 Rule evaluation
 - 44.3 Model sync
 - 44.4 Retention
- 45 Architecture
- 46 Architecture
- 47 Rule Cookbook
- 48 Rule Cookbook
- 49 Windowing & debugging
- 50 Windowing & debugging
 - 50.1 Lookback vs rolling window
 - 50.2 Rolling windows (Arrow)
 - 50.3 Rule Lab console
- 51 GL36 algorithm stubs
- 52 GL36 algorithm stubs (doc-only)
 - 52.1 Shared lookback helper
 - 52.2 VAV zone cooling requests (0-3)
 - 52.3 AHU duct static trim & respond (advisory fault)
 - 52.4 Chiller plant enable (valve request counting)
 - 52.5 Hot water plant HWST trim & respond (advisory)
 - 52.6 Chilled water plant (DP + CHWST reset advisory)
 - 52.7 Testing later
- 53 Central plants (CHW / CTW / BLR)
- 54 Central plant Arrow recipes
 - 54.1 Starter fault codes
 - 54.2 Required point roles (CHW)

54.3	Synthetic test pattern
55	Dashboard overview
56	Dashboard overview
56.1	Primary areas
56.2	Live updates
56.3	Roles
57	Auth and roles
58	Auth and roles
58.1	Production (LAN / edge)
58.2	Localhost dev
59	Rule Lab
60	Rule Lab
60.1	Equipment-scoped test and export
60.2	Export all rules
60.3	Workflow
60.4	Dev kit zip (download)
60.5	Lookback windows
60.6	Algorithms (supervisory — coming soon)
60.7	Related
61	JSON API driver
62	JSON API driver
62.1	Supported features
62.2	Secrets: <code>json_api.env.local</code>
62.3	OpenWeatherMap showcase (recommended demo)
62.3.1	1. Configure env
62.3.2	2. Register from the UI
62.3.3	3. Headless / script
62.3.4	4. FDD: local OA-T vs web weather
62.4	Commissioning (UI)
62.4.1	API for agents
62.4.2	Bench preset
62.5	Authentication examples
62.5.1	Query-string API key via env (OpenWeather)
62.5.2	Bearer token (API key)
62.5.3	HTTP Basic
62.5.4	POST with JSON body
62.6	REST API
62.7	Typical OT URLs
62.8	Limitations
62.9	Disable polling (save API quota)
62.10	Smoke test
63	Algorithms
64	Algorithms (coming soon)
64.1	GL36 Trim & Respond reference
64.2	Planned workflow (same kit shape as Rule Lab)
64.3	Lookback windows
64.4	AHU supervisory checks (doc-only stubs)
64.4.1	Duct static pressure too high
64.4.2	Supply air temperature too cold (cooling coil over-delivering)
64.5	Plant supervisory checks (doc-only)
64.6	Related

- 65 Model workflow
- 66 Model workflow
 - 66.1 Brick model
 - 66.2 Typical integrator flow
- 67 Driver framework
- 68 Driver framework
 - 68.1 Drivers
 - 68.2 Data layout
 - 68.3 Historian and FDD
 - 68.4 Rule Lab (Arrow upload/download)
 - 68.5 Smoke validation
 - 68.6 Related docs
- 69 Operator Bridge
- 70 Operator Bridge
- 71 Ollama and analytics
- 72 Ollama and analytics
 - 72.1 What runs without login
 - 72.2 Ollama setup
 - 72.3 Automatic analytics (deterministic, always on)
 - 72.4 When Ollama is used
 - 72.5 AI Agent (authenticated)
 - 72.6 Code map
- 73 FDD and assignments
- 74 FDD and assignments
 - 74.1 What the product actually does
 - 74.1.1 BRICK modeling (integrator + AI-assisted)
 - 74.1.2 Rule assignment (three binding kinds)
 - 74.1.3 CLASS vs device
 - 74.2 Commissioning JSON shape
 - 74.2.1 Rule names vs ids (Rule Lab alignment)
 - 74.3 Related
- 75 Network setup
- 76 Network setup
 - 76.1 Bind address
 - 76.2 Discovery range
 - 76.3 Verify
- 77 Discover and read
- 78 Discover and read
 - 78.1 Operator workflow
- 79 Polling
- 80 Polling
 - 80.1 Commission poll loop (default)
 - 80.2 Bridge ingest worker
 - 80.3 Health
 - 80.4 Poll strategy (edge)
 - 80.5 Async driver and single-stack I/O
 - 80.6 Operator override scans
- 81 Operator override scans
- 82 Operator override scans (P8)
 - 82.1 Schedule
 - 82.2 What each scan does
 - 82.3 BACnet I/O priority

- 82.4 Manual trigger
- 82.5 Health checks
- 82.6 Data paths
- 83 Write safety
- 84 Write safety
 - 84.1 Defaults
 - 84.2 Enable writes (commission role)
 - 84.3 Operator rules
- 85 BACnet
- 86 BACnet
- 87 Convention
- 88 Fault code convention
 - 88.1 Format (Grade-A, 3.0.18+)
 - 88.2 Categories (Grade-A)
 - 88.3 Severity
 - 88.4 Linking rules
 - 88.5 Cookbook mapping
- 89 Live site update
- 90 Live site update
 - 90.1 Layout on the edge host
 - 90.2 Concepts
 - 90.3 1. Verify new images on GHCR
 - 90.4 2. Update dashboard UI (when release changed React)
 - 90.5 3. Pull and recreate (edge host)
 - 90.6 4. Ansible image-only (control machine)
 - 90.7 5. Validate
 - 90.8 Rollback
 - 90.9 Related
- 91 Central collection
- 92 OpenFDD RCx Central — collection
 - 92.1 Interval summary schema
 - 92.2 Edge export formats
 - 92.3 Collect today (rollup API)
 - 92.4 Tuning proposals
- 93 AHU faults
- 94 AHU faults
- 95 Standards crosswalk
- 96 Standards crosswalk
 - 96.1 Example
- 97 Backup and restore
- 98 Backup and restore
 - 98.1 Quick backup (edge host)
 - 98.2 Manual backup (SSH)
 - 98.3 What to protect
 - 98.4 Restore after a bad upgrade
 - 98.5 Safe cleanup
 - 98.6 Related
- 99 OpenFDD RCx Central API
- 100 OpenFDD RCx Central API
 - 100.1 Start
 - 100.2 Edge registry (browser auth)
 - 100.3 Analytics & RCx

- 100.4 Validation (legacy collect workflow)
- 100.5 RCx report body
- 101 VAV faults
- 102 VAV faults
- 103 Docker images (GHCR)
- 104 Docker images (GHCR)
 - 104.1 Images
 - 104.2 Tags
 - 104.3 Publish
 - 104.4 vs PyPI
- 105 RTU faults
- 106 RTU faults
- 107 Deployment validation
- 108 Deployment validation
 - 108.1 Edge host smoke (5 minutes)
 - 108.2 Browser checklist
 - 108.3 Control-machine insurance check
 - 108.4 LAN security smoke (optional)
 - 108.5 Arrow / FDD rules (3.0+)
 - 108.6 Related
- 109 Sensor and data quality
- 110 Sensor and data quality
 - 110.1 Catalog codes
 - 110.2 Default bounds (imperial, occupied)
 - 110.3 Communication quality
 - 110.4 Operator workflow
- 111 Logging and audit
- 112 Logging and audit
 - 112.1 Log types
 - 112.2 Audit record schema
 - 112.2.1 Auth events (industry-standard login trail)
 - 112.2.2 OT / commissioning events
 - 112.2.3 Secret redaction
 - 112.3 Integrator API (read logs in the UI stack)
 - 112.4 Retention and rotation (defaults)
 - 112.5 Docker edge: json-file caps (not journald for app audit)
 - 112.6 Local dev (run_local.sh)
 - 112.7 Quick checks
 - 112.8 Comparison to typical web apps
 - 112.9 Related
- 113 GHCR image retention
- 114 GHCR image retention
 - 114.1 Policy (conservative)
 - 114.2 Dry-run first
 - 114.3 Protect Acme rollback tags
 - 114.4 Run locally
 - 114.5 GitHub Actions workflow
 - 114.6 Permissions
 - 114.7 Verify images still pull
 - 114.8 Rollback example
 - 114.9 Related issues
- 115 Fault Codes

- 116 Fault Codes
- 117 Operations
- 118 Operations
- 119 Portfolio
- 120 Portfolio (central desk)
- 121 Acme VAV/AHU rule guidance
- 122 Acme VAV/AHU FDD rule bundle
 - 122.1 Mixed manufacturers and units
 - 122.2 Rule matrix
 - 122.2.1 Phase 2+ (not enabled by default)
 - 122.2.2 Phase 3 rollups (future)
 - 122.3 Data model checks
 - 122.4 Tuning notes
 - 122.5 JSON API weather + BACnet OAT
 - 122.6 BACnet override scans
 - 122.7 Docker backup / recovery
- 123 Acme live validation
- 124 Acme live validation
 - 124.1 Recommended flow
 - 124.2 Modes
 - 124.3 What counts as pass
 - 124.4 Configuration (no secrets in git)
 - 124.5 Optional live pytest
 - 124.6 Overnight FDD validation (read-only)
 - 124.6.1 Live bridge vs branch fix
 - 124.7 Safety
 - 124.8 Reports
- 125 ACME validation follow-ups
- 126 ACME validation follow-ups
 - 126.1 1. FDD run-history equipment grouping
 - 126.2 2. RTU normalized role mapping
 - 126.3 3. True overnight validation (post-3.0.33 deploy)
- 127 ACME deploy 3.0.33 validation plan
- 128 ACME deploy 3.0.33 validation plan
 - 128.1 What this deploy fixes
 - 128.2 Prerequisites
 - 128.3 Deploy sequence
 - 128.4 Post-deploy read-only validation
 - 128.4.1 Quick harness
 - 128.4.2 Overnight try-out (4 cycles, no wall-clock sleep)
 - 128.4.3 True overnight (optional)
 - 128.5 Safety
- 129 LAN hardening
- 130 LAN hardening
 - 130.1 Auth and bind
 - 130.2 Network exposure
 - 130.3 Rule Lab
 - 130.4 TLS and LAN security scans
 - 130.5 Ollama on the edge
- 131 ZAP baseline (local bench)
- 132 ZAP baseline (local bench)
 - 132.1 Run

- 132.2 Expected results (HTTP bench mode)
- 132.3 Header ownership
- 132.4 Authenticated scan (later)
- 132.5 After fixes
- 133 TLS and certificates
- 134 TLS and certificates
 - 134.1 Ownership
 - 134.2 Generate bench certs (local)
 - 134.3 ZAP / Nmap with TLS bench
 - 134.4 Renewal
 - 134.5 Enterprise CA on Caddy (edge)
 - 134.6 Caddy internal CA mode (lab)
 - 134.7 Secrets
- 135 Authenticated scanning (roadmap)
- 136 Authenticated scanning (roadmap)
 - 136.1 Current state (3.0.x)
 - 136.2 Why baseline is not enough
 - 136.3 Planned approach (contributors welcome)
 - 136.4 Manual authenticated ZAP today
 - 136.5 Related
- 137 Secrets and auth
- 138 Secrets and auth
 - 138.1 Files (gitignored)
 - 138.2 Required variables (production)
 - 138.3 GHCR pulls
 - 138.4 Backup
- 139 BACnet write allowlists
- 140 BACnet write allowlists
- 141 Linux host hardening
- 142 Linux host hardening
 - 142.1 Scope
 - 142.2 Quick operator workflow
 - 142.3 Ubuntu version and EOL
 - 142.4 Kernel and package updates
 - 142.5 Host Python (pip, wheel, pyOpenSSL)
 - 142.6 Ollama — no LAN exposure
 - 142.7 OpenSSH Terrapin (CVE-2023-48795)
 - 142.8 ICMP timestamp (Low)
 - 142.9 TLS and certificate scans
 - 142.10 Maintainer security audits (CI parity)
- 143 Tenable / Nessus remediation
- 144 Tenable / Nessus remediation
 - 144.1 Prioritized action plan
 - 144.2 Finding classification table
 - 144.3 Operator commands (edge VM)
 - 144.3.1 Validate (read-only)
 - 144.3.2 Remediate host (maintenance window)
 - 144.3.3 Remediate Open-FDD containers
 - 144.3.4 Rescan
 - 144.4 Ollama unauthenticated access (Critical)
 - 144.5 pyOpenSSL and pip in containers
 - 144.6 TLS — expected vs production

- 144.7 Residual findings after remediation
- 144.8 Notes for IT / security team
- 144.9 Repo-owned fixes (this document's release)
- 145 AI agents
- 146 AI agents and MCP
- 147 Security
- 148 Security
- 149 API routes
- 150 API routes
 - 150.1 Health & audit
 - 150.2 Auth
 - 150.3 Rules & FDD
 - 150.4 Rule Lab playground
 - 150.5 BRICK / data model
 - 150.6 BACnet
 - 150.7 Faults (check-engine)
 - 150.8 Timeseries & sites
 - 150.9 Building & host
 - 150.10 Local agent (Ollama)
 - 150.11 Modbus
 - 150.12 JSON API (HTTP/HTTPS)
 - 150.13 PyPI package (separate)
 - 150.14 Errors
- 151 Python package
- 152 Python package (open-fdd)
 - 152.1 Modules
 - 152.2 When to use package-only
 - 152.3 Versioning
 - 152.4 Offline Arrow example
- 153 Configuration reference
- 154 Configuration reference
 - 154.1 Bridge / auth
 - 154.2 BACnet
 - 154.3 Docker edge
- 155 Glossary
- 156 Glossary
- 157 Workspace env files
- 158 Workspace env files
 - 158.1 Ansible / edge extras
 - 158.2 Related docs
- 159 Appendix
- 160 Appendix
- 161 GL36 lab site (Acme)
- 162 GL36 lab site (Acme)
 - 162.1 BACnet poll scope
 - 162.2 Example FDD rules (Arrow)
 - 162.2.1 Duct static pressure high (AHU)
 - 162.2.2 SAT too cold vs setpoint
 - 162.2.3 Site rule stubs in the repo
 - 162.2.4 Local OA-T vs web weather (JSON API)
 - 162.3 Deploy / upgrade (Ansible, this lab only)
 - 162.4 AI-assisted data modeling (lab workflow)

- 163 Examples & lab notes
- 164 Examples & lab notes
- 165 Arrow-native runtime
- 166 Arrow-native runtime
 - 166.1 Authoring contract
 - 166.2 Package layout
- 167 Release process
- 168 Release process
 - 168.1 1. Prepare version
 - 168.2 2. Merge and tag
 - 168.3 3. PyPI Trusted Publishing setup (one-time)
 - 168.4 4. Verify release
 - 168.5 5. Manual workflow_dispatch
 - 168.6 Package vs Docker
- 169 PyPI package
- 170 PyPI package (open-fdd)
 - 170.1 What it is
 - 170.2 What it is not
 - 170.3 Install
 - 170.4 CLI
 - 170.5 Rule contract
 - 170.6 Modules shipped on PyPI
 - 170.7 Examples
 - 170.8 Local validation
- 171 MCP server
- 172 Open-FDD MCP server
 - 172.1 Modes
 - 172.2 Transport
 - 172.3 Human approval
 - 172.4 Client examples
 - 172.5 Site registry example
 - 172.6 Module layout
- 173 Dashboard Analytics
- 174 Dashboard analytics
 - 174.1 Pages
 - 174.2 API (read-only)
 - 174.3 Fault hours
 - 174.4 Theme
 - 174.5 Tests
- 175 Dashboard Rcx Makeover Inventory
- 176 Dashboard + RCx Makeover — Inventory
 - 176.1 What exists
 - 176.2 What partially exists
 - 176.3 What is missing (this branch targets)
 - 176.4 Files inspected
 - 176.5 Recommended implementation path
 - 176.6 Known risks
- 177 Rcx Central Current State
- 178 OpenFDD RCx Central — current state
 - 178.1 Product names
 - 178.2 Entrypoints
 - 178.3 Central API (new/changed)

- 178.4 Edge REST (read-only)
- 178.5 Dash UI tabs
- 178.6 RCx / charts
- 178.7 Docker
- 178.8 Tests
- 178.9 Remaining gaps
- 178.10 Recommended next PR
- 179 Data Model
- 180 Data Model — sync and FDD queries
 - 180.1 Explorer (BACnet poll sync)
 - 180.2 FDD query presets
- 181 Host Resources
- 182 Host Resources — Easy Pooge reset
- 183 Trend Plots
- 184 Trend plots
 - 184.1 HTTP / Tailscale
 - 184.2 Troubleshooting
- 185 Cloud Exporter
- 186 Cloud exporter sidecar
 - 186.1 Enable (edge compose)
 - 186.2 Security
- 187 Ai Agent Workflow
- 188 AI agent workflow vs runtime use
 - 188.1 Runtime analyst (no git clone)
 - 188.2 Developer / coding agent (git working tree)
 - 188.3 Secrets
 - 188.4 Model routing (test triage)
- 189 Docker Desktop Windows
- 190 RCx Central on Docker Desktop (Windows)
 - 190.1 Prerequisites
 - 190.2 Run
 - 190.3 Volumes
 - 190.4 Tailscale networking
 - 190.5 Smoke test
- 191 Edge Auth
- 192 Edge authentication (RCx Central)
 - 192.1 Browser flow
 - 192.2 API
 - 192.3 Auth types
 - 192.4 Rejected URLs
- 193 Index
- 194 OpenFDD RCx Central
 - 194.1 Quick start (host Python)
 - 194.2 Docker Desktop
 - 194.3 Pages
 - 194.4 Safety
- 195 Model Queries
- 196 Model queries (RCx Central → OpenFDD Edge)
 - 196.1 Primary endpoints
 - 196.2 Trends (matplotlib preview + fault overlays)
 - 196.3 Analytics
 - 196.4 RCx Central API wrappers

- 197 Report Builder
- 198 RCx Report Builder (RCx Central)
 - 198.1 Flow
 - 198.2 Fault overlays
 - 198.3 DOCX
- 199 Rcx Report Builder
- 200 RCx Report Builder
 - 200.1 Workflow
 - 200.2 Implementation
 - 200.3 Safety
 - 200.4 Dependencies
 - 200.5 Central vs edge

Generated June 12, 2026

1 Home

2 Open-FDD

Open-FDD is an open-source **building edge platform** for BACnet integration, feather historian storage, Arrow-native fault detection, and operator dashboards — designed for **trusted LAN / OT edge** deployment behind Caddy, not direct public internet exposure.

2.1 Who it is for

Role	What you get
IT / controls engineer	Pull three GHCR images, log in, poll BACnet, view faults
Commissioning integrator	Discover points, bind BRICK model, pin FDD rules in Rule Lab
Developer / maintainer	Extend the Operator Bridge, publish images, run CI and LAN security scans

2.2 Start here

Path	Go to
Try it	[Quick Start — Run with Docker] (<code>{ { "/quick-start/docker/"</code>

Path	Go to
Operate it	Updating the stack ({{ "/quick-start/updates/"
Develop it	Developer Guide ({{ "/developer/"

2.3 v3 edge stack

Three primary containers on a Linux edge host:

Container	Role
openfdd-bridge	Operator Bridge — API, dashboard, feather ingest
openfdd-commission	BACnet discover/read/write + poll loop
openfdd-mcp-rag	Doc-search sidecar for agent tools

Host **Caddy** on :80 or :443 is the normal LAN front door. BACnet UDP :47808 is bound by **commission** only — the bridge ingests samples.csv into the feather historian.

Details: [Containers](#)({{ "/architecture/containers/" | relative_url }}) · [Deployment modes](#)({{ "/architecture/deployment-modes/" | relative_url }})

LAN / OT edge only. Do not expose the Operator Bridge to the public internet without TLS, strong auth, and site review. BACnet writes are disabled by default — see [\[BACnet write guard\]](#)({{ "/security/bacnet-writes/" | relative_url }}).

2.4 Distribution

Channel	Use when
GHCR ghcr.io/bbartling/openfdd-*	Production or trial edge deploy
This repository	Custom builds, commissioning, Rule Lab development
PyPI open-fdd	Arrow runtime lint/test without full UI

2.5 License

MIT — see repository LICENSE.

3 Open-FDD Central / Portfolio / RCx reports

4 Open-FDD Central / Portfolio / RCx reports

Planning doc for the next feature branch: `feature/openfdd-central-portfolio-rcx-reports`.

4.1 Boundary

Layer	Role
Open-FDD Edge	Lives at the building. BACnet, local FDD, model/trends/faults, safe REST APIs.
Open-FDD Central	Multi-building desk over Tailscale/VPN. No direct BACnet. No equipment commands. Validation jobs, RCx reports, portfolio health.

Existing code to extend (do not rewrite):

- `portfolio/collector/` — edge login, rollup fetch, CSV history
- `portfolio/dash/` — multi-site Dash dashboard
- `scripts/portfolio_collect.py` — collector CLI
- Edge APIs: `/api/building/portfolio-rollup`, `/api/faults/status`, `/api/fdd/results`

4.2 Incremental build order

1. **Edge registry** — extend `portfolio/sites.json` schema (name, base URL, `site_id`, last check-in).

2. **Remote edge client** — reuse portfolio/collector/edge_client.py; add validation job endpoints.
3. **Portfolio page** — edge health, BACnet/model/fault status, last check-in.
4. **One-off validation** — trigger read-only harness against one edge (acme_overnight_fdd_validate pattern).
5. **24-hour validation planner** — dropdown intervals (2h / 6h / 12h), store cycle results.
6. **Fault-hour analytics** — elapsed fault hours from historian + FDD runs.
7. **Minimal DOCX generator** — python-docx + matplotlib (BytesIO charts).
8. **Report download endpoint** — query edges via REST, render .docx.
9. **Tests/fixtures** — deterministic edge mocks; no live BACnet in CI.

4.3 RCx report content (normalized roles)

- Elapsed fault hours by equipment/severity
- SAT vs setpoint, duct static vs setpoint
- Fan/motor runtime analytics
- Missing data warnings
- Duplicate/model warnings from edge audit APIs
- **Never** severity-only cards without equipment context

4.4 Prerequisites

- ACME validation PR merged and **3.0.33** deployed (equipment context on live FDD alerts).
- Follow-ups: FDD run-history equipment grouping, RTU role mapping (see [ACME validation follow-ups](#)({{ "/ops/acme-validation-follow-ups/" | relative_url }})).

4.5 Safety

Central is read-only toward edges. No BACnet writes, commands, or BAS changes from Central.

5 Run with Docker images

6 Run with Docker images

Deploy Open-FDD on a Linux edge host using **three published GHCR images**. No git clone required.

6.1 Images

GHCR image	Service	Role
ghcr.io/bbartling/openfdd-bridge	bridge	Operator API, dashboard, historian ingest
ghcr.io/bbartling/openfdd-commission	commission	BACnet discover/ read/write and poll loop
ghcr.io/bbartling/openfdd-mcp-rag	mcp-rag	Doc-search sidecar

Edge hosts pull **latest** from GHCR (three images: bridge, commission, mcp-rag). The retired **openfdd-bacnet-poll** image is no longer published.

6.2 1. Install and validate Docker

```
sudo systemctl enable --now docker
sudo usermod -aG docker "$USER"
newgrp docker    # or log out/in

docker --version
docker compose version
docker ps
docker run --rm hello-world
```

Expect: active / enabled for docker, docker in groups, hello-world succeeds.

6.3 2. Bootstrap the site (one script)

Downloads docker-compose.yml, creates workspace/, generates auth.env.local, and sets BACNET_BIND from the host LAN NIC (e.g. ens192 → 10.200.200.185/24:47808):

```
curl -fsSL -o /tmp/openfdd_edge_bootstrap.sh \
https://github.com/bbartling/open-fdd/raw/refs/heads/master/
scripts/openfdd_edge_bootstrap.sh
bash /tmp/openfdd_edge_bootstrap.sh
```

Bootstrap + pull + start in one go:

```
bash /tmp/openfdd_edge_bootstrap.sh --start
```

Auth — bootstrap writes ~/open-fdd/workspace/auth.env.local (gitignored). This file holds the API signing secret and one username/password per role. Use it for your first dashboard login:

```
cat ~/open-fdd/workspace/auth.env.local
```

Variable	Role
OFDD_AUTH_SECRET	Signs session tokens (do not share)
OFDD_OPERATOR_*	Read-only operator
OFDD_INTEGRATOR_*	Default dashboard login — commissioning + BACnet
OFDD_AGENT_*	Agent / automation

Example shape (passwords are **random on first bootstrap only** — existing file is kept on re-runs):

```
OFDD_AUTH_SECRET=<random>
OFDD_OPERATOR_USER=operator
OFDD_OPERATOR_PASSWORD=<random>
OFDD_INTEGRATOR_USER=integrator
OFDD_INTEGRATOR_PASSWORD=<random>
OFDD_AGENT_USER=agent
OFDD_AGENT_PASSWORD=<random>
```

Sign in as **integrator** with the password from that file → First login and health check({{ "/quick-start/health-check/" | relative_url }}).

Action	Touches auth.env.local?
First bash ... bootstrap.sh --start	Creates file with random passwords (if missing)

Action	Touches auth.env.local?
bash ... bootstrap.sh --start again	Keeps your file — does not overwrite
bash ... bootstrap.sh --restart	Keeps your file — only restarts bridge to reload it
nano auth.env.local + --restart	Uses your edited passwords
--force-auth	Regenerates random passwords (opt-in only)

The **bridge** container reads auth.env.local at startup only. After you change passwords (manual edit or --force-auth), recreate bridge (env files are not reloaded by restart alone):

```
cd ~/open-fdd && docker compose up -d --force-recreate bridge
```

Regenerate passwords and reload (stack already running):

```
bash /tmp/openfdd_edge_bootstrap.sh --force-auth --restart --show-secrets
```

Manual edit then reload:

```
nano ~/open-fdd/workspace/auth.env.local
bash /tmp/openfdd_edge_bootstrap.sh --restart
```

Options:

Flag	Purpose
--start	docker compose pull && up -d after layout; curls http://127.0.0.1:8765/health
--image-tag TAG	default latest
--repo-ref BRANCH	branch for compose.edge.yml if not on master yet
--force-auth	regenerate auth.env.local (restarts bridge if stack is up)
--restart	recreate bridge to reload auth.env.local; curls /health after
--show-secrets	print passwords at end (lab only)

From a repo checkout: ./scripts/openfdd_edge_bootstrap.sh --start

The script prints **BACnet NIC**, **BACNET_BIND**, and file paths — **validate** commission.env before polling OT devices:

```
nano ~/open-fdd/workspace/bacnet/commissioning/commission.env
```

If you used `--start`, the stack is already up. Next step → First login and health check(`{{ "/quick-start/health-check/" | relative_url }}`)).

6.3.1 Manual start (optional)

Use this only if you ran bootstrap **without** `--start` and want to bring the stack up yourself:

```
cd ~/open-fdd
docker compose pull
docker compose up -d
docker compose ps
curl -sf http://127.0.0.1:8765/health && echo
```

Expected: **bridge, commission, mcp-rag** — all up. Then → First login and health check(`{{ "/quick-start/health-check/" | relative_url }}`)).

6.4 Long-term operation

6.4.1 Survive power cycles

All services use restart: `unless-stopped`. After reboot:

```
cd ~/open-fdd && docker compose ps
curl -sf http://127.0.0.1:8765/health
```

6.4.2 Start / stop / restart

```
cd ~/open-fdd
docker compose up -d          # idempotent
docker compose stop
docker compose restart commission
docker compose logs -f --tail 100 commission
```

Never run `docker compose down -v` or delete workspace/ on a live site.

6.4.3 LAN access

Put **Caddy** (or `nginx`) on port 80 → `127.0.0.1:8765`, or expose 8765 through the firewall.

6.5 Deployment choices

Mode	Compose services	When to use
Standard OT / BACnet	bridge + commission + mcp-rag	Real buildings — commission polls BACnet into samples.csv; bridge ingests to feather
Non-BACnet / demo	bridge + mcp-rag (omit commission)	JSON API, Modbus-only, or lab without field BACnet — see Driver framework ({{ “/drivers/”
TLS on OT LAN	Same stack + host Caddy OFDD_CADDY_MODE=tls	Encrypt browser↔edge; trust self-signed CA on operator PCs — not for public internet

Do **not** run the retired openfdd-bacnet-poll image or legacy openfdd-bacnet-poll systemd unit alongside Docker **commission** — that double-polls BACnet.

6.6 Next steps

→ [First login and health check](#)({{ “/quick-start/health-check/” | relative_url }})
→ [Updating the stack](#)({{ “/quick-start/updating/” | relative_url }})
— ./scripts/openfdd_site_update.sh

7 First login and health check

8 First login and health check

Quick checks after docker compose up -d on the edge host. Services use restart: unless-stopped — after a reboot, run docker compose ps once Docker is up (see [Run with Docker]({{ “/quick-start/docker/” | relative_url }}#survive-power-cycles)).

8.1 Public health

```
curl -s http://127.0.0.1:8765/health
```

Through Caddy on port 80:

```
curl -s http://127.0.0.1/health
```

Expect "ok": true and "auth_required": true when auth is configured.

8.2 Login

1. Open the dashboard ([http://<host-lan-ip>/ or :8765](http://<host-lan-ip>/or :8765)).
2. Sign in with credentials from `workspace/auth.env.local`.

```
curl -s -X POST http://127.0.0.1:8765/api/auth/login \
-H 'Content-Type: application/json' \
-d '{"username":"integrator","password":"<from-auth-env>"}'
```

8.3 Smoke checklist

Check	Pass
docker compose ps	bridge, commission, mcp-rag Up
GET /health	200, ok: true
Login	Token returned
BACnet poll	samples.csv growing (tail -1 workspace/bacnet/ polls/samples.csv)
Historian	Files under workspace/data/ feather_store/

8.4 Stack detail (authenticated)

Integrator token required:

```
TOKEN=$(curl -sf -X POST http://127.0.0.1:8765/api/auth/login \
-H 'Content-Type: application/json' \
-d '{"username":"integrator","password":"..."}' | jq -r .token)
curl -sf http://127.0.0.1:8765/health/stack -H "Authorization:
Bearer $TOKEN" | jq .
```

Look for `bacnet_poll` green/yellow in the services list.

8.5 Troubleshooting

Symptom	Fix
401 everywhere	Configure workspace/ auth.env.local
Empty BACnet discover	Fix BACNET_BIND in commission.env — network setup ({ { “/ bacnet/network- setup/”
No poll rows	Commission container running? points.csv has enabled rows?
LAN browser timeout	Open firewall port 80 or 8765

Advanced probes (model graph, Rule Lab, compose profiles):
[Developer health check]({ { “/developer/health-check/” |
relative_url } }).

9 Quick Start

10 Quick Start

Run Open-FDD on a Linux edge host using **three GHCR Docker images**. No git clone on the host.

Step	Page
1	Run with Docker images ({ { “/quick-start/docker/”
2	First login and health check ({ { “/quick-start/health- check/”
3	Updating the stack ({ { “/quick-start/updating/”

One-liner bootstrap (edge host):

```
curl -fsSL -o /tmp/openfdd_edge_bootstrap.sh \  
https://github.com/bbartling/open-fdd/raw/refs/heads/master/  
scripts/openfdd_edge_bootstrap.sh  
bash /tmp/openfdd_edge_bootstrap.sh --start
```

Prerequisites: Linux, Docker enabled on boot, BACnet LAN if polling OT equipment.

BACnet writes are disabled by default. See [Write safety](#)({{ "/bacnet/write-safety/" | relative_url }}).

Stack: bridge + commission (BACnet + poll) + mcp-rag. Details: [Containers](#)({{ "/architecture/containers/" | relative_url }}).

11 Updating the stack

12 Updating the stack

Upgrade GHCR images on the edge host: **backup workspace/, pull new tags, recreate containers.** No git pull on the host.

12.1 Before you start

1. SSH to the edge host (cd ~/open-fdd).
2. Pick a tag from [GitHub Packages](#) — default is **latest**.
3. Short maintenance window (containers restart briefly;
restart: unless-stopped brings them back after reboot).

12.2 Fetch helper scripts (no git clone)

If you bootstrapped with openfdd_edge_bootstrap.sh, scripts are already under ~/open-fdd/scripts/. Otherwise:

```
mkdir -p ~/open-fdd/scripts
curl -fsSL -o ~/open-fdd/scripts/openfdd_site_backup.sh \
    https://github.com/bbartling/open-fdd/raw/refs/heads/master/
scripts/openfdd_site_backup.sh
curl -fsSL -o ~/open-fdd/scripts/openfdd_site_update.sh \
    https://github.com/bbartling/open-fdd/raw/refs/heads/master/
scripts/openfdd_site_update.sh
chmod +x ~/open-fdd/scripts/openfdd_site_*.sh
```

12.3 One-command upgrade (recommended)

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
./scripts/openfdd_site_update.sh
```

Pulls **:latest** by default, verifies all three images exist on GHCR, recreates containers, and hits /health.

12.4 Step by step

12.4.1 1. Backup site state

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
```

Archives workspace/ (feather, BACnet CSVs, model, auth) under ~/openfdd-backups/<timestamp>/.

Custom backup location:

```
BACKUP_ROOT=~/openfdd-backups/manual ./scripts/
openfdd_site_backup.sh
```

12.4.2 2. Verify images (optional)

```
export NEW_TAG="${NEW_TAG:-latest}"

docker manifest inspect ghcr.io/bbartling/openfdd-bridge:${
{NEW_TAG}} >/dev/null &&
docker manifest inspect ghcr.io/bbartling/openfdd-commission:${
{NEW_TAG}} >/dev/null &&
docker manifest inspect ghcr.io/bbartling/openfdd-mcp-rag:${
{NEW_TAG}} >/dev/null &&
echo "All images exist for ${NEW_TAG}"
```

12.4.3 3. Pull and recreate

```
cd ~/open-fdd
./scripts/openfdd_site_update.sh
```

Manual equivalent (same as the script):

```
cd ~/open-fdd
docker compose pull
docker compose up -d --force-recreate
```

```
docker compose ps
curl -sf http://127.0.0.1:8765/health && echo
```

12.4.4 4. Verify

```
docker compose ps
curl -sf http://127.0.0.1:8765/health | jq .
tail -1 workspace/bacnet/polls/samples.csv
ls -lah workspace/data/feather_store/
```

→ [Health check]({{ "/quick-start/health-check/" | relative_url }})

12.5 Dashboard UI updates

If the release changed the React UI, copy a new workspace/api/static/app/ build onto the host before or after the image pull. Image pull alone may not change the browser bundle hash.

12.6 Rollback

Restore docker-compose.yml from backup and pull again, or re-run bootstrap from a known-good master commit. GHCR keeps only the **three newest** versions per image; early sites should rely on **latest** plus workspace/ backups.

workspace/ is untouched by image-only upgrades.

12.7 Safe cleanup

```
docker image prune -f
```

Never run docker compose down -v, docker volume prune, or delete workspace/ on a live site.

12.8 Next steps

→ Run with Docker images({{ "/quick-start/docker/" | relative_url }}) — bootstrap a new host
→ [Health check]({{ "/quick-start/health-check/" | relative_url }})

13 Local development

14 Local development

14.1 Clone and auth

```
git clone https://github.com/bbartling/open-fdd.git && cd open-fdd
cp workspace/auth.env.example workspace/auth.env.local
# Edit integrator/operator passwords and OFDD_AUTH_SECRET (32+
chars)
```

14.2 Start stack

```
./scripts/build_and_test.sh           # dashboard build + pytest
./scripts/docker_build.sh
./scripts/openfdd_stack.sh up
./scripts/stack_health_check.sh
```

URL	Service
http://127.0.0.1:8765	Bridge (direct)
http://127.0.0.1:8765/docs	OpenAPI

14.3 BACnet bench overlay (optional)

```
docker compose -f docker/compose.dev.yml -f docker/
compose.bench.yml up -d
# commission.env – set BACNET_BIND to your OT interface
```

14.4 Production-like local stack (Caddy, LAN scans)

Same shape as an Acme edge deploy: **prod React UI, Caddy on : 80**, bridge on loopback **8765**, auth enabled. Use for OWASP ZAP or nmap from another machine on the LAN.

```
./scripts/pentest_production_stack.sh start  # build prod UI +
Caddy + auth.pentest.local
./scripts/pentest_production_stack.sh status # bridge,
commission, caddy, mcp-rag
./scripts/pentest_production_stack.sh verify # LAN IP, /health,
```

ZAP target URL

```
./scripts/pentest_production_stack.sh stop # when done
```

Credentials: workspace/auth.pentest.local (generated on first start). ZAP target is usually http://<lan-ip>/ (benserver example: http://192.168.204.18/). If LAN clients cannot reach :80, run `sudo ./scripts/open_lan_port.sh 80`.

See also Health checks (developer)(({ { "/developer/health-check/" | relative_url } }) for probe details and [ZAP baseline expectations](({ { "/security/zap-baseline/" | relative_url } }) for accepted Medium/Low findings.

14.5 Docs preview

```
cd docs && bundle install && bundle exec jekyll serve  
# http://127.0.0.1:4000/open-fdd/
```

15 Build Docker images

16 Build Docker images

16.1 Local build

```
./scripts/docker_build.sh  
# Optional tar for air-gap:  
./scripts/docker_build.sh --save
```

Images: openfdd-bridge, openfdd-commission, openfdd-mcp-rag.

16.2 Publish to GHCR (maintainers)

GitHub Actions workflow **Publish Docker addons** — manual dispatch; publishes :latest only and prunes GHCR (retired openfdd-bacnet-poll removed; keep 3 versions per image).

Maintainer checklist:

1. Green CI on master
2. Run **Publish Docker addons** workflow
3. Verify ghcr.io/bbartling/openfdd-{bridge,commission,mcp-rag}:latest
4. Edge hosts: `docker compose pull && docker compose up -d`

Details live in `.github/workflows/` and `scripts/docker_build.sh` — not duplicated here.

17 Developer Guide

18 Developer Guide

Clone, build, test, and contribute to Open-FDD.

Topic	Page
Local setup	Local development ({{ "/developer/local-setup/"
Docker builds	Build Docker images ({{ "/developer/docker-build/"
Health checks	Health checks (developer) ({{ "/developer/health-check/"
Tests & CI	Tests and CI ({{ "/developer/tests-ci/"
Security testing	[Release & LAN scan cycle] ({{ "/developer/security-testing/"
PRs	Contributing ({{ "/developer/contributing/"

AI-assisted contributors: see repository `AGENTS.md` for workspace layout, skill routing, and agent policy (one paragraph in public docs; details stay internal).

19 Tests and CI

20 Tests and CI

20.1 Local tests

```
./scripts/build_and_test.sh # UI + workspace bridge
pytest python3 -m pytest open_fdd/tests -q # PyPI package tests
```

```
cd workspace/dashboard && npm test # dashboard unit tests (if configured)
```

20.2 CI (GitHub Actions)

Workflow	Trigger	Checks
ci.yml	PR / push	pytest, bridge security audit, dashboard build, Jekyll docs
docs-pages.yml	push master	GitHub Pages site
publish-open-fdd.yml	tag v* / open-fdd-v*	PyPI wheel (Trusted Publishing)
docker-publish.yml	tag v* / manual	GHCR bridge, commission, mcp-rag

20.3 Docs build (same as CI)

```
cd docs && bundle exec jekyll build -d /tmp/open-fdd-site
```

Fix any template or link errors before opening a PR that touches docs/.

20.4 Security-related CI

ci.yml includes bridge security tests (tests/workspace_bridge/test_security.py). That complements — but does not replace — LAN [ZAP + Nmap scans]({{ "/security/zap-baseline/" | relative_url }}) on each patch revision. See [Security testing cycle](#)({{ "/developer/security-testing/" | relative_url }}).

21 Contributing

22 Contributing

22.1 Expectations

- Open an issue or discuss large changes before big refactors.
- Keep PRs focused; include test or docs updates when behavior changes.
- Do not commit secrets (`auth.env.local`, Ansible secrets/`*.env.local`, commissioning CSVs with real site data).
- Follow existing code style in `workspace/api/` and `workspace/dashboard/`.

22.2 Pull request checklist

☐

Tests pass locally (`./scripts/build_and_test.sh` or `scoped pytest`)

☐

Docs updated if user-facing behavior changed

☐

`docs/` Jekyll build succeeds

☐

No credentials in diff

☐

Auth/Caddy/header changes: re-run `[pentest verify + LAN ZAP]({{ "/developer/security-testing/" | relative_url }})` and update `[ZAP baseline]({{ "/security/zap-baseline/" | relative_url }})` if expectations changed

22.3 Repository layout (short)

Path	Contents
<code>workspace/api/</code>	Operator Bridge (FastAPI)
<code>workspace/dashboard/</code>	React SPA
<code>open_fdd/</code>	PyPI package (<code>arrow_runtime</code> , <code>playground</code>)
<code>docker/</code>	Compose files and image contexts
<code>infra/ansible/</code>	Edge deploy playbooks
<code>docs/</code>	This site (Jekyll + Just the Docs)

22.4 Docs links (GitHub Pages)

The site is a **project page** at <https://bbartling.github.io/open-fdd/> (baseurl: /open-fdd in docs/_config.yml).

- **Do not** use `{% raw %}/path/{% endraw %}` in Markdown body text — it omits baseurl and 404s on GitHub Pages.
- **Do** use `[label]({{ "/section/page/" | relative_url }})` for internal links.
- After `bundle exec jekyll build`, run `python3 scripts/check_docs_internal_links.py --site _site` from the repo root.

22.5 Security issues

Do not file public issues for vulnerabilities. Contact the maintainer or use GitHub private security advisories.

22.6 Agent-assisted development

Cursor/Claude contributors: read `AGENTS.md` and `skills/` for automation boundaries. Public docs intentionally avoid agent playbook detail.

23 Health checks (developer)

24 Health checks (developer)

Extended validation for engineers with a **full git checkout** — CI, compose overlays, and pre-release gates.

IT operators on edge hosts should use `[Quick Start — health check]({{ "/quick-start/health-check/" | relative_url }})` and `Deployment validation({{ "/ops/deployment-validation/" | relative_url }})` instead.

24.1 Clone and local stack

```
git clone https://github.com/bbartling/open-fdd.git && cd open-fdd
cp workspace/auth.env.example workspace/auth.env.local #
loopback dev only
./scripts/docker_build.sh # or: ./
```

```
scripts/openfdd_stack.sh prod
./scripts/openfdd_stack.sh up
```

GHCR production pull (no local build):

```
OPENFDD_IMAGE_TAG=2026.06.07-edge ./scripts/openfdd_stack.sh prod
```

24.2 Stack health script

```
./scripts/stack_health_check.sh
OPENFDD_BASE_URL=http://192.168.204.18:8765 ./scripts/
stack_health_check.sh
./scripts/stack_health_check.sh --require-ollama
```

Probes: containers up, /health, /api/model/health, sites, tree, SPARQL graph (with integrator auth when configured).

24.3 Compose overlays

Overlay	Use
docker/compose.dev.yml	Local dev bind-mount
docker/compose.bench.yml	Host-network BACnet lab
docker/compose.prod.yml	GHCR images instead of local build
docker/compose.edge.yml	IT edge template (copy to ~/open-fdd/ docker-compose.yml)

```
docker compose -f docker/compose.dev.yml -f docker/
compose.bench.yml ps
docker compose -f docker/compose.dev.yml config --images
```

24.4 BACnet poll pipeline

```
tail -1 workspace/bacnet/polls/samples.csv
cat workspace/data/bacnet_ingest_state.json
docker compose logs --since 10m commission | grep -i poll
docker compose logs --since 10m bridge | grep -i ingest
```

24.5 pytest (bridge security / BACnet)

```
PYTHONPATH=workspace/api pytest tests/workspace_bridge/
test_security.py -q
```

24.6 Pentest production stack (LAN ZAP)

```
./scripts/pentest_production_stack.sh start
./scripts/pentest_production_stack.sh verify
```

Then from a **LAN workstation**, run the packaged scan:

- Windows: `scripts/security/Run-OpenFddSecurityScan.ps1`
- macOS/Linux: `scripts/security/run_openfdd_security_scan.sh`

See [scripts/security/README.md](#), `[Security — ZAP baseline]({{ "/security/zap-baseline/" | relative_url }})`, and the full [security testing cycle](#)(`{{ "/developer/security-testing/" | relative_url }}`).
Host-side notes: `workspace/deploy/PENTEST.md`.

24.7 Post-deploy insurance (inventory hosts)

For automated checks against named inventory hosts, see `infra/ansible/scripts/post_deploy_check.sh` (maintainer tooling — not required for IT docker-pull sites).

25 Security testing cycle

26 Security testing cycle

How Open-FDD validates each **patch revision** before it ships to the live Acme HVAC bench — local automation, AI-assisted PR review, LAN passive scans, and edge post-deploy checks.

Related security docs: `[ZAP baseline]({{ "/security/zap-baseline/" | relative_url }})`, `[TLS and certificates]({{ "/security/tls-and-certs/" | relative_url }})`, `[LAN hardening]({{ "/security/lan-hardening/" | relative_url }})`, `[Linux host hardening]({{ "/security/linux-host-hardening/" | relative_url }})`, `[Tenable remediation]({{ "/security/tenable-remediation/" | relative_url }})`, `[Authenticated scanning (roadmap)]({{ "/security/authenticated-scanning/" | relative_url }})`.

26.1 Who owns what

Concern	Owner	Where
HTTP security headers (CSP, X-Frame, COOP, ...)	Bridge middleware	workspace/api/ openfdd_bridge/ security_headers.py
TLS termination + HSTS	Caddy	workspace/deploy/ caddy/, Ansible Caddyfile.j2 ./scripts/ setup_caddy_certs.sh → workspace/deploy/ caddy/certs/; Ansible /etc/ openfdd/caddy/ on edge
OT LAN TLS certificates	Site integrator / maintainer	
Pentest credentials	Generated per stack	workspace/ auth.pentest.local (never commit)
LAN ZAP + Nmap scans	Developer workstation on test LAN	scripts/security/

See [TLS and certificate ownership]({{ "/security/tls-and-certs/" | relative_url }}) for cert lifecycle.

26.2 Per-revision workflow

Typical cycle on a **control machine** (local dev) through a **lab edge host** (live bench):

flowchart LR

```
A[Local dev + pytest] --> B[Pentest stack verify]
B --> C[LAN ZAP + Nmap]
C --> D[PR + GitHub CI]
D --> E[CodeRabbit AI review]
E --> F[Merge + tag open-fdd-vX.Y.Z]
F --> G[GHCR + PyPI publish]
G --> H[Acme upgrade + post_deploy_check --full]
H --> I[Bump next patch locally]
```

26.2.1 1. Local functional tests

```
./scripts/build_and_test.sh
PYTHONPATH=workspace/api pytest tests/workspace_bridge/
test_security.py -q
```

```
infra/ansible/scripts/bench_5007_arrow_battery.sh # when FDD/  
Arrow paths change
```

26.2.2 2. Pentest production stack (on Open-FDD host)

```
./scripts/pentest_production_stack.sh start  
./scripts/pentest_production_stack.sh verify
```

Confirms Caddy :80 fronts the bridge, auth is enabled, BACnet writes disabled, and security headers are singular (no Caddy duplicates). Details: [Health checks — pentest]({{ "/developer/health-check/" | relative_url }}#pentest-production-stack-lan-zap).

26.2.3 3. Host + exposure checks (on edge VM)

After IT Nessus scans or before Acme deploy sign-off:

```
./scripts/security/check_host_security.sh  
./scripts/security/check_openfdd_exposure.sh --edge-ip <lan-ip>
```

Host remediation (dry-run first): ./scripts/security/remediate_ubuntu_host.sh

26.2.4 4. LAN security scan (from laptop)

Use the packaged scripts — do not hand-roll one-off docker/nmap commands unless debugging:

Platform	Command
Windows	.\scripts\security\Run-OpenFddSecurityScan.ps1
macOS / Linux	./scripts/security/run_openfdd_security_scan.sh

Setup (Docker Desktop, Nmap): [scripts/security/README.md](#).

Target URL is usually **http://<lan-ip>/** (Caddy), not :8765.

Review openfdd-security-report/90-quick-findings-summary.txt and compare against [ZAP baseline expectations]({{ "/security/zap-baseline/" | relative_url }}).

26.2.5 5. Pull request + automated review

- Open PR against master
- **GitHub Actions** (ci.yml): pytest, bridge security audit, dashboard build, Jekyll docs
- **CodeRabbit** (or similar AI PR review): style, security footguns, missing tests/docs

Do not merge with failing CI or unresolved duplicate-header regressions.

26.2.6 6. Release

```
git tag open-fdd-v3.0.4 # example
git push origin open-fdd-v3.0.4
```

Tag triggers GHCR :latest and PyPI publish workflows.

26.2.7 7. Lab edge validation

After pulling new images on a live bench VM:

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_full.sh --limit
<inventory_host>
    infra/ansible/scripts/post_deploy_check.sh --limit
<inventory_host> --full
```

Re-run LAN ZAP + Nmap against the edge LAN IP if Caddy or auth behavior changed. Site-specific example: [GL36 lab note] (`{{ "/examples/acme-gl36-lab/" | relative_url }}`).

26.2.8 8. Next cycle

Bump patch version locally (pyproject.toml, open_fdd/__init__.py) on master for the next development round — do not tag until the next release is ready.

26.3 What each scan layer covers

Layer	Tool	Depth
Unit / integration	pytest, test_security.py	Header middleware, auth gates
Stack smoke	pentest_production_stack.sh verify	Live headers, health, auth file
Passive web	ZAP baseline	Public routes, CSP, cookies, CORS
Port exposure	Nmap scoped	One host, known service ports
Authenticated API/dashboard	ZAP full + login	Roadmap — [Authenticated scanning]({{ "/security/"

Layer	Tool	Depth
		authenticated-scanning/

Baseline ZAP does **not** exercise integrator login or protected /api/* routes deeply.

26.4 Open-source contributors

The scripts/security/ folder is part of the public repo so any fork can run the same LAN smoke against their bench. PRs that change Caddy, auth, or security_headers.py should update [ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}) and re-run the scan scripts.

27 Python recipes (full Arrow library)

28 Python recipes — full Arrow library

Copy-paste `apply_faults_arrow` modules for Rule Lab. Replaces the legacy pandas/YAML Expression Rule Cookbook.

- **No pandas** on the edge — PyArrow + `pyarrow.compute` only
- Set `fault_code` in Rule Lab metadata (letter codes or Grade-A AHU-ECON-001)
- Map historian column names in the data model / rule bindings (ma-t, oa-t, stat_zn-t, ...)

Quick patterns: `Arrow recipes`({{ "/rule-cookbook/arrow-recipes/" | relative_url }}) · Index: `Expression cookbook (Arrow-native)` ({{ "/rule-cookbook/expression-cookbook/" | relative_url }})

28.1 Shared helpers (paste once per rule file)

```
import pyarrow as pa
import pyarrow.compute as pc
```



```

from open_fdd.arrow_runtime.cookbook import mixing_envelope_mask
from open_fdd.arrow_runtime.windows import (
    arrow_rolling_min,
    arrow_rolling_max,
    arrow_abs_diff,
)

def _norm_cmd(col: pa.ChunkedArray) -> pa.ChunkedArray:
    c = pc.cast(col, pa.float64())
    return pc.if_else(pc.greater(c, 1.0), pc.divide(c, 100.0), c)

def _col(table, name: str) -> pa.ChunkedArray:
    return pc.cast(table[name], pa.float64())

def _hypot_tol(a: float, b: float) -> float:
    return (a * a + b * b) ** 0.5

```

28.2 GL36 AHU Rules A-M

28.2.1 Rule A — duct static low at full fan speed (AHU-A)

```

FAULT_CODE = "AHU-A"
SP, SP_SP, FAN = "duct-static-pressure", "duct-static-pressure-
sp", "supply-fan-speed-command"
SP_MARGIN, DRV_HI, DRV_NEAR = 0.12, 0.93, 0.06

def apply_faults_arrow(table, cfg, context=None):
    sp, sp_sp = _col(table, SP), _col(table, SP_SP)
    fan = _norm_cmd(table[FAN])
    return pc.and_(
        pc.less(sp, pc.subtract(sp_sp, SP_MARGIN)),
        pc.greater_equal(fan, DRV_HI - DRV_NEAR),
    )

```

28.2.2 Rules B & C — blended air outside OAT/RAT band (AHU-D)

Uses `mixing_envelope_mask` (covers below-band and above-band).

```

FAULT_CODE = "AHU-D"

def apply_faults_arrow(table, cfg, context=None):

```

```

return mixing_envelope_mask(
    table,
    {**cfg, "mixing_tol": 1.15, "normalize_cmd_percent": 1},
    mat_col="ma-t",
    oat_col="oa-t",
    rat_col="ra-t",
    fan_col="supply-fan-speed-command",
)

```

28.2.3 Rule D — discharge cold when heating commanded (AHU-B)

```

FAULT_CODE = "AHU-B"
BLEND_TOL, SAT_TOL, FAN_DT = 1.15, 1.15, 0.55

```

```

def apply_faults_arrow(table, cfg, context=None):
    mat, sat = _col(table, "ma-t"), _col(table, "sa-t")
    valve = _norm_cmd(table["heating-valve-command"])
    fan = _norm_cmd(table["supply-fan-speed-command"])
    rhs = pc.add(pc.subtract(mat, BLEND_TOL), FAN_DT)
    cold = pc.less_equal(pc.add(sat, SAT_TOL), rhs)
    return pc.and_(cold, pc.greater(valve, 0.01), pc.greater(fan,
0.01))

```

28.2.4 Rule E — SAT too low with full heating (AHU-C)

```

FAULT_CODE = "AHU-C"
SUPPLY_ERR = 1.0

```

```

def apply_faults_arrow(table, cfg, context=None):
    sat = _col(table, "sa-t")
    sp = _col(table, "sa-t-sp") if "sa-t-sp" in
table.column_names else _col(table, "supply-air-temperature-
setpoint")
    valve = _norm_cmd(table["heating-valve-command"])
    fan = _norm_cmd(table["supply-fan-speed-command"])
    return pc.and_(
        pc.less(sat, pc.subtract(sp, SUPPLY_ERR)),
        pc.greater(valve, 0.9),
        pc.greater(fan, 0.01),
    )

```

28.2.5 Rule F — SAT/MAT mismatch in economizer mode (AHU-E)

```
FAULT_CODE = "AHU-E"
FAN_DT, BLEND_TOL, SAT_TOL, ECON_MIN = 0.55, 1.15, 1.15, 0.12
TOL = _hypot_tol(SAT_TOL, BLEND_TOL)

def apply_faults_arrow(table, cfg, context=None):
    mat, sat = _col(table, "ma-t"), _col(table, "sa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    mismatch = pc.greater(pc.abs(pc.subtract(pc.subtract(sat,
FAN_DT), mat))), TOL)
    econ = pc.and_(pc.greater(damper, ECON_MIN), pc.less(cool,
0.1))
    return pc.and_(mismatch, econ)
```

28.2.6 Rule G — ambient too warm for free cooling (AHU-E)

```
FAULT_CODE = "AHU-E"
OAT_TOL, FAN_DT, SAT_TOL, ECON_MIN = 1.15, 0.55, 1.15, 0.12

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    sp = _col(table, "sa-t-sp")
    damper = _norm_cmd(table["oa-damper-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    warm = pc.greater(oat, pc.add(pc.subtract(sp, FAN_DT),
SAT_TOL - OAT_TOL))
    econ = pc.and_(pc.greater(damper, ECON_MIN), pc.less(cool,
0.1))
    return pc.and_(warm, econ)
```

28.2.7 Rule H — OAT/MAT mismatch (econ + mech cooling) (AHU-E)

```
FAULT_CODE = "AHU-E"
OAT_TOL, BLEND_TOL = 1.15, 1.15
TOL = _hypot_tol(OAT_TOL, BLEND_TOL)

def apply_faults_arrow(table, cfg, context=None):
    oat, mat = _col(table, "oa-t"), _col(table, "ma-t")
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    return pc.and_(
        pc.greater(pc.abs(pc.subtract(mat, oat)), TOL),
```

```

        pc.greater(cool, 0.01),
        pc.greater(damper, 0.9),
    )

```

28.2.8 Rule I — OAT/MAT mismatch (economizer only) (AHU-E)

```

FAULT_CODE = "AHU-E"
TOL = _hypot_tol(1.15, 1.15)

def apply_faults_arrow(table, cfg, context=None):
    oat, mat = _col(table, "oa-t"), _col(table, "ma-t")
    damper = _norm_cmd(table["oa-damper-command"])
    return
pc.and_(pc.greater(pc.abs(pc.subtract(mat, oat)), TOL),
pc.greater(damper, 0.9))

```

28.2.9 Rule J — discharge above blended in cooling (AHU-B)

```

FAULT_CODE = "AHU-B"
FAN_DT, BLEND_TOL, SAT_TOL, ECON_MIN = 0.55, 1.15, 1.15, 0.12
TOL = _hypot_tol(SAT_TOL, BLEND_TOL)

def apply_faults_arrow(table, cfg, context=None):
    sat, mat = _col(table, "sa-t"), _col(table, "ma-t")
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    hot = pc.greater(sat, pc.add(mat, pc.add(TOL, FAN_DT)))
    mode_a = pc.and_(pc.greater(damper, 0.9), pc.greater(cool,
0.0))
    mode_b = pc.and_(pc.less_equal(damper, ECON_MIN),
pc.greater(cool, 0.9))
    return pc.and_(hot, pc.or_(mode_a, mode_b))

```

28.2.10 Rule K — discharge above setpoint in full cooling (AHU-C)

```

FAULT_CODE = "AHU-C"
SAT_TOL, ECON_MIN = 1.15, 0.12

def apply_faults_arrow(table, cfg, context=None):
    sat = _col(table, "sa-t")
    sp = _col(table, "sa-t-sp")
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])

```

```

high = pc.greater(sat, pc.add(sp, SAT_TOL))
full = pc.or_(
    pc.and_(pc.greater(damper, 0.9), pc.greater(cool, 0.9)),
    pc.and_(pc.less_equal(damper, ECON_MIN), pc.greater(cool,
0.9))),
)
return pc.and_(high, full)

```

28.2.11 Rule L — cooling coil ΔT when inactive (CH-C)

```

FAULT_CODE = "CH-C"
ENTER_TOL, LEAVE_TOL, ECON_MIN = 1.15, 1.15, 0.12
TOL = _hypot_tol(ENTER_TOL, LEAVE_TOL)

```

```

def apply_faults_arrow(table, cfg, context=None):
    ent = _col(table, "cooling-coil-entering-air-temperature")
    leave = _col(table, "cooling-coil-leaving-air-temperature")
    heat = _norm_cmd(table["heating-valve-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    drop = pc.greater(pc.subtract(ent, leave), TOL)
    mode_a = pc.and_(pc.greater(heat, 0), pc.equal(cool, 0),
pc.less_equal(damper, ECON_MIN))
    mode_b = pc.and_(pc.equal(heat, 0), pc.equal(cool, 0),
pc.greater(damper, ECON_MIN))
    return pc.and_(drop, pc.or_(mode_a, mode_b))

```

28.2.12 Rule M — heating coil ΔT when inactive (AHU-B)

```

FAULT_CODE = "AHU-B"
ENTER_TOL, LEAVE_TOL, FAN_DT, ECON_MIN = 1.15, 1.15, 0.55, 0.12
TOL = _hypot_tol(ENTER_TOL, LEAVE_TOL) + FAN_DT

```

```

def apply_faults_arrow(table, cfg, context=None):
    ent = _col(table, "heating-coil-entering-air-temperature")
    leave = _col(table, "heating-coil-leaving-air-temperature")
    heat = _norm_cmd(table["heating-valve-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    rise = pc.greater(pc.subtract(leave, ent), TOL)
    m1 = pc.and_(pc.equal(heat, 0), pc.equal(cool, 0),
pc.greater(damper, ECON_MIN))
    m2 = pc.and_(pc.equal(heat, 0), pc.greater(cool, 0),
pc.greater(damper, 0.9))
    m3 = pc.and_(pc.equal(heat, 0), pc.greater(cool, 0),

```

```
pc.less_equal(damper, ECON_MIN))
    return pc.and_(rise, pc.or_(m1, m2, m3))
```

28.3 Starter pack (VAV / AHU baseline)

28.3.1 01_vav_zone_temp_bounds_occupied (VAV-C)

```
from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask,
_unoccupied_mask
```

```
FAULT_CODE = "VAV-C"
```

```
def apply_faults_arrow(table, cfg, context=None):
    occupied = pc.invert(_unoccupied_mask(table, cfg))
    oob = sensor_bounds_mask(table, "zone_temp", cfg)
    return pc.and_(oob, occupied)
```

28.3.2 02_vav_zone_temp_flatline_occupied (VAV-C)

```
from open_fdd.arrow_runtime.cookbook import sensor_flatline_mask,
_unoccupied_mask
```

```
FAULT_CODE = "VAV-C"
```

```
def apply_faults_arrow(table, cfg, context=None):
    occupied = pc.invert(_unoccupied_mask(table, cfg))
    flat = sensor_flatline_mask(table, "zone_temp", cfg)
    return pc.and_(flat, occupied)
```

28.3.3 03_vav_damper_command_extreme_flatline (VAV-D)

```
from open_fdd.arrow_runtime.cookbook import flatline_1h_mask
```

```
FAULT_CODE = "VAV-D"
```

```
DAMPER = "damper-position-command"
```

```
def apply_faults_arrow(table, cfg, context=None):
    stuck = flatline_1h_mask(table, {**cfg, "column": DAMPER})
    wide = pc.greater(_norm_cmd(table[DAMPER]), 0.975)
    return pc.and_(stuck, wide)
```

28.3.4 04_ahu_runtime_outside_schedule (BLD-C)

Use run-hours analytics script + schedule compare; boolean mask:

```
from open_fdd.arrow_runtime.cookbook import _fan_on_mask,
_unoccupied_mask
```

```
FAULT_CODE = "BLD-C"
```

```
def apply_faults_arrow(table, cfg, context=None):
    return pc.and_( _fan_on_mask(table, cfg),
_unoccupied_mask(table, cfg))
```

28.3.5 05 / 06 / 07 — see Rules A, sensor_bounds_mask on sa-t / sensor_flatline_mask on sa-t

28.4 Economizer starters

28.4.1 ahu_econ_100oa_temp_tracking_fault (AHU-E)

```
FAULT_CODE = "AHU-E"
```

```
DAMPER_FULL, FAN_ON, TRACK_TOL, FAN_HEAT = 0.95, 0.5, 2.0, 0.5
```

```
def apply_faults_arrow(table, cfg, context=None):
    oat, mat, sat = _col(table, "oa-t"), _col(table, "ma-t"),
_col(table, "sa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    fan = _col(table, "supply-fan-status")
    econ = pc.and_(pc.greater(fan, FAN_ON),
pc.greater_equal(damper, DAMPER_FULL))
    mat_bad = pc.greater(pc.abs(pc.subtract(mat, oat)), TRACK_TOL)
    sat_bad = pc.greater(pc.abs(pc.subtract(pc.subtract(sat,
FAN_HEAT), mat)), TRACK_TOL)
    return pc.and_(econ, pc.or_(mat_bad, sat_bad))
```

28.4.2 ahu_mech_cooling_when_free_cooling_available (AHU-E)

```
FAULT_CODE = "AHU-E"
```

```
MARGIN, DAMPER_LOW, COOL_ON = 2.0, 0.50, 0.10
```

```
def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
```

```

        sp = _col(table, "sa-t-sp")
        damper = _norm_cmd(table["oa-damper-command"])
        cool = _norm_cmd(table["cooling-valve-command"])
        free = pc.less_equal(oat, pc.subtract(sp, MARGIN))
        return pc.and_(free, pc.less(damper, DAMPER_LOW),
pc.greater_equal(cool, COOL_ON))

```

28.4.3 ahu_oa_damper_excess_open_extreme_ambient (AHU-E)

```

FAULT_CODE = "AHU-E"
DAMPER_MIN, HI_OAT, LO_OAT = 0.50, 70.0, 40.0

```

```

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    extreme = pc.or_(pc.greater_equal(oat, HI_OAT),
pc.less_equal(oat, LO_OAT))
    return pc.and_(pc.greater_equal(damper, DAMPER_MIN), extreme)

```

28.5 VAV zones

28.5.1 zone_reheat_warm_ambient (VAV-A)

```

FAULT_CODE = "VAV-A"
T_CUTOFF, REHEAT_MIN = 78.0, 0.52

```

```

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    reheat = _norm_cmd(table["reheat-valve-command"])
    return pc.and_(pc.greater(oat, T_CUTOFF), pc.greater(reheat,
REHEAT_MIN))

```

28.5.2 zone_damper_valve_full_open (VAV-D)

```

FAULT_CODE = "VAV-D"
FULL_OPEN, ROLL = 97.5, 105

```

```

def apply_faults_arrow(table, cfg, context=None):
    d = _norm_cmd(table["damper-position-command"])
    hi = pc.greater(d, FULL_OPEN)
    rmin = arrow_rolling_min(d, ROLL)
    return pc.and_(hi, pc.greater(rmin, FULL_OPEN))

```


28.5.3 Zone / IAQ bounds

Use `sensor_bounds_mask(table, "zone_temp", cfg)` or `sensor_bounds_mask` with CO₂ profile — see `[sensor validation]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}#sensor-validation-bounds-flatline-rate-of-change)`.

28.6 Central plant

28.6.1 dp_below_sp_pump_max (CH-E)

```
FAULT_CODE = "CH-E"
DP_MARGIN, PMP_HI, PMP_NEAR = 2.2, 0.93, 0.06

def apply_faults_arrow(table, cfg, context=None):
    dp = _col(table, "differential-pressure")
    sp = _col(table, "differential-pressure-sp")
    pump = _norm_cmd(table["pump-speed-command"])
    return pc.and_(
        pc.less(dp, pc.subtract(sp, DP_MARGIN)),
        pc.greater_equal(pump, PMP_HI - PMP_NEAR),
    )
```

28.6.2 flow_high_pump_max (CH-B)

```
FAULT_CODE = "CH-B"
FLOW_HI, PMP_HI, PMP_NEAR = 1100.0, 0.93, 0.06

def apply_faults_arrow(table, cfg, context=None):
    flow = _col(table, "water-flow")
    pump = _norm_cmd(table["pump-speed-command"])
    return pc.and_(pc.greater(flow, FLOW_HI),
pc.greater_equal(pump, PMP_HI - PMP_NEAR))
```

28.6.3 plant_supply_temp_deadband (CH-D)

```
FAULT_CODE = "CH-D"
SP_BAND = 2.2

def apply_faults_arrow(table, cfg, context=None):
    temp = _col(table, "chilled-water-supply-temperature")
    sp = _col(table, "chilled-water-supply-temperature-sp")
    pump = _norm_cmd(table["pump-speed-command"])
    low = pc.less(temp, pc.subtract(sp, SP_BAND))
```

```

high = pc.greater(temp, pc.add(sp, SP_BAND))
return pc.and_(pc.greater(pump, 0.01), pc.or_(low, high))

```

28.6.4 chiller_excessive_runtime (CH-F)

```

from open_fdd.arrow_runtime.cookbook import arrow_rolling_mean

FAULT_CODE = "CH-F"
WINDOW, MAX_ON = 276, 264 # 5-min data ≈ 23 h window, 22 h max on

def apply_faults_arrow(table, cfg, context=None):
    on = pc.greater(_col(table, "chiller-status"),
0.5).cast(pa.float64())
    roll = arrow_rolling_mean(on, WINDOW)
    count = pc.multiply(roll, float(WINDOW))
    return pc.greater(count, float(MAX_ON))

```

28.7 Heat pumps

28.7.1 hp_discharge_cold_when_heating (HP-D)

```

FAULT_CODE = "HP-D"
MIN_SAT, ZONE_COLD, FAN_ON = 85.0, 69.0, 0.01

def apply_faults_arrow(table, cfg, context=None):
    sat = _col(table, "sa-t")
    zone = _col(table, "stat_zn-t")
    fan = _col(table, "supply-fan-status")
    return pc.and_(
        pc.greater(fan, FAN_ON),
        pc.less(zone, ZONE_COLD),
        pc.less(sat, MIN_SAT),
    )

```

28.8 Opportunistic / ventilation

28.8.1 econ_active_warm_ambient (AHU-E)

```

FAULT_CODE = "AHU-E"
T_CUTOFF, DPR_MIN = 63.0, 0.42

def apply_faults_arrow(table, cfg, context=None):

```

```

        oat = _col(table, "oa-t")
        damper = _norm_cmd(table["oa-damper-command"])
        return pc.and_(pc.greater(oat, T_CUTOFF), pc.greater(damper,
DPR_MIN))

```

28.8.2 mech_cool_when_econ_available (AHU-E)

```

FAULT_CODE = "AHU-E"
T_CUTOFF, DPR_MAX = 63.0, 0.32

```

```

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    return pc.and_(pc.less(oat, T_CUTOFF), pc.less(damper,
DPR_MAX), pc.greater(cool, 0.01))

```

28.8.3 low_oa_fraction_estimated (VAV-B)

```

FAULT_CODE = "VAV-B"
OA_MIN, GAP = 21.0, 2.2

```

```

def apply_faults_arrow(table, cfg, context=None):
    mat, rat, oat = _col(table, "ma-t"), _col(table, "ra-t"),
_col(table, "oa-t")
    fan = _norm_cmd(table["supply-fan-speed-command"])
    denom = pc.subtract(oat, rat)
    safe = pc.greater(pc.abs(denom), GAP)
    num = pc.subtract(mat, rat)
    oa_pct = pc.multiply(pc.divide(num, denom), 100.0)
    low = pc.less(oa_pct, OA_MIN)
    return pc.and_(pc.greater(fan, 0.01), safe, low)

```

28.8.4 preheat_excess_temp (AHU-B)

```

FAULT_CODE = "AHU-B"
EXCESS = 2.2

```

```

def apply_faults_arrow(table, cfg, context=None):
    pre = _col(table, "preheat-coil-leaving-air-temperature")
    sp = _col(table, "sa-t-sp")
    oat = _col(table, "oa-t")
    valve = _norm_cmd(table["preheat-valve-command"])
    hot_oa = pc.and_(
        pc.greater(oat, sp),
        pc.greater(pc.subtract(pre, oat), EXCESS),
    )

```

```

        cold_oa = pc.and_(
            pc.less(oat, sp),
            pc.greater(pc.subtract(pre, sp), EXCESS),
        )
    return pc.and_(pc.greater(valve, 0.01), pc.or_(hot_oa,
cold_oa))

```

28.9 Weather station

28.9.1 weather_temp_spike (BLD-B)

```

from open_fdd.arrow_runtime.cookbook import rate_of_change_mask

FAULT_CODE = "BLD-B"

def apply_faults_arrow(table, cfg, context=None):
    return rate_of_change_mask(
        table,
        {**cfg, "max_per_sample": 16.0, "column": "oa-t"},
        col="oa-t",
    )

```

28.9.2 weather_gust_lt_wind (BLD-B)

```

FAULT_CODE = "BLD-B"

def apply_faults_arrow(table, cfg, context=None):
    gust = _col(table, "wind-gust-speed")
    wind = _col(table, "wind-speed")
    return pc.and_(
        pc.is_valid(gust),
        pc.is_valid(wind),
        pc.less(gust, wind),
    )

```

28.9.3 RH bounds

```

from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask

FAULT_CODE = "DC-C"

def apply_faults_arrow(table, cfg, context=None):
    merged = {**cfg, "value_kind": "rh"}
    return sensor_bounds_mask(table, "relative_humidity", merged)

```

28.10 Schedule + weather gating (occupied hours)

```
from open_fdd.arrow_runtime.cookbook import _unoccupied_mask,
_fan_on_mask
```

```
FAULT_CODE = "BLD-C"
```

```
def apply_faults_arrow(table, cfg, context=None):
    """Fan running when schedule says unoccupied."""
    return pc.and(_fan_on_mask(table, cfg),
        _unoccupied_mask(table, cfg))
```

Pass occupied_start_hour, occupied_end_hour, tz_offset_hours in Rule Lab cfg.


28.11 Next steps


1. Copy a module into workspace/data/rules_py/<site>_<rule>.py
2. Bind feather columns on the Rule Lab row
3. Set fault_code metadata
4. Quick-test on 3-24 h feather window
5. Ship via setup_gl36_fdd.py or Rule Lab save

See also: [Expression cookbook]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}) · [Fault codes](#)({{ "/fault-codes/" | relative_url }}) · [Rule Lab](#)({{ "/operator-bridge/rule-lab/" | relative_url }})

29 System overview

30 System overview





30.1 Docker edge stack (production)

Three GHCR images — see [Containers\({{ "/architecture/containers/" | relative_url }}\)](#):

Container	BACnet OT	Operator LAN
bridge	No (HTTP only)	Yes, via Caddy :80 or loopback :8765
commission	Yes (host network, :47808)	No (internal :8767)
mcp-rag	No	No (internal :8090)

BACnet **polling** is not a separate container — it runs inside **commission**. The bridge only **ingests** poll CSV into feather.

30.2 Components

Layer	Responsibility
Operator Bridge	Auth, REST/WebSocket API, compiled dashboard, Rule Lab, historian ingest
BACnet commission	Who-Is, read/write (gated), scheduled poll loop → samples.csv
Historian	Feather files per point; local-first retention
FDD runner	workspace/data/rules_py/*.py on timer or POST /api/rules/batch
Model	Brick TTL + model.json bindings (fdd_input, equipment tree)
MCP RAG	Optional doc retrieval for agent tools
Caddy	

Layer	Responsibility
	Host reverse proxy :80 → bridge (typical edge)
Ollama	Optional host LLM for building insight (not required for FDD)

30.3 Deployment

IT operators: [Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }}). Modes and Caddy: Deployment modes({{ "/architecture/deployment-modes/" | relative_url }}).

30.4 Optional PyPI-only path

`pip install open-fdd ships Arrow runtime + playground lint helpers` **without** the Operator Bridge UI. Use for offline rule tests or CI. See [Appendix — Python package]({{ "/appendix/python-package/" | relative_url }}).

31 Expression cookbook (Arrow-native)

32 Expression cookbook (Arrow-native)

Reference for **Open-FDD 3.x Rule Lab**: every rule is a Python module with `apply_faults_arrow(table, cfg, context)` using `pyarrow.compute` — **no pandas, no YAML expression files, no NumPy DataFrames on the IoT edge.**

This is the **only** expression cookbook for Open-FDD 3.x. The `pandas/YAML RuleRunner` path is retired — use `Arrow apply_faults_arrow` and the operator bridge Rule Lab. Legacy GL36-style recipes map to **fixed fault codes**({{ "/fault-codes/" | relative_url }}) and `Arrow` patterns below.

Topic	Page
Full copy-paste library (GL36 A-M, VAV, plant)	<u>**Python recipes (full Arrow library)</u> ({{ "/rule-cookbook/python-recipes-arrow/"

Topic	Page
Quick templates	Arrow recipes ({{ "/rule-cookbook/arrow-recipes/"
Shared imports	[Python recipes]({{ "/rule-cookbook/python-recipes/"
Console window stats	[Lookback window]({{ "/rule-cookbook/lookback-window/"
Fault code catalog	Fault codes ({{ "/fault-codes/"
Programmatic defaults	open_fdd.arrow_runtime.sensor_catalog

32.1 Legacy → modern translation

Legacy (pandas / YAML)	Arrow-native (3.x)
type: expression + expression: string	apply_faults_arrow() in rules_py/*.py
RuleRunner.run(df, column_map=...)	Rule Lab batch on feather PyArrow table
np.maximum(a, b)	pc.max(a, b)
series.rolling(n).min()	arrow_rolling_min(vals, n) from open_fdd.arrow_runtime.windows
series.diff().abs()	arrow_abs_diff(vals, 1)
normalize_cmd(x)	pc.if_else(pc.greater(x, 1), pc.divide(x, 100), x)
params.max_temp in YAML	Module constant or cfg["bounds_high"]
flag: rule_a_flag	Rule metadata fault_code → AHU-A ... VAV-C
Numeric codes VAV-03	Letter codes VAV-C (see LEGACY_CODE_MAP in bridge)

Edge constraint: Docker / BACnet poll path never imports pandas. Central portfolio Dash may use pandas for CSV analytics only.

32.2 How Arrow rules are structured

1. **Historian columns** — Feather column names from BACnet poll (oa-t, sa-t, stat_zn-t, ...) or Brick labels via model export.
2. **Module constants** — Thresholds at top of file (bench style) or read from cfg for site tuning.

3. **apply_faults_arrow** — Returns a **boolean PyArrow array** (True = fault sample).
4. **fault_code** — Set in Rule Lab metadata; must exist in GET /api/faults/catalog.

```
import pyarrow.compute as pc
from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask

FAULT_CODE = "VAV-C" # metadata in Rule Lab UI

def apply_faults_arrow(table, cfg, context=None):
    return sensor_bounds_mask(table, "zone_temp", cfg)
```

32.2.1 Command scaling (0-1 vs 0-100 %)

BACnet often exposes **0-100** for damper/VFD commands. Scale explicitly:

```
def _norm_cmd(col):
    return pc.if_else(pc.greater(col, 1.0), pc.divide(col,
100.0), col)
```

32.2.2 Occupied hours (schedule gating)

Use `open_fdd.arrow_runtime.cookbook._unoccupied_mask` or compare local hour from timestamp column. Example: **fan on when unoccupied** → **BLD-C** / `schedule_compare`.

32.3 Sensor validation (bounds, flatline, rate of change)

Use `open_fdd.arrow_runtime.sensor_catalog.SENSOR_PROFILES` for defaults, or copy constants into `rules_py`. Tune per site in Rule Lab `cfg` or building-agent tuning brief.

32.3.1 Bounds (out of range) — oob_rolling

Sensor kind	Min	Max	Flatline tol	Max Δ / hour	Max Δ / 15 min	Typical fault code
Zone temp (°F)	55	90	0.10	4.0	2.0	VAV-C
Supply air temp	50	110	0.15	8.0	3.0	AHU-C, RTU-C

Sensor kind	Min	Max	Flatline tol	Max Δ / hour	Max Δ / 15 min	Typical fault code
Return air temp	55	95	0.10	3.0	1.5	AHU-D (also mixing)
Mixed air temp	40	110	0.15	6.0	2.5	AHU-D
Outdoor air temp	-40	130	0.10	12.0	6.0	BLD-B
Duct static (inH ₂ O)	-0.5	3.0	0.02	0.5	0.25	AHU-A
Relative humidity (%)	0	100	1.0	15.0	8.0	DC-C
Chilled water (°F)	40	90	0.10	4.0	2.0	CH-D
Hot water (°F)	70	200	0.15	6.0	3.0	CH-D
Condenser water (°F)	50	110	0.15	5.0	2.5	CH-A
CO ₂ (ppm, occupied)	400	1000	5.0	200	80	VAV-B (ventilation)
Discharge air temp	45	120	0.15	10.0	4.0	VAV-E, HP-D

Return air uses a **narrow band** vs zone/OAT because RAT should track building return conditions, not outdoor extremes. When OAT/RAT/MAT are all present, prefer **mixing envelope** (below) over RAT bounds alone.

CO₂ upper bound is an occupied ventilation target; unoccupied rules may use 400-2000 ppm per policy.

32.3.2 Flatline (stuck sensor) — flatline_1h

Default **12 samples $\approx$ 1 hour** at 5-minute poll. True when rolling max – min $\leq$ tolerance.

```

from open_fdd.arrow_runtime.cookbook import sensor_flatline_mask

def apply_faults_arrow(table, cfg, context=None):
    return sensor_flatline_mask(table, "outdoor_air_temp", cfg)
# BLD-B

```

Bench references: workspace/data/rules_py/bench_oa-t_flatline_1h.py, bench_stat_zn-t_flatline_1h.py.

32.3.3 Rate of change (spike) — rate_of_change

Flags physically impossible step changes (comms glitch, substituted value).

```
from open_fdd.arrow_runtime.cookbook import rate_of_change_mask
from open_fdd.arrow_runtime.sensor_catalog import cfg_from_profile

def apply_faults_arrow(table, cfg, context=None):
    merged = cfg_from_profile("outdoor_air_temp", cfg)
    merged["samples_per_hour"] = 12 # 5-min poll
    return rate_of_change_mask(table, merged, col="oa-t")
```

Legacy **weather_temp_spike** (spike_limit: 16 °F per step) → **BLD-B** with max_per_15min: 6 or stricter per-step limit.

32.3.4 Mixing envelope (MAT vs OAT/RAT) — mixing_envelope

Legacy GL36 **Rule B / C** and **AHU-D**. MAT should sit between OAT and RAT ($\pm$ tolerance) while fan runs.

```
from open_fdd.arrow_runtime.cookbook import mixing_envelope_mask

def apply_faults_arrow(table, cfg, context=None):
    return mixing_envelope_mask(
        table,
        {**cfg, "mixing_tol": 1.15},
        mat_col="ma-t",
        oat_col="oa-t",
        rat_col="ra-t",
        fan_col="supply-fan-speed-command",
    )
```

32.4 GL36-inspired AHU rules (legacy expression → fault code)

ASHRAE Guideline 36-style rules from the old YAML cookbook, translated to Arrow. Assign **fault_code** per row in Rule Lab.

Legacy rule	Summary	Code	Full Arrow module
Rule A — duct static low @ full fan	SP below SP	AHU-A	[Rule A]({{ "/rule-cookbook/python-recipes-arrow/"

Legacy rule	Summary	Code	Full Arrow module
	setpoint at high VFD		
Rule B — blend below band	MAT below OAT/RAT envelope	AHU-D	[Rules B & C]({ { "/rule-cookbook/python-recipes-arrow/"
Rule C — blend above band	MAT above OAT/RAT envelope	AHU-D	[Rules B & C]({ { "/rule-cookbook/python-recipes-arrow/"
Rule D — discharge cold when heating	SAT low vs MAT, heat valve open	AHU-B	[Rule D]({ { "/rule-cookbook/python-recipes-arrow/"
Rule E — SAT low, full heating	SAT below SP, valve > 90%	AHU-C	[Rule E]({ { "/rule-cookbook/python-recipes-arrow/"
Rule F — SAT/MAT mismatch econ	Econ mode, SAT $\neq$ MAT	AHU-E	[Rule F]({ { "/rule-cookbook/python-recipes-arrow/"
Rule G — ambient warm free cool	OAT > SAT SP, econ open, cool off	AHU-E	[Rule G]({ { "/rule-cookbook/python-recipes-arrow/"
Rule H — OAT/MAT mismatch econ+mech	Mech + econ, MAT $\neq$ OAT	AHU-E	[Rule H]({ { "/rule-cookbook/python-recipes-arrow/"
Rule I — OAT/MAT mismatch econ-only	Econ only, MAT $\neq$ OAT	AHU-E	[Rule I]({ { "/rule-cookbook/python-recipes-arrow/"
Rule J — discharge above blend cooling	SAT > MAT in cooling	AHU-B	[Rule J]({ { "/rule-cookbook/python-recipes-arrow/"
Rule K — discharge above SP full cool	SAT > SP, full cooling	AHU-C	[Rule K]({ { "/rule-cookbook/python-recipes-arrow/"
Rule L — cooling coil ΔT when off	CHW drop when valves closed	CH-C	[Rule L]({ { "/rule-cookbook/python-recipes-arrow/"
Rule M — heating coil ΔT when off	HW rise when valves closed	AHU-B	[Rule M]({ { "/rule-cookbook/python-recipes-arrow/"

All rules A-M have **full apply_faults_arrow modules** in Python recipes (full Arrow library)(`{{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}`).

32.5 Starter pack (VAV / AHU baseline)

Maps to legacy YAML starter filenames; use as first deploy bundle.

Legacy YAML starter	Arrow approach	Fault
01_vav_zone_temp_bounds_occupied	sensor_bounds_mask(..., "zone_temp") + occupied mask	VAV
02_vav_zone_temp_flatline_occupied	sensor_flatline_mask(..., "zone_temp") + occupied	VAV
03_vav_damper_command_extreme_flatline	flatline_1h_mask on damper cmd column	VAV
04_ahu_runtime_outside_schedule	after_hours_fan_satisfied_mask / run-hours script	BL
05_ahu_duct_static_pressure_not_maintained	[Rule A](<code>{{ "/rule-cookbook/python-recipes-arrow/" }}</code>)	rela #ru stat full- ahu
06_ahu_internal_temp_sensor_bounds	sensor_bounds_mask on SAT/MAT	AH
07_ahu_internal_temp_sensor_flatline	sensor_flatline_mask on SAT	AH

32.5.1 Economizer starters

Full modules: [economizer section](`{{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}`)#economizer-starters)
(ahu_econ_100oa_temp_tracking_fault,
ahu_mech_cooling_when_free_cooling_available,
ahu_oa_damper_excess_open_extreme_ambient).

32.6 VAV, central plant, heat pump

Full modules: [VAV](`{{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}`)#vav-zones) · Central plant(`{{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}`)#central-plant) · Heat pumps(`{{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}`)#heat-pumps).

Rolling persistence: `arrow_rolling_min + pc.and_ (replaces pandas .rolling(n).min())`.

32.7 Opportunistic / ventilation

Full modules: [Opportunistic section]({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#opportunistic-ventilation) · [Weather]({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#weather-station).

32.8 Data quality vs equipment faults

Symptom	Pattern	Code	Do not confuse with
Flatline 1h	flatline_1h	VAV-C, AHU-C, BLD-B	Equipment off / damper closed
OOB sample	oob_rolling	sensor-specific	True process excursion
Spike between polls	rate_of_change	BLD-B	Fast legitimate weather front
No new samples	stale_points	BLD-D	Equipment fault
MAT ∉ [OAT, RAT]	mixing_envelope	AHU-D	Stratification during startup

Always gate sensor faults with **fan on, valve open, or occupied** where appropriate — see [Sensor & data quality]({{ "/fault-codes/sensor-quality/" | relative_url }}).

32.9 Metric (°C) equivalents

Set `cfg["temp_unit"] = "metric"` in Rule Lab or scale constants:

Imperial	Metric (approx)
55 °F	12.8 °C
90 °F	32.2 °C
50 °F	10.0 °C
110 °F	43.3 °C
2.0 °F tol	1.1 °C
0.15 inH ₂ O	~37 Pa

open_fdd.playground.temp_units documents UI field keys for °F/°C toggle.

32.10 Binding rules to the fault catalog

1. Pick a **letter code** from `Fault_codes({{ "/fault-codes/" | relative_url }})` — never invent suffixes.
2. In Rule Lab, set **fault_code** on the rule row.
3. Batch FDD aggregates into GET `/api/faults/status` and portfolio rollup.
4. Legacy numeric codes (AHU-03) migrate via `LEGACY_CODE_MAP` in the bridge.

```
curl -s http://127.0.0.1:8765/api/faults/catalog | jq  
' .families[].codes[] | select(.code=="VAV-C") '
```

32.11 Pandas YAML → Arrow checklist (commissioning)

- ☐ Replace each type: expression YAML with a `rules_py` module
- ☐ Map inputs Brick labels → feather column names in model/poll CSV
- ☐ Set `fault_code` per rule (letter suffix)
- ☐ Run Rule Lab kit on 7-day feather window; confirm flag rate sane
- ☐ Apply `sensor_catalog` defaults; tune bounds for site climate
- ☐ Enable building-agent check-in; verify faults in portfolio rollup

Next: `Python recipes (full Arrow library)({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}) · Arrow recipes({{ "/rule-cookbook/arrow-recipes/" | relative_url }}) · Fault codes({{ "/fault-codes/" | relative_url }}) · Rule Lab({{ "/operator-bridge/rule-lab/" | relative_url }})`

33 Deployment modes

34 Deployment modes

How Open-FDD is typically run: local development, lab LAN trials, and production edge on a trusted OT/IT network. Open-FDD is designed for **building LAN or OT edge** deployment — not direct exposure to the public internet.

34.1 Mode summary

Mode	Stack	BACnet	Front door	Auth
Local dev	Compose on control machine	Optional bench simulator	127.0.0.1:8765	OFDD_AUTH_DISABLED=1 optional on loopback
Lab LAN	Three GHCR containers	Real or simulator VLAN	Caddy :80 or direct :8765	Required unless explicit insecure lab flags
Edge production	Three GHCR containers + host Caddy	OT NIC via commission	Caddy :80 or :443 → loopback bridge	Required — workspace/auth.env.local

34.2 v3 container stack (all edge modes)

Image	Role
openfdd-bridge	Operator Bridge API, dashboard, feather historian ingest
openfdd-commission	BACnet discover/read/write + poll loop
openfdd-mcp-rag	Doc-search sidecar for agent tools

openfdd-bacnet-poll is retired. BACnet polling runs inside **commission** only. Do not run the legacy poll container or openfdd-bacnet-poll systemd unit alongside Docker commission — that double-polls the OT network.

See [Containers](#)({{ "/architecture/containers/" | relative_url }}) for ports, networks, and persistence.

34.3 Caddy HTTP (typical edge)

- Caddy listens on building LAN :80
- Reverse-proxies to bridge at 127.0.0.1:8765
- Bridge stays loopback-only; operators bookmark `http://<edge-ip>/`

Bootstrap and compose: [Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }}).


34.4 Caddy TLS (OT LAN)

For HTTPS on the edge LAN (self-signed or site CA):

1. Generate certs: `./scripts/setup_caddy_certs.sh` (control machine) or site PKI
2. Start with `OFDD_CADDY_MODE=tls`
3. Trust the CA on operator PCs

Details: [TLS and certificates](#)({{ "/security/tls-and-certs/" | relative_url }}). Security headers are set by the **Operator Bridge**; Caddy adds **HSTS** only in TLS mode.

34.5 BACnet data path



The bridge thread named `bacnet_poll_worker` is **ingest only** — it does not bind BACnet.

34.6 What not to do on production edges

- Port-forward :8765 to the public internet without TLS and strong auth
- Run `docker compose down -v` or delete workspace/ on a live site
- Deploy the retired `openfdd-bacnet-poll` image alongside `commission`

34.7 Related

Topic	Page
First deploy	[Quick Start — Docker]({{ "/quick-start/docker/"
Upgrade	Updating the stack ({{ "/quick-start/updates/"
LAN security	LAN hardening ({{ "/security/lan-hardening/"
Lab example site	[Examples — GL36 lab note]({{ "/examples/acme-gl36-lab/"

35 Arrow recipes

36 Arrow recipes (default)

Open-FDD 3.0 Rule Lab rules use `apply_faults_arrow(table, cfg, context)`, `pyarrow.compute`, and **module constants** (no `config.json`).

For full GL36 A-M and plant recipes, see [Python recipes \(full Arrow library\)](#)({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}). Sensor tables: [\[Expression cookbook\]](#)({{ "/rule-cookbook/expression-cookbook/" | relative_url }}).

36.1 Simple threshold

```
import pyarrow.compute as pc

VALUE_COLUMN = "zone_temp"
MAX_ZONE_TEMP = 78.0

def apply_faults_arrow(table, cfg, context=None):
    return pc.greater(table[VALUE_COLUMN], MAX_ZONE_TEMP)
```

36.2 Supply air temp high

```
import pyarrow.compute as pc

VALUE_COLUMN = "sa-t"
HIGH_F = 75.0
```

```

def apply_faults_arrow(table, cfg, context=None):
    return pc.greater(pc.cast(table[VALUE_COLUMN], "float64"),
HIGH_F)

```

36.3 Fan commanded but no airflow

```

import pyarrow.compute as pc

```

```

FAN_CMD = "fan-cmd"
AIRFLOW = "supply-cfm"
FAN_ON = 0.5
MIN_CFM = 500.0

```

```

def apply_faults_arrow(table, cfg, context=None):
    fan_on = pc.greater(table[FAN_CMD], FAN_ON)
    low_airflow = pc.less(table[AIRFLOW], MIN_CFM)
    return pc.and_(fan_on, low_airflow)

```

36.4 Flatline (1 h rolling window)

```

import pyarrow.compute as pc
from open_fdd.arrow_runtime.windows import arrow_rolling_max,
arrow_rolling_min

```

```

VALUE_COLUMN = "oa-t"
WINDOW_SAMPLES = 12
FLATLINE_TOLERANCE = 0.1

```

```

def apply_faults_arrow(table, cfg, context=None):
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    spread = pc.subtract(arrow_rolling_max(vals, WINDOW_SAMPLES),
arrow_rolling_min(vals, WINDOW_SAMPLES))
    return pc.less_equal(pc.abs(spread), FLATLINE_TOLERANCE)

```

36.5 Sensor out of range (catalog defaults)

```

from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask

def apply_faults_arrow(table, cfg, context=None):
    return sensor_bounds_mask(table, "outdoor_air_temp", cfg) #
fault_code: BLD-B

```

36.6 Sensor flatline + spike (catalog)

```
from open_fdd.arrow_runtime.cookbook import sensor_flatline_mask,
rate_of_change_mask
from open_fdd.arrow_runtime.sensor_catalog import cfg_from_profile

def apply_faults_arrow(table, cfg, context=None):
    merged = cfg_from_profile("zone_temp", cfg)
    merged["samples_per_hour"] = 12
    flat = sensor_flatline_mask(table, "zone_temp", cfg)
    spike = rate_of_change_mask(table, merged, col="stat_zn-t")
    return pc.or_(flat, spike) # import pyarrow.compute as pc
```

Bounds table: [Expression cookbook — sensor validation]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}#sensor-validation-bounds-flatline-rate-of-change).

More templates ship in `open_fdd.playground.arrow_templates` and via GET `/api/playground/arrow-templates`.

Bench examples: `workspace/data/rules_py/bench_*.py`.

Dev kit zip layout: [Rule Lab — dev kit zip]({{ "/operator-bridge/rule-lab/" | relative_url }}#dev-kit-zip-download).

37 Python recipes (Arrow)

38 Python recipes (Arrow)

All Rule Lab Python rules use `apply_faults_arrow(table, cfg, context)` on PyArrow tables with `pyarrow.compute` and **module constants**.

See [Arrow recipes](#)({{ "/rule-cookbook/arrow-recipes/" | relative_url }}) for the canonical cookbook (flatline, spread, OOB, schedule faults).

Shared helpers live in `open_fdd.arrow_runtime.cookbook` and `open_fdd.arrow_runtime.windows`. For console validation, copy `_kit_lookback_stats` from [Lookback window helper](#)({{ "/rule-cookbook/lookback-window/" | relative_url }}).

```
from open_fdd.arrow_runtime.windows import arrow_rolling_min,
arrow_rolling_max
import pyarrow.compute as pc

VALUE_COLUMN = "oa-t"
```

```

WINDOW_SAMPLES = 12
FLATLINE_TOLERANCE = 0.1

def apply_faults_arrow(table, cfg, context=None):
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    spread = pc.subtract(arrow_rolling_max(vals, WINDOW_SAMPLES),
arrow_rolling_min(vals, WINDOW_SAMPLES))
    return pc.less_equal(pc.abs(spread), FLATLINE_TOLERANCE)

```

39 Containers

40 Containers

Open-FDD v3 edge sites run **three** GHCR containers plus optional **host** services (Caddy, Ollama). There is no separate BACnet poll container — **field BACnet polling lives in commission**.

Quick answer: Who binds BACnet UDP 47808? **openfdd-commission**. Bridge only ingests samples.csv into the feather historian.


40.1 GHCR images

Image	Compose service	Role
ghcr.io/bbartling/openfdd-bridge	bridge	Operator API, React dashboard, feather ingest
ghcr.io/bbartling/openfdd-commission	commission	BACnet discover / read / write + poll loop
ghcr.io/bbartling/openfdd-mcp-rag	mcp-rag	Doc-search sidecar for agent tools

Tag: **latest** on [GitHub Packages](#). Retired: openfdd-bacnet-poll (poll runs inside **commission**). GHCR retains only the **three newest** versions per image.

Template: `docker/compose.edge.yml` → copy to `~/open-fdd/docker-compose.yml`.

40.2 Stack diagram



40.3 Responsibilities

Concern	Container
BACnet Who-Is / read / write	commission
BACnet scheduled RPM reads	commission (bacnet_poll_loop)
CSV → feather historian	bridge (feather ingest worker — bacnet_poll_worker module name is historical)
Operator login, Rule Lab, faults UI	bridge
Agent doc search	mcp-rag

The bridge thread named `bacnet_poll_worker` is **ingest only** — it does not bind BACnet.

40.4 Network and ports (typical edge)

Endpoint	Reachable from	Notes
Caddy :80	Building LAN	

Endpoint	Reachable from	Notes
		Reverse proxy to bridge
Bridge :8765	Loopback (default)	Bind 127.0.0.1 in compose
Commission : 8767	Bridge / loopback	HTTP API for BACnet ops
Commission : 47808	OT BACnet LAN	UDP; requires network_mode: host
MCP :8090	Bridge container network	Not exposed to LAN by default

40.5 Long-lived deployment

All compose services set restart: unless-stopped. After host reboot:

```
sudo systemctl enable docker
cd ~/open-fdd && docker compose ps
```

If containers are down: `docker compose up -d` (idempotent).

See [Run with Docker images](#)({{ "/quick-start/docker/" | relative_url }}).

40.6 Persistent data

State lives on the **host** under `workspace/` (bind mount). Containers are replaceable; **backup workspace/** before image upgrades.

Path	Contents
<code>workspace/data/feather_store/</code>	Historian
<code>workspace/data/*.json</code>	Model, rules, FDD results
<code>workspace/bacnet/commissioning/</code>	<code>commission.env</code> , <code>points.csv</code>
<code>workspace/bacnet/polls/samples.csv</code>	Poll output
<code>workspace/auth.env.local</code>	Login secrets

Path	Contents
workspace/api/static/app/	Dashboard bundle (if updated separately)

40.7 Optional host services

Service	Role
Caddy	TLS or plain HTTP :80 → 127.0.0.1:8765
Ollama	Optional LLM on :11434 (not in the three-image stack)
FDD loop timer	Optional openfdd-fdd-loop.timer on host (docker exec batch)

41 Lookback window helper

42 Lookback window helper

Rules that depend on **time history** (flatline, spread, streaks, trim/respond validation) should print a clear window summary in the Rule Lab console or local run_test.py output.

42.1 Recommended pattern (copy into rule.py)

Use module constants for the lookback you intend; the bridge passes the full feather window into apply_faults_arrow based on batch lookback_hours (default **1 h** on the scheduled loop; **24 h** when using **Update all records** with chunks).

```
import pyarrow.compute as pc

LOOKBACK_HOURS = 3 # tune: 1, 3, 6, 12, 24

def _kit_lookback_stats(table, *, hours=None):
    """Dev helper – prints row count, timestamp span, and
    configured lookback."""
    h = hours if hours is not None else LOOKBACK_HOURS
```



```

        if "timestamp" not in table.column_names:
            print(f"lookback={h}h rows={table.num_rows} (no timestamp
column)")
            return
        ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
        tmin = pc.min(ts).as_py()
        tmax = pc.max(ts).as_py()
        if tmin is None or tmax is None:
            print(f"lookback={h}h rows={table.num_rows} start=None
stop=None span=0.00h")
            return
        span_h = (tmax - tmin).total_seconds() / 3600.0
        print(
            f"lookback={h}h rows={table.num_rows} "
            f"start={tmin.isoformat()} stop={tmax.isoformat()}
span={span_h:.2f}h"
        )

    def _kit_value_stats(table, column):
        vals = pc.cast(table[column], "float64")
        print(
            f"column={column} min={pc.min(vals).as_py():.2f} "
            f"max={pc.max(vals).as_py():.2f}
mean={pc.mean(vals).as_py():.2f}"
        )

    def apply_faults_arrow(table, cfg, context=None):
        _kit_lookback_stats(table)
        _kit_value_stats(table, "oa-t")
        # ... fault logic ...

```

42.2 Why not hide this behind a library call yet?

A future `open_fdd.arrow_runtime.kit.lookback_stats(table, hours=3)` helper is reasonable once the Algorithms tab shares the same kit export path. For now, keeping the helper **inline in rule.py** matches the constants-first Rule Lab style and prints the same fields in:

- Local `run_test.py`
- Rule Lab **Quick test** console
- Batch run logs

42.3 Lookback vs rolling samples

Concept	Controlled by	Typical use
Historian lookback	Batch lookback_hours, FDD loop env	How many rows are in table
Rolling window	WINDOW_SAMPLES constant (~12 ≈ 1 h @ 5 min poll)	Flatline, spread, consecutive-true

Always call `_kit_lookback_stats(table)` first so operators can confirm the table span matches expectations before interpreting rolling-window faults.

42.4 Batch intervals

Trigger	Default lookback
openfdd-fdd-loop / OFDD_FDD_INTERVAL_MINUTES	1 h
Rule Lab Update all records	24 h (chunk_hours: 6, use_chunks: true)
Rule Lab Quick test	3 h (UI default)

See [Windowing & debugging](#)({{ "/rule-cookbook/windowing-debugging/" | relative_url }}) for `arrow_rolling_min / arrow_consecutive_true`.

43 Data flow

44 Data flow

44.1 Telemetry ingest

Open-FDD supports three commissioning drivers. Each appends long-format samples to workspace CSVs and writes **feather shards** tagged by source (bacnet, modbus, json_api).

44.1.1 BACnet

1. **Commission poll loop** (inside the commission container) reads enabled BACnet points from `points.csv` on a schedule (host network, BACnet :47808).

2. RPM results append to workspace/bacnet/polls/samples.csv.
3. **Bridge ingest worker** loads new rows into feather_store/bacnet/.

BACnet devices → commission (poll loop) → samples.csv → bridge (ingest) → feather_store/bacnet

44.1.2 Modbus TCP

1. Operator configures registers on the **Modbus** tab (or read_and_store API).
2. Poll worker reads holding/input registers via Modbus TCP.
3. Samples append to workspace/modbus/polls/samples.csv → feather_store/modbus/.

44.1.3 JSON API (HTTP/HTTPS)

1. Operator configures REST endpoints on the **JSON API** tab — GET/POST, Bearer or Basic auth, \${ENV:VAR} placeholders from json_api.env.local, optional TLS verify off for self-signed OT gateways.
2. Poll worker issues HTTP requests (one GET can fan out to multiple JSON paths, e.g. OpenWeather web-oat-t / web-rh / web-weather-desc).
3. Samples append to workspace/json_api/polls/samples.csv → feather_store/json_api/.
4. FDD batch **merges** json_api columns with BACnet/Modbus on the same site (nearest timestamp, 30 min tolerance) for cross-source rules.

OT REST / weather API → bridge JSON API worker → samples.csv → feather_store/json_api

↘ merged

into FDD frame with bacnet/modbus

Showcase: [OpenWeatherMap bundle]({{ "/drivers/json-api/" | relative_url }})#openweathermap-showcase-recommended-demo).
 Details: Driver framework({{ "/drivers/" | relative_url }}),
 [BACnet polling]({{ "/bacnet/polling/" | relative_url }}), JSON API driver({{ "/drivers/json-api/" | relative_url }}), Containers({{ "/" | architecture/containers/" | relative_url }}).

44.2 Rule evaluation

1. Rules are Python files in workspace/data/rules_py/ with metadata in rules_store.json.
2. **Bindings** map rules to points via the Brick model (fdd_input tags).
3. Batch runner (POST /api/rules/batch or host timer) produces fdd_results.json.

4. Dashboard **faults** view and check-engine status read aggregated results.

44.3 Model sync

- Commissioning imports update `model.json` / TTL graph.
- `POST /api/model/sync-ttl` refreshes SPARQL-backed tree used by the UI.

44.4 Retention

Feather files grow on disk; retention is configurable (`workspace/data.env.local`). Image upgrades must **preserve** `workspace/data/` — `backup` before `docker compose up -d --force-recreate`. See [Updating the stack](#)(`{{ "/quick-start/updating/" | relative_url }}`).

45 Architecture

46 Architecture

Open-FDD v3 edge: **three Docker containers** (`bridge`, `commission`, `mcp-rag`), BACnet polling in **commission**, feather ingest in **bridge**, optional host Caddy and Ollama.

Page	Topic
System overview (<code>{{ "/architecture/overview/" relative_url }}</code>)	
Deployment modes (<code>{{ "/architecture/deployment-modes/" relative_url }}</code>)	
Data flow (<code>{{ "/architecture/data-flow/" relative_url }}</code>)	
Containers (<code>{{ "/architecture/containers/" relative_url }}</code>)	
Driver framework (<code>{{ "/drivers/" relative_url }}</code>)	

Operators: `[Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }})` — no git clone on the edge host.

BACnet polling: `Polling({{ "/bacnet/polling/" | relative_url }})` — commission container only.

47 Rule Cookbook

48 Rule Cookbook

Practical patterns for **Arrow-native Rule Lab**
(`apply_faults_arrow`) on feather historian PyArrow tables — **no pandas on the IoT edge**.

Page	Use when
[Python recipes (full Arrow library)] (<code>{{ "/rule-cookbook/python-recipes-arrow/"</code>	<code>relative_url }}</code>)
[Expression cookbook (Arrow-native)] (<code>{{ "/rule-cookbook/expression-cookbook/"</code>	<code>relative_url }}</code>)
<u>Arrow recipes</u> (<code>{{ "/rule-cookbook/arrow-recipes/"</code>	<code>relative_url }}</code>)
[Python recipes] (<code>{{ "/rule-cookbook/python-recipes/"</code>	<code>relative_url }}</code>)
<u>Lookback window helper</u> (<code>{{ "/rule-cookbook/lookback-window/"</code>	<code>relative_url }}</code>)
<u>Windowing & debugging</u> (<code>{{ "/rule-cookbook/windowing-debugging/"</code>	<code>relative_url }}</code>)
<u>GL36 algorithm stubs</u> (<code>{{ "/rule-cookbook/gl36-algorithm-stubs/"</code>	<code>relative_url }}</code>)

Programmatic sensor defaults:
`open_fdd.arrow_runtime.sensor_catalog.SENSOR_PROFILES.`

```

import pyarrow.compute as pc
from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask

def apply_faults_arrow(table, cfg, context=None):
    return sensor_bounds_mask(table, "zone_temp", cfg) #
fault_code: VAV-C

```

Future graph ML (sklearn / PyG) runs in a separate training service — see [GitHub issue #211](#).

49 Windowing & debugging

50 Windowing & debugging

50.1 Lookback vs rolling window

	Historian lookback	Rolling window
Set by	Batch lookback_hours, FDD loop, Quick test UI	WINDOW_SAMPLES constant in rule.py
Typical	1 h scheduled; 24 h Update all	12 samples $\approx$ 1 h @ 5 min poll
Validate with	<code>_kit_lookback_stats(table)</code> — see Lookback window helper (<code>{{ "/rule-cookbook/lookback-window/"</code>	<code>relative_url }}</code>)

50.2 Rolling windows (Arrow)

Use `open_fdd.arrow_runtime.windows` for sample-based rolling min/max and consecutive-true streaks:

```

from open_fdd.arrow_runtime.windows import arrow_rolling_min,
arrow_rolling_max, arrow_consecutive_true

```

Cookbook masks (`flatline_1h_mask`, `spread_1h_mask`, `oob_mask`) default to ~ 12 samples (~ 1 h at 5 min poll).

Bench rules use constants: `WINDOW_SAMPLES`, `FLATLINE_TOLERANCE`, `OAT_LOW` / `OAT_HIGH`, etc. Legacy `cfg` keys still work for uploaded rules that read `cfg.get(...)`.

50.3 Rule Lab console

Quick-test and batch responses include backend: arrow, ms, and flagged row counts. Arrow summary events appear in the event console on fault hits.

51 GL36 algorithm stubs

52 GL36 algorithm stubs (doc-only)

Draft **supervisory** PyArrow patterns for the future Algorithms tab. These mirror Niagara GL36 blocks documented in:

README_TRIM_RESPOND.md

FDD rules return **fault masks**. Algorithms return **setpoints or request integers** — the stubs below use `apply_algorithm_arrow` as the planned entrypt. For early testing in Rule Lab, you can adapt the logic into advisory FDD rules (boolean “sequence unhealthy” flags).

52.1 Shared lookback helper

```
import pyarrow.compute as pc

LOOKBACK_HOURS = 6

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")
```

52.2 VAV zone cooling requests (0-3)

Simplified from GL36 VAV box request generator — zone temp vs cooling setpoint bands.

```
"""GL36 VAV cooling requests – doc stub."""

import pyarrow.compute as pc

ZONE_TEMP = "zn-t"
ZONE_SP = "zn-t-sp"
ZONE_DEMAND = "zn-cool-loop"
HIGH_DIFF_F = 5.0
MED_DIFF_F = 3.0
LOOP_ON = 95.0
LOOP_OFF = 85.0

def apply_algorithm_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    tz = pc.cast(table[ZONE_TEMP], "float64")
    sp = pc.cast(table[ZONE_SP], "float64")
    diff = pc.subtract(tz, sp)
    demand = pc.cast(table[ZONE_DEMAND], "float64")
    # Last row request level for kit demo (full port needs timer
state)
    last_diff = diff[-1].as_py() if table.num_rows else 0.0
    last_demand = demand[-1].as_py() if table.num_rows else 0.0
    if last_diff >= HIGH_DIFF_F:
        req = 3
    elif last_diff >= MED_DIFF_F:
        req = 2
    elif last_demand > LOOP_ON:
        req = 1
    else:
        req = 0
    print(f"cooling_requests={req} dT={last_diff:.1f}F
loop={last_demand:.0f}%")
    return {"cooling_requests": req}
```

52.3 AHU duct static trim & respond (advisory fault)

Detect **duct static stuck high** while VAV pressure requests are low — trim & respond may not be trimming.

```
"""AHU duct static trim advisory – doc stub."""

import pyarrow.compute as pc
```



```

DUCT_SP = "duct-static"
DUCT_SP_MAX = 1.50
DUCT_SP_TRIM_TARGET = 0.80
VAV_PRESS_REQ_SUM = "vav-press-req-sum"
LOOKBACK_HOURS = 12

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table, hours=LOOKBACK_HOURS)
    sp = pc.cast(table[DUCT_SP], "float64")
    reqs = pc.cast(table[VAV_PRESS_REQ_SUM], "float64")
    stuck_high = pc.and_(pc.greater(sp, DUCT_SP_TRIM_TARGET),
pc.less(reqs, 1.0))
    return pc.and_(stuck_high, pc.greater(sp, DUCT_SP_MAX * 0.9))

```

52.4 Chiller plant enable (valve request counting)

From GL36 §5.18.15.2 — count AHUs with CHW valve above threshold.

```

"""Chiller plant enable advisory – doc stub."""

import pyarrow.compute as pc

AHU_VALVE_COLS = ["ahu1-clg-vlv", "ahu2-clg-vlv", "ahu3-clg-vlv"]
REQ_THRESH = 95.0
DIS_THRESH = 10.0
MIN_AHUS_REQ = 2

def apply_algorithm_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    requesting = 0
    for col in AHU_VALVE_COLS:
        if col not in table.column_names:
            continue
        v = pc.cast(table[col], "float64")[-1].as_py()
        if v >= REQ_THRESH:
            requesting += 1
    enable = requesting >= MIN_AHUS_REQ
    print(f"chiller_enable={enable} requesting_ahus={requesting}/
{MIN_AHUS_REQ}")
    return {"chiller_enable": enable, "requesting_ahus":
requesting}

```

52.5 Hot water plant HWST trim & respond (advisory)

Flags **HWST trimmed too low** while heating requests remain high.

```
"""HWST trim advisory – doc stub."""

import pyarrow.compute as pc

HWST = "hw-supply-t"
HWST_SP = "hw-supply-t-sp"
HEAT_REQ_SUM = "hw-reset-req-sum"
LOW_HWST_F = 120.0
LOOKBACK_HOURS = 6

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table, hours=LOOKBACK_HOURS)
    temp = pc.cast(table[HWST], "float64")
    reqs = pc.cast(table[HEAT_REQ_SUM], "float64")
    return pc.and_(pc.less(temp, LOW_HWST_F), pc.greater(reqs,
2.0))
```

52.6 Chilled water plant (DP + CHWST reset advisory)

Flags **CHWST at design cold** with low cooling requests — possible stuck 100% plant loop.

```
"""CHW plant reset advisory – doc stub."""

import pyarrow.compute as pc

CHWST = "chw-supply-t"
CHWST_DESIGN_COLD_F = 44.0
COOL_REQ_SUM = "chw-reset-req-sum"
LOOKBACK_HOURS = 6

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table, hours=LOOKBACK_HOURS)
    temp = pc.cast(table[CHWST], "float64")
    reqs = pc.cast(table[COOL_REQ_SUM], "float64")
    return pc.and_(pc.less(temp, CHWST_DESIGN_COLD_F + 1.0),
pc.less(reqs, 1.0))
```

52.7 Testing later

1. Bind historian columns in **Model & assignments** (fdd_input / brick types).
2. Copy a stub into Rule Lab as an FDD advisory rule, or wait for the **Algorithms** tab kit export.
3. Run `python run_test.py` from a downloaded kit and confirm `_kit_lookback_stats` prints expected start / stop / span.

Reference implementation (Niagara Java):
[README_TRIM_RESPOND.md](#).

53 Central plants (CHW / CTW / BLR)

54 Central plant Arrow recipes

Chiller plant, condenser water, cooling tower, boiler, and hot-water distribution faults use the same Arrow-native primitives as air-side rules.

54.1 Starter fault codes

Code	Primitive	Recipe
CHW-DT-001	<code>low_delta_t_mask</code>	Low chilled-water ΔT syndrome
CHW-DP-001	<code>reset_stuck_mask</code>	CHW differential pressure reset stuck high

54.2 Required point roles (CHW)

- `chw_supply_temp`, `chw_return_temp` — ΔT rules
- `chw_dp`, `chw_dp_setpoint` — reset stuck rules
- `pump_command`, `pump_feedback` — command/feedback mismatch

54.3 Synthetic test pattern

```
import pyarrow as pa
from open_fdd.arrow_runtime.primitives import low_delta_t_mask

table = pa.table({
    "chw_supply_temp": [44.0] * 10,
    "chw_return_temp": [44.5] * 10,
})
mask = low_delta_t_mask(
    table,
    {"min_delta_t": 4.0},
    supply_col="chw_supply_temp",
    return_col="chw_return_temp",
)
assert mask.to_pylist()[-1] is True
```

See [Fault codes — chiller plant]({{ "/fault-codes/" | relative_url }}) (expanded in 3.0.19).

55 Dashboard overview

56 Dashboard overview

56.1 Primary areas

Area	Purpose
Home / Building insight	Check-engine status; fault cards show equipment, rule, point, historian column, BACnet
Trends	Point history from feather store
Faults	Rule hits grouped by equipment family
Rule Lab	Edit, lint, and test Python FDD rules (PyArrow kit zip)
Algorithms	Supervisory GL36 trim & respond (coming soon)
Model & assignments	Equipment tree, FDD rule pins, commissioning JSON
BACnet	Discovery, reads, commission workflows

Area	Purpose
Settings / health	Stack status, auth mode

56.2 Live updates

Dashboard tiles use REST polling and WS `/ws/dashboard` for selected live views (ticket auth via POST `/api/auth/ws-ticket`).

56.3 Roles

Read-only operators see trends and faults; integrators access Rule Lab and model import. See `Auth and roles({ { "/operator-bridge/auth-roles/" | relative_url } })`.

57 Auth and roles

58 Auth and roles

58.1 Production (LAN / edge)

- Set `OFDD_AUTH_SECRET` and role passwords in `workspace/auth.env.local`.
- Bridge on non-loopback addresses **requires** auth unless explicit insecure dev flags are set (lab only).

Role	Typical access
viewer	Read trends, faults, model tree
operator	Run batch FDD, acknowledge views
integrator	Rule Lab, bindings, model import
commission	BACnet writes (plus write guard)
agent	Agent tools / app-edit gates
admin	Full configuration

Login: POST `/api/auth/login` → Bearer JWT on API calls.

58.2 Localhost dev

OFDD_BRIDGE_HOST=127.0.0.1 with OFDD_AUTH_DISABLED=1 is acceptable on a single machine. **Never** use auth-disabled mode on a building LAN.

Full hardening: `Security({ { "/security/" | relative_url } })`.

59 Rule Lab

60 Rule Lab

Rule Lab authors **Arrow-native** Python FDD rules against the feather historian.

60.1 Equipment-scoped test and export

Use **Equipment-scoped test & export** on Rule Lab:

1. Select site, equipment, and sensor (point).
2. **Test selected rule** or **Test all for equipment** against recent feather data.
3. **Download equipment kit** — zip with manifest.json, equipment.json, points.json, per-rule samples, expanded helper source, and commissioning export subset.

API: GET /api/rules/export-equipment-kit?equipment_id=... · expanded helpers: GET /api/playground/rules/{id}/source-expanded.

60.2 Export all rules

Integrators can download **Export all rules** — one zip with per-rule kits, manifest.json, catalog snapshots, and model TTL. API: GET /api/rules/export-all-kit. Bench rules use **module constants** at the top of rule.py — no browser config panel, no config.json in the dev kit zip.

```
"""Bench OA-T out of bounds (Arrow)."""
```

```
import pyarrow.compute as pc
```

```
VALUE_COLUMN = "oa-t"
```

```
OAT_LOW = 68.0
```

```
OAT_HIGH = 88.0
```

```

LOOKBACK_HOURS = 1

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

def _kit_value_stats(table):
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    print(
        f"column={VALUE_COLUMN} min={pc.min(vals).as_py():.2f} "
        f"max={pc.max(vals).as_py():.2f}
mean={pc.mean(vals).as_py():.2f}"
    )

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    _kit_value_stats(table)
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    return pc.or_(pc.less(vals, OAT_LOW), pc.greater(vals,
OAT_HIGH))

```

60.3 Workflow

1. **Download kit** — PyArrow zip (see below)
2. **Edit constants** locally (VALUE_COLUMN, limits, LOOKBACK_HOURS, WINDOW_SAMPLES)
3. **Run** `pip install -r requirements.txt` then `python run_test.py`
4. **Upload** rule.py on Rule Lab (integrator)

Upload validation (Phase B): AST parse, forbidden imports, `apply_faults_arrow(table, cfg, context=None)` signature.

The bridge runs rules on **PyArrow tables** via `open_fdd.arrow_runtime`, and persists .py sources under `workspace/data/rules_py/`.

- **Quick test** — `POST /api/playground/test-rule` (default 3 h lookback)
- **Batch** — `POST /api/rules/batch / openfdd-fdd-loop timer (1 h default lookback)`
- **Update all records** — 24 h lookback, 6 h chunks (`use_chunks: true`)

- **Templates** — GET /api/playground/arrow-templates

Pin points to rules via **Model & assignments** (/model) commissioning JSON or BACnet tree right-click. Export shows Rule Lab **names** on each point (fdd_rules_linked); import uses rule **ids** (fdd_rule_ids).

Bench seed: python3 scripts/setup_bench_afdd.py — imports bench_import_model.json and bench cookbook rules with matching id/name pairs.

60.4 Dev kit zip (download)

Download kit on Rule Lab exports openfdd-rule-kit-<rule_id>.zip with:

File	Purpose
rule.py	Arrow rule + constants at top; optional _kit_lookback_stats / _kit_value_stats helpers
data.py	SITE_ID, LOOKBACK_HOURS, load_table() reading sample.feather
sample.feather	Full historian window for the kit lookback (all rows, not a CSV preview)
run_test.py	Runs rule.apply_faults_arrow(table, {}, context=...) and prints flagged=N
requirements.txt	open-fdd>=3.0.1 and pyarrow
README.md	Install and run instructions
column_map.json	BRICK logical keys → feather column names
kit_meta.json	Export metadata (site, columns, row count, lookback hours)

Not included: config.json (retired — tune thresholds as Python constants).

Local test:

```
unzip openfdd-rule-kit-*.zip
cd openfdd-rule-kit-*
pip install -r requirements.txt
python run_test.py
```

Expected console output:

```
site=demo lookback_h=3 rows=...
lookback=3h rows=... start=... stop=... span=2.98h
```


column=oa-t min=... max=... mean=...
flagged=...

60.5 Lookback windows

Rules that need multi-hour history should call `_kit_lookback_stats(table)` (see [Lookback window helper](#)({{ `"/rule-cookbook/lookback-window/"` | `relative_url` }})). Pass `hours=1, 3, 6, 12, or 24` to validate timestamp span in the console.

Rolling-window rules (flatline, spread) use `WINDOW_SAMPLES` (~12 samples $\approx$ 1 h at 5 min poll) — see [Windowing & debugging](#)({{ `"/rule-cookbook/windowing-debugging/"` | `relative_url` }}).

60.6 Algorithms (supervisory — coming soon)

GL36 trim & respond and plant reset sequences will live on the [Algorithms](#)({{ `"/operator-bridge/algorithms/"` | **`relative_url`** }}) tab with the same zip kit shape but `apply_algorithm_arrow` outputs. Reference: [README_TRIM_RESPOND](#).

60.7 Related

- [Model workflow](#)({{ `"/operator-bridge/model-workflow/"` | `relative_url` }})
- [Arrow recipes](#)({{ `"/rule-cookbook/arrow-recipes/"` | `relative_url` }})
- [GL36 algorithm stubs](#)({{ `"/rule-cookbook/gl36-algorithm-stubs/"` | `relative_url` }}) (doc-only)

61 JSON API driver

62 JSON API driver

Poll **HTTP or HTTPS** REST endpoints on the OT LAN (or public APIs such as [OpenWeatherMap](#)) and store extracted JSON values in the feather historian (`source=json_api`).

Use this driver for gateways, micro-PLCs, IoT hubs, vendor APIs, and **web weather** when you want to cross-check shaky local outdoor-air sensors against a reference.

62.1 Supported features

Feature	Support
Methods	GET, POST
Transport	http:// and https://
TLS certificate verify	On by default; disable for self-signed OT gateways
Authentication	None, Bearer token , HTTP Basic , or query-string API keys via env
Env placeholders	\${ENV:VAR} or \${VAR} in URL, headers, body, bearer token
Custom headers	Optional headers map (merged with auth headers)
Value extraction	Dot-path into JSON body (title, main.temp, weather.0.description)
Multi-extract poll	One HTTP request per URL group; fan-out to multiple json_path rows
Polling	1 / 5 / 15 / 30 min or 1 hour (shared with BACnet/Modbus)
Historian	workspace/json_api/polls/samples.csv → feather_store/json_api/
FDD merge	Scheduled FDD merges bacnet + modbus + json_api columns by nearest timestamp

62.2 Secrets: json_api.env.local

Copy workspace/json_api.env.example → workspace/json_api.env.local (gitignored). The bridge loads this file at startup and when run_local.sh starts the stack.

Use placeholders in commissioning URLs so API keys never land in git:

```
https://api.openweathermap.org/data/2.5/weather?q=$
{ENV:OPENWEATHER_CITY}&appid=${ENV:OPENWEATHER_API_KEY}&units=$
{ENV:OPENWEATHER_UNITS}
```

Check which vars are configured: GET /api/json-api/env/status.

62.3 OpenWeatherMap showcase (recommended demo)

This is the flagship example of what the generic JSON API driver can do — **one URL, three historian columns**, env-based API key, browser tree like BACnet/Modbus.

62.3.1 1. Configure env

```
cp workspace/json_api.env.example workspace/json_api.env.local
# Edit: OPENWEATHER_API_KEY, OPENWEATHER_CITY, OPENWEATHER_UNITS
(imperial = °F)
```

Restart the bridge (or ./scripts/run_local.sh restart) so env vars load.

62.3.2 2. Register from the UI

1. Sign in as **integrator** → **JSON API** tab.
2. Open the **OpenWeatherMap showcase** panel.
3. Use the **OpenWeatherMap** preset → **Register** (default poll 30 min; choose interval in the form).

Three endpoints appear under api.openweathermap.org in the commissioning tree:

Label	JSON path	Historian column	Units
web-oat-t	main.temp	web-oat-t	degF / degC
web-rh	main.humidity	web-rh	%
web-weather-desc	weather.0.description	web-weather-desc	text

Poll worker deduplicates: **one GET** serves all three extractions per cycle.

62.3.3 3. Headless / script

```
# Standalone fetch (like the original playground tester)
python3 scripts/openweather_json_api_example.py
```

```
# Register via REST (integrator login)
python3 scripts/openweather_json_api_example.py --register --base
http://127.0.0.1:8000
```

62.3.4 4. FDD: local OA-T vs web weather

With BACnet oa-t and JSON API web-oat-t in the merged site frame, scheduled FDD compares local outdoor air to the weather service.

Item	Detail
Rule module	oat_vs_web_spread_1h.py
Fault code	BLD-B (outdoor air sensor fault)
Default threshold	oa-t - web-oat-t > 8 °F (max_spread_f in rule cfg)
Acme rule id	acme-oat-vs-web-spread (via setup_gl36_fdd.py)
Local OAT source	RTU 1100-unknown-2 (Outdoor Air Temperature Local) — same value as boiler/AHU networked OAT
Web column	web-oat-t from OpenWeather bundle

Model alias: local BACnet historian column must be oa-t:

```
python3 scripts/acme_patch_oat_column.py --point-id 1100-
unknown-2 --host "$ACME_HOST" --token "$TOKEN"
```

Or set external_id / fdd_input to oa-t on the chosen
Outside_Air_Temperature_Sensor in the model.

Units: keep OPENWEATHER_UNITS=imperial when BACnet OAT is °F.

Enable the rule in Rule Lab (or setup_gl36_fdd.py push) and run an
FDD batch. Missing either column → rule returns all-false (no
crash).

62.4 Commissioning (UI)

The **JSON API** tab follows [Home Assistant sensor.rest](#):

1. Sign in → **RESTful sensor (JSON API)** tab.
2. Pick a **preset** (JSONPlaceholder, DummyJSON, httpbin, Open-Meteo, OpenAQ, OpenWeather) or enter a **resource URL**.
3. Add one or more **sensors** — each row is a value_json_path +
historian **label** (multi-value from one GET, like HA
json_attributes).

4. Click **Test resource** — probes without saving; shows extracted values and raw JSON.
5. Click **Register & poll** — writes endpoints.csv, enables polling at the selected interval.
6. Poll choices match BACnet/Modbus: **1 / 5 / 15 / 30 min** or **1 hour**.

62.4.1 API for agents

Endpoint	Purpose
GET /api/json-api/presets	Full preset catalog + poll intervals (human + AI readable)
POST /api/json-api/test	Probe resource + multi-sensor extraction
POST /api/json-api/register-bundle	Register one resource with many sensors
POST /api/json-api/presets/{id}/register	One-click preset registration

62.4.2 Bench preset

Use **JSONPlaceholder** — **todo title** → **Test resource** to verify outbound HTTPS without field hardware.

62.5 Authentication examples

62.5.1 Query-string API key via env (OpenWeather)

```
{
  "url": "https://api.openweathermap.org/data/2.5/weather?q=${ENV:OPENWEATHER_CITY}&appid=${ENV:OPENWEATHER_API_KEY}&units=${ENV:OPENWEATHER_UNITS}",
  "method": "GET",
  "json_path": "main.temp",
  "label": "web-oat-t",
  "auth_type": "none"
}
```

62.5.2 Bearer token (API key)

```
{
  "url": "https://192.168.10.50/api/v1/status",
  "method": "GET",
  "json_path": "sensors.zone_temp",
  "label": "zone-temp",
}
```

```

    "auth_type": "bearer",
    "bearer_token": "${ENV:GATEWAY_API_KEY}",
    "verify_tls": false
}

```

62.5.3 HTTP Basic

```

{
  "url": "http://192.168.10.50/data.json",
  "method": "GET",
  "json_path": "value",
  "label": "sensor-value",
  "auth_type": "basic",
  "basic_user": "operator",
  "basic_password": "changeme"
}

```

62.5.4 POST with JSON body

```

{
  "url": "https://gateway.local/api/read",
  "method": "POST",
  "json_path": "result.pv",
  "label": "pv",
  "body": { "point": "AHU-1_SAT", "command": "read" },
  "auth_type": "bearer",
  "bearer_token": "..."
}

```

Credentials in endpoints.csv are redacted in API responses (***).
Prefer \${ENV:...} for production keys.

62.6 REST API

Method	Path	Role	Description
GET	/api/json-api/ env/status	operator+	Which env vars are configured (no secret values)
POST	/api/json-api/ presets/ openweather	integrator+	Register 3-point OpenWeather bundle + optional poll
GET	/api/json-api/ driver/tree	operator+	Commissioning tree grouped by host
GET	/api/json-api/ poll/status	operator+	Poll worker status
POST		integrator+	Run one poll cycle

Method	Path	Role	Description
	/api/json-api/poll/once		
POST	/api/json-api/request	operator+	One-shot HTTP request (no store)
POST	/api/json-api/read_and_store	integrator+	Request + CSV + feather ingest
POST	/api/json-api/refresh	operator+	Re-fetch one endpoint
PATCH	/api/json-api/endpoint/poll	integrator+	Enable/disable poll interval
DELETE	/api/json-api/endpoint/{point_id}	integrator+	Remove endpoint

Full route list: `API routes({ { "/appendix/bridge_api/" | relative_url } })`.

62.7 Typical OT URLs

Device type	Example URL	Notes
Web weather	<code>https://api.openweathermap.org/data/2.5/weather?...</code>	Env-based appid; 3 historian columns
Gateway status	<code>http://192.168.1.50/api/status</code>	Often plain HTTP on LAN
HTTPS BMS API	<code>https://10.0.0.12/rest/points/zone1</code>	May need <code>verify_tls: false</code>
Local mock	<code>https://jsonplaceholder.typicode.com/todos/1</code>	Bench / CI only

62.8 Limitations

- Response body must be **JSON** (not XML or plain text).
- Numeric paths (e.g. `main.temp`) are stored as strings in poll CSV; FDD rules cast with `pc.cast(..., "float64")`.
- Outbound requests originate from the **bridge** container/host — ensure routing and firewall rules allow the edge box to reach the target (OT subnet or public internet for weather).

62.9 Disable polling (save API quota)

Stop scheduled calls without deleting endpoints: JSON API tree → select OpenWeather points → **Stop polling**, or integrator API:

```
curl -X PATCH http://127.0.0.1:8765/api/json-api/endpoint/poll \
-H "Authorization: Bearer $TOKEN" \
-d '{"point_id":"ja-api-openweathermap-org-get-web-oat-
t","enabled":false,"poll_interval_s":0}'
```

API keys live in `json_api.env.local` (gitignored) — never committed; audit logs do not record expanded URLs with `appid=`. See [Logging and audit](#)({{ "/ops/logging/" | relative_url }}).

62.10 Smoke test

```
python3 scripts/smoke_multi_driver_stack.py
```

Validates JSON API ingest alongside BACnet and Modbus, feather isolation, BRICK scope, and FDD batch.

63 Algorithms

64 Algorithms (coming soon)

The **Algorithms** dashboard tab (`/algorithms`) is a placeholder for **supervisory Python sequences** — the mirror image of Rule Lab FDD:

	FDD (Rule Lab)	Algorithms (planned)
Purpose	Detect faults	Compute setpoints, request levels, plant enables
Entrypoint	<code>apply_faults_arrow(table, cfg, context)</code>	<code>apply_algorithm_arrow(table, cfg, context)</code> (planned)
Output	Boolean fault mask	Numeric outputs / structured dict
Historian	Same feather_store PyArrow tables	Same

Until the tab ships, draft patterns live in this doc and in [GL36 algorithm stubs](#)({{ "/rule-cookbook/gl36-algorithm-stubs/" | relative_url }}).

64.1 GL36 Trim & Respond reference

Open-FDD algorithms will follow the same ASHRAE Guideline 36 trim & respond methodology already implemented for Niagara in:

README_TRIM_RESPOND.md

That guide covers:

- VAV zone request generators (cooling + static pressure)
- AHU duct static pressure reset
- AHU supply air temperature reset
- Central plant chiller / boiler enable and HWST / CHWST trim & respond

Porting those blocks to PyArrow is in progress; the dashboard tab shows **COMING SOON** until upload, batch, and BACnet write paths are wired.

64.2 Planned workflow (same kit shape as Rule Lab)

1. Download **algorithm kit** zip from the Algorithms tab (future)
2. Edit **constants** at the top of algorithm.py (no config.json)
3. Run `python run_test.py` locally against `sample.feather`
4. Upload algorithm.py when satisfied

Kit files will match the Rule Lab zip layout (see [Rule Lab — dev kit zip]({{ "/operator-bridge/rule-lab/" | relative_url }}#dev-kit-zip-download)).

64.3 Lookback windows

Rules and algorithms that need multi-hour history should use the shared **lookback stats helper** documented in [Lookback window helper](#)({{ "/rule-cookbook/lookback-window/" | relative_url }}).

Pass `hours=1, 3, 6, 12, or 24` to print row count, timestamp start/stop, and span for console validation.

Scheduled batch defaults: **1 h** lookback on the FDD loop; **Update all records** in Rule Lab uses **24 h** with 6 h chunks.

64.4 AHU supervisory checks (doc-only stubs)

These are **not** uploaded rules yet — copy-paste references for future algorithm or FDD work.

64.4.1 Duct static pressure too high

Flags sustained high duct static (possible stuck setpoint, blocked filter, or trim/respond not trimming).

```
"""AHU duct static high – doc stub (Arrow constants)."""

import pyarrow.compute as pc

VALUE_COLUMN = "duct-static"
HIGH_INWC = 1.20
LOOKBACK_HOURS = 3
MIN_SAMPLES_ABOVE = 6

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    high = pc.greater(vals, HIGH_INWC)
    # Require several consecutive highs (~30 min at 5 min poll)
    from open_fdd.arrow_runtime.windows import import
arrow_consecutive_true

    streak = arrow_consecutive_true(high, MIN_SAMPLES_ABOVE)
    return streak
```

64.4.2 Supply air temperature too cold (cooling coil over-delivering)

```
"""AHU SAT too cold vs setpoint – doc stub."""

import pyarrow.compute as pc
```

```

SAT_COLUMN = "sa-t"
SP_COLUMN = "sa-t-sp"
COLD_DELTA_F = 5.0
LOOKBACK_HOURS = 1

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    sat = pc.cast(table[SAT_COLUMN], "float64")
    sp = pc.cast(table[SP_COLUMN], "float64")
    return pc.less(pc.subtract(sat, sp), -COLD_DELTA_F)

```

64.5 Plant supervisory checks (doc-only)

See [GL36 algorithm stubs](#)(`{{ "/rule-cookbook/gl36-algorithm-stubs/" | relative_url }}`) for chiller plant enable, HWST trim & respond, and CHW DP/CHWST reset patterns aligned with the Niagara README.

64.6 Related

- [Rule Lab](#)(`{{ "/operator-bridge/rule-lab/" | relative_url }}`) — live FDD authoring
- [Model workflow](#)(`{{ "/operator-bridge/model-workflow/" | relative_url }}`) — point bindings
- [Windowing & debugging](#)(`{{ "/rule-cookbook/windowing-debugging/" | relative_url }}`) — rolling windows

65 Model workflow

66 Model workflow

66.1 Brick model

- **Equipment tree** — SPARQL over synced TTL (workspace/data/data_model.ttl)
- **Point registry** — BACnet inventory → series_id for historian bindings
- **Health score** — orphan points, missing fdd_input, stale telemetry

66.2 Typical integrator flow

1. Import or sync BACnet point registry.
2. Map equipment classes (AHU, VAV, ...) in the model UI — set brick_type on points and feeds on equipment (AHU→VAV).
3. Tag points with fdd_input roles (zone temp, SAT, damper cmd, ...).
4. Bind Rule Lab rules to points, equipment, or BRICK classes (bindings in rules_store.json).
5. Run POST /api/model/sync-ttl after bulk imports.
6. Validate on **Trend plot** with FDD overlays (?fdd=1) — faults render on a right-hand 0/1 axis per device scope.

AI Agent and commissioning JSON import can bulk-apply steps 2-4; integrator should review model health before production FDD. See [FDD and assignments](#)({{ "/operator-bridge/fdd-assignments/" | relative_url }}) and [Ollama and analytics](#)({{ "/operator-bridge/ollama-analytics/" | relative_url }}).

Export: GET /api/model/export (TTL/JSON). Commissioning bundle: GET /api/model/commissioning-export — includes per-point fdd_rules_linked (Rule Lab names) plus fdd_rules[] catalog. Use **Import / export** tab preview table or **Point → FDD rule pins** before editing raw JSON. API detail in [Appendix](#)({{ "/appendix/bridge_api/" | relative_url }}).

67 Driver framework

68 Driver framework

Open-FDD edge commissioning uses a **shared driver pattern** for OT data sources. Each driver polls field devices on a schedule, stores long-format samples in workspace CSVs, and ingests into the **feather historian** under a distinct source tag for FDD and plots.

68.1 Drivers

Driver	Protocol	Feather source	Commissioning tab
BACnet({{ "/bacnet/"	relative_url }}	MS/TP / IP (:47808)	bacnet
Modbus	Modbus TCP	modbus	Modbus
[JSON API]({{ "/drivers/json-api/"	relative_url }}	HTTP/HTTPS REST (+ [OpenWeather showcase]({{ "/drivers/json-api/"	relative_url }} #openweathermap-showcase-recommended-demo))

All three drivers share the same operator workflow:

1. **Discover or configure** — add devices/endpoints to the driver registry.
2. **Request once** — on-demand read to verify connectivity and JSON path / register map.
3. **Request & store** — append to poll CSV and write a feather shard.
4. **Enable polling** — 1 / 5 / 10 / 15 minute intervals via tree right-click or bulk toolbar.
5. **Poll all now** — force one worker cycle without waiting for the interval.

68.2 Data layout

```
workspace/
  bacnet/commissioning/  points.csv, discovered inventory
  bacnet/polls/          samples.csv
  modbus/commissioning/  registers.csv
  modbus/polls/          samples.csv
```

```
json_api/commissioning/ endpoints.csv
json_api/polls/          samples.csv
data/feather_store/
  bacnet/{site_id}/      shard-*.feather
  modbus/{site_id}/
  json_api/{site_id}/
```

68.3 Historian and FDD

- **Plot tab** — numeric columns from bacnet and modbus sources (GET /api/timeseries/plot?source=...).
- **String JSON fields** — stored in feather under json_api; use the JSON API tree or feather directly (plot is numeric-only).
- **FDD batch** — merges bacnet + modbus + json_api historian columns by nearest timestamp; rules use BRICK-bound external_id names (e.g. compare BACnet oa-t vs JSON API web-oat-t — see [JSON API]({{ "/drivers/json-api/" | relative_url }})).
- **BRICK model** — bind points in **Model & assignments** commissioning JSON; sync TTL for SPARQL scope.

68.4 Rule Lab (Arrow upload/download)

1. **Download kit** — zip with rule.py (constants at top), data.py, sample.feather (~3h), run_test.py, requirements.txt.
2. Local test: pip install -r requirements.txt then edit constants in rule.py and python run_test.py.
3. **Upload rule.py** — Arrow-only; must define apply_faults_arrow(table, cfg, context=None).
4. Browser shows **read-only** source; use Quick test + Update all records.

API: GET /api/rules/export-kit, POST /api/rules/upload.

68.5 Smoke validation

From repo root on a running stack (<http://127.0.0.1:8765>):

```
python3 scripts/smoke_multi_driver_stack.py
python3 scripts/validate_modbus_temp_e2e.py --no-server
```

68.6 Related docs

- Data flow({{ "/architecture/data-flow/" | relative_url }}) — poll → CSV → feather → FDD

- [API routes](#)({{ "/appendix/bridge_api/" | relative_url }}) — REST reference
- [\[BACnet polling\]](#)({{ "/bacnet/polling/" | relative_url }}) — commission container loop

69 Operator Bridge

70 Operator Bridge

The Operator Bridge is the FastAPI service and React dashboard operators use daily.

Page	Topic
Dashboard overview ({{ "/operator-bridge/dashboard/" relative_url }})	relative_url }}
Auth and roles ({{ "/operator-bridge/auth-roles/" relative_url }})	relative_url }}
Rule Lab ({{ "/operator-bridge/rule-lab/" relative_url }})	relative_url }}
Algorithms ({{ "/operator-bridge/algorithms/" relative_url }})	relative_url }}
Model workflow ({{ "/operator-bridge/model-workflow/" relative_url }})	relative_url }}
FDD and assignments ({{ "/operator-bridge/fdd-assignments/" relative_url }})	relative_url }}
Ollama and analytics ({{ "/operator-bridge/ollama-analytics/" relative_url }})	relative_url }}

REST details: [\[Appendix — API routes\]](#)({{ "/appendix/bridge_api/" | relative_url }}). Env files: [Workspace env files](#)({{ "/appendix/workspace-env-files/" | relative_url }}).

71 Ollama and analytics

72 Ollama and analytics

72.1 What runs without login

The **Building status** home page (/) and GET /openfdd-agent/building-insight are **public** (same policy as fault status). Anyone on the LAN can read the briefing sentence and underlying numeric levers; only the **AI Agent** chat and stack revision endpoints require sign-in.

72.2 Ollama setup

1. Copy workspace/ollama.env.example → workspace/ollama.env.local.
2. Pick a model for available RAM (comments in the example file):

RAM tier	Suggested model
4 GB Pi	qwen3:0.6b
8 GB	qwen3:1.7b
16 GB	qwen3:4b
32 GB	qwen3:8b
64 GB	qwen3:14b

1. Set OFDD_OLLAMA_BASE_URL (default http://127.0.0.1:11434).
2. Optional: OFDD_OLLAMA_GPU_MODE (cpu / auto / gpu), OFDD_OLLAMA_TIMEOUT_S for slow CPUs.
3. Bootstrap helper: ./scripts/bootstrap_ollama.sh.

Bridge reads env via run_local.sh / compose. Model resolution: workspace/api/openfdd_bridge/ollama_profiles.py.

72.3 Automatic analytics (deterministic, always on)

These pandas calculations run on a refresh interval and feed the home dashboard **whether or not Ollama is up**:

Lever	Module	Refresh env	What it computes
Zone temperature snapshot	zone_temp_analytics.py	OFDD_ZONE_TEMP_INTERVAL_S (default 3600s)	Site-wide and per AHU zone temperature averages, spread out-of-band computed using BRICK feeds (AHU→VAV) which is modeled; falls back to all Zone_Air_Temperature points
Device poll health	device_poll_health.py	stack health cycle	BACnet device liveness seen / stale poll detection
Operational brief	building_insight.py → get_operational_brief	same as insight	Compact numerical status for integrators
Root-cause hints	root_cause_hints.py	on insight refresh	Multi-zone fault chains using brick:feeds from

Shared lookback window: OFDD_ANALYTICS_LOOKBACK_DAYS (default 14) in operational_analytics.py.

API routes (auth optional unless noted):

- GET /openfdd-agent/building-insight — sentence + zone snapshot + fault sentences
- GET /openfdd-agent/zone-temp-analytics
- GET /openfdd-agent/device-poll-health
- GET /openfdd-agent/ollama/health — integrator diagnostics

72.4 When Ollama is used

building_insight.get_building_insight():

1. Refreshes zone + device snapshots (pandas).
2. Calls ollama_client.health().
3. If Ollama is reachable and should_use_ollama_for_insight() passes, sends a **compact context** (status, zone levers, feeds chains) to the configured model for a one-sentence briefing (source: "ollama").
4. On failure, uses _fallback_sentence() (source: "deterministic").

Context assembly: building_insight._compact_context(). Prompt template references BRICK feeds and root_cause_hints.

72.5 AI Agent (authenticated)

/agent page uses POST /openfdd-agent/chat with tool access (agent_tools.py): BRICK graph, scope bundles, rule binding patches, model health, etc. This is separate from the public home briefing.

72.6 Code map

```
workspace/api/openfdd_bridge/
  building_insight.py      # cached home briefing + Ollama
sentence
  zone_temp_analytics.py   # zone temp levers (BRICK feeds)
  device_poll_health.py    # BACnet poll staleness
  operational_analytics.py # lookback window + methodology dict
  root_cause_hints.py      # multi-fault BRICK chain hints
  ollama_client.py         # HTTP client to Ollama
  ollama_profiles.py       # RAM tiers / model names
```

Dashboard consumers: BuildingStatusPage.tsx,
StackStatusStrip.tsx (WebSocket /ws/dashboard).

73 FDD and assignments

74 FDD and assignments

74.1 What the product actually does

Open-FDD separates **data modeling** (BRICK equipment, points, feeds relationships) from **rule assignment** (which FDD rules apply to which points, equipment, or BRICK classes). Both are editable in **Model & assignments** and via commissioning JSON import.

74.1.1 BRICK modeling (integrator + AI-assisted)

Concern	Where it lives	Notes
Equipment tree	ModelService + TTL sync	AHU, VAV, sensors; equipment_type and brick_type on points

Concern	Where it lives	Notes
brick:feeds	model_feeds.py, ttl_service.py	AHU→VAV→zone relationships; used by zone analytics and root-cause hints
Point registry	BACnet inventory → model points	fdd_input roles (oa-t, stat_zn-t, ...), series_id / historian column
Commissioning import	POST /api/model/commissioning-import	Bulk JSON: sites, equipment, points, optional fdd_rules

AI Agent (agent_tools.py) can read slim_brick_graph, scope_bundle, patch rule bindings, and upsert points — but it does **not** auto-generate a full site model without operator review. Expected workflow:

1. BACnet discover/poll populates point registry.
2. Integrator or agent tags brick_type, fdd_input, and feeds on equipment.
3. POST /api/model/sync-ttl writes workspace/data/data_model.ttl.
4. Model health (model_health.py) flags orphan points and missing fdd_input.

74.1.2 Rule assignment (three binding kinds)

Saved rules in rules_store.json carry bindings:

```
{
  "point_ids": ["5007-analog-input-1173"],
  "equipment_ids": ["bench-1"],
  "brick_types": ["Outside_Air_Temperature_Sensor"]
}
```

Binding kind	Effect
point_ids	Rule runs for that historian point / series
equipment_ids	Rule runs for all points on equipment (mass bind)
brick_types	

Binding kind	Effect
	Rule runs for any point with that BRICK class on site

Assign via:

- **Model & assignments** UI — equipment/point chips, rule pin menu on trend plot
- **Rule Lab** — bindings panel
- **Commissioning import** — `fdd_rules[].bindings` and per-point `fdd_rule_ids`
- **AI Agent** — `patch_rule_binding` tool

Runtime evaluation: `fdd_runner.py` (batch FDD) and `plot_readings.evaluate_fault_plots()` (trend overlays). Plot scope filters rules to those bound to **selected telemetry** (point, equipment, or BRICK class); unbound rules still evaluate site-wide.

Brick bindings (3.0.20+): when a rule binds `brick_types` (or `equipment_ids` / `point_ids`), the batch runner resolves **every** matching historian column via `historian_columns_for_rule`, runs the Arrow rule per column with `value_column` set, and OR-combines fault masks. One rule config therefore applies consistently to all zone temps, discharge temps, etc.

74.1.3 CLASS vs device

- **BRICK class** (`brick_type` on points, or `brick_types` on rule bindings) — template-style assignment (“all `Zone_Air_Temperature_Sensor`”).
- **Device / equipment** (`equipment_id`, BACnet device instance) — instance assignment (“this VAV-12”).
- **Point** (`point_ids`) — single-sensor assignment.

`applies_to` on legacy rules is deprecated; use bindings in 3.0+.

74.2 Commissioning JSON shape

Export: `GET /api/model/commissioning-export`. Import accepts `import_ready_json` wrappers (see `commissioningImport.ts`).

74.2.1 Rule names vs ids (Rule Lab alignment)

Rule Lab shows **human names** (Bench OA-T flatline 1h). Saved rules use stable **ids** (bench-oa-t-flatline-1h from setup scripts, or a UUID for uploaded custom rules). Commissioning export includes both so you never have to cross-reference sections by hand:

Field	Direction	Purpose
points[].fdd_rule_ids	import + export	Assignment surface — array of rule ids
points[].fdd_rules_linked	export only	[[id, name]] — Rule Lab names beside each point
fdd_rules[].id	import + export	Stable rule key (matches Rule Lab / rules_store.json)
fdd_rules[].name	import + export	Same label as Rule Lab dropdown
fdd_rules[].source_file	export	Basename of deployed .py when present (e.g. bench_oa-t_flatline_1h.py)

On import, fdd_rules_linked is stripped (like fdd_rule_ids — not stored in model.json). Use the **Point → FDD rule pins** table on Model & assignments to read names without parsing JSON.

Minimum fields integrators/AI should produce:

- sites, equipment[] with id, equipment_type, optional feeds[]
- points[] with site_id, equipment_id, brick_type, fdd_input, BACnet IDs, optional fdd_rule_ids
- fdd_rules[] with id, name, bindings, enabled (optional source_file on export)

After import, verify in **Trend plot** with ?fdd=1 — fault lanes appear on the right-hand 0/1 axis for bound rules.

74.3 Related

- [Model workflow](#)({ { “/operator-bridge/model-workflow/” | relative_url } })
- [Rule Lab](#)({ { “/operator-bridge/rule-lab/” | relative_url } })

- [Trend plot / fault overlays]({{ "/operator-bridge/dashboard/" | relative_url }}#trend-plot)

75 Network setup

76 Network setup

76.1 Bind address

Commission and poll containers need the **OT interface** IP and UDP **47808**:

```
# workspace/bacnet/commissioning/commission.env
BACNET_BIND=192.168.1.50/24:47808
BACNET_INSTANCE=599999
```

- Use the NIC that can reach controllers (not only the management VLAN unless routed).
- Poll driver uses network_mode: host on Linux edges.

76.2 Discovery range

```
DISCOVER_LOW=1
DISCOVER_HIGH=4194302
DISCOVER_TIMEOUT=30
```

Narrow the range in large sites to avoid broadcast storms.

76.3 Verify

From commission container logs or API: Who-Is → I-Am responses. If zero devices, check firewall, bind IP, and VLAN routing before tuning rules.

77 Discover and read

78 Discover and read

The **commission** container exposes HTTP APIs for discovery and read-property workflows used by the dashboard BACnet tools.

Capability	Notes
Who-Is / I-Am	Device discovery on OT subnet
Read property	Present value, object name, units
RPM	Bulk reads for inventory export
Write property	Gated — see Write safety ({{ "/bacnet/write-safety/"

Exported inventory feeds `points_discovered.csv` and the Brick point registry.

78.1 Operator workflow

1. Confirm `network_setup`({{ "/bacnet/network-setup/" | relative_url }}).
2. Run discover from dashboard or API.
3. Review discovered objects; enable points for poll profiles.
4. Sync model bindings for FDD inputs.

79 Polling

80 Polling

BACnet field reads run in the `openfdd-commission` container.
The Operator Bridge does not bind UDP 47808.

Retired: `openfdd-bacnet-poll` image and `openfdd-bacnet-poll` systemd unit. Poll loop lives in **commission** only — do not run both.

BACnet polling has two stages:

1. **Field reads** — commission poll loop → workspace/bacnet/polls/samples.csv
2. **Historian ingest** — bridge background worker → workspace/data/feather_store/

80.1 Commission poll loop (default)

The **commission** container runs the poll loop at startup. It reads enabled rows from points.csv and appends BACnet RPM results to samples.csv.

Setting	Location
BACnet bind	workspace/bacnet/commissioning/commission.env
Enabled points	workspace/bacnet/commissioning/points.csv
Poll output	workspace/bacnet/polls/samples.csv
Historian	workspace/data/feather_store/

Check activity:

```
tail -1 workspace/bacnet/polls/samples.csv  
docker compose logs --since 5m commission | grep -i poll
```

80.2 Bridge ingest worker

Inside **bridge**, a background thread watches samples.csv and ingests new rows into feather. Disable only for debugging:
OFDD_DISABLE_POLL_WORKER=1.

80.3 Health

Dashboard stack health (GET /health/stack) reports bacnet_poll status from the commission agent — not a separate container.

Stale points trigger data-quality fault patterns — see [Sensor quality faults]({{ "/fault-codes/sensor-quality/" | relative_url }}).

80.4 Poll strategy (edge)

Open-FDD intentionally keeps BACnet field traffic **minimal**:

- **One enabled row per object** in points.csv — poll only what the model/FDD needs.

- **Uniform cycle** — every enabled point is RPM-polled each cycle; the loop sleeps `max(15, min(poll_interval_s))` (typically **60 s** on Acme).
- Per-point `poll_interval_s` in the UI is the **commissioned target**; throughput analytics compare configured vs observed samples.
- **Unit conversion** (e.g. Trane °C → °F) uses `device_poll_profiles.csv` at ingest — not a poll-rate file.

Acme ships **FDD-minimal polling** (~76 points on a typical GL36 lab when 8 rules are enabled), not the full discovery tree (~340+ GL36 objects or 566 discovered objects). Disable unneeded objects in BACnet commissioning rather than raising global poll rates.

AI agents / MCP: Never enable BACnet polling for every discovered object. Poll **only** historian columns bound to **enabled** FDD rules (`rules_store.json` `brick_types`, `point_ids`, and rule config column hints). Use `bacnet_toolshed.fdd_minimal_poll` or `acme_commission_fdd_minimal.sh` — not `bulk --all enable` scripts.

80.5 Async driver and single-stack I/O

Layer	Behavior
Dedicated <code>bacnet-io</code> thread	One asyncio loop + serial lock for all field I/O
RPM batching	Present-value reads chunked (25 objects) to cut APDUs
Poll loop	Sequential per-device RPM when <code>interruptible=True</code> so operator UI can preempt
Operator UI	INTERACTIVE priority — cancels in-flight background work
Override scans	BACKGROUND , 15 min timeout — see <code>Operator override scans({{ “/bacnet/override-scans/”</code>
Bridge ingest	Async notify after each poll cycle → feather historian

Do **not** run a second BACnet bind on 47808 (no parallel `openfdd-bacnet-poll` container). See `Containers({{ “/architecture/containers/” | relative_url }}`).

80.6 Operator override scans

Hourly P8 supervisory scans rotate one device at a time. Documented in `Operator override scans({ { "/bacnet/override-scans/" | relative_url } })`.

81 Operator override scans

82 Operator override scans (P8)

The commission agent rotates **one BACnet device per hour** (default) through a supervisory priority-array scan. Results are persisted for operator review and portfolio rollup — not for automatic writes.

82.1 Schedule

Setting	Default	Meaning
OFDD_OVERRIDE_SCAN_INTERVAL_S	3600	Seconds between single-device scans
OFDD_OPERATOR_OVERRIDE_PRIORITY	8	BACnet priority counted as “operator override”
Device list	points_discovered.csv	Unique device_instance rows
Rotation	registry.json cursor	Full plant rotation $\approx$ device_count $\times$ interval

Example: **33 devices $\times$ 1 h $\approx$ 33 h** for a full pass. Dashboard shows **next device** and **last scan** time.

82.2 What each scan does

1. point_discovery on the target device (commandable objects).
2. read_property on each object's **priority-array** (not RPM — RPM loses priority slots).
3. Merge into workspace/bacnet/overrides/registry.json and append overrides_export.csv.
4. Advance cursor to the next device.

Fault code **operator_override** (P8) surfaces active overrides on the BACnet tree and building status.

82.3 BACnet I/O priority

Override scans run at **BACKGROUND** priority on the single shared BACnet stack (UDP 47808). Operator reads/writes use **INTERACTIVE** and preempt background work. Scheduled RPM polling also uses BACKGROUND and shares the same asyncio lock — polls and override scans take turns; neither starves the other indefinitely.

Override scans allow up to **15 minutes** per device (`_run_bacnet_override_scan` timeout). Bridge POST `/api/bacnet/overrides/scan-once` proxies with a matching 900 s timeout.

82.4 Manual trigger

```
curl -X POST -H "Authorization: Bearer $TOKEN" \
  http://EDGE:8765/api/bacnet/overrides/scan-once
```

Dashboard: BACnet page → **Scan next device now**.

82.5 Health checks

```
curl -H "Authorization: Bearer $TOKEN" http://EDGE:8765/api/
bacnet/overrides/status
```

Expect `device_count > 0`, `last_scan_at` within the last few hours on a healthy edge, and `export_row_count` growing over time.

82.6 Data paths

Path	Content
workspace/bacnet/overrides/registry.json	Per-device last scan + override points

Path	Content
workspace/bacnet/ overrides/ overrides_export.csv	Flat export for spreadsheets

Preserved across Docker upgrades when workspace/ is on the edge volume — see [Backup & restore]({{ "/ops/backup-restore/" | relative_url }}).

83 Write safety

84 Write safety

BACnet writes can change live plant behavior. Open-FDD disables writes by default. Enable only with operator sign-off, a tested allowlist, and audit logging.

84.1 Defaults

Control	Default
Supervisory writes	Off
Write allowlist	Empty — must enumerate device/object
Audit	Commands logged when writes enabled

84.2 Enable writes (commission role)

1. Set env flag documented in `Security({{ "/security/" | relative_url }})` (`OFDD_BACNET_WRITE_ENABLED` or site equivalent).
2. Populate write allowlist CSV / config with explicit object IDs.
3. Use **commission** role JWT; every write should include reason/note where API supports it.
4. Test on bench hardware before production OT.

84.3 Operator rules

- Never write setpoints or overrides on life-safety or fire/smoke interlocks through experimental rules.
- Prefer read-only polling for FDD until rules are validated in Rule Lab.

- Revert overrides through BACnet priority relinquish where supported.

85 BACnet

86 BACnet

Open-FDD integrates with field controllers via BACnet/IP (and bench MSTP overlays in dev compose).

Page	Topic
Network setup ({{ "/bacnet/network-setup/"	relative_url }}
Discover and read ({{ "/bacnet/discover-read/"	relative_url }}
Polling ({{ "/bacnet/polling/"	relative_url }}
Operator override scans ({{ "/bacnet/override-scans/"	relative_url }}
Write safety ({{ "/bacnet/write-safety/"	relative_url }}

87 Convention

88 Fault code convention

88.1 Format (Grade-A, 3.0.18+)

Short stable code: FAMILY-SUBSYSTEM-NNN — e.g. AHU-ECON-001, CHW-DT-001, DATA-STAL-001.

Semantic ID: dotted canonical_id — e.g. ahu.economizer.not_using_free_cooling.

Legacy letter codes (AHU-E, VAV-C) remain **aliases** in open_fdd/faults/catalog/*.yaml until bridge sync completes.

Field	Example
code	AHU-ECON-001
canonical_id	ahu.economizer.not_using_free_cooling
family	AHU, VAV, CHW, DATA, CRS, ...
rule_doc_path	Link to rule cookbook recipe

Full schema: `open_fdd/faults/schema.py`. Catalog loader: `open_fdd/faults/catalog.py`.

88.2 Categories (Grade-A)

Category	Meaning
energy	Waste, reset stuck, plant inefficiency
comfort	Setpoint not met, poor zone performance
reliability	Short cycling, staging, equipment stress
maintenance	Leaking valves, filters, fouling proxies
indoor_air_quality	Ventilation shortfall, humidity
healthcare_risk	Pressure, isolation, critical-space excursions
data_quality	Stale, flatline, OOB, missing historian
controls_integrity	Overrides, chatter, schedule violations

88.3 Severity

Level	Operator response
info	Log; trend for maintenance window
low	Review in routine rounds
medium	Investigate within days
high	Prompt attention; comfort/energy impact likely
critical	Immediate operational risk (especially <code>healthcare_risk</code>)

88.4 Linking rules

In Rule Lab, set `fault_code` on the rule metadata. Batch FDD aggregates hits into `GET /api/faults/status` by family.

88.5 Cookbook mapping

Each catalog entry lists `cookbook_patterns` (e.g. `flatline_1h`, `mixing_envelope`, `rate_of_change`) — see [Expression cookbook \(Arrow-native\)](#)(`{{ "/rule-cookbook/expression-cookbook/" | relative_url }}`).

Legacy pandas type: expression YAML rules are **not** used on the edge in 3.x; translate to `rules_py` Arrow modules and bind `fault_code` in Rule Lab.

89 Live site update

90 Live site update

Upgrade GHCR images on a **live edge host** that already has `~/open-fdd/` — no `git pull` on the host.

IT operators: prefer [Quick Start — Updating the stack] (`{{ "/quick-start/updating/" | relative_url }}`) and `openfdd_site_backup.sh` / `openfdd_site_update.sh` on the edge host. This page adds control-machine UI deploy and Ansible paths.

90.1 Layout on the edge host

```
~/open-fdd/  
  docker-compose.yml  
  workspace/           # site state – backup first
```

`workspace/` holds BACnet commissioning, poll CSV, feather historian, BRICK model, FDD rules, and `auth.env.local`. Image upgrades must **preserve** it.

See [Backup and restore](#)(`{{ "/ops/backup-restore/" | relative_url }}`) before any upgrade.

90.2 Concepts

Term	Meaning
Container	Running instance (bridge, commission, mcp-rag) — recreated on upgrade
Image	

Term	Meaning
	GHCR package (tag latest or dated tag)
workspace/	Open-FDD site state on disk — do not delete

90.3 1. Verify new images on GHCR

Three images must exist for every tag:

```
export NEW_TAG="${NEW_TAG:-latest}"

docker manifest inspect ghcr.io/bbartling/openfdd-bridge:${NEW_TAG} >/dev/null &&
docker manifest inspect ghcr.io/bbartling/openfdd-commission:${NEW_TAG} >/dev/null &&
docker manifest inspect ghcr.io/bbartling/openfdd-mcp-rag:${NEW_TAG} >/dev/null &&
echo "All three images exist for ${NEW_TAG}"
```

90.4 2. Update dashboard UI (when release changed React)

Image pull alone does not update the browser UI. The Operator Bridge serves workspace/api/static/app/ from the bind mount **before** image-baked assets.

From control machine (full repo):

```
cd /path/to/open-fdd
./scripts/build_operator_dashboard.sh prod
cd infra/ansible
RUN_POST_CHECK=0 ./deploy.sh ui --limit <inventory_host>
```

Confirm hash on edge:

```
curl -sf http://<edge-ip>/ | grep -o 'index-[^"]*\.' | head -1
```

One command (UI + images + insurance check):

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_full.sh --limit <inventory_host>
```


90.5 3. Pull and recreate (edge host)

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
./scripts/openfdd_site_update.sh
```

Manual equivalent:

```
cd ~/open-fdd
docker compose pull
docker compose up -d --force-recreate
docker compose ps
curl -sf http://127.0.0.1:8765/health
```

90.6 4. Ansible image-only (control machine)

```
OPENFDD_IMAGE_TAG=latest RUN_POST_CHECK=1 ./scripts/
upgrade_edge_ghcr.sh --limit <inventory_host>
```

90.7 5. Validate

→ [Deployment validation](#)({ { “/ops/deployment-validation/” | relative_url } })

90.8 Rollback

Restore docker-compose.yml from backup, pull previous tag, docker compose up -d --force-recreate. workspace/ is unchanged. Details: [Backup and restore](#)({ { “/ops/backup-restore/” | relative_url } }).

90.9 Related

- [Updating the stack](#)({ { “/quick-start/updating/” | relative_url } }) — edge-host helper scripts
- [Containers](#)({ { “/architecture/containers/” | relative_url } }) — three-image architecture

91 Central collection

92 OpenFDD RCx Central — collection

OpenFDD Edge sites emit **interval summaries** (not raw historian by default). **OpenFDD RCx Central** ingests rollups over Tailscale/VPN, stores them locally, and feeds the Dash overview and validation jobs.

RCx Central is read-only toward Edge/BACnet. It runs on an analyst workstation or Docker Desktop — not on the OT edge by default.

92.1 Interval summary schema

Defined in `portfolio/store/interval_schema.py` as `FaultIntervalSummary`:

- Identity: `site_id`, `building_id`, `equipment_id`, `equipment_family`
- Window: `timestamp_start`, `timestamp_end`
- Fault: `fault_code`, `canonical_id`, `severity`, `confidence`
- Activity: `active_minutes`, `percent_active`, `occurrence_count`
- Evidence: `evidence_json` (summarized, not full trend)
- Tuning: `tuning_version`, `tuning_params_hash`
- Operator: `operator_status` (new | acknowledged | resolved | false_positive | ...)

92.2 Edge export formats

- JSONL (append-only events)
- Parquet / Feather (batch intervals)

92.3 Collect today (rollup API)

```
source infra/ansible/secrets/acme.env.local  
python3 scripts/portfolio_collect.py
```

92.4 Tuning proposals

Human-reviewable proposals use `TuningProposal` in the same module. The AI agent **never** auto-writes BACnet points on edge — use `GET /api/building-agent/tuning-brief` and `POST /api/building-agent/apply-tuning` with `apply: false` first. Maintainer workflow: `skills/openfdd-edge-deploy-tune/SKILL.md`.

93 AHU faults

94 AHU faults

Air handling unit codes (sample from catalog).

Code	Title	Severity	Detection summary	Likely causes	Operator checks
AHU-A	Supply fan performance degradation	warning	Spread/runtime vs baseline	Belt slip, dirty filters, VFD limit	Trend speed vs airflow; filter dP
AHU-B	Simultaneous heating and cooling	critical	Heat + cool outputs active together	Sequencing bug, leaking valve	Trend coil commands; valve feedback
AHU-C	SAT sensor fault	warning	Flatline / OOB SAT	Failed sensor, bad calibration	SAT trend; compare to coil discharge
AHU-D	MAT inconsistent with OAT/RAT	warning	MAT outside OAT-RAT envelope	MAT/OAT/RAT sensor errors	Verify damper positions; cross-check OAT
AHU-E	Economizer not economizing	warning	Free cool available, OA minimum	Stuck damper, lockout	OA damper vs OAT trend
AHU-F	Damper command vs feedback mismatch	warning	Cmd $\neq$ feedback	Stuck actuator, linkage	Compare cmd/feedback trends

Example rule: flatline_1h on SAT → tag **AHU-C**. Recipe: [Python recipes]({{ "/rule-cookbook/python-recipes/" | relative_url }}).

95 Standards crosswalk

96 Standards crosswalk

Grade-A fault definitions carry a standards_crosswalk block in open_fdd/faults/catalog/*.yaml.

Field	Source	Use in Open-FDD
ornl_lbnl_taxonomy	ORNL/ LBNL unified HVAC fault taxonomy	Canonical ontology backbone
ashrae_g36_reference_type	ASHRAE Guideline 36	Trim-and-respond, plant requests, supervisory sequences
ashrae_207_reference_type	ASHRAE Standard 207	Economizer FDD test categories
brick_classes	<u>Brick</u> <u>Schema</u>	Equipment/point semantic roles
haystack_tags	Project Haystack (optional)	Interoperability tags

96.1 Example

```
standards_crosswalk:  
  ornl_lbnl_taxonomy: ahu/economizer/free_cooling  
  ashrae_g36_reference_type: supply_air_temp_reset  
  ashrae_207_reference_type: economizer_fault_detection  
  brick_classes: [brick:Air_Handler_Unit, brick:Economizer]  
  haystack_tags: [equip, ahu, econ]
```

```
Export full catalog: python3 -c "from open_fdd.faults.catalog  
import catalog_export; import json;  
print(json.dumps(catalog_export(), indent=2))"
```

97 Backup and restore

98 Backup and restore

workspace/ on the edge host is the **live site state** — feather historian, BACnet commissioning files, BRICK model, FDD rules, auth, and dashboard static bundle. Container images are replaceable; **backup workspace/ before every upgrade.**

98.1 Quick backup (edge host)

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
```

Archives land under ~/openfdd-backups/<timestamp>/.

Custom location:

```
BACKUP_ROOT=~/openfdd-backups/manual ./scripts/
openfdd_site_backup.sh
```

98.2 Manual backup (SSH)

Container processes may write files as **root:root** with mode **0600**.
Use **sudo** for a full archive:

```
cd ~/open-fdd

export BACKUP_ROOT="$HOME/openfdd-backups/$(date +%Y%m%d-%H%M%S)"
mkdir -p "$BACKUP_ROOT"

cp docker-compose.yml "$BACKUP_ROOT/docker-compose.yml.before"
docker compose ps > "$BACKUP_ROOT/docker-compose-ps-before.txt"
docker compose config --images > "$BACKUP_ROOT/docker-images-
before.txt"

sudo tar --xattrs --acls -czf "$BACKUP_ROOT/workspace-full.tgz"
workspace
sudo chown "$USER:$USER" "$BACKUP_ROOT/workspace-full.tgz"

du -h "$BACKUP_ROOT/workspace-full.tgz"
```

98.3 What to protect

Path	Contents
workspace/data/ feather_store/	Feather historian
workspace/bacnet/ commissioning/	points.csv, commission.env
workspace/bacnet/ polls/samples.csv	Poll output
workspace/data/*.json	Model, rules store, FDD results
workspace/ auth.env.local	Login secrets
workspace/api/static/ app/	Dashboard bundle (if deployed separately)

98.4 Restore after a bad upgrade

1. Stop containers: `docker compose stop` (do **not** use `down -v`)
2. Restore `docker-compose.yml` from backup
3. If data corruption: extract selective files from `workspace-full.tgz` — model, rules, feather shards
4. `docker compose pull && docker compose up -d --force-recreate`
5. Verify: `Deployment validation({{ "/ops/deployment-validation/" | relative_url }})`

98.5 Safe cleanup

```
docker image prune -f
```

Never on live sites: `docker compose down -v`, `docker volume prune`, `docker system prune -a --volumes`, or deleting `workspace/`.

98.6 Related

- `Updating the stack({{ "/quick-start/updating/" | relative_url }})`
- `Live site update({{ "/ops/live_site_update/" | relative_url }})`

99 OpenFDD RCx Central API

100 OpenFDD RCx Central API

Local analyst API for multi-edge RCx workflows over Tailscale/VPN. **Read-only toward OpenFDD Edge** — no BACnet, no commands.

Package path: portfolio/central/api.py — service name **openfdd-rcx-central**.

100.1 Start

```
pip install -r portfolio/requirements.txt
./scripts/run_central_api.sh # http://127.0.0.1:8060/health
```

Docker Desktop: [docs/rcx-central/docker-desktop-windows.md](#)

100.2 Edge registry (browser auth)

Method	Path	Purpose
GET	/api/central/edges	Saved Edge instances (secrets masked)
POST	/api/central/edges	Add/update Edge
POST	/api/central/edges/test	Test connection (health + model)
PUT	/api/central/edges/{site_id}	Update Edge
DELETE	/api/central/edges/{site_id}	Remove Edge

100.3 Analytics & RCx

Method	Path	Purpose
GET	/api/central/mechanical-summary/{site_id}	Equipment counts, BACnet, readiness
GET		

Method	Path	Purpose
	/api/central/fdd-analytics/{site_id}	FDD rules + chart packs
POST	/api/central/rcx/preview	Data readiness + chart catalog
POST	/api/central/rcx/charts/preview	Matplotlib PNG previews (base64)
POST	/api/central/rcx/report	Download DOCX report

100.4 Validation (legacy collect workflow)

Method	Path	Purpose
GET	/api/central/sites	Edge registry + last check-in
POST	/api/central/sites/{site_id}/collect-validate	Collect rollup + validation
POST	/api/central/validation/run	One-off or scheduled plan
GET	/api/central/validation/jobs	Stored jobs
GET	/api/central/validation/jobs/{id}	Job detail

100.5 RCx report body

```
{
  "site_id": "acme",
  "hours": 24,
  "charts": ["fault_hours_by_severity", "ahu_sat_vs_setpoint"],
  "sections": ["executive_summary", "mechanical_summary"],
  "save_to_volume": true
}
```

Reports save under portfolio/data/reports/ (configurable via OPENFDD_RCX_CENTRAL_DATA).

Legacy endpoint: POST /api/central/rcx/report-legacy

101 VAV faults

102 VAV faults

Variable air volume terminal codes (sample).

Code	Title	Severity	Detection summary	Likely causes	Operator checks
VAV-A	Zone heating/cooling overlap	warning	Heat and cool at terminal	Reheat valve stuck, SAT too low	Zone temp vs SAT; valve cmd
VAV-B	Poor zone temperature control	warning	Persistent deviation from setpoint	Oversized box, bad tuning	PI loop trends; occupancy
VAV-C	Zone temperature sensor fault	warning	Flatline / OOB zone temp	Failed zone sensor	Flatline test; compare to neighbor zones
VAV-D	Minimum airflow not met	warning	Flow below minimum cmd	Damper stuck, pressure issue	Airflow vs damper cmd
VAV-E	Discharge temp deviation from SAT	warning	DAT far from SAT setpoint	Coil issue, sensor drift	DAT vs SAT SP

Example rule: oob_rolling on zone temp → **VAV-C** or comfort bounds per site policy.

103 Docker images (GHCR)

104 Docker images (GHCR)

Full **Open-FDD edge/operator stack** — not the PyPI library.

104.1 Images

GHCR image	Service	Role
ghcr.io/bbartling/openfdd-bridge	bridge	API, dashboard, historian
ghcr.io/bbartling/openfdd-commission	commission	BACnet discover/read/poll
ghcr.io/bbartling/openfdd-mcp-rag	mcp-rag	MCP + doc-search sidecar

Image name openfdd-mcp-rag is retained for compatibility; the container runs the unified MCP server.

104.2 Tags

Tag	Meaning
3.0.30	Exact release (preferred for production)
3.0	Minor alias on release tags
latest	Latest tagged release only
edge	Not published by default — use pinned versions on OT hosts

```
export OPENFDD_IMAGE_TAG=3.0.30
docker pull ghcr.io/bbartling/openfdd-bridge:${OPENFDD_IMAGE_TAG}
docker pull ghcr.io/bbartling/openfdd-commission:${
{OPENFDD_IMAGE_TAG}
docker pull ghcr.io/bbartling/openfdd-mcp-rag:${OPENFDD_IMAGE_TAG}
```

104.3 Publish

Triggered by git tag vX.Y.Z → workflow **Publish Docker images to GPCR**.

Manual: Actions → workflow_dispatch (publishes latest).

104.4 vs PyPI

Need	Use
Embed FDD in your Python/cloud job	<code>pip install open-fdd</code>
BACnet + UI + bridge on an edge host	GHCR images

See [Release process](#)({ { "/developer/release-process/" | relative_url } }).

105 RTU faults

106 RTU faults

Packaged rooftop unit codes (sample).

Code	Title	Severity	Detection summary	Likely causes	Operator checks
RTU-A	Compressor short cycling	warning	Rapid on/off cycles	Low charge, oversized unit	Run-time histogram
RTU-B	Economizer / OA damper fault	warning	OA behavior vs conditions	Actuator, sensor	OA damper vs enthalpy/OAT
RTU-C	Supply air temperature fault	warning	SAT flatline or OOB	Sensor failure	SAT trend vs outdoor conditions
RTU-D	Simultaneous heat and cool	critical	Heat + cool stages together	Control board, relay stuck	Stage status trends

Bind rules to packaged unit fdd_input points (SAT, OAT, compressor cmd, ...).

107 Deployment validation

108 Deployment validation

For the **live Acme site** after GHCR updates, use the dedicated harness documented in [Acme live validation](#)(({ "/ops/acme-live-validation/" | relative_url } }) (acme_post_deploy_validate.sh).

Non-destructive checks after deploy or image upgrade. Run from the **edge host** (smoke) or from a **control machine** with the full repo (insurance suite).

108.1 Edge host smoke (5 minutes)

```
cd ~/open-fdd

docker compose ps
curl -sf http://127.0.0.1:8765/health | jq . || curl -sf http://
127.0.0.1:8765/health

tail -1 workspace/bacnet/polls/samples.csv
du -sh workspace/data/feather_store/

docker compose logs --since 20m | grep -Ei "error|exception|
traceback|critical" | tail -20 || true
```

Via Caddy (building LAN):

```
curl -sf http://<edge-ip>/health
curl -sf http://<edge-ip>/ | grep -o 'index-[^"]*\.\js' | head -1
```

108.2 Browser checklist

1. Open <http://<edge-ip>/> (Caddy :80, not only loopback :8765)
2. Integrator login (workspace/auth.env.local on the edge host)
3. **Host stats** — container image tag / git SHA
4. **BACnet** — driver tree shows devices; last poll timestamp recent
5. **Model & assignments** — commissioning export returns JSON
6. **Rule Lab** — quick-test a saved rule (backend: arrow)

108.3 Control-machine insurance check

From a machine with the full open-fdd repo and Ansible inventory:

```
cd infra/ansible/scripts
./post_deploy_check.sh --limit <inventory_host> --full
```

Or by IP:

```
./post_deploy_check.sh --host <edge-ip> --ssh-user <deploy-user>
--full
```

Checks include: Caddy → React dashboard, /health/stack, MCP RAG, BACnet tree, BRICK/SPARQL, Docker log scan.

Do not run on live commissioned sites without approval: acme_operational_verify.sh with BACnet rediscover — use --skip-discover for smoke only. See [Examples — GL36 lab]({{ "/examples/acme-gl36-lab/" | relative_url }}).

108.4 LAN security smoke (optional)

From a workstation on the same LAN as the edge:

- Windows: scripts/security/Run-OpenFddSecurityScan.ps1
- macOS/Linux: scripts/security/run_openfdd_security_scan.sh

Expected findings: [ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}).

108.5 Arrow / FDD rules (3.0+)

On control machine:

```
./scripts/validate_fdd_backends.sh --docker
```

On edge after upgrade:

```
grep -R "apply_faults_arrow" workspace/data/rules_py | wc -l
```

108.6 Related

- [Health check]({{ "/quick-start/health-check/" | relative_url }})
- Security testing cycle({{ "/developer/security-testing/" | relative_url }}) (maintainers)

109 Sensor and data quality

110 Sensor and data quality

Sensor faults use cookbook patterns `flatline_1h`, `oob_rolling`, `rate_of_change`, and `mixing_envelope`. Full thresholds: [Expression cookbook — sensor validation]({{ “/rule-cookbook/expression-cookbook/” | relative_url }}#sensor-validation-bounds-flatline-rate-of-change).

110.1 Catalog codes

Code	Title	Severity	Pattern	Detection summary
BLD-B	Outdoor air sensor fault	warning	flatline, oob, rate_of_change	OAT flatline, OOB, or unrealistic spike
BLD-D	Stale telemetry	critical	stale_points	No new samples within threshold
AHU-C	SAT sensor fault	warning	flatline_1h, oob_rolling	Supply air temp stuck or out of band
AHU-D	MAT inconsistent with OAT/RAT	warning	mixing_envelope	Mixed air outside OAT-RAT envelope
VAV-C	Zone temperature sensor fault	warning	flatline_1h, oob_rolling	Zone temp stuck or 55–90 °F band breach
RTU-C	Supply air temperature fault	warning	flatline_1h, oob_rolling	Packaged unit SAT fault
CH-D	CHW supply temperature sensor fault	warning	flatline_1h, oob_rolling	Plant CHW sensor fault
DC-C	Datacom sensor anomaly	warning	flatline_1h	CRAH/room sensor flatline or RH OOB

Code	Title	Severity	Pattern	Detection summary
HP-D	Discharge/suction temperature sensor fault	warning	flatline_1h, oob_rolling	Heat pump refrigerant/air temp sensor

110.2 Default bounds (imperial, occupied)

Sensor	Min	Max	Flatline tol	Max Δ /hr
Zone temp	55 °F	90 °F	0.10 °F	4 °F
Supply air temp	50 °F	110 °F	0.15 °F	8 °F
Return air temp	55 °F	95 °F	0.10 °F	3 °F
Duct static	−0.5	3.0 inH ₂ O	0.02	0.5
RH	0 %	100 %	1.0 %	15 %
CHW	40 °F	90 °F	0.10 °F	4 °F
HW	70 °F	200 °F	0.15 °F	6 °F
Condenser water	50 °F	110 °F	0.15 °F	5 °F
CO ₂ (occupied)	400 ppm	1000 ppm	5 ppm	200 ppm

Return-air checks use **narrow bands**; when MAT/OAT/RAT are available, prefer **mixing envelope** over RAT bounds alone.

110.3 Communication quality

- Monitor poll cycle timestamps in dashboard.
- Use `stale_points` for dropout detection (**BLD-D**).
- Do not confuse **comm loss** with **equipment fault** — verify BACnet device online before dispatching mechanical.

110.4 Operator workflow

1. Confirm **BLD-D** (stale) is resolved before trusting other sensor codes.
2. Cross-check **BLD-B** OAT against weather service or JSON API driver.
3. For **VAV-C** / **AHU-C**, compare neighbor zones / coil behavior before replacing sensor.

111 Logging and audit

112 Logging and audit

Open-FDD uses a **two-tier logging model** familiar to IT and security teams: structured **audit/error JSONL** for forensics and compliance, plus **service stdout** for engineering troubleshooting. Defaults include **age pruning**, **size rotation in MB**, and **Docker log caps** — no operator cron required.

112.1 Log types

Tier	Location	Format	Who reads it
Audit	workspace/logs/audit.jsonl	JSON Lines	Security, MSI, integrator API
Errors	workspace/logs/error.jsonl	JSON Lines	Support, integrator API
Service stdout	Docker: docker compose logs · Dev: workspace/.local-run/*.log	Plain text (uvicorn, workers)	Engineering
Historian	workspace/data/feather_store/	Feather	FDD, plots — separate retention (data.env.local)

Structured audit logs are **not** mixed into uvicorn access logs. That separation matches common practice: SIEM-friendly JSONL for auth and OT commands; unstructured stdout for stack traces and poll worker noise.

112.2 Audit record schema

Each line in audit.jsonl / error.jsonl is one JSON object:

Field	Example	Notes
@timestamp	2026-06-07T19:57:21+00:00	UTC ISO-8601
event_id	UUID	Unique per event
event_type	auth.login.failure	Stable taxonomy (see below)
severity	warning	debug ... critical
outcome	failure	success, failure, denied, ...

Field	Example	Notes
service	openfdd-bridge	
host	hostname	
action	login	Human-readable verb
actor	{username, role}	After successful auth
client	{ip, user_agent}	Respects OFDD_TRUST_X_FORWARDED_FOR behind Caddy
http	method, path, status	When HTTP-triggered
resource	BACnet object, model id, ...	When applicable
detail	Sanitized map	Passwords, tokens, secrets stripped by key name
request_id	UUID	On audited HTTP paths

112.2.1 Auth events (industry-standard login trail)

event_type	When
auth.login.success	Valid credentials
auth.login.failure	Bad password (generic client message)
auth.login.lockout	Rate limit exceeded (default 5 failures / 5 min)

Login rate limits and lockouts are **audited**; responses never reveal whether the username exists.

112.2.2 OT / commissioning events

event_type	When
bacnet.command	Supervisory write (allowed, denied, dry-run)
bacnet.discover	Who-Is / point discovery
model.write	BRICK model mutations
agent.tool	Agent tool calls (prompts hashed/truncated)
api.access	Sensitive POST/PUT/PATCH/DELETE (BACnet, ingest)
error.unhandled	Unhandled exception (also in error.jsonl)

Not audited: routine GETs (dashboard reads, plot data, health). This reduces noise while keeping **auth and field commands** on the trail.

112.2.3 Secret redaction

Never logged: passwords, bearer tokens, `OFDD_AUTH_SECRET`, private keys. Detail objects drop keys containing password, token, secret, authorization. Agent tool arguments use additional hashing for prompts and rule source.

Opt-in full prompt logging (lab only): `OFDD_AUDIT_LOG_PROMPTS=1`.

112.3 Integrator API (read logs in the UI stack)

Method	Path	Role
GET	<code>/api/audit/events?limit=100</code>	integrator
GET	<code>/api/audit/errors?limit=100</code>	integrator
GET	<code>/api/audit/summary</code>	integrator

Use these for post-incident review without shell access. Forward `workspace/logs/*.jsonl` to SIEM (rsyslog, Filebeat, Wazuh) on production edges.

112.4 Retention and rotation (defaults)

Configured in `workspace/data.env.local` (copy from `data.env.example`):

Variable	Default	Behavior
<code>OFDD_LOG_RETENTION_DAYS</code>	90	Drop audit/error JSONL lines older than N days; delete aged <code>.local-run</code> and archived <code>*.log / audit/*.jsonl</code>
<code>OFDD_LOG_MAX_MB</code>	50	When <code>audit.jsonl</code> or <code>error.jsonl</code> exceeds N MB, archive to <code>audit.{UTC}.jsonl</code> and start fresh
<code>OFDD_LOCAL_RUN_LOG_MAX_MB</code>	25	

Variable	Default	Behavior
OFDD_LOG_ROTATE_INTERVAL_HOURS	6	Rotate workspace/.local-run/*.log (bridge, Caddy, FDD loop, ...) Background retention while bridge is running (not only at restart)

Rotation runs at **bridge startup** and on the **scheduled interval**. No logrotate.d entry is required for audit JSONL.

Optional path overrides:

```
OFDD_AUDIT_LOG_PATH=/var/log/openfdd/audit.jsonl
OFDD_ERROR_LOG_PATH=/var/log/openfdd/error.jsonl
```

112.5 Docker edge: json-file caps (not journald for app audit)

Production stacks use **Docker Compose** (docker/compose.edge.yml). Container stdout uses the **json-file driver with size limits**:

```
logging:
  driver: json-file
  options:
    max-size: "25m"
    max-file: "5"
```

That caps each service at roughly **125 MB** of rotated container logs on disk — the same pattern many teams use instead of unbounded docker logs.

Why audit JSONL stays on disk (not journald)?

- Append-only files under workspace/logs/ survive container recreate and bind-mount to the host.
- JSONL lines import cleanly into SIEM without journal field parsing.
- OT incident response often needs **months** of auth/BACnet write history on the edge box.

When journald still applies: native systemd units (Caddy, Ollama on bare metal) — use `journalctl -u <unit>` per your Linux runbook. Bridge audit remains in `workspace/logs/` even when uvicorn stdout goes to Docker or `.local-run/`.

112.6 Local dev (run_local.sh)

File	Service
workspace/.local-run/bridge.log	Bridge / uvicorn
workspace/.local-run/commission.log	BACnet commission agent
workspace/.local-run/caddy.log	Caddy
workspace/.local-run/fdd_loop.log	Scheduled FDD
workspace/.local-run/mcp_rag.log	MCP RAG
workspace/.local-run/ollama.log	Ollama

These are **engineering logs**. Structured audit still lands in `workspace/logs/audit.jsonl` when auth is enabled.

112.7 Quick checks

```
# Last auth failures
grep 'auth.login' workspace/logs/audit.jsonl | tail -5

# Integrator API (after login)
curl -s -H "Authorization: Bearer $TOKEN" http://127.0.0.1:8765/
api/audit/summary | jq .

# Docker edge
docker compose logs bridge --tail 50
```

112.8 Comparison to typical web apps

Practice	Open-FDD
Structured auth audit	Yes — JSONL with actor, IP, outcome
Login rate limit + logout audit	Yes
Secret redaction in logs	Yes — key-based + agent sanitization
Request correlation ID	Yes — on audited mutation paths
Centralized stdout JSON	No — stdout is plain text; audit is JSONL

Practice	Open-FDD
Full HTTP access log	No — mutations and auth only (OT noise reduction)
Log rotation / size caps	Yes — defaults above + Docker max-size
SIEM-ready export	Yes — file tail / Filebeat on workspace/logs/

For BACnet write safety and credential generation, see [SECURITY.md](#) and [Secrets and auth](#)({{ "/security/secrets-auth/" | relative_url }}).

112.9 Related

- [JSON API driver](#)({{ "/drivers/json-api/" | relative_url }}) — OpenWeatherMap showcase, env-based API keys (json_api.env.local)
- [Live site update](#)({{ "/ops/live_site_update/" | relative_url }}) — docker compose logs after upgrades
- [Data flow](#)({{ "/architecture/data-flow/" | relative_url }}) — historian retention (OFDD_FEATHER_*) is separate from audit logs

113 GHCR image retention

114 GHCR image retention

Open-FDD publishes edge images to **GHCR** (ghcr.io/bbartling/openfdd-*). During rapid development, old package versions accumulate. This retention system prunes **noise** while protecting rollback tags for **Acme**, our live validation building.

114.1 Policy (conservative)

Always keep:

- latest and edge
- Latest **5** SemVer release tags per image (configurable)
- Tags listed in scripts/ghcr-retention-protected-tags.txt
- Current Acme deployed tag (workflow input or --current-acme-tag)
- Previous Acme known-good tag (--previous-acme-tag)

Delete candidates (only with `--confirm-delete`):

- Untagged versions older than **7** days
- SHA-only tags older than **30** days
- Feature/dev-style tags older than **30** days
- SemVer releases beyond the latest N window (unless protected)

Images are defined in `docker/images.yaml`:

- `openfdd-bridge`
- `openfdd-commission`
- `openfdd-mcp-rag`
- `openfdd-cloud-exporter`

114.2 Dry-run first

The script defaults to **dry-run**. It prints a keep/delete table and optional JSON/Markdown reports. Nothing is deleted until you pass `--confirm-delete`.

There is **no scheduled automatic deletion** yet — only manual runs locally or via GitHub Actions `workflow_dispatch`.

114.3 Protect Acme rollback tags

Before cleanup, edit `scripts/ghcr-retention-protected-tags.txt`:

```
latest
edge
v3.0.31
v3.0.30
```

Or pass tags at runtime:

```
./scripts/ghcr_prune_packages.sh --all-images --dry-run \  
  --current-acme-tag v3.0.31 \  
  --previous-acme-tag v3.0.30
```

114.4 Run locally

```
gh auth login    # needs read:packages + delete:packages for  
confirm-delete
```

```
./scripts/ghcr_prune_packages.sh --all-images --dry-run  
./scripts/ghcr_prune_packages.sh --image openfdd-bridge --dry-run \  
  --json-out reports/ghcr-prune-plan.json \  
  --confirm-delete
```

```
--markdown-out reports/ghcr-prune-plan.md

# After reviewing the plan:
./scripts/ghcr_prune_packages.sh --all-images --confirm-delete \
--current-acme-tag v3.0.31 --previous-acme-tag v3.0.30
```

114.5 GitHub Actions workflow

Workflow: **Prune old GHCR images** (.github/workflows/ghcr-prune.yml)

1. Actions → **Prune old GHCR images** → **Run workflow**
2. Leave **Dry run only** = true for the first run
3. Download the ghcr-prune-report artifact
4. Re-run with **Dry run only** = false only after reviewing the plan
5. Set **Current Acme deployed tag** and **Previous Acme rollback tag** when known

114.6 Permissions

Deleting package versions requires:

- Local: gh auth login with delete:packages (and read:packages)
- Actions: permissions.packages: write on the workflow (already set)

If deletion fails, the script prints:

```
Deleting GHCR package versions requires package delete
permissions...
```

114.7 Verify images still pull

After pruning:

```
docker pull ghcr.io/bbartling/openfdd-bridge:latest
docker pull ghcr.io/bbartling/openfdd-commission:latest
```

On Acme:

```
export OPENFDD_IMAGE_TAG=v3.0.31
./scripts/upgrade_edge_ghcr.sh --limit acme_vm_bbartling
./scripts/acme_post_deploy_validate.sh --limit acme_vm_bbartling
--quick
```

114.8 Rollback example

```
export OPENFDD_IMAGE_TAG=v3.0.30
./scripts/upgrade_edge_ghcr.sh --limit acme_vm_bbartling
```

114.9 Related issues

Track open Acme/deploy blockers in [GitHub issue #276](#).

115 Fault Codes

116 Fault Codes

Open-FDD uses a **check-engine** model: one building-level status (green / yellow / red) with a catalog of fixed fault codes per equipment family.

Page	Content
Convention ({ { "/fault-codes/convention/"	relative_url }}
AHU faults ({ { "/fault-codes/ahu/"	relative_url }}
VAV faults ({ { "/fault-codes/vav/"	relative_url }}
RTU faults ({ { "/fault-codes/rtu/"	relative_url }}
[Sensor & data quality] ({ { "/fault-codes/sensor-quality/"	relative_url }}

Live catalog API: GET /api/faults/catalog on the Operator Bridge.

117 Operations

118 Operations

Runbooks for live edge hosts after the initial `Quick Start({{ "/quick-start/" | relative_url }})` deploy.

Page	When to use
Live site update ({{ "/ops/live_site_update/" relative_url }})	
Backup and restore ({{ "/ops/backup-restore/" relative_url }})	
Logging and audit ({{ "/ops/logging/" relative_url }})	
Deployment validation ({{ "/ops/deployment-validation/" relative_url }})	
Acme live validation ({{ "/ops/acme-live-validation/" relative_url }})	
[Acme deploy 3.0.33 plan] ({{ "/ops/acme-deploy-3.0.33-validation/" relative_url }})	
Acme validation follow-ups ({{ "/ops/acme-validation-follow-ups/" relative_url }})	

Site-specific lab notes (example BACnet scope, GL36 rules):
[Examples & lab notes](#)({{ "/examples/" | relative_url }}).

For first-time deploy: `[Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }})`.

119 Portfolio

120 Portfolio (central desk)

Multi-site analytics on **benserver** — not part of the edge Docker stack.

Topic	Page
Collect rollups from edge sites	Central collection ({{ "/"portfolio/central-collection/"

Repo layout: portfolio/ (collector, Dash, sites.json). Maintainer tuning API flow: skills/openfdd-edge-deploy-tune/SKILL.md.

121 Acme VAV/AHU rule guidance

122 Acme VAV/AHU FDD rule bundle

Practical Arrow-native rule set for **acme** (vm-bbartling): one RTU/AHU (acme-vm-bbartling-rtu-01, BACnet **1100**) feeding **JCI VAVs** (instances 1-100, imperial °F at wire) and **Trane VAVs** (11000-13000, metric °C converted to °F before feather via device_poll_profiles.csv).

Install / refresh rules:

```
python3 scripts/setup_gl36_fdd.py --site-id acme --building-id vm-bbartling \
--ahu-equipment-id acme-vm-bbartling-rtu-01 --fan-point-id 1100-analog-output-1
```

Validate bundle locally:

```
python3 scripts/acme_validate_fdd_bundle.py
```

122.1 Mixed manufacturers and units

Manufacturer	BACnet instances	Wire units	Open-FDD handling
JCI VAV	1-100	°F	Rules use temp_unit: imperial; no poll conversion
Trane VAV	11000-13000	°C	metric_temp_f in edge_config/acme/vm-bbartling/device_poll_profiles.csv converts to °F before feather
RTU AHU	1100	°F	AHU rules bind to equipment / fan point

All zone-temperature rules share **imperial bounds** after poll conversion. If a new Trane box is added without a profile row, zone OOB/flatline will be wrong until the profile is added and data re-ingested.

Command scaling (damper, reheat, fan): rules normalize **0-1 vs 0-100%** with `pc.if_else(greater(c, 1.0), divide(c, 100), c)`.

Poll interval: Acme BACnet poll loop is **60 s**. Flatline windows use `poll_interval_s: 60` and `flatline_minutes: 60` → **60 samples per hour**, not the legacy 5-min × 12 assumption.

122.2 Rule matrix

Phase	Priority	Rule ID (prefix acme-)	Module	Fault	Equip
0	1	oat-bounds	oat_sensor_bounds.py	BLD-B	Buildi
0	2	oat-flatline-1h	oat_sensor_flatline.py	BLD-B	Buildi
0	3	oat-spike	oat_sensor_spike.py	BLD-B	Buildi
0	3b	oat-vs-web-spread	oat_vs_web_spread_1h.py	BLD-B	Buildi

Phase	Priority	Rule ID (prefix acme-)	Module	Fault	Equipment
0	4	zn-t-oob-occupied	vav_zone_temp_bounds_occupied.py	VAV-C	VAV
0	5	zn-t-flatline-1h	vav_zone_temp_flatline_occupied.py	VAV-C	VAV
0	6	da-t-flatline-1h	flatline_1h.py	VAV-E	VAV
0	7	sat-flatline-1h	flatline_1h.py	AHU-C	AHU
0	8	sap-flatline-1h	flatline_1h.py	AHU-F	AHU
1	9	vav-damper-stuck	vav_damper_stuck_flatline.py	VAV-D	VAV
1	10	vav-airflow-low	vav_airflow_low.py	VAV-D	VAV
1	11	vav-reheat-warm-ambient	zone_reheat_warm_ambient.py	VAV-A	VAV
1	12	vav-reheat-leak	vav_reheat_dat_vs_sat.py	VAV-A	VAV
2	13	ahu-afterhours-runtime	ahu_afterhours_runtime.py	BLD-C	AHU
2	14	mat-oob-economizer	oob_rolling.py	AHU-D	AHU
2	15	ahu-run-hours	ahu_run_hours.py	—	AHU
—	—	Stale telemetry	Poll health dashboard	BLD-D	All

122.2.1 Phase 2+ (not enabled by default)

Enable only after point coverage on RTU **1100** is verified (OAT, MAT, RAT, SAT, OA damper, cooling cmd):

- **AHU-A** duct static not maintained — needs static SP + fan speed (future rule)
- **AHU-D** mixed air envelope — `mixing_envelope_mask` + fan on
- **AHU-E** economizer trio — 100% OA tracking, mech cooling when free cooling available, OA damper excess open

122.2.2 Phase 3 rollups (future)

- Many simultaneous **VAV-D** airflow-low → suggest AHU static / fan issue
- Many **VAV-B/C** comfort faults → AHU scheduling or SAT problem
- Hot-water plant support when HW supply temp is modeled

122.3 Data model checks

Before enabling more rules:

1. **No duplicate BACnet device instances** on equipment rows (poll health merges by `bacnet_device_id`).
2. **No duplicate point_id** rows with different `external_id` / `fdd` aliases (causes `historian_lag` double-count).
3. **Trane devices** in `device_poll_profiles.csv` with `metric_temp_f`.
4. Run `scripts/acme_validate_fdd_bundle.py` after model edits.

122.4 Tuning notes

- **acme-zn-t-oob-occupied**: if flag rate > ~70%, use tuning brief / bounds auto-tune (needs ≥85% flagged + analytics on Arrow sweep).
- Disable noisy rules via `enabled: false` in `setup_gl36_fdd.py` rather than deleting modules.
- Economizer and reheat-leak rules stay off until OAT/MAT/SAT columns are confirmed on the 7-day feather window.

122.5 JSON API weather + BACnet OAT

- OpenWeather registered on edge JSON API tab (`web-oat-t`, `web-rh`, ~20–30 min poll).
- Local OAT: bind **1100-unknown-2** (RTU outdoor air local) with `external_id: oa-t` — `scripts/acme_patch_oat_column.py`.

- Rule acme-oat-vs-web-spread flags when local vs web spread exceeds 8 °F.

122.6 BACnet override scans

Commission agent rotates **one device/hour** through P8 priority-array reads. Status: GET /api/bacnet/overrides/status. See [Operator override scans](#)({{ "/bacnet/override-scans/" | relative_url }}).

122.7 Docker backup / recovery

Edge upgrades via scripts/upgrade_edge_ghcr.sh preserve workspace/data and feather volumes on the VM. After upgrade:

1. curl /health → expect matching openfdd_version
2. ./infra/ansible/scripts/acme_operational_verify.sh
3. Re-push rules if rules_store.json was reset: setup_gl36_fdd.py --host ... --token ...

Feather backup: snapshot workspace/data/feather/ (or site pack export) before major model changes.

123 Acme live validation

124 Acme live validation

Acme (vm-bbartling) is the **live Open-FDD test site** on the OT LAN (reachable over Tailscale from the control machine). After every GHCR image update, run the read-only validation harness before closing a patch cycle.

124.1 Recommended flow

```
export OPENFDD_IMAGE_TAG=3.0.32

# Full upgrade: React static bundle + GHCR containers (not image-
only)
./scripts/upgrade_edge_full.sh --limit acme_vm_bbartling

# Rigorous live validation
./scripts/acme_post_deploy_validate.sh --limit acme_vm_bbartling
```

```
--full \
    --json-out reports/acme-live-validate.json
```

Use `upgrade_edge_full.sh`, not `upgrade_edge_ghcr.sh` alone, when the Operator Bridge UI changed — the edge bind-mount serves `workspace/api/static/app/` **before** image-baked assets (`edge_sync_ui_static.sh` rsyncs the bundle; `deploy.sh ui` was removed).

GHCR SemVer tags omit the leading `v` (`3.0.32`, not `v3.0.32`).
`upgrade_edge_ghcr.sh` normalizes `OPENFDD_IMAGE_TAG` automatically.

124.2 Modes

Flag	What runs
<code>--quick</code>	Health, auth, UI bundle, Docker tag, model health, duplicate device/point checks , BACnet poll, trends, FDD summary
<code>--full</code>	Quick + SPARQL presets, Rule Lab export, local bundle/PyPI rule smoke, <code>stack_health_check.sh</code>
<code>--long</code>	Same depth as <code>--full</code> (reserved for extended soak hooks)

124.3 What counts as pass

- Bridge `/health` OK and reports expected `openfdd_version`
- Running GHCR image tag matches `OPENFDD_IMAGE_TAG` (when set)
- Dashboard serves current `index-*.js` bundle (matches control machine build when available)
- **No duplicate BACnet device instances** in model (`duplicate_bacnet_device_instances == 0`)
- **No duplicate point IDs** in commissioning export
- Model equipment/point counts above profile thresholds (default ≥ 10 / ≥ 50)
- BACnet poll heartbeat recent; enabled point count above threshold
- Historian/trend API returns chartable data (or explicit warm-up warning)
- FDD rules saved and lint-clean; Building Status faults include equipment/point context
- Recent ops logs free of `Traceback` / fatal import errors
- Host disk/memory within thresholds (when Ansible remote probe succeeds)

Warnings (e.g. MCP/Ollama disabled, single stale BACnet point) do not fail the run unless paired with hard errors.

124.4 Configuration (no secrets in git)

Copy and customize locally:

```
cp scripts/acme_validation_profile.example.json scripts/
acme_validation_profile.local.json
```

Point the harness at it:

```
./scripts/acme_post_deploy_validate.sh --limit acme_vm_bbartling
--full \
    --profile scripts/acme_validation_profile.local.json
```

Credentials load from gitignored files only:

- workspace/auth.env.local
- infra/ansible/secrets/acme.env.local

Quote passwords that contain \$ or & in auth.env.local.

124.5 Optional live pytest

```
ACME_VALIDATE_LIVE=1 python -m pytest tests/live/
test_acme_live.py -q
```

Requires Tailscale/inventory reachability and local secrets. CI skips this test by default.

124.6 Overnight FDD validation (read-only)

Four-cycle runner for BACnet health, duplicate audit, equipment roles, and FDD fault schema. **Requires explicit opt-in:**

```
OPENFDD_LIVE_ACME=1 OPENFDD_IMAGE_TAG=3.0.32
ACME_OVERNIGHT_CYCLES=4 \
    ACME_WINDOW_HOURS=2 ACME_CYCLE_SLEEP_MINUTES=0 \
    python3 scripts/acme_overnight_fdd_validate.py --limit
acme_vm_bbartling
```

Variable	Default	Notes
OPENFDD_LIVE_ACME	(unset)	Must be 1 for live API calls
ACME_OVERNIGHT_CYCLES	4	

Variable	Default	Notes
		Number of validation cycles
ACME_WINDOW_HOURS	2	Historian lookback per cycle
ACME_CYCLE_SLEEP_MINUTES	0	Set 120 for true 2-hour wall-clock spacing

Reports are written under `reports/` (gitignored). See [ACME validation follow-ups](#)(`{{ "/ops/acme-validation-follow-ups/" | relative_url }}`) and [ACME deploy 3.0.33 validation plan](#)(`{{ "/ops/acme-deploy-3.0.33-validation/" | relative_url }}`).

124.6.1 Live bridge vs branch fix

Live ACME on **3.0.32** may fail `building_status_context` because the deployed bridge does not yet include `fault_model_context` equipment enrichment. The branch fix enriches payloads correctly in tests and via the overnight runner's post-enrich check. **Do not claim live ACME is fixed until a new image (e.g. 3.0.33) is published and deployed**, then re-run validation.

124.7 Safety

Normal validation is **read-only**. It does not:

- Reset BACnet, model, rules, or historian data
- Run Easy Pooge or bench resets
- Write setpoints or BACnet values
- Start packet captures

Destructive actions require explicit operator tooling outside this harness.

124.8 Reports

JSON reports redact tokens and private hostnames. Example fields:

- `summary.ok`, `summary.failed`, `summary.warnings`
- `checks[].id`, `checks[].category`, `checks[].status`, `checks[].message`

On failure, the console output lists suggested next steps (re-run full upgrade, check static bind mount, run `stack_health_check.sh`).

125 ACME validation follow-ups

126 ACME validation follow-ups

Tracked work after the overnight FDD validation PR (harden/acme-overnight-fdd-validation).

126.1 1. FDD run-history equipment grouping

Problem: Live alert enrichment populates `model_context.equipment`, but batch FDD run history rows often have `equipment: null / missing equipment_names`.

Goal: Populate equipment identity on persisted run rows when inferable (title prefix, fault code, flagged columns) so Central and RCx reports can group historical faults by equipment.

Acceptance criteria:

- Batch FDD run rows include `equipment_names` or equivalent when inferable.
- Historical fault summaries group by equipment without re-parsing titles client-side.
- Missing equipment is explicit in the API, not silent `null`.
- Tests cover run rows that currently return `equipment: null`.

Suggested files: `workspace/api/openfdd_bridge/fdd_results.py`, `validate_fdd_run_schema()` in `acme_fdd_audit.py`.

126.2 2. RTU normalized role mapping

Problem: `acme-vm-bbartling-rtu-01` is flagged as missing some normalized AHU roles (`supply_fan_command`, etc.) in `equipment_point_role_audit()`.

Goal: Decide whether RTU maps to AHU-like roles, RTU-specific roles, or partial-equipment warnings only.

Acceptance criteria:

- RTU missing roles reported clearly (informational unless blocking).
- RTU gaps do not fail VAV/AHU duplicate or BACnet health checks.
- Role expectations distinguish AHU, VAV, RTU, and building-level equipment.

Suggested files: `acme_fdd_audit.py` (AHU_POINT_ROLES, `_equipment_type()`), site commissioning model.

126.3 3. True overnight validation (post-3.0.33 deploy)

Problem: Try-out validation used `ACME_CYCLE_SLEEP_MINUTES=0` (~2 minutes total), not wall-clock 2-hour spacing.

Goal: After bridge image **3.0.33+** is deployed to ACME, run read-only overnight cycles with real spacing.

Acceptance criteria:

- At least 4 cycles with `ACME_CYCLE_SLEEP_MINUTES=120`.
- Live bridge reports deployed tag (e.g. 3.0.33).
- `building_status_context` passes on live bridge (not deferred).
- BACnet freshness, duplicate checks, and equipment context remain healthy.
- Reports under `reports/acme_overnight_logs/` document actual timestamps.

Command:

```
OPENFDD_LIVE_ACME=1 OPENFDD_IMAGE_TAG=3.0.33
ACME_OVERNIGHT_CYCLES=4 \
    ACME_WINDOW_HOURS=2 ACME_CYCLE_SLEEP_MINUTES=120 \
    python3 scripts/acme_overnight_fdd_validate.py --limit
acme_vm_bbartling
```

127 ACME deploy 3.0.33 validation plan

128 ACME deploy 3.0.33 validation plan

Do not run automatically. Use after the overnight FDD validation PR is merged and a new GHCR tag is published.

128.1 What this deploy fixes

Live ACME on bridge **3.0.32** still returns FDD alerts with empty `model_context.equipment.name`. The branch fix in `fault_model_context.py` parses GL36-style titles (AHU-C · AHU SAT flatline 1h) and fault codes to populate equipment name/type. **The running bridge is not fixed until a new image is deployed.**

Local/tests and the overnight runner's **post-enrich** checks pass; live `building_status_context` fails on 3.0.32 by design until deploy.

128.2 Prerequisites

1. PR merged: *Harden ACME live-site FDD validation and VAV AHU rule coverage*
2. CI published GHCR tag 3.0.33 (no leading v)
3. Operator approval for live edge upgrade (read-only validation only; no BACnet writes)

128.3 Deploy sequence

```
export OPENFDD_IMAGE_TAG=3.0.33

# Full upgrade: UI static + GHCR containers
./scripts/upgrade_edge_full.sh --limit acme_vm_bbartling

# Confirm live bridge version/tag
# GET /health → openfdd_version
# GET /health/stack → image_tag
```

128.4 Post-deploy read-only validation

128.4.1 Quick harness

```
OPENFDD_IMAGE_TAG=3.0.33 ./scripts/acme_post_deploy_validate.sh \  
  --limit acme_vm_bbartling --full \  
  --profile scripts/acme_validation_profile.example.json
```

Expected: building_status_context **pass** — FDD alerts include non-empty model_context.equipment.name (e.g. AHU-C, VAV-E).

128.4.2 Overnight try-out (4 cycles, no wall-clock sleep)

```
OPENFDD_LIVE_ACME=1 OPENFDD_IMAGE_TAG=3.0.33  
ACME_OVERNIGHT_CYCLES=4 \  
  ACME_WINDOW_HOURS=2 ACME_CYCLE_SLEEP_MINUTES=0 \  
  python3 scripts/acme_overnight_fdd_validate.py --limit  
acme_vm_bbartling
```

Expected: 4/4 pass; schema_errors_live_bridge empty; harness not deferred.

128.4.3 True overnight (optional)

```
OPENFDD_LIVE_ACME=1 OPENFDD_IMAGE_TAG=3.0.33  
ACME_OVERNIGHT_CYCLES=4 \  
  ACME_WINDOW_HOURS=2 ACME_CYCLE_SLEEP_MINUTES=120 \  
  python3 scripts/acme_overnight_fdd_validate.py --limit  
acme_vm_bbartling
```

Reports: reports/acme_overnight_fdd_validation.md (gitignored).

128.5 Safety

All validation is **read-only**. No BACnet writes, commands, overrides, schedules, or setpoint changes.

129 LAN hardening

130 LAN hardening

Open-FDD targets **trusted building LAN / OT edge** deployment. The Operator Bridge is not intended for direct public internet exposure.

Full mode matrix: `Deployment modes({{ "/architecture/deployment-modes/" | relative_url }})`.

130.1 Auth and bind

Mode	Bridge bind	Auth
Local dev	127.0.0.1	Optional OFDD_AUTH_DISABLED=1 on loopback
Lab LAN	0.0.0.0	Required unless explicit insecure lab flags
Edge production	Loopback + Caddy on LAN	Required — OFDD_AUTH_SECRET + role passwords

Startup **fails** on non-loopback bind without credentials (unless insecure lab flags are set).

130.2 Network exposure

- Put **Caddy** on :80 / :443; keep bridge :8765 on loopback when possible.
- Do not port-forward the Operator Bridge to the public internet without TLS and strong auth.
- Keep BACnet on OT VLANs; management UI on IT VLAN with firewall rules.
- BACnet **writes** are gated by default — [BACnet write guard] (`{{ "/security/bacnet-writes/" | relative_url }}`).

130.3 Rule Lab

Rule Lab runs **operator-authored Python** in a sandbox. Restrict integrator accounts; review rules before enable on production sites.

130.4 TLS and LAN security scans

Topic	Page
Certificates (self-signed / site CA)	TLS and certificates ({{ "/" security/tls-and-certs/"
ZAP + Nmap bench smoke	[ZAP baseline] ({{ "/"security/ zap-baseline/"
Ubuntu host + Tenable/Nessus	Linux host hardening ({{ "/" security/linux-host-hardening/"
Release test cycle (maintainers)	[Security testing] ({{ "/" developer/security-testing/"

130.5 Ollama on the edge

Ollama has **no built-in auth**. Bind OLLAMA_HOST=127.0.0.1:11434 on the host; never expose :11434 on the OT LAN. Open-FDD bridge reaches Ollama server-side only. Validation: scripts/security/check_openfdd_exposure.sh.

131 ZAP baseline (local bench)

132 ZAP baseline (local bench)

Passive [OWASP ZAP baseline](#) against the **pentest production stack** on benserver is the standard LAN security smoke before Acme edge deploys.

Full per-revision workflow (pytest → PR → GHCR → Acme):
[Developer — security testing cycle]({{ "/"developer/security-testing/" | relative_url }}).

Packaged scan scripts (Windows + Mac/Linux): [scripts/security/README.md](#).

132.1 Run

On the Open-FDD host:

```
./scripts/pentest_production_stack.sh start  
./scripts/pentest_production_stack.sh verify
```

From a LAN workstation (after verify passes):

```
# Windows  
.\scripts\security\Run-OpenFddSecurityScan.ps1  
  
# macOS / Linux  
./scripts/security/run_openfdd_security_scan.sh --url http://  
192.168.204.18
```

ZAP target (example): <http://192.168.204.18/> — Caddy on :80 only; bridge :8765 stays loopback. TLS bench: see [TLS and certificates](#)(`{ { "/security/tls-and-certs/" | relative_url } }`).

132.2 Expected results (HTTP bench mode)

Finding	Severity	Status
CSP style-src 'unsafe-inline'	Medium	Accepted — Vite/React inline styles; TODO to nonce/hash
Missing COEP	Low	Accepted — require-corp not enabled (breaks some assets)
Port 80 open (Caddy)	Info	Expected — intentional LAN entry
Ports 8765, 5173, 8000, 8080 closed	—	Good
Port 443 filtered	—	Expected in HTTP mode; use <code>OFDD_CADDY_MODE=tls</code> for HTTPS bench
Duplicate Referrer-Policy / X-Frame-Options	Low	Fixed — bridge owns headers;

Finding	Severity	Status
		Caddy does not duplicate

132.3 Header ownership

Layer	Sets
Bridge (security_headers.py)	CSP, X-Frame-Options: DENY, frame-ancestors 'none', COOP, CORP, Permissions-Policy, Referrer-Policy, X-Content-Type-Options
Caddy HTTP	Reverse proxy only; strips Server banners
Caddy TLS	Adds Strict-Transport-Security only

132.4 Authenticated scan (later)

Baseline scan hits ~4 public endpoints (/health, public agent insight routes). Deep API/dashboard coverage requires ZAP with integrator login — see [Authenticated scanning \(roadmap\)](#)({{ “/security/authenticated-scanning/” | relative_url }}).

132.5 After fixes

Re-run `pentest_production_stack.sh verify`, then the packaged LAN scan from `scripts/security/`. Confirm response headers show **one** X-Frame-Options: DENY and no duplicate Referrer-Policy.

133 TLS and certificates

134 TLS and certificates

Who generates, stores, and renews TLS material for Open-FDD on OT LANs — and how that ties into ZAP/Nmap bench testing.

Developer release cycle: [Security testing cycle](#)({{ “/developer/security-testing/” | relative_url }}).

134.1 Ownership

Environment	Who owns certs	Storage
Local / benserver bench	Developer / maintainer	workspace/ deploy/caddy/ certs/ (cert.pem, key.pem)
Ansible edge (Acme, customer sites)	Site integrator	/etc/openfdd/ caddy/ on the VM (playbook- managed or manual)
Public internet	Not in scope	Open-FDD targets OT LAN; use site PKI or self- signed

Open-FDD does **not** ship Let's Encrypt or public CA automation. OT benches use **self-signed** or customer-provided certs.

134.2 Generate bench certs (local)

```
./scripts/setup_caddy_certs.sh  
# or: ./scripts/setup_caddy_certs.sh --cn openfdd.local --out  
workspace/deploy/caddy/certs
```

Then start with TLS mode:

```
OFDD_CADDY_MODE=tls ./scripts/run_local.sh  
# or pentest stack with OFDD_CADDY_MODE=tls
```

Caddy serves :443 and redirects :80 → HTTPS. Caddy adds **Strict-Transport-Security** only; all other security headers remain on the **bridge** ([ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}#header-ownership)).

134.3 ZAP / Nmap with TLS bench

When `OFDD_CADDY_MODE=tls`:

- Nmap: expect **443 open**, 80 may redirect
- ZAP: use `https://<lan-ip>/` (add `-k trust` or import `cert.pem` on the scan workstation)

- PowerShell: `.\Run-OpenFddSecurityScan.ps1 -TargetUrl "https://192.168.204.18"`
- Bash: `./run_openfdd_security_scan.sh --url https://192.168.204.18`

Self-signed certs produce ZAP TLS warnings — expected on OT LAN.

134.4 Renewal

Self-signed certs from `setup_caddy_certs.sh` default to **365 days**. Re-run the script before expiry or bake renewal into site runbooks.

Edge Ansible deploys should document whether the integrator rotates certs manually or via site PKI.

134.5 Enterprise CA on Caddy (edge)

When IT requires **clean Nessus SSL plugins** (no self-signed / untrusted chain), install a site-provided certificate on the edge VM instead of `setup_caddy_certs.sh` output.

Typical layout (Ansible / manual):

```
/etc/openfdd/caddy/cert.pem # full chain (leaf + intermediates)
/etc/openfdd/caddy/key.pem  # private key (0600, root or caddy
user)
```

Ansible TLS mode (`caddy_mode: tls`) already points Caddy at those paths — see `infra/ansible/templates/Caddyfile.j2`.

Internal enterprise CA workflow:

1. Generate CSR on the edge host or request cert from site PKI for the operator hostname (e.g. `openfdd.acme.local`).
2. Install `cert.pem` + `key.pem` under `/etc/openfdd/caddy/`.
3. Distribute the **CA root** to admin laptops (trust store) so browsers and ZAP scans validate the chain.
4. Monitor expiry:

```
openssl x509 -in /etc/openfdd/caddy/cert.pem -noout -dates
```

Caddyfile snippet (TLS, enterprise cert):

```
:443 {
    tls /etc/openfdd/caddy/cert.pem /etc/openfdd/caddy/key.pem
    header {
        Strict-Transport-Security "max-age=31536000;
includeSubDomains"
```

```
    }  
    reverse_proxy 127.0.0.1:8765  
}
```

Lab/self-signed mode still produces expected **Medium** Tenable findings — document as accepted risk or switch to enterprise CA. See [Tenable remediation]({{ "/security/tenable-remediation/" | relative_url }}).

134.6 Caddy internal CA mode (lab)

`./scripts/setup_caddy_certs.sh` generates a **self-signed** pair for bench TLS. Trust `cert.pem` on scan workstations (`-k curl`, ZAP import) or accept browser warnings. Not suitable when IT mandates trusted chains.

134.7 Secrets

- **Never commit** `key.pem` or production cert bundles
- `workspace/deploy/caddy/certs/` is for local bench only unless your `.gitignore` already excludes generated keys (verify before push)

135 Authenticated scanning (roadmap)

136 Authenticated scanning (roadmap)

[ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}) is **unauthenticated** — it checks public pages, response headers, and a handful of routes reachable without login. That is the right default for every docker image / patch revision smoke on a test LAN.

For **deep** coverage of integrator dashboards, `/api/*` routes, WebSocket sessions, and role-gated writes, plan a separate **authenticated** scan — only on fake/bench stacks with explicit approval.

Release context: `Security testing cycle({{ "/developer/security-testing/" | relative_url }})`.

136.1 Current state (3.0.x)

Capability	Status
ZAP baseline via <code>scripts/security/</code>	Shipped
Pentest creds in <code>workspace/auth.pentest.local</code>	Shipped (host-local, not in git)
ZAP full / active scan automation	Not shipped — manual only
ZAP authenticated context (login script + session)	Roadmap
CI running ZAP against PR previews	Not planned (LAN bench only)

136.2 Why baseline is not enough

After login, the bridge exposes model editing, BACnet/JSON API configuration, Rule Lab, commissioning export, and write-gated commands. Baseline ZAP never exercises:

- Session cookies / JWT persistence
- CSRF or auth bypass on mutating endpoints
- IDOR on site-scoped resources
- Rate limits and audit logging on failed auth

136.3 Planned approach (contributors welcome)

1. **Bench-only target** — same pentest stack; never point active scans at live OT controllers
2. **Login hook** — ZAP `zap-full-scan.py` or Automation Framework with:
 - POST `/api/auth/login` using integrator creds from env (not committed)
 - Regex or JSON extractor for session token / cookie
3. **Scope file** — include `/api/model/*`, `/api/commissioning/*`, dashboard static assets; exclude BACnet UDP and unrelated LAN hosts
4. **Report parity** — extend `scripts/security/` with opt-in - Authenticated / `--zap-full` flags and separate report prefix (`22-zap-authenticated-*`)

5. **Gate** — document accepted findings; fail release only on High/
Critical regressions

136.4 Manual authenticated ZAP today

1. Start pentest stack; note creds in workspace/auth.pentest.local
2. Open ZAP desktop or docker with API port exposed
3. Configure **Context** → **Authentication** → script or form-based login to /api/auth/login
4. Run **Spider** then **Active Scan** on http://<lan-ip>/ only
5. Compare with baseline report in openfdd-security-report/

Do **not** run active scans against production Acme without a maintenance window and BACnet write lock.

136.5 Related

- [scripts/security/README.md](#) — baseline setup
- [Secrets and auth](#)({{ "/security/secrets-auth/" | relative_url }}) — env file layout
- [LAN hardening](#)({{ "/security/lan-hardening/" | relative_url }}) — bind and auth modes

137 Secrets and auth

138 Secrets and auth

138.1 Files (gitignored)

File	Contents
workspace/ auth.env.local	JWT secret, role passwords
workspace/ json_api.env.local	REST API keys for JSON API \${ENV:VAR} URLs (e.g. OpenWeather OPENWEATHER_API_KEY)
workspace/ data.env.local	Historian + audit log retention (OFDD_LOG_*, OFDD_FEATHER_*)
workspace/ ollama.env.local	Ollama URL, model, RAM tier, GPU mode
workspace/ mcp.env.local	MCP RAG sidecar

File	Contents
workspace/ caddy.env.local	Reverse proxy TLS/HTTP mode
workspace/ pentest.env.local	LAN security scan stack
infra/ansible/secrets/ <host>.env.local	SSH deploy secrets (maintainers)

Copy from *.example templates only. Full inventory: [Workspace env files](#)({{ "/appendix/workspace-env-files/" | relative_url }}).

138.2 Required variables (production)

Variable	Purpose
OFDD_AUTH_SECRET	HMAC signing (32+ chars)
OFDD_INTEGRATOR_USER / PASSWORD	Rule Lab, bindings
OFDD_OPERATOR_USER / PASSWORD	Operations

138.3 GHCR pulls

Use read-only registry credentials on edge if images are private; rotate tokens periodically.

138.4 Backup

Back up workspace/data/ and auth env in secure operator vault — not in git.

Audit JSONL under workspace/logs/ may contain client IPs and usernames — treat like security logs. See [Logging and audit](#)({{ "/ops/logging/" | relative_url }}).

139 BACnet write allowlists

140 BACnet write allowlists

Supervisory writes require:

1. **Feature flag** enabled in environment (off by default).

2. **Allowlist** file at workspace/bacnet/write_allowlist.json (copy from [write_allowlist.example.json](#)). If the flag is on but the allowlist is missing, writes are **denied**.
3. **Integrator** role on API calls.
4. **Audit** log review after commissioning sessions.

Allowlist entries support device_instance, object_identifier, property_identifier, optional priority_min/priority_max, value_min/value_max, and allowed_values for binary/multistate targets.

Lab-only override: OFDD_BACNET_WRITE_ALLOW_ANY=1 (audited; not for production edges).

See operator guide: [BACnet write safety]({{ "/bacnet/write-safety/" | relative_url }}).

Never enable blanket write access for agent or integrator automation without human approval per site.

141 Linux host hardening

142 Linux host hardening

Generic **Ubuntu edge VM** guidance for Open-FDD deployments scanned by IT tools (Tenable/Nessus, Qualys, etc.). This complements application-level [LAN hardening](#)({{ "/security/lan-hardening/" | relative_url }}) and [TLS]({{ "/security/tls-and-certs/" | relative_url }}).

Nessus-specific finding tables: [Tenable remediation]({{ "/security/tenable-remediation/" | relative_url }}).

142.1 Scope

Layer	Owner	Repo support
Ubuntu kernel, OpenSSH, apt packages	Site IT / integrator	scripts/security/remediate_ubuntu_host.sh
Docker engine, compose, Caddy	Integrator	Ansible + check_openfdd_exposure.sh
Open-FDD containers		

Layer	Owner	Repo support
(pip/ pyOpenSSL)	Open-FDD maintainers	docker/python-security- constraints.txt, GHCR images
Self-signed TLS on OT LAN	Expected lab finding	Enterprise CA path in [TLS] ({{ "/security/tls-and-certs/"

142.2 Quick operator workflow

On the edge VM (SSH):

```
cd ~/open-fdd
./scripts/security/check_host_security.sh
./scripts/security/check_openfdd_exposure.sh --edge-ip "$
(hostname -I | awk '{print $1}')
```

Remediate host OS (maintenance window):

```
./scripts/security/remediate_ubuntu_host.sh # dry-run
sudo ./scripts/security/remediate_ubuntu_host.sh --apply
# if /var/run/reboot-required exists:
sudo reboot
./scripts/security/check_host_security.sh
```

Pull new Open-FDD images after a release that pins container pip/
pyOpenSSL:

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_ghcr.sh --limit
<inventory_host>
```

142.3 Ubuntu version and EOL

Supported targets: **Ubuntu 22.04 LTS** or **24.04 LTS** (64-bit).
Rebuild hosts still on **16.04** or **18.04** — apt upgrade cannot clear
an SEoL finding.

Validate a surprising 16.04 Nessus hit:

```
lsb_release -a
cat /etc/os-release
# Scan credential / stale DNS / container banner mismatch?
```

142.4 Kernel and package updates

```
sudo apt update
sudo apt full-upgrade -y
uname -r
```

```
test -f /var/run/reboot-required && echo "reboot required"
sudo reboot    # maintenance window
```

Optional status tools:

```
ubuntu-security-status    # or: pro status
apt list --upgradable | grep -i security
```

142.5 Host Python (pip, wheel, pyOpenSSL)

Tenable often reports **host** pip, wheel, and pyOpenSSL versions installed by Ubuntu packages or admin pip install. Prefer **apt** on the host:

```
python3 -m pip show pip setuptools wheel pyOpenSSL
sudo apt install --only-upgrade python3-pip python3-openssl
python3-wheel
```

Open-FDD **containers** pin toolchain versions at image build — see docker/python-security-constraints.txt. Rescan after docker compose pull.

142.6 Ollama — no LAN exposure

Ollama has **no built-in authentication** in typical deployments. Treat LAN exposure as **Critical**.

Rule	Implementation
Bind loopback only	OLLAMA_HOST=127.0.0.1:11434 in systemd (ollama.service) or dev bootstrap
Bridge calls server-side	OFDD_OLLAMA_BASE_URL=http://127.0.0.1:11434 or host.docker.internal:11434 from containers
Never publish :11434 on 0.0.0.0	Compose uses 127.0.0.1:11434:11434 when Docker Ollama is enabled

Validation:

```
ss -tulpn | grep 11434
curl -sf http://127.0.0.1:11434/api/tags | head
curl -sf --max-time 3 http://<edge-lan-ip>:11434/api/tags
# must FAIL from another host
```

Firewall (if management host needs GPU Ollama — rare):

```
# Example: block LAN → 11434; allow loopback only (adjust interface names)
```

```
sudo ufw deny 11434/tcp
sudo ufw allow from 127.0.0.0/8 to any port 11434 proto tcp
```

142.7 OpenSSH Terrapin (CVE-2023-48795)

Apply Ubuntu security updates first (openssh-server, openssh-client). Verify:

```
ssh -V
sudo sshd -T | grep -Ei '^(ciphers|macs|kexalgorithms)'
```

Manual algorithm hardening is **optional** and can lock out clients — document rollback (sshd_config.bak) before changes. Do not automate cipher stripping in repo scripts.

142.8 ICMP timestamp (Low)

Nessus may report ICMP timestamp disclosure. Optional hardening at host firewall or upstream network — low priority for isolated OT VLANs.

Example (nftables — site-specific):

```
# Block ICMP timestamp / type 13 – verify with IT before applying
sudo nft add rule inet filter input icmp type timestamp-request
drop
```

142.9 TLS and certificate scans

Self-signed or internal CA certificates produce **Medium** Nessus SSL findings (untrusted, self-signed, expiry). That is **expected** for lab/OT encryption-in-transit. For clean SSL plugin results, install a **site enterprise CA** certificate on Caddy — [TLS and certificates](#)(`{ { “/security/tls-and-certs/” | relative_url } }` `#enterprise-ca-production`).

142.10 Maintainer security audits (CI parity)

```
./scripts/security/run_maintainer_audits.sh
```

Matches GitHub Actions operator-bridge-security job where possible.

143 Tenable / Nessus remediation

144 Tenable / Nessus remediation

Remediation plan for **IT/Tenable.io Nessus** findings on an Open-FDD **OT/LAN edge** deployment (e.g. Acme GL36 lab VM). Open-FDD runs behind a building firewall on Ubuntu with Docker Compose, Caddy, and optional host Ollama.

Related: [Linux host hardening](#)({{ "/security/linux-host-hardening/" | relative_url }}), [TLS and certificates](#)({{ "/security/tls-and-certs/" | relative_url }}), [LAN hardening](#)({{ "/security/lan-hardening/" | relative_url }}), [Security testing cycle](#)({{ "/developer/security-testing/" | relative_url }}).

144.1 Prioritized action plan

Priority	Action	Owner
P0	Confirm Ubuntu is not 16.04/18.04; rebuild if EOL	IT / integrator
P0	Bind Ollama to 127.0.0.1 only; verify LAN cannot reach :11434	Integrator
P0	apt full-upgrade + reboot for kernel USNs (8254, 8278, 8373)	IT / integrator
P1	Upgrade host pip/wheel/pyOpenSSL via apt or documented pip path	IT / integrator
P1	Pull GHCR images built with docker/python-security-constraints.txt	Integrator
P2	OpenSSH packages current;	IT

Priority	Action	Owner
P2	review Terrapin after patch	IT decision
	TLS: accept self-signed findings or install enterprise CA cert	
P3	ICMP timestamp: optional firewall rule	Network / IT

144.2 Finding classification table

Nessus finding	Severity	Class	Remediation
Canonical Ubuntu Linux SEoL (16.04.x)	Critical	Host OS / false positive?	lsb_release -a — rebuild VM on 24.04 LTS if truly 16.04; if host is 22.04/24.04, check scan target IP, credentials, stale asset record
Ollama Unauthenticated Access	Critical	Deployment config	OLLAMA_HOST=127.0.0.1:11434; no 0.0.0.0:11434; firewall deny; see Ollama
Ubuntu kernel USN-8254-1	Critical	Host OS	sudo apt update && sudo apt full-upgrade -y && sudo reboot
pyOpenSSL 22.0.x < 26.0.0 Buffer Overflow	Critical	Host pip and container	Host: apt upgrade python3-openssl or pip ≥26; Container: GHCR image with constraints file
Ubuntu pip USN-8344-1	High	Host OS + container build	apt full-upgrade; image build upgrades pip≥26
SSL Certificate Cannot Be Trusted	Medium	Accepted risk (lab) / deployment	Self-signed Caddy — use enterprise CA for clean scan
SSL Self-Signed Certificate	Medium	Accepted risk (lab)	Same as above
SSL Certificate Expiry	Medium	Deployment / monitoring	openssl x509 -dates; renew setup_caddy_certs.sh or site PKI
SSH Terrapin (CVE-2023-48795)	Medium	Host OS	Upgrade openssh-server; validate ssh -V
Ubuntu wheel USN-8221-1	Medium	Host OS	apt full-upgrade

Nessus finding	Severity	Class	Remediation
Ubuntu kernel USN-8278-1, USN-8373-1	Medium	Host OS	apt full-upgrade + reboot
pyOpenSSL 0.14.x Security Bypass	Medium	Host + container	Same as pyOpenSSL Critical — upgrade to ≥ 26
ICMP Timestamp Request	Low	Network / optional host	Firewall drop; often accepted on isolated OT VLAN

Class legend: (1) repo-owned fix · (2) Docker base/image · (3) host OS · (4) deployment/config · (5) accepted risk · (6) validate false positive

144.3 Operator commands (edge VM)

144.3.1 Validate (read-only)

```
cd ~/open-fdd
./scripts/security/check_host_security.sh
./scripts/security/check_openfdd_exposure.sh --edge-ip "$
(hostname -I | awk '{print $1}')"
lsb_release -a
uname -r
test -f /var/run/reboot-required && cat /var/run/reboot-
required.pkgs
python3 -m pip show pip setuptools wheel pyOpenSSL 2>/dev/null |
grep -E '^(Name|Version):'
ss -tulpn | grep -E ':80|:443|:8765|:11434'
curl -sf http://127.0.0.1:11434/api/tags | head -3
```

From a **different LAN workstation** (must fail):

```
curl -sf --max-time 3 http://<edge-ip>:11434/api/tags
```

144.3.2 Remediate host (maintenance window)

```
./scripts/security/remediate_ubuntu_host.sh # dry-run
./scripts/security/remediate_ubuntu_host.sh --apply
sudo reboot # if reboot-required
./scripts/security/check_host_security.sh
```

144.3.3 Remediate Open-FDD containers

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_ghcr.sh --limit
<inventory_host>
docker compose pull && docker compose up -d
```

144.3.4 Rescan

After reboot and image pull, request IT **Nessus rescan** of the edge IP. Compare plugin output to the table above.

144.4 Ollama unauthenticated access (Critical)

Not an Open-FDD code bug — Ollama’s API is unauthenticated by design. Risk is **network exposure**.

Repo defaults (3.0.5+):

- Systemd: Environment=OLLAMA_HOST=127.0.0.1:11434 in infra/ansible/templates/ollama.service.j2
- Compose Ollama (optional profile): 127.0.0.1:11434:11434 only
- Acme-style edge: host Ollama + bridge via host.docker.internal:11434 (container → host loopback path)
- post_deploy_check.sh warns if :11434 listens on 0.0.0.0

Re-apply Ansible Ollama unit after upgrade:

```
ansible-playbook -i inventory.yml ollama_bootstrap.yml --limit
<host> -e enable_ollama=true
```

144.5 pyOpenSSL and pip in containers

Docker build installs docker/python-security-constraints.txt before application requirements:

- pip>=26.0, setuptools>=75.0, wheel>=0.45
- pyOpenSSL>=26.0.0, cryptography>=44.0.0

CI pip-audit runs against bridge + bacnet requirements with the same constraints.

144.6 TLS — expected vs production

Mode	Nessus SSL plugins	When to use
Caddy HTTP :80	No TLS plugins	Dev / HTTP-only VLAN
Caddy self- signed : 443	Medium: untrusted, self- signed, expiry	OT LAN encryption, lab

Mode	Nessus SSL plugins	When to use
Enterprise CA cert on Caddy	Clean SSL plugins (if chain trusted)	IT mandates clean Nessus

See [TLS — enterprise CA]({{ "/security/tls-and-certs/" | relative_url }}#enterprise-ca-on-caddy-edge).

144.7 Residual findings after remediation

Even with a patched host and loopback-only Ollama, IT may still see:

- **SSL** Medium on self-signed TLS (accepted for lab; document in risk register)
- **ICMP** Low (optional network block)
- **Container** plugins if Nessus scans Docker overlay networks — clarify scan scope with IT

144.8 Notes for IT / security team

1. Scan the **edge VM IP**, not individual container IPs, unless container CVE correlation is required.
2. Open-FDD **bridge :8765** should be **loopback-only**; LAN entry is **Caddy :80/:443**.
3. **BACnet UDP 47808** on commission is expected OT traffic — out of scope for web/plugin remediation.
4. Do not expose Ollama **11434** to the building LAN; agent chat is server-side only.
5. Kernel CVEs require **host reboot** — schedule with operations.
6. For authenticated web/API depth, see roadmap [Authenticated scanning]({{ "/security/authenticated-scanning/" | relative_url }}).

144.9 Repo-owned fixes (this document's release)

Item	Location
Container pip/pyOpenSSL pins	docker/python-security-constraints.txt, docker/Dockerfile
Ollama loopback systemd	infra/ansible/templates/ollama.service.j2

Item	Location
Host/exposure check scripts	scripts/security/check_*.sh, remediate_ubuntu_host.sh
Post-deploy Ollama bind warn	infra/ansible/scripts/post_deploy_check.sh
CI pip-audit + constraints	.github/workflows/ci.yml

145 AI agents

146 AI agents and MCP

- `MCP_server({{ "/ai/mcp-server/" | relative_url }})` — FastMCP tools over the operator bridge
- Skills under `skills/openfdd-*agent/` and `skills/openfdd-mcp-server/`
- Operator memory: `workspace/MEMORY.md` (see `workspace/MEMORY.md.example`)

147 Security

148 Security

LAN deployment security for the Operator Bridge and BACnet write guard. Open-FDD is for **trusted edge / OT LAN** — not direct public internet exposure.

Page	Topic
LAN hardening ({{ "/security/lan-hardening/" relative_url }})	
ZAP baseline (local bench) ({{ "/security/zap-baseline/" relative_url }})	
TLS and certificates ({{ "/security/tls-and-certs/" relative_url }})	
Linux host hardening ({{ "/security/linux-host-hardening/" relative_url }})	
	relative_url }}

Page	Topic
Tenable / Nessus remediation ({{ "/security/tenable-remediation/"	
Authenticated scanning (roadmap) ({{ "/security/authenticated-scanning/"	relative_url }}
Secrets and auth ({{ "/security/secrets-auth/"	relative_url }}
BACnet write allowlists ({{ "/security/bacnet-writes/"	relative_url }}
[Release & LAN scan cycle] ({{ "/developer/security-testing/"	relative_url }}
Logging and audit ({{ "/ops/logging/"	relative_url }}

149 API routes

150 API routes

REST API served by **openfdd-bridge** (default <http://127.0.0.1:8765>).
Production: Caddy on :80 proxies to the bridge.

OpenAPI: GET /docs and GET /redoc when the bridge runs.

Auth: JWT via POST /api/auth/login. Most routes require Authorization: Bearer <token>. Roles: viewer, operator, integrator, commission, agent, admin. BACnet writes require commission role + [write safety](#)({{ "/bacnet/write-safety/" | relative_url }}). Dev: OFDD_AUTH_DISABLED on loopback only.

WebSocket: WS /ws/dashboard — POST /api/auth/ws-ticket, then pass the ticket via Sec-WebSocket-Protocol: ofdd.ws, <ticket>. Query ?ticket= is dev-only when OFDD_WS_ALLOW_QUERY_TICKET=1. Tickets are short-lived and not interchangeable with the Bearer token.

150.1 Health & audit

Method	Path	Role	Description
GET	/health	public	

Method	Path	Role	Description
			Minimal liveness (ok, service, version, auth_required)
GET	/health/stack	auth	Stack traffic-light (verbose URLs/bind with OFDD_DEBUG_DIAGNOSTICS)
POST	/api/auth/ws-ticket	auth	Short-lived WebSocket ticket
GET	/api/audit/summary	auth	Audit counters
GET	/api/audit/events	auth	Audit log (query params)
GET	/api/audit/errors	auth	Recent API errors

*Exact public set depends on OFDD_AUTH_DISABLED and middleware.

150.2 Auth

Method	Path	Description
POST	/api/auth/login	Username/password → JWT
GET	/api/auth/me	Current user
GET	/api/auth/status	Auth mode / lockout hints

150.3 Rules & FDD

Method	Path	Role	Description
GET	/api/rules/saved	user	Rule index
POST	/api/rules/save	operator+	Create/update rule metadata
GET	/api/rules/saved/{id}/source	user	Python source
PUT		operator+	Write .py file

Method	Path	Role	Description
	/api/rules/saved/{id}/source		
GET	/api/rules/assignments	user	Point bindings
POST	/api/rules/bind	integrator+	Bind rule to point
POST	/api/rules/bindings	integrator+	Bulk bindings
POST	/api/rules/batch	operator+	Run all enabled rules → fdd_results.json
GET/POST	/api/rules/drafts	user	Draft rules

150.4 Rule Lab playground

Method	Path	Description
POST	/api/playground/lint	AST lint Python rule
POST	/api/playground/test-rule	Run apply_faults_arrow() on feather PyArrow window
POST	/api/playground/run-script	Execute script mode
GET	/api/playground/sample-frame	Sample DataFrame for editor

150.5 BRICK / data model

Method	Path	Description
GET	/api/model/sites	Site list
GET	/api/model/tree	Equipment tree (SPARQL)
GET	/api/model/graph	RDF graph fragment
GET	/api/model/scope	Scoped query
GET	/api/model/export	Export TTL/JSON
GET	/api/model/health	

Method	Path	Description
		Model point/equipment counts
GET	/api/model/ttl	TTL metadata
POST	/api/model/sync-ttl	Regenerate TTL from JSON
POST	/api/model/import	Import model payload
POST	/api/model/sites	Create site
GET/ POST	/api/model/bacnet-sync	BACnet ↔ model sync state

150.6 BACnet

Method	Path	Role	Description
GET	/config/bacnet	read	Commission URL / config
GET	/api/bacnet/commission/status	read	Commission agent health
GET	/api/bacnet/server/points	read	Server point table
GET	/api/bacnet/inventory	read	Discovered inventory
POST	/api/bacnet/whois	commission	Who-Is
POST	/api/bacnet/discover	commission	Discover devices
POST	/api/bacnet/read	commission	Read property
POST	/api/bacnet/read-multiple	commission	RPM read
POST	/api/bacnet/write	write	Supervisory write (gated)
POST	/api/bacnet/	integrator	Inventory → BRICK

Method	Path	Role	Description
	import-to-model		
POST	/api/bacnet/driver/sync-discovery	commission	Sync driver tree
POST	/api/bacnet/poll/once	commission	Trigger poll cycle
GET	/api/bacnet/poll/status	read	Poll worker status
POST	/ingest/bacnet	read	Ingest samples into feather

Bind address: BACNET_BIND in commission env — see [BACnet network setup]({{ "/bacnet/network-setup/" | relative_url }}).
 Operator guide: [Discover and read](#)({{ "/bacnet/discover-read/" | relative_url }}).

PATCH | /api/bacnet/driver/point | commission | Enable poll + interval on point |
 PATCH | /api/bacnet/driver/device | commission | Enable poll for all points on device |
 PATCH | /api/bacnet/driver/device/remap | commission | Change instance and/or address |
 DELETE | /api/bacnet/driver/point/{point_id} | commission | Remove point from registry |
 DELETE | /api/bacnet/driver/device/{device_instance} | commission | Remove device |
 DELETE | /api/bacnet/driver/registry | commission | Clear CSVs + model sync |

150.7 Faults (check-engine)

Method	Path	Description
GET	/api/faults/catalog	Fixed fault codes
GET	/api/faults/status	GREEN/YELLOW/RED aggregate
GET	/api/faults/tree	Fault tree by equipment
GET	/api/faults/code/{code}	Code metadata

150.8 Timeseries & sites

Method	Path	Description
GET	/api/timeseries/sites	Feather sites
GET	/api/timeseries/series	Series metadata
GET	/api/timeseries/plot	Plot payload
GET	/api/timeseries/readings	Raw readings
GET	/api/sites	Site list
GET	/api/sites/{site_id}/frame	Wide frame for site

150.9 Building & host

Method	Path	Description
GET	/api/building/status	Building summary
GET	/api/building/alerts	Active alerts
GET	/api/host/stats	CPU/mem/disk

150.10 Local agent (Ollama)

Prefix **/openfdd-agent**. Role **agent** for tool execution.

Method	Path	Description
GET	/openfdd-agent/context	Composed prompt context
GET	/openfdd-agent/tools	Tool manifest
POST	/openfdd-agent/tool	Execute tool (e.g. rules.save)
GET	/openfdd-agent/ollama/health	Ollama reachability
GET	/openfdd-agent/building-insight	Check-engine narrative context
GET	/openfdd-agent/zone-temps	Zone temperature insight

Method	Path	Description
POST	/openfdd-agent/chat	Chat completion (catalog-bound)

Optional host Ollama for building insight — not required for core FDD. Configure via compose profile or host service; see [Architecture overview]({{ "/architecture/overview/" | relative_url }}).

150.11 Modbus

Method	Path	Role	Description
GET	/api/modbus/driver/tree	operator+	Commissioning tree
GET	/api/modbus/poll/status	operator+	Poll worker status
POST	/api/modbus/poll/once	integrator+	Force poll cycle
POST	/api/modbus/read_registers	operator+	One-shot register read
POST	/api/modbus/read_and_store	operator+	Read + CSV + feather (source=modbus)
POST	/api/modbus/refresh	operator+	Re-read one register
PATCH	/api/modbus/register/poll	integrator+	Enable poll interval

See [Driver framework](#)({{ "/drivers/" | relative_url }}).

150.12 JSON API (HTTP/HTTPS)

Method	Path	Role	Description
GET	/api/json-api/env/status	operator+	Env var configured flags (no secret values)
POST	/api/json-api/presets/openweather	integrator+	Register 3-point OpenWeather bundle + optional poll
GET	/api/json-api/driver/tree	operator+	Endpoints grouped by host
GET		operator+	Poll worker status

Method	Path	Role	Description
	/api/json-api/ poll/status		
POST	/api/json-api/ poll/once	integrator+	Force poll cycle
POST	/api/json-api/ request	operator+	One-shot GET/POST (no store)
POST	/api/json-api/ read_and_store	operator+	Request + CSV + feather (source=json_api)
POST	/api/json-api/ refresh	operator+	Re-fetch endpoint
PATCH	/api/json-api/ endpoint/poll	integrator+	Enable poll interval
DELETE	/api/json-api/ endpoint/ {point_id}	integrator+	Remove endpoint

Outbound auth: auth_type = none | bearer | basic; optional verify_tls (default true). See [JSON API driver](#)({{ "/drivers/json-api/" | relative_url }}).

150.13 PyPI package (separate)

Library-only HTTP is **not** bundled. See [Python package](#)({{ "/appendix/python-package/" | relative_url }}) for open_fdd.arrow_runtime (Arrow rules offline).

150.14 Errors

JSON error bodies; stack traces hidden unless OFDD_DEBUG_TRACEBACKS=1. See [LAN hardening](#)({{ "/security/lan-hardening/" | relative_url }}).

151 Python package

152 Python package (open-fdd)

Install from PyPI (embeddable FDD runtime — not the Docker edge stack):

```
pip install open-fdd
pip install "open-fdd[analytics]"      # optional NumPy helpers
pip install "open-fdd[ml]"            # optional sklearn for
offline experiments
```

152.1 Modules

Module	Purpose
open_fdd.arrow_runtime	Default — apply_faults_arrow on PyArrow Tables, cookbook masks, column maps
open_fdd.playground	Rule Lab lint/compile helpers for Arrow rules

Retired in 3.0.1+: open_fdd.engine (YAML/pandas RuleRunner) is **not** shipped on PyPI. Use Operator Bridge Rule Lab or import rules from workspace/data/rules_py/.

152.2 When to use package-only

Scenario	Use
Lint/test Arrow rules offline	open_fdd.arrow_runtime + open_fdd.playground
Graph ML experiments (Layer B)	open-fdd[ml] in experiments/ (see issue #211)
Full building operator stack	Docker Operator Bridge

152.3 Versioning

Publish: git tag vX.Y.Z (or legacy open-fdd-vX.Y.Z) → GitHub Actions **Publish open-fdd to PyPI**. See [Release process](#)({{ "/" developer/release-process/" | relative_url }}).

```
import open_fdd
print(open_fdd.__version__)
```

152.4 Offline Arrow example

```
import pyarrow as pa
import pyarrow.compute as pc
from open_fdd.arrow_runtime import run_arrow_rule

code = '''
import pyarrow.compute as pc

def apply_faults_arrow(table, cfg, context=None):
    return pc.greater(table["SAT"], float(cfg["high"]))
'''

table = pa.table({"SAT": [70.0, 90.0, 88.0]})
result = run_arrow_rule(code, table, {"high": 85})
print(result.flagged_count)
```

API surface: `open_fdd/arrow_runtime` docstrings and `Arrow recipes` (`{ "/rule-cookbook/arrow-recipes/" | relative_url }`).

153 Configuration reference

154 Configuration reference

154.1 Bridge / auth

Variable	Default	Notes
OFDD_BRIDGE_HOST	127.0.0.1	0.0.0.0 for LAN
OFDD_AUTH_SECRET	—	Required for LAN
OFDD_AUTH_DISABLED	0	Localhost dev only
OFDD_INSECURE_LAN_DEV	0	Lab only with auth disabled

154.2 BACnet

Variable	Notes
BACNET_BIND	ip/mask:47808 in commission.env
OFDD_BACNET_WRITE_ENABLED	

Variable	Notes
	Default off — site-specific name may vary

154.3 Docker edge

Variable	Notes
OPENFDD_IMAGE_TAG	GHCR tag for Ansible deploy
openfdd_docker_pull_from_ghcr	Ansible host_var

Rule Lab Python rules use `rules_store.json + workspace/data/rules_py/*.py`. Legacy YAML schema (`docs/config_schema.json`) is archived — not used by Operator Bridge 3.0.1+.

155 Glossary

156 Glossary

Term	Definition
Operator Bridge	FastAPI service serving API + static dashboard
Rule Lab	UI and APIs for Arrow <code>apply_faults_arrow()</code> rules
Feather store	On-disk columnar historian under <code>workspace/data/feather_store/</code>
fdd_input	Brick tag linking a point to a rule binding role
Check-engine	Building-level GREEN/YELLOW/RED fault summary
Commission	BACnet discovery/read (and optional write) agent container
Poll driver	Scheduled BACnet RPM reads into historian
GHCR	GitHub Container Registry — <code>ghcr.io/bbartling/openfdd-*</code>

157 Workspace env files

158 Workspace env files

All live under workspace/. Copy from *.example templates;
committed *.local files are gitignored.

File	Loaded by	Purpose
auth.env.local	run_local.sh, Docker compose, Ansible	JWT secret (OFDD_AUTH_SECRET), integrator/operator/agent passwords, OFDD_AUTH_DISABLED for localhost dev only
data.env.local	run_local.sh, bridge, feather maintain	Feather historian caps (OFDD_FEATHER_*), audit/error log rotation (OFDD_LOG_*), BACnet discovery mutation toggle
json_api.env.local	bridge, Ansible edge sync	API keys for JSON API driver \${ENV:VAR} substitution (e.g. OPENWEATHER_API_KEY)
ollama.env.local	run_local.sh, bridge	Ollama base URL, model name, RAM tier, GPU mode, timeouts — see Ollama and analytics ({{ "/operator-bridge/ollama-analytics/"
mcp.env.local	run_local.sh, MCP sidecar	Enable MCP RAG REST (OFDD_MCP_*), index path
caddy.env.local	run_local.sh, Ansible edge	Reverse proxy mode (http / tls / off), TLS CN, port overrides
pentest.env.local	pentest_production_stack.sh	Production-like LAN scan stack: CORS, auth, passive BACnet defaults

158.1 Ansible / edge extras

Path	Purpose
infra/ansible/secrets/ <host>.env.local	SSH deploy credentials, GHCR pull tokens, site-specific BACnet bind — maintainers only

158.2 Related docs

- [Secrets and auth](#)({{ "/security/secrets-auth/" | relative_url }}) — required production variables
- [Logging and audit](#)({{ "/ops/logging/" | relative_url }}) — OFDD_LOG * detail
- [JSON API driver](#)({{ "/drivers/json-api/" | relative_url }}) — \${ENV:VAR} pattern
- [Configuration reference](#)({{ "/appendix/configuration/" | relative_url }}) — bridge runtime flags not in env files

159 Appendix

160 Appendix

Reference material for integrators and library users.

Page	Content
API routes ({{ "/appendix/bridge_api/" relative_url }})	relative_url }}
Python package ({{ "/appendix/python-package/" relative_url }})	relative_url }}
Configuration reference ({{ "/appendix/configuration/" relative_url }})	relative_url }}
Workspace env files ({{ "/appendix/workspace-env-files/" relative_url }})	relative_url }}
Glossary ({{ "/appendix/glossary/" relative_url }})	relative_url }}

161 GL36 lab site (Acme)

162 GL36 lab site (Acme)

Lab note only. This documents a maintainer **example edge host** (site acme, building vm-bbartling) used for Guideline 36 supervisory FDD development. Replace inventory host names, IPs, and BACnet ranges for your site.

Reference for **ASHRAE Guideline 36** supervisory monitoring on a live lab edge. Rule code lives in `workspace/data/rules_py/`; commissioning uses **Arrow constants** (no `config.json`).

Trim & respond Niagara reference: [README_TRIM_RESPOND](#).

162.1 BACnet poll scope

Device filter (`infra/ansible/scripts/acme_trim_devices.sh`):

Range	Equipment
1-100	JCI VMA/VAV
1100	RTU-01 (AHU)
1002	Hot water plant
11000-13000	Trane UC210 VAV

Poll interval: **60 s**. Commission from control machine:

```
cd infra/ansible
POLL_INTERVAL=60 ./scripts/acme_commission_gl36.sh
```

Points land in `edge_backup/local/acme/vm-bbartling/points.csv` for Ansible sync.

162.2 Example FDD rules (Arrow)

162.2.1 Duct static pressure high (AHU)

```
""AHU duct static high – GL36 trim advisory.""

import pyarrow.compute as pc

VALUE_COLUMN = "duct-static"
HIGH_INWC = 1.20
LOOKBACK_HOURS = 3
```

```

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin, tmax = pc.min(ts).as_py(), pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    return pc.greater(pc.cast(table[VALUE_COLUMN], "float64"),
HIGH_INWC)

```

162.2.2 SAT too cold vs setpoint

```

"""AHU SAT too cold vs setpoint."""

import pyarrow.compute as pc

SAT_COLUMN = "sa-t"
SP_COLUMN = "sa-t-sp"
COLD_DELTA_F = 5.0

def apply_faults_arrow(table, cfg, context=None):
    sat = pc.cast(table[SAT_COLUMN], "float64")
    sp = pc.cast(table[SP_COLUMN], "float64")
    return pc.less(pc.subtract(sat, sp), -COLD_DELTA_F)

```

162.2.3 Site rule stubs in the repo

Rule file	Use
bench_stat_zn-t_flatline_1h.py	Zone temp flatline — bind ZN-T per VAV
acme_duct_static_flatline_1h_gl36_duct_t_r_input.py	RTU duct static flatline
oat_vs_web_spread_1h.py	Local OAT vs OpenWeather JSON API

162.2.4 Local OA-T vs web weather (JSON API)

1. Control machine: workspace/json_api.env.local with
OPENWEATHER_API_KEY
2. JSON API tab → **OpenWeatherMap** preset → **Register**
(default poll **30 min**)
3. Bind BACnet local OAT in the model (oa-t historian column)
4. Enable oat_vs_web_spread_1h.py in Rule Lab — flags when |oa-t
- web-oat-t| > 8 °F

162.3 Deploy / upgrade (Ansible, this lab only)

```
cd infra/ansible
OPENFDD_IMAGE_TAG=latest ./deploy.sh docker --limit
<inventory_host> -e enable_bacnet_poll_driver=true
```

Full UI + image upgrade from control machine:

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_full.sh --limit
<inventory_host>
infra/ansible/scripts/post_deploy_check.sh --limit
<inventory_host> --full
```

Do **not** rsync dev auth.env.local to the edge (deploy_sync_auth: false in private host_vars). Regenerate credentials on the edge host if login fails after upgrade.

162.4 AI-assisted data modeling (lab workflow)

1. BACnet poll running (~340 GL36 points @ 60 s on this lab host).
2. **Model & assignments** → export commissioning JSON for LLM-assisted binding.
3. Import returned JSON via commissioning import.
4. Pin FDD rules on ZN-T, DA-T, duct-static, OAT, etc. — export shows readable names in fdd_rules_linked.

Model seed: workspace/data/acme_gl36_model.json.

163 Examples & lab notes

164 Examples & lab notes

Site-specific commissioning notes, GL36 examples, and maintainer lab workflows. These pages are **not** required for a generic edge deployment.

Page	Description
GL36 lab site (Acme)({{ "/examples/acme-gl36-lab/" relative_url }})	relative_url }}

For production IT operators, start with [Quick Start\({{ "/quick-start/" | relative_url }}\)](#) and [Operations\({{ "/ops/" | relative_url }}\)](#).

165 Arrow-native runtime

166 Arrow-native runtime

Open-FDD 3.0 executes Rule Lab rules on **PyArrow tables** end to end.

```
feather_store.read_site_table()
→ fdd_runner / playground.run_arrow_table()
→ apply_faults_arrow(table, cfg, context)
→ pyarrow.compute masks
```

166.1 Authoring contract

```
import pyarrow.compute as pc

def apply_faults_arrow(table, cfg, context=None):
    return pc.greater(table["zone_temp"], cfg["max_zone_temp"])
```

Cookbook helpers: `open_fdd.arrow_runtime.cookbook` (flatline, spread, OOB, after-hours fan).

Script-mode analytics rules receive table (PyArrow) and cfg in the sandbox — not pandas DataFrames.

166.2 Package layout

Module	Role
open_fdd.arrow_runtime.backend	Execute rule code, batch chunks
open_fdd.arrow_runtime.cookbook	Shared fault masks
open_fdd.arrow_runtime.windows	Rolling min/max, consecutive-true
open_fdd.playground.arrow_templates	Rule Lab starter templates

167 Release process

168 Release process

Open-FDD has **two publish paths**:

Artifact	Trigger	Registry
PyPI open-fdd	Git tag vX.Y.Z (or legacy open-fdd-vX.Y.Z)	pypi.org/project/open-fdd
Docker edge stack	Same release tag (or manual workflow)	ghcr.io/bbartling/openfdd-*

Do **not** publish from ordinary branch pushes. Merge to master, bump version, tag, push tag.

168.1 1. Prepare version

```
git checkout master
git pull --ff-only
# Edit pyproject.toml + open_fdd/__init__.py → same X.Y.Z
python scripts/release/check_version.py
```

168.2 2. Merge and tag

```
git tag -a v3.0.30 -m "open-fdd 3.0.30"
git push origin v3.0.30
```

Tag push runs:

- `.github/workflows/publish-open-fdd.yml` — build, test, twine check, PyPI via **Trusted Publishing**
- `.github/workflows/docker-publish.yml` — GHCR images with tags 3.0.30, 3.0, latest

Legacy tag `open-fdd-v3.0.30` is still accepted during transition.

168.3 3. PyPI Trusted Publishing setup (one-time)

On pypi.org → project **open-fdd** → Publishing → **Add a new trusted publisher**:

Field	Value
PyPI project name	open-fdd
Owner	bbartling
Repository	open-fdd
Workflow name	Publish open-fdd to PyPI
Environment	pypi (optional; enables approval gate)

No long-lived API token in the repo.

168.4 4. Verify release

```
pip install open-fdd==3.0.30
python -c "import open_fdd; print(open_fdd.__version__)"

docker pull ghcr.io/bbartling/openfdd-bridge:3.0.30
docker manifest inspect ghcr.io/bbartling/openfdd-bridge:3.0.30
```

168.5 5. Manual workflow_dispatch

- **PyPI**: Publish open-fdd to PyPI with `dry_run=true` (default) — build/test only
- **Docker**: Publish Docker images to GHCR — publishes `:latest` (maintainer use)

168.6 Package vs Docker

See `PyPI package({{ "/developer/pypi-package/" | relative_url }})`
and `[Docker images]({{ "/ops/docker-images/" | relative_url }})`.

169 PyPI package

170 PyPI package (open-fdd)

170.1 What it is

Embeddable **Arrow-native FDD compute** for consultants, cloud pipelines, and test benches:

- Lint and test `apply_faults_arrow(table, cfg, context)` rules
- Run rules on PyArrow Tables, Feather, or Parquet
- Optional NumPy analytics helpers (`pip install "open-fdd[analytics]"`)

170.2 What it is not

The PyPI wheel does **not** include:

- Operator Bridge / FastAPI app
- React dashboard
- BACnet commission/poll service
- MCP server
- Ansible / Tailscale deploy tooling

Use **GHCR Docker images** for the full edge stack.

170.3 Install

```
pip install open-fdd
pip install "open-fdd[analytics]" # optional NumPy helpers
pip install "open-fdd[ml]"        # offline sklearn experiments
```

170.4 CLI

```
open-fdd version
open-fdd lint-rule path/to/rule.py
```

```

    open-fdd test-rule path/to/rule.py --input sample.feather --
config cfg.json
    open-fdd run-arrow path/to/rule.py --input in.feather --output
out.feather
    open-fdd validate-rule-pack ./rules

```

170.5 Rule contract

```

def apply_faults_arrow(table, cfg, context=None):
    # return PyArrow bool mask, length == table.num_rows
    ...

```

Use `open_fdd.arrow_runtime.run_arrow_rule` for structured ArrowRuleResult (counts, errors, preview).

170.6 Modules shipped on PyPI

Module	Purpose
<code>open_fdd.arrow_runtime</code>	Rule execution, cookbook masks, column maps
<code>open_fdd.playground</code>	Lint/compile helpers
<code>open_fdd.faults</code>	Fault catalog YAML
<code>open_fdd.schema</code>	Result schemas

`open_fdd.engine` (pandas/YAML) is **not** in the wheel.

170.7 Examples

Repo examples/ — [arrow_minimal](#), Feather batch, generic IoT pipeline.

170.8 Local validation

```

pip install -e ".[test,dev,analytics]"
python scripts/release/check_version.py
pytest open_fdd/tests -q
python -m build && twine check dist/*

```

171 MCP server

172 Open-FDD MCP server

FastMCP agent interface over the **operator bridge** — not a parallel FDD stack.

172.1 Modes

Mode	OFDD_MCP_MODE	Site resolution
Edge	edge	OPENFDD_BRIDGE_BASE_URL (default http:// 127.0.0.1:8765)
Portfolio	portfolio	portfolio/sites.json + optional site_id per tool

Acme production edge runs **without** MCP (enable_mcp: false). Run MCP centrally and call http://100.122.106.124 via Tailscale.

172.2 Transport

Transport	Env	Use
Streamable HTTP	OFDD_MCP_TRANSPORT=streamable- http (default in Docker)	http:// 127.0.0.1:8090/ mcp
Stdio	OFDD_MCP_TRANSPORT=stdio	Cursor / Claude Desktop

Legacy bridge doc search: POST /tools/search_docs on :8090 (unchanged).

172.3 Human approval

These tools require human_approved=true:

- save_rule
- apply_fdd_tuning
- run_fdd_batch

MCP does not command BACnet writes — only Open-FDD bridge APIs.

172.4 Client examples

Cursor (~/.cursor/mcp.json):

```
{
  "mcpServers": {
    "open-fdd": {
      "command": "python",
      "args": ["-m", "mcp_server.run"],
      "env": {
        "PYTHONPATH": "/path/to/open-fdd/workspace:/path/to/open-fdd/workspace/api",
        "OPENFDD_REPO_ROOT": "/path/to/open-fdd",
        "OFDD_MCP_TRANSPORT": "stdio",
        "OFDD_MCP_MODE": "portfolio",
        "OFDD_PORTFOLIO_SITES_PATH": "/path/to/open-fdd/portfolio/sites.json"
      }
    }
  }
}
```

HTTP (bensserver dev stack):

```
docker compose -f docker/compose.dev.yml up -d mcp-rag
curl -fsS http://127.0.0.1:8090/health
```

172.5 Site registry example

```
{
  "sites": [
    {
      "site_id": "acme",
      "name": "Acme GL36 Lab",
      "base_url": "http://100.122.106.124",
      "username": "integrator"
    }
  ]
}
```

Store passwords in env or OS keychain — not in git.

172.6 Module layout

- workspace/mcp_server/ — FastMCP tools, resources, prompts

- `workspace/mcp_rag/retrieval.py` — RAG index (rebuild separately)
- Docker image `openfdd-mcp-rag` — compatibility name; runs unified server

173 Dashboard Analytics

174 Dashboard analytics

Engineering analytics pages live under **Analytics** in the operator dashboard (`/analytics`).

174.1 Pages

Route	Purpose
<code>/analytics</code>	Overview KPIs, fault-hour charts, top faults table
<code>/analytics/faults</code>	Time-range fault analytics
<code>/analytics/equipment</code>	AHU / VAV fault-hour summary
<code>/analytics/health</code>	BACnet / BRICK model health
<code>/analytics/rcx</code>	RCx Report Builder (preview + DOCX download)

174.2 API (read-only)

- GET `/api/analytics/overview`
- GET `/api/analytics/faults?hours=24`
- GET `/api/analytics/model-health`
- POST `/api/reports/rcx/preview`
- POST `/api/reports/rcx/generate` → DOCX download

174.3 Fault hours

Elapsed fault hours are estimated from FDD batch run `analytics.estimated_fault_duration_sec` when present, otherwise from `flagged/total` sample ratio. See `open_fdd/reports/fault_hours.py`.

174.4 Theme

All Plotly charts use `getPlotlyThemeLayout(theme)` from `workspace/dashboard/src/lib/plotly-theme.ts`.

174.5 Tests

```
    pytest tests/workspace_bridge/test_dashboard_analytics.py
open_fdd/tests/test_fault_hours.py
    cd workspace/dashboard && npm test
```

Live BACnet is not required. Gate live ACME validation with `OPENFDD_LIVE_ACME=1`.

175 Dashboard Rcx Makeover Inventory

176 Dashboard + RCx Makeover — Inventory

Branch: `feature/dashboard-rcx-mega-makeover`
Date: 2026-05-30

176.1 What exists

Area	Location	Notes
React operator dashboard	<code>workspace/dashboard/</code>	Vite + React 19, theme via <code>contexts/theme-context.tsx</code> , CSS vars
Plotly charts	<code>lib/plot-chart.ts</code> , <code>PlotPage.tsx</code> , <code>HostStatsPage.tsx</code>	Partial theme handling; not centralized
Building check-engine	<code>building_status.py</code> , <code>FaultsPage</code> , <code>BuildingInsightDashboard</code>	Single source for alerts
FDD batch + analytics	<code>fdd_results.py</code> , <code>fdd_fault_analytics.py</code>	Per-run sample analytics,

Area	Location	Notes
		equipment enrichment
Poll / model health	poll_throughput.py, model_health.py, device_poll_health.py	Used by agent, not dashboard analytics pages
Zone temp analytics	zone_temp_analytics.py	VAV comfort metrics via agent routes
Central RCx DOCX	portfolio/central/rcx_report.py, fault_hours.py	Central-only (POST /api/central/rcx/report)
Generic open_fdd reports	open_fdd/reports/docx_generator.py, fault_viz.py	Equipment FDD reports, optional deps
Portfolio desk	portfolio/dash/app.py, portfolio/central/api.py	Separate Dash + FastAPI stack
Frontend unit tests	14 Vitest files under workspace/dashboard/src/lib/	Not in CI
Bridge Python tests	tests/workspace_bridge/, tests/portfolio/	Strong coverage for building insight, central

176.2 What partially exists

- **Theme toggle** — app shell updates; Plotly uses inline colors in `plot-chart.ts` / `HostStatsPage.tsx` (inconsistent).
- **Fault display** — equipment names in check-engine alerts when model maps columns; catalog page is not analytics-focused.
- **RCx DOCX** — portfolio central builder with basic sections; not exposed on edge bridge; no chart/section checkboxes.
- **Fault hours** — `portfolio/central/fault_hours.py` estimates from rollups; FDD run analytics has duration estimates but no REST aggregation.
- **Demo data** — `workspace/data/acme_gl36_model.json`, `fdd_results.json`, `samples/demo_site.csv`; no unified analytics fixture.

176.3 What is missing (this branch targets)

- Shared `getPlotlyThemeLayout()` helper + all charts using it

- Analytics pages: Overview, Fault Analytics, Equipment, BACnet/Model Health, RCx Report Builder
- Bridge REST: /api/analytics/overview, /faults, /equipment/{id}, /model-health, /reports/rcx/preview, /reports/rcx/generate
- Edge RCx DOCX with selectable sections/charts (open_fdd/reports/rcx_docx.py)
- Fault-hour aggregation module with tests
- Demo analytics fixture for CI
- Docs: docs/dashboard-analytics.md, docs/rcx-report-builder.md

176.4 Files inspected

AGENTS.md, README.md, pyproject.toml
 workspace/dashboard/src/App.tsx, AppLayout.tsx, theme-context.tsx, plot-chart.ts
 workspace/api/openfdd_bridge/main.py, building_status.py, fdd_results.py, fdd_fault_analytics.py
 workspace/api/openfdd_bridge/routes/analytics_routes.py
 portfolio/central/rcx_report.py, fault_hours.py, api.py
 open_fdd/reports/
 tests/workspace_bridge/, tests/portfolio/test_central.py

176.5 Recommended implementation path

1. **Foundation** — open_fdd/reports/fault_hours.py, charts.py, rcx_docx.py; bridge dashboard_analytics.py + routes; deps in bridge requirements.
2. **Theme** — plotly-theme.ts; refactor plot-chart.ts + HostStatsPage.tsx.
3. **UI** — Analytics nav section + pages wired to new APIs; RCx Report Builder with preview/generate.
4. **Fixtures + tests** — demo JSON, backend pytest, Vitest for theme + report builder.
5. **Docs** — operator-facing how-to.

176.6 Known risks

- **Scope** — full prompt is multi-PR; this branch delivers edge dashboard + bridge RCx; Central Dash remains separate.
- **Live BACnet** — analytics read persisted FDD/model/poll data only (read-only).
- **Trend charts in RCx** — need timeseries API + point roles; may be partial when historian empty.
- **ACME coupling** — use demo fixture + model-driven roles, not hard-coded point names.

177 Rcx Central Current State

178 OpenFDD RCx Central — current state

Branch: feature/rcx-central-edge-analytics-docx
Updated: 2026-05-30

178.1 Product names

User-facing	Internal path
OpenFDD Edge	workspace/, docker/, GHCR images
OpenFDD RCx Central	portfolio/ (Dash + Central API)

178.2 Entrypoints

Service	Command	Port
RCx Central Dash	python -m portfolio.dash / ./scripts/run_portfolio_dash.sh	8050
RCx Central API	./scripts/run_central_api.sh → python scripts/run_central_api.py	8060
Docker (both)	./scripts/run_rcx_central_docker.sh	8050, 8060

178.3 Central API (new/changed)

- GET/POST/PUT/DELETE /api/central/edges, POST /api/central/edges/test
- GET /api/central/mechanical-summary/{site_id}
- GET /api/central/fdd-analytics/{site_id}
- POST /api/central/rcx/preview, /charts/preview, /report
- POST /api/central/rcx/report-legacy (backward compatible)

178.4 Edge REST (read-only)

Model: /api/model/tree, /api/model/health, SPARQL, /api/model/fdd-query-presets

Trends: /api/timeseries/readings, /api/timeseries/series

Analytics: /api/analytics/overview, /api/analytics/faults

Faults: /api/faults/status

Collect: /api/building/portfolio-rollup

178.5 Dash UI tabs

Overview · Edge Connections · Mechanical Summary · FDD Analytics · Trend Explorer · RCx Report Builder · Validation Runs · Settings

Header: **OpenFDD RCx Central**

178.6 RCx / charts

- portfolio/central/chart_preview.py — matplotlib base64 previews, fault overlay bands from timeseries fault flags
- portfolio/central/trend_charts.py — role→column mapping, trend fetch
- portfolio/central/fdd_analytics.py — rules + chart packs
- open_fdd/reports/rcx_docx.py — DOCX when installed

178.7 Docker

docker/rcx-central/ — Dockerfile, compose, volumes rcx-central-data, rcx-central-config

Smoke: scripts/test_rcx_central_docker.sh, scripts/test_rcx_central_docker.ps1

178.8 Tests

tests/portfolio/test_central.py, test_edge_registry.py, test_chart_preview.py

178.9 Remaining gaps

- GHCR publish for openfdd-rcx-central image tag
- Trend Explorer tab (placeholder; Overview Plotly charts use local CSV collect)
- Live ACME opt-in manual workflow doc section in CI

- Deeper equipment-tree scope in RCx builder UI
- More chart types (economizer, VAV worst zones)

178.10 Recommended next PR

Publish RCx Central image + expand chart catalog + equipment-tree report scope.

179 Data Model

180 Data Model — sync and FDD queries

180.1 Explorer (BACnet poll sync)

The **Explorer** tab focuses on **BACnet poll CSV** ↔ **model.json** sync status and **Sync poll** → **model**. Write TTL lives under **Advanced** (or SPARQL RDF tools).

180.2 FDD query presets

The **SPARQL** tab includes **FDD / BRICK query presets** — composed queries across `model.json`, rule bindings, and BACnet metadata:

- Rules → Equipment / Sensors / BACnet devices
- Equipment → Points, AHUs/VAVs/Zones
- Missing rule bindings, orphan points, sensor classes, coverage by equipment type

API: GET `/api/model/fdd-query-presets`, GET `/api/model/fdd-query-presets/{id}`.

181 Host Resources

182 Host Resources — Easy Pooge reset

Integrators see a **Danger Zone** on the Host Resources tab for job-site redeploys.

- Typed confirmation: POOGE THIS EDGE
- Dry-run preview by default
- Allowlisted path cleanup (historian, BACnet scratch, exports)
- Optional Linux apt upgrade and GHCR image pull

API: POST /api/host/pooge/preview, POST /api/host/pooge/run (integrator only).

183 Trend Plots

184 Trend plots

The **Trend plot** tab reads feather historian data via GET /api/timeseries/readings.

184.1 HTTP / Tailscale

Charts work over plain HTTP on localhost, LAN, and Tailscale — COOP/CORP security headers are omitted on non-HTTPS origins so Plotly is not blocked.

184.2 Troubleshooting

If the chart is blank, open **Trend plot debug** at the bottom of the tab:

- Endpoint called
- Site, equipment, selected keys
- Series and timestamp row counts
- Last error message

Common fixes: enable BACnet polling, pick points with feather columns, reduce FDD overlay scope.

185 Cloud Exporter

186 Cloud exporter sidecar

Optional openfdd-cloud-exporter container polls the bridge API and POSTs JSON to a webhook-compatible URL (PostBin, webhook.site, etc.).

186.1 Enable (edge compose)

```
export OPENFDD_EXPORT_ENDPOINT=https://webhook.site/your-uuid
export OPENFDD_EXPORT_DRY_RUN=1
docker compose --profile cloud-exporter up -d cloud-exporter
```

Set OPENFDD_EXPORT_DRY_RUN=0 only when you intend live export.

186.2 Security

- Disabled by default (OPENFDD_EXPORT_DRY_RUN=1).
- Does not export operator passwords or auth env files.
- Tokens are redacted in logs.

See workspace/cloud_exporter/README.md for environment variables.

187 Ai Agent Workflow

188 AI agent workflow vs runtime use

188.1 Runtime analyst (no git clone)

1. docker compose -f docker/rcx-central/docker-compose.yml up
2. Open <http://localhost:8050>
3. Add ACME Edge via Tailscale URL in Edge Connections

4. Test → Save → Mechanical Summary → RCx Report Builder → DOCX

Kill container when done. Data persists in Docker volumes.

188.2 Developer / coding agent (git working tree)

Use Cursor or Codex against the open-fdd repo to change Central code, tests, and docs. This requires a clone or working tree — **not** the runtime Docker image alone.

188.3 Secrets

- Never commit portfolio/config/credentials.json or sites.json with passwords
- Use env vars for CI: 0FDD_AGENT_PASSWORD, etc.
- Live ACME tests: OPENFDD_LIVE_ACME=1 only

188.4 Model routing (test triage)

See AGENTS.md — classify CI failures as SIMPLE (primary model) vs COMPLEX (thinking model) before processing.

189 Docker Desktop Windows

190 RCx Central on Docker Desktop (Windows)

190.1 Prerequisites

- Docker Desktop for Windows
- Edge reachable from the host (e.g. Tailscale)

190.2 Run

```
cd open-fdd
docker compose -f docker/rcx-central/docker-compose.yml up --build
```

Open:

- Dash: `http://localhost:8050`
- API health: `http://localhost:8060/health`

No git clone required at runtime if you pull `ghcr.io/bbartling/openfdd-rcx-central` (when published). Build locally with `OPENFDD_IMAGE_TAG=local`.

190.3 Volumes

Volume	Purpose
<code>rcx-central-data</code>	Rollups, reports (<code>portfolio/data/reports/</code>)
<code>rcx-central-config</code>	<code>sites.json</code> , masked credentials

190.4 Tailscale networking

If Edge is reachable on the Windows host but not from inside the Linux container:

1. Test from host: `curl https://<tailscale-ip>:8765/health`
2. Test from container: `docker compose exec rcx-central-api curl -s http://<tailscale-ip>:8765/health`
3. If container cannot route, use the host's Tailscale IP (Docker Desktop often routes LAN correctly) or document `host.docker.internal` proxy for dev.

190.5 Smoke test

```
./scripts/test_rcx_central_docker.sh
```

Windows PowerShell variant: run `compose up`, then `curl` health URLs manually per steps above.

191 Edge Auth

192 Edge authentication (RCx Central)

192.1 Browser flow

1. Open RCx Central → **Edge Connections**
2. Enter site_id, name, Edge base URL (https://<tailscale-ip>:8765)
3. Enter username/password (or bearer token via API)
4. **Test Connection** — probes /health, /api/model/health, /api/faults/status
5. **Save Edge** — writes to portfolio/config/sites.json + credentials.json (Docker volume)

192.2 API

```
GET /api/central/edges
POST /api/central/edges
POST /api/central/edges/test
PUT /api/central/edges/{site_id}
DELETE /api/central/edges/{site_id}
```

Secrets are **never** returned in API responses or committed to git.
Passwords are masked in UI after save.

192.3 Auth types

- password — POST /api/auth/login on Edge
- bearer — static token in credentials store
- none — public Edge endpoints only (dev)

192.4 Rejected URLs

file://, ftp://, and hosts without scheme are rejected.

193 Index

194 OpenFDD RCx Central

OpenFDD RCx Central is the local analyst / RCx engineer dashboard. It runs on an analyst workstation or **Docker Desktop (Windows/Linux)** — not on the OT edge by default.

Product	Role
OpenFDD Edge	Arrow-native, no-pandas OT-LAN FDD machine at the building
OpenFDD RCx Central	Read-only multi-edge analytics, chart preview, DOCX reports

Internal source path: `portfolio/` (package name unchanged).

194.1 Quick start (host Python)

```
pip install -r portfolio/requirements.txt
./scripts/run_central_api.sh    # :8060
./scripts/run_portfolio_dash.sh # :8050
```

194.2 Docker Desktop

```
./scripts/run_rcx_central_docker.sh
# Dash http://localhost:8050  API http://localhost:8060/health
```

See [docker-desktop-windows.md](#).

194.3 Pages

- Overview — collected rollup trends (Plotly, light/dark theme)
- Edge Connections — add/test/save Edge URLs (secrets in local volume)
- Mechanical Summary — BRICK equipment counts from Edge APIs
- FDD Rules & Analytics — configured rules, chart packs
- Trend Explorer — pointer to Overview Plotly charts (local collect CSVs)
- RCx Report Builder — matplotlib preview, fault overlays, DOCX download

- Validation Runs — one-off read-only Edge probes
- Settings — API URL and volume paths

Model query details: [model-queries.md](#)

194.4 Safety

RCx Central is **read-only** toward Edge and BACnet. No writes, commands, or setpoint changes.

195 Model Queries

196 Model queries (RCx Central → OpenFDD Edge)

OpenFDD RCx Central reuses the **same read-only Edge REST APIs** as the Edge operator React **Data model** tab. RCx Central does not scrape the React UI.

196.1 Primary endpoints

Method	Edge path	Purpose
GET	/api/model/tree	Equipment + points (BRICK roles, timeseries columns)
GET	/api/model/health	Point/equipment counts, model issues
GET	/api/model/sparql/predefined	Prebuilt SPARQL query list
POST	/api/model/sparql	Run SPARQL (<code>{"query": "..."} </code>)
GET	/api/model/fdd-query-presets	FDD commissioning query presets
GET	/api/model/fdd-query-presets/{id}	Run preset by id

196.2 Trends (matplotlib preview + fault overlays)

Method	Edge path	Purpose
GET	/api/timeseries/series?site_id=	Plottable columns per site
GET	/api/timeseries/readings?site_id=&columns=&hours=	Trend samples + optional FDD fault flags

RCx Central maps BRICK **point roles** (e.g. supply_air_temperature) to historian columns via /api/model/tree, then calls /api/timeseries/readings with include_faults=true for overlay bands.

196.3 Analytics

Method	Edge path	Purpose
GET	/api/analytics/overview	KPIs, fault hours by severity/equipment
GET	/api/analytics/faults?hours=	Fault rows for selected window
GET	/api/analytics/model-health	Stale/missing roles

196.4 RCx Central API wrappers

Method	Central path
GET	/api/central/mechanical-summary/{site_id}
GET	/api/central/fdd-analytics/{site_id}
POST	/api/central/rcx/preview

All calls are **read-only** toward Edge.

197 Report Builder

198 RCx Report Builder (RCx Central)

198.1 Flow

1. Select saved Edge site
2. Choose date range (2h / 24h / 7d)
3. **Collect Data / Preview** — POST /api/central/rcx/preview
4. **Preview Charts** — matplotlib PNG as base64 in browser
5. Select chart/section checkboxes
6. **Generate DOCX** — POST /api/central/rcx/report

Reports save to portfolio/data/reports/ when save_to_volume=true.

198.2 Fault overlays

Preview charts include severity-colored bands when fault rows exist and overlay toggle is on.

198.3 DOCX

Uses open_fdd/reports/rcx_docx.py when available (selectable sections/charts). Falls back to portfolio/central/rcx_report.py.

Read-only safety note is included in every report.

199 Rcx Report Builder

200 RCx Report Builder

The **RCx Report Builder** (/analytics/rcx) collects a read-only snapshot from the edge bridge and generates a Word document.

200.1 Workflow

1. Choose report window (2 h / 24 h / 7 d).
2. Click **Collect Data / Preview** — calls `POST /api/reports/rcx/preview`.
3. Review available vs disabled charts (disabled charts show missing point roles or no fault data).
4. Select sections and charts.
5. Click **Generate DOCX** — `POST /api/reports/rcx/generate` returns `application/vnd.openxmlformats-officedocument.wordprocessingml.document`.

200.2 Implementation

- Preview/readiness: `workspace/api/openfdd_bridge/dashboard_analytics.py`
- DOCX builder: `open_fdd/reports/rcx_docx.py`
- Charts: `open_fdd/reports/charts.py` (matplotlib → BytesIO, no temp PNGs)

200.3 Safety

Report generation is **read-only**. No BACnet writes, commands, overrides, or setpoint changes.

200.4 Dependencies

Bridge API requires `python-docx` and `matplotlib` (see `workspace/api/requirements.txt`).

200.5 Central vs edge

Portfolio Central (`portfolio/central/rcx_report.py`, port 8060) supports multi-site rollups. The edge builder uses local FDD results and building status for single-site RCx exports from the operator UI.