

Open-FDD Documentation

Generated by scripts/build_docs_pdf.py

June 16, 2026

- 1 Home
- 2 Open-FDD
 - 2.1 Who it is for
 - 2.2 Start here
 - 2.3 v3 edge stack
 - 2.4 Distribution
 - 2.5 License
- 3 Open-FDD Central / Portfolio / RCx reports
- 4 Open-FDD Central / Portfolio / RCx reports
 - 4.1 Boundary
 - 4.2 Incremental build order
 - 4.3 RCx report content (normalized roles)
 - 4.4 Prerequisites
 - 4.5 Safety
- 5 Arrow rule contract (v1)
- 6 Arrow rule contract (v1)
 - 6.1 Entrypoint
 - 6.2 Return type (authoring)
 - 6.3 Runtime result (ArrowRuleResult)
 - 6.4 Raw mask vs confirmation
 - 6.5 DataFusion SQL rules
 - 6.6 Lint & forbidden imports
 - 6.7 Chunked execution
 - 6.8 Related
- 7 Data types and units
- 8 Data types and units
 - 8.1 Required table shape
 - 8.2 Numeric casting and nulls
 - 8.3 Command normalization
 - 8.4 Boolean / status columns
 - 8.5 Sensor profiles and units
 - 8.6 Time and windows
 - 8.7 Raw fault vs confirmed fault
 - 8.8 Related
- 9 Legacy pandas parity
- 10 Legacy pandas parity matrix
 - 10.1 Helper utilities

- 10.2 GL36 fault conditions (gist classes)
- 10.3 Fault Rule 4 (FC4) — modernized hunting detector
 - 10.3.1 Legacy (pandas gist)
 - 10.3.2 Modern (Open-FDD v1)
- 10.4 Default YAML starter pack (open_fdd/default_rules/)
- 10.5 Fault code mapping
- 10.6 Related
- 11 Rust readiness checklist
- 12 Rust readiness checklist
 - 12.1 Rule style
 - 12.2 Backend choice
 - 12.3 Do not use DataFusion SQL for
 - 12.4 Confirmation and evidence
 - 12.5 Packaging
 - 12.6 Related ADRs
- 13 Run with Docker images
- 14 Run with Docker images
 - 14.1 Images
 - 14.2 1. Install and validate Docker
 - 14.3 2. Bootstrap the site (one script)
 - 14.3.1 Manual start (optional)
 - 14.4 Long-term operation
 - 14.4.1 Survive power cycles
 - 14.4.2 Start / stop / restart
 - 14.4.3 LAN access
 - 14.5 Deployment choices
 - 14.6 Next steps
- 15 First login and health check
- 16 First login and health check
 - 16.1 Public health
 - 16.2 Login
 - 16.3 Smoke checklist
 - 16.4 Stack detail (authenticated)
 - 16.5 Troubleshooting
- 17 Quick Start
- 18 Quick Start
- 19 Updating the stack
- 20 Updating the stack
 - 20.1 Before you start
 - 20.2 Fetch helper scripts (no git clone)
 - 20.3 One-command upgrade (recommended)
 - 20.4 Step by step
 - 20.4.1 1. Backup site state
 - 20.4.2 2. Verify images (optional)
 - 20.4.3 3. Pull and recreate
 - 20.4.4 4. Verify
 - 20.5 Dashboard UI updates
 - 20.6 Rollback
 - 20.7 Safe cleanup
 - 20.8 Next steps
- 21 Local development

22	Local development
22.1	Clone and auth
22.2	Start stack
22.3	BACnet bench overlay (optional)
22.4	Production-like local stack (Caddy, LAN scans)
22.5	Docs preview
23	Build Docker images
24	Build Docker images
24.1	Local build
24.2	Publish to GHCR (maintainers)
25	Developer Guide
26	Developer Guide
27	Tests and CI
28	Tests and CI
28.1	Local tests
28.2	CI (GitHub Actions)
28.3	Docs build (same as CI)
28.4	Security-related CI
29	DataFusion SQL rule recipes
30	DataFusion SQL recipes
30.1	Temperature high
30.2	Humidity high
30.3	Occupied + temperature
30.4	With fault confirmation
31	Contributing
32	Contributing
32.1	Expectations
32.2	Pull request checklist
32.3	Repository layout (short)
32.4	Docs links (GitHub Pages)
32.5	Security issues
32.6	Agent-assisted development
33	Health checks (developer)
34	Health checks (developer)
34.1	Clone and local stack
34.2	Stack health script
34.3	Compose overlays
34.4	BACnet poll pipeline
34.5	pytest (bridge security / BACnet)
34.6	Pentest production stack (LAN ZAP)
34.7	Post-deploy insurance (inventory hosts)
35	Security testing cycle
36	Security testing cycle
36.1	Who owns what
36.2	Per-revision workflow
36.2.1	1. Local functional tests
36.2.2	2. Pentest production stack (on Open-FDD host)
36.2.3	3. Host + exposure checks (on edge VM)
36.2.4	4. LAN security scan (from laptop)
36.2.5	5. Pull request + automated review
36.2.6	6. Release
36.2.7	7. Lab edge validation

- 36.2.8 8. Next cycle
- 36.3 What each scan layer covers
- 36.4 Open-source contributors
- 37 Python recipes (full Arrow library)
- 38 Python recipes — full Arrow library
 - 38.1 Shared helpers (paste once per rule file)
 - 38.2 GL36 AHU Rules A-M
 - 38.2.1 Rule A — duct static low at full fan speed (AHU-A)
 - 38.2.2 Rules B & C — blended air outside OAT/RAT band (AHU-D)
 - 38.2.3 Rule D — discharge cold when heating commanded (AHU-B)
 - 38.2.4 Rule E — SAT too low with full heating (AHU-C)
 - 38.2.5 Rule F — SAT/MAT mismatch in economizer mode (AHU-E)
 - 38.2.6 Rule G — ambient too warm for free cooling (AHU-E)
 - 38.2.7 Rule H — OAT/MAT mismatch (econ + mech cooling) (AHU-E)
 - 38.2.8 Rule I — OAT/MAT mismatch (economizer only) (AHU-E)
 - 38.2.9 Rule J — discharge above blended in cooling (AHU-B)
 - 38.2.10 Rule K — discharge above setpoint in full cooling (AHU-C)
 - 38.2.11 Rule L — cooling coil ΔT when inactive (CH-C)
 - 38.2.12 Rule M — heating coil ΔT when inactive (AHU-B)
 - 38.3 Starter pack (VAV / AHU baseline)
 - 38.3.1 01_vav_zone_temp_bounds_occupied (VAV-C)
 - 38.3.2 02_vav_zone_temp_flatline_occupied (VAV-C)
 - 38.3.3 03_vav_damper_command_extreme_flatline (VAV-D)
 - 38.3.4 04_ahu_runtime_outside_schedule (BLD-C)
 - 38.3.5 05 / 06 / 07 — see Rules A, sensor_bounds_mask on sa-t / sensor_flatline_mask on sa-t
 - 38.4 Economizer starters
 - 38.4.1 ahu_econ_100oa_temp_tracking_fault (AHU-E)
 - 38.4.2 ahu_mech_cooling_when_free_cooling_available (AHU-E)
 - 38.4.3 ahu_oa_damper_excess_open_extreme_ambient (AHU-E)
 - 38.5 VAV zones
 - 38.5.1 zone_reheat_warm_ambient (VAV-A)
 - 38.5.2 zone_damper_valve_full_open (VAV-D)
 - 38.5.3 Zone / IAQ bounds
 - 38.6 Central plant
 - 38.6.1 dp_below_sp_pump_max (CH-E)
 - 38.6.2 flow_high_pump_max (CH-B)
 - 38.6.3 plant_supply_temp_deadband (CH-D)
 - 38.6.4 chiller_excessive_runtime (CH-F)
 - 38.7 Heat pumps
 - 38.7.1 hp_discharge_cold_when_heating (HP-D)
 - 38.8 Opportunistic / ventilation
 - 38.8.1 econ_active_warm_ambient (AHU-E)
 - 38.8.2 mech_cool_when_econ_available (AHU-E)
 - 38.8.3 low_oa_fraction_estimated (VAV-B)
 - 38.8.4 preheat_excess_temp (AHU-B)

- 38.9 Weather station
 - 38.9.1 weather_temp_spike (BLD-B)
 - 38.9.2 weather_gust_lt_wind (BLD-B)
 - 38.9.3 RH bounds
- 38.10 Schedule + weather gating (occupied hours)
- 38.11 FC4 — PID hunting (modernized from legacy GL36)
- 38.12 Next steps
- 39 System overview
- 40 System overview
 - 40.1 Docker edge stack (production)
 - 40.2 Components
 - 40.3 Deployment
 - 40.4 Optional PyPI-only path
- 41 Rule authoring (v1)
- 42 Rule authoring (stable v1)
 - 42.1 YAML in the repo today
 - 42.2 Install extras (packaging)
 - 42.3 Legacy reference
- 43 Deployment modes
- 44 Deployment modes
 - 44.1 Mode summary
 - 44.2 v3 container stack (all edge modes)
 - 44.3 Caddy HTTP (typical edge)
 - 44.4 Caddy TLS (OT LAN)
 - 44.5 BACnet data path
 - 44.6 What not to do on production edges
 - 44.7 Related
- 45 Containers
- 46 Containers
 - 46.1 GHCR images
 - 46.2 Stack diagram
 - 46.3 Responsibilities
 - 46.4 Network and ports (typical edge)
 - 46.5 Long-lived deployment
 - 46.6 Persistent data
 - 46.7 Optional host services
- 47 Data flow
- 48 Data flow
 - 48.1 Telemetry ingest
 - 48.1.1 BACnet
 - 48.1.2 Modbus TCP
 - 48.1.3 JSON API (HTTP/HTTPS)
 - 48.2 Rule evaluation
 - 48.3 Model sync
 - 48.4 Retention
- 49 Architecture
- 50 Architecture
- 51 Fault confirmation / minimum duration
- 52 Fault confirmation
 - 52.1 Config fields
 - 52.2 Example
 - 52.3 Paired smoke default (5 minutes)

53	Rule Cookbook
54	Rule Cookbook
55	Windowing & debugging
56	Windowing & debugging
56.1	Lookback vs rolling window
56.2	Rolling windows (Arrow)
56.3	Rule Lab console
57	Expression cookbook (Arrow-native)
58	Expression cookbook (Arrow-native)
58.1	PyArrow vs DataFusion SQL
58.1.1	Use PyArrow when
58.1.2	Use DataFusion SQL when
58.1.3	Do not use DataFusion SQL for
58.2	Legacy → modern translation
58.3	How Arrow rules are structured
58.3.1	Command scaling (0-1 vs 0-100 %)
58.3.2	Occupied hours (schedule gating)
58.4	Sensor validation (bounds, flatline, rate of change)
58.4.1	Bounds (out of range) — oob_rolling
58.4.2	Flatline (stuck sensor) — flatline_1h
58.4.3	Rate of change (spike) — rate_of_change
58.4.4	Mixing envelope (MAT vs OAT/RAT) — mixing_envelope
58.5	GL36-inspired AHU rules (legacy expression → fault code)
58.6	Starter pack (VAV / AHU baseline)
58.6.1	Economizer starters
58.7	VAV, central plant, heat pump
58.8	Opportunistic / ventilation
58.9	Data quality vs equipment faults
58.10	Metric (°C) equivalents
58.11	Binding rules to the fault catalog
58.12	Pandas YAML → Arrow checklist (commissioning)
59	GL36 algorithm stubs
60	GL36 algorithm stubs (doc-only)
60.1	Shared lookback helper
60.2	VAV zone cooling requests (0-3)
60.3	AHU duct static trim & respond (advisory fault)
60.4	Chiller plant enable (valve request counting)
60.5	Hot water plant HWST trim & respond (advisory)
60.6	Chilled water plant (DP + CHWST reset advisory)
60.7	Testing later
61	Central plants (CHW / CTW / BLR)
62	Central plant Arrow recipes
62.1	Starter fault codes
62.2	Required point roles (CHW)
62.3	Synthetic test pattern
63	Dashboard overview
64	Dashboard overview
64.1	Primary areas
64.2	Live updates
64.3	Roles
65	Auth and roles

- 66 Auth and roles
 - 66.1 Production (LAN / edge)
 - 66.2 Localhost dev
- 67 Rule Lab
- 68 Rule Lab
 - 68.1 Equipment-scoped test and export
 - 68.2 Export all rules
 - 68.3 Workflow
 - 68.4 Dev kit zip (download)
 - 68.5 Lookback windows
 - 68.6 Algorithms (supervisory — coming soon)
 - 68.7 Related
- 69 JSON API driver
- 70 JSON API driver
 - 70.1 Supported features
 - 70.2 Secrets: `json_api.env.local`
 - 70.3 OpenWeatherMap showcase (recommended demo)
 - 70.3.1 1. Configure env
 - 70.3.2 2. Register from the UI
 - 70.3.3 3. Headless / script
 - 70.3.4 4. FDD: local OA-T vs web weather
 - 70.4 Commissioning (UI)
 - 70.4.1 API for agents
 - 70.4.2 Bench preset
 - 70.5 Authentication examples
 - 70.5.1 Query-string API key via env (OpenWeather)
 - 70.5.2 Bearer token (API key)
 - 70.5.3 HTTP Basic
 - 70.5.4 POST with JSON body
 - 70.6 REST API
 - 70.7 Typical OT URLs
 - 70.8 Limitations
 - 70.9 Disable polling (save API quota)
 - 70.10 Smoke test
- 71 Algorithms
- 72 Algorithms (coming soon)
 - 72.1 GL36 Trim & Respond reference
 - 72.2 Planned workflow (same kit shape as Rule Lab)
 - 72.3 Lookback windows
 - 72.4 AHU supervisory checks (doc-only stubs)
 - 72.4.1 Duct static pressure too high
 - 72.4.2 Supply air temperature too cold (cooling coil over-delivering)
 - 72.5 Plant supervisory checks (doc-only)
 - 72.6 Related
- 73 Model workflow
- 74 Model workflow
 - 74.1 Brick model
 - 74.2 Typical integrator flow
- 75 Driver framework
- 76 Driver framework
 - 76.1 Drivers

- 76.2 Data layout
- 76.3 Historian and FDD
- 76.4 Rule Lab (Arrow upload/download)
- 76.5 Smoke validation
- 76.6 Related docs
- 77 Operator Bridge
- 78 Operator Bridge
- 79 Ollama and analytics
- 80 Ollama and analytics
 - 80.1 What runs without login
 - 80.2 Ollama setup
 - 80.3 Automatic analytics (deterministic, always on)
 - 80.4 When Ollama is used
 - 80.5 AI Agent (authenticated)
 - 80.6 Code map
- 81 FDD and assignments
- 82 FDD and assignments
 - 82.1 What the product actually does
 - 82.1.1 BRICK modeling (integrator + AI-assisted)
 - 82.1.2 Rule assignment (three binding kinds)
 - 82.1.3 CLASS vs device
 - 82.2 Commissioning JSON shape
 - 82.2.1 Rule names vs ids (Rule Lab alignment)
 - 82.3 Related
- 83 Network setup
- 84 Network setup
 - 84.1 Bind address
 - 84.2 Discovery range
 - 84.3 Verify
- 85 Discover and read
- 86 Discover and read
 - 86.1 Operator workflow
- 87 Polling
- 88 Polling
 - 88.1 Commission poll loop (default)
 - 88.2 Bridge ingest worker
 - 88.3 Health
 - 88.4 Poll strategy (edge)
 - 88.5 Async driver and single-stack I/O
 - 88.6 Operator override scans
- 89 Operator override scans
- 90 Operator override scans (P8)
 - 90.1 Schedule
 - 90.2 What each scan does
 - 90.3 BACnet I/O priority
 - 90.4 Manual trigger
 - 90.5 Health checks
 - 90.6 Data paths
- 91 Write safety
- 92 Write safety
 - 92.1 Defaults
 - 92.2 Enable writes (commission role)

- 92.3 Operator rules
- 93 BACnet
- 94 BACnet
- 95 Convention
- 96 Fault code convention
 - 96.1 Format (Grade-A, 3.0.18+)
 - 96.2 Categories (Grade-A)
 - 96.3 Severity
 - 96.4 Linking rules
 - 96.5 Cookbook mapping
- 97 Live site update
- 98 Live site update
 - 98.1 Layout on the edge host
 - 98.2 Concepts
 - 98.3 1. Verify new images on GHCR
 - 98.4 2. Update dashboard UI (when release changed React)
 - 98.5 3. Pull and recreate (edge host)
 - 98.6 4. Ansible image-only (control machine)
 - 98.7 5. Validate
 - 98.8 Rollback
 - 98.9 Related
- 99 Central collection
- 100 OpenFDD RCx Central — collection
 - 100.1 Interval summary schema
 - 100.2 Edge export formats
 - 100.3 Collect today (rollup API)
 - 100.4 Tuning proposals
- 101 AHU faults
- 102 AHU faults
- 103 Standards crosswalk
- 104 Standards crosswalk
 - 104.1 Example
- 105 Backup and restore
- 106 Backup and restore
 - 106.1 Quick backup (edge host)
 - 106.2 Manual backup (SSH)
 - 106.3 What to protect
 - 106.4 Restore after a bad upgrade
 - 106.5 Safe cleanup
 - 106.6 Related
- 107 OpenFDD RCx Central API
- 108 OpenFDD RCx Central API
 - 108.1 Start
 - 108.2 Edge registry (browser auth)
 - 108.3 Analytics & RCx
 - 108.4 Validation (legacy collect workflow)
 - 108.5 RCx report body
- 109 VAV faults
- 110 VAV faults
- 111 Docker images (GHCR)
- 112 Docker images (GHCR)
 - 112.1 Images

- 112.2 Tags
- 112.3 Publish
- 112.4 vs PyPI
- 113 RTU faults
- 114 RTU faults
- 115 Deployment validation
- 116 Deployment validation
 - 116.1 Edge host smoke (5 minutes)
 - 116.2 Browser checklist
 - 116.3 Control-machine insurance check
 - 116.4 LAN security smoke (optional)
 - 116.5 Arrow / FDD rules (3.0+)
 - 116.6 Related
- 117 Sensor and data quality
- 118 Sensor and data quality
 - 118.1 Catalog codes
 - 118.2 Default bounds (imperial, occupied)
 - 118.3 Communication quality
 - 118.4 Operator workflow
- 119 Logging and audit
- 120 Logging and audit
 - 120.1 Log types
 - 120.2 Audit record schema
 - 120.2.1 Auth events (industry-standard login trail)
 - 120.2.2 OT / commissioning events
 - 120.2.3 Secret redaction
 - 120.3 Integrator API (read logs in the UI stack)
 - 120.4 Retention and rotation (defaults)
 - 120.5 Docker edge: json-file caps (not journald for app audit)
 - 120.6 Local dev (run_local.sh)
 - 120.7 Quick checks
 - 120.8 Comparison to typical web apps
 - 120.9 Related
- 121 GHCR image retention
- 122 GHCR image retention
 - 122.1 Policy (conservative)
 - 122.2 Dry-run first
 - 122.3 Protect Acme rollback tags
 - 122.4 Run locally
 - 122.5 GitHub Actions workflow
 - 122.6 Permissions
 - 122.7 Verify images still pull
 - 122.8 Rollback example
 - 122.9 Related issues
- 123 Fault Codes
- 124 Fault Codes
- 125 Operations
- 126 Operations
- 127 Portfolio
- 128 Portfolio (central desk)
- 129 Acme VAV/AHU rule guidance

- 130 Acme VAV/AHU FDD rule bundle
 - 130.1 Mixed manufacturers and units
 - 130.2 Rule matrix
 - 130.2.1 Phase 2+ (not enabled by default)
 - 130.2.2 Phase 3 rollups (future)
 - 130.3 Data model checks
 - 130.4 Tuning notes
 - 130.5 JSON API weather + BACnet OAT
 - 130.6 BACnet override scans
 - 130.7 Docker backup / recovery
- 131 Bench 5007 dual-source smoke
- 132 Bench 5007 dual-source smoke
 - 132.1 Run
 - 132.2 Paired semantic points
- 133 Bench 5007 long FDD smoke
- 134 Bench 5007 long FDD smoke
 - 134.1 Commands
 - 134.2 Key environment
 - 134.3 Fault confirmation window
 - 134.4 Artifacts
 - 134.5 Pass / fail
 - 134.6 Related
- 135 ACME live validation
- 136 ACME live validation
 - 136.1 Model export / import
 - 136.2 Run FDD (read-only)
 - 136.3 Reports
 - 136.4 Fault confirmation
 - 136.5 Safe rules on ACME
 - 136.6 Related
- 137 AI agent context
- 138 AI agent context
 - 138.1 1. Open-FDD in one paragraph
 - 138.2 2. Deployment mental model
 - 138.3 3. Source / driver modes
 - 138.4 4. Data model contract
 - 138.5 5. Rule execution contract
 - 138.6 6. Fault confirmation window
 - 138.7 7. Validation modes
 - 138.8 8. Security rules
 - 138.9 9. Where to look
- 139 LAN hardening
- 140 LAN hardening
 - 140.1 Auth and bind
 - 140.2 Network exposure
 - 140.3 Rule Lab
 - 140.4 TLS and LAN security scans
 - 140.5 Ollama on the edge
- 141 ZAP baseline (local bench)
- 142 ZAP baseline (local bench)
 - 142.1 Run
 - 142.2 Expected results (HTTP bench mode)

- 142.3 Header ownership
- 142.4 Authenticated scan (later)
- 142.5 After fixes
- 143 TLS and certificates
- 144 TLS and certificates
 - 144.1 Ownership
 - 144.2 Generate bench certs (local)
 - 144.3 ZAP / Nmap with TLS bench
 - 144.4 Renewal
 - 144.5 Enterprise CA on Caddy (edge)
 - 144.6 Caddy internal CA mode (lab)
 - 144.7 Secrets
- 145 Authenticated scanning (roadmap)
- 146 Authenticated scanning (roadmap)
 - 146.1 Current state (3.0.x)
 - 146.2 Why baseline is not enough
 - 146.3 Planned approach (contributors welcome)
 - 146.4 Manual authenticated ZAP today
 - 146.5 Related
- 147 Secrets and auth
- 148 Secrets and auth
 - 148.1 Files (gitignored)
 - 148.2 Required variables (production)
 - 148.3 GHCR pulls
 - 148.4 Backup
- 149 BACnet write allowlists
- 150 BACnet write allowlists
- 151 Linux host hardening
- 152 Linux host hardening
 - 152.1 Scope
 - 152.2 Quick operator workflow
 - 152.3 Ubuntu version and EOL
 - 152.4 Kernel and package updates
 - 152.5 Host Python (pip, wheel, pyOpenSSL)
 - 152.6 Ollama — no LAN exposure
 - 152.7 OpenSSH Terrapin (CVE-2023-48795)
 - 152.8 ICMP timestamp (Low)
 - 152.9 TLS and certificate scans
 - 152.10 Maintainer security audits (CI parity)
- 153 Tenable / Nessus remediation
- 154 Tenable / Nessus remediation
 - 154.1 Prioritized action plan
 - 154.2 Finding classification table
 - 154.3 Operator commands (edge VM)
 - 154.3.1 Validate (read-only)
 - 154.3.2 Remediate host (maintenance window)
 - 154.3.3 Remediate Open-FDD containers
 - 154.3.4 Rescan
 - 154.4 Ollama unauthenticated access (Critical)
 - 154.5 pyOpenSSL and pip in containers
 - 154.6 TLS — expected vs production
 - 154.7 Residual findings after remediation

- 154.8 Notes for IT / security team
- 154.9 Repo-owned fixes (this document's release)
- 155 AI agents
- 156 AI agents and MCP
- 157 Security
- 158 Security
- 159 API routes
- 160 API routes
 - 160.1 Health & audit
 - 160.2 Auth
 - 160.3 Rules & FDD
 - 160.4 Rule Lab playground
 - 160.5 BRICK / data model
 - 160.6 Rule Lab (dashboard)
 - 160.7 Bench validation (read-only)
 - 160.8 Niagara baskStream
 - 160.9 BACnet
 - 160.10 Faults (check-engine)
 - 160.11 Timeseries & sites
 - 160.12 Building & host
 - 160.13 Local agent (Ollama)
 - 160.14 Modbus
 - 160.15 JSON API (HTTP/HTTPS)
 - 160.16 PyPI package (separate)
 - 160.17 Errors
- 161 Python package
- 162 Python package (open-fdd)
 - 162.1 Modules
 - 162.2 When to use package-only
 - 162.3 Versioning
 - 162.4 Offline Arrow example
- 163 Configuration reference
- 164 Configuration reference
 - 164.1 Bridge / auth
 - 164.2 BACnet
 - 164.3 Docker edge
- 165 Glossary
- 166 Glossary
- 167 Workspace env files
- 168 Workspace env files
 - 168.1 Ansible / edge extras
 - 168.2 Related docs
- 169 Appendix
- 170 Appendix
- 171 GL36 lab site (Acme)
- 172 GL36 lab site (Acme)
 - 172.1 BACnet poll scope
 - 172.2 Example FDD rules (Arrow)
 - 172.2.1 Duct static pressure high (AHU)
 - 172.2.2 SAT too cold vs setpoint
 - 172.2.3 Site rule stubs in the repo
 - 172.2.4 Local OA-T vs web weather (JSON API)

- 172.3 Deploy / upgrade (Ansible, this lab only)
- 172.4 AI-assisted data modeling (lab workflow)
- 173 Examples & lab notes
- 174 Examples & lab notes
- 175 Paired FDD smoke (bench + Acme)
- 176 Paired FDD smoke
 - 176.1 What is tested
 - 176.2 Fault confirmation (5 minutes)
 - 176.3 Modes (hardcoded)
 - 176.4 Run detached (required for in-depth runs)
 - 176.5 Run
 - 176.6 Reports
 - 176.7 Pass criteria
- 177 Arrow-native runtime
- 178 Arrow-native runtime
 - 178.1 Authoring contract
 - 178.2 PyArrow-only policy (edge + Rule Lab)
 - 178.3 Package layout
- 179 Release process
- 180 Release process
 - 180.1 1. Prepare version
 - 180.2 2. Merge and tag
 - 180.3 3. PyPI Trusted Publishing setup (one-time)
 - 180.4 4. Verify release
 - 180.5 5. Manual workflow_dispatch
 - 180.6 Package vs Docker
- 181 PyPI package
- 182 PyPI package (open-fdd)
 - 182.1 What it is
 - 182.2 What it is not
 - 182.3 Install
 - 182.4 CLI
 - 182.5 Rule contract
 - 182.6 Modules shipped on PyPI
 - 182.7 Examples
 - 182.8 Local validation
- 183 MCP server
- 184 Open-FDD MCP server
 - 184.1 Modes
 - 184.2 Transport
 - 184.3 Human approval
 - 184.4 Client examples
 - 184.5 Site registry example
 - 184.6 RCx Central (not MCP)
 - 184.7 Fault code labels (agents)
 - 184.8 Doc RAG refresh
 - 184.9 Module layout
- 185 Adr Datafusion Rust Ready Rule Backend
- 186 ADR: DataFusion as optional Rust-ready rule backend
 - 186.1 Status
 - 186.2 Context
 - 186.3 Decision

- 186.4 Why
- 186.5 Non-goals (this milestone)
- 186.6 Future path
- 186.7 Consequences
- 187 Adr Rust Ready Arrow Fdd Contract
- 188 ADR: Rust-ready Arrow FDD contract
 - 188.1 Status
 - 188.2 Context
 - 188.3 Decision
 - 188.4 Consequences
- 189 Bench Validation Agent
- 190 Bench validation agent (local benserver)
 - 190.1 Topology
 - 190.2 One-command validation
 - 190.3 API tools (bridge must be running)
 - 190.4 MCP / agent notes
 - 190.5 Overnight
- 191 Rcx Central Dash Agent
- 192 RCx Central Dash — agent guide
 - 192.1 Runtime stack (benserver / analyst workstation)
 - 192.2 Dash UI (2026-06)
 - 192.3 Edge parity (Data Model tab)
 - 192.4 BRICK equipment typing (common bug)
 - 192.5 Fault codes (stable labels)
 - 192.6 Central API routes (agent smoke)
 - 192.7 Tests
 - 192.8 PRs (typical split)
 - 192.9 Related
- 193 Rcx Central Overnight Patch Cycle
- 194 RCx Central overnight patch-cycle (agent runbook)
 - 194.1 Safety (non-negotiable)
 - 194.2 One patch cycle
 - 194.3 GH Actions
 - 194.4 RCx Central local
 - 194.5 Live ACME (gated)
 - 194.6 Try-out vs overnight
 - 194.7 Rev bump / deploy
 - 194.8 Branch cleanup after merge
- 195 Bench Bacnet Vs Niagara
- 196 BACnet direct vs Niagara bench validation
 - 196.1 Topology
 - 196.2 Quick start
 - 196.3 Mapping config
 - 196.4 Brick model
 - 196.5 Normalized data model
 - 196.6 Poll intervals
 - 196.7 Overnight smoke
 - 196.8 Read-only rules
- 197 Dashboard Analytics
- 198 Dashboard analytics
 - 198.1 Pages
 - 198.2 API (read-only)

- 198.3 Fault hours
- 198.4 Theme
- 198.5 Tests
- 199 Datafusion Sql Rules
- 200 DataFusion SQL rules (optional)
 - 200.1 When to use SQL vs PyArrow
 - 200.1.1 Do not use DataFusion SQL for
 - 200.2 Rule metadata (saved rules)
 - 200.3 Safety
 - 200.4 Rules Lab
- 201 Dashboard Rcx Makeover Inventory
- 202 Dashboard + RCx Makeover — Inventory
 - 202.1 What exists
 - 202.2 What partially exists
 - 202.3 What is missing (this branch targets)
 - 202.4 Files inspected
 - 202.5 Recommended implementation path
 - 202.6 Known risks
- 203 Rcx Central Current State
- 204 OpenFDD RCx Central — current state
 - 204.1 Product names
 - 204.2 Entrypoints
 - 204.3 Central API
 - 204.4 Edge REST (read-only, shared with Data Model tab)
 - 204.5 Dash UI tabs
 - 204.6 Pre-Docker owner checklist (benserver :8050)
 - 204.7 BRICK model notes (agents)
 - 204.8 Fault codes
 - 204.9 Agent docs
 - 204.10 Tests
 - 204.11 Remaining gaps
- 205 Short Lookup
- 206 Fault code short descriptions
- 207 Niagara Baskstream Connector
- 208 Niagara baskStream connector (read-only)
 - 208.1 Read-only posture
 - 208.2 Niagara station setup
 - 208.2.1 Health check behavior
 - 208.3 Open-FDD configuration
 - 208.3.1 ORD encoding
 - 208.3.2 Allowed Origins
 - 208.4 Dependencies
 - 208.5 Polling
 - 208.6 Bench reference (benserver)
- 209 Data Model
- 210 Data Model — sync and FDD queries
 - 210.1 Explorer (BACnet poll sync)
 - 210.2 FDD query presets
- 211 Host Resources
- 212 Host Resources — Easy Pooge reset
- 213 Trend Plots

- 214 Trend plots
 - 214.1 HTTP / Tailscale
 - 214.2 Troubleshooting
- 215 Cloud Exporter
- 216 Cloud exporter sidecar
 - 216.1 Enable (edge compose)
 - 216.2 Security
- 217 Overnight Bench Smoke
- 218 Overnight bench smoke test
 - 218.1 Command
 - 218.2 Each checkpoint
 - 218.3 Final deliverable
 - 218.4 GH Actions loop
- 219 Ai Agent Workflow
- 220 AI agent workflow vs runtime use
 - 220.1 Three agent surfaces
 - 220.2 Runtime analyst (no git clone)
 - 220.3 Developer / coding agent (git working tree)
 - 220.4 Model / SPARQL validation (Acme)
 - 220.5 Secrets
 - 220.6 Model routing (test triage)
- 221 Docker Desktop Windows
- 222 RCx Central on Docker Desktop (Windows)
 - 222.1 Prerequisites
 - 222.2 Run
 - 222.3 Volumes
 - 222.4 Tailscale networking
 - 222.5 Smoke test
- 223 Edge Auth
- 224 Edge authentication (RCx Central)
 - 224.1 Browser flow
 - 224.2 API
 - 224.3 Auth types
 - 224.4 Rejected URLs
- 225 Index
- 226 OpenFDD RCx Central
 - 226.1 Quick start (host Python)
 - 226.2 Docker Desktop
 - 226.3 Pages
 - 226.4 Safety
- 227 Model Queries
- 228 Model queries (RCx Central → OpenFDD Edge + local TTL mirror)
 - 228.1 Primary endpoints
 - 228.2 Trends (matplotlib preview + fault overlays)
 - 228.3 Analytics
 - 228.4 RCx Central API wrappers
 - 228.5 FDD preset ids (Edge parity)
 - 228.6 BRICK typing (do not mis-count AHUs/VAVs)
- 229 Overnight Acme Validation
- 230 Overnight ACME validation via RCx Central
 - 230.1 Prerequisites

- 230.2 Try-out (2 cycles, no sleep)
- 230.3 Overnight (10 cycles, 2 h spacing)
- 230.4 Read-only scope
- 231 Patch Cycle Release Process
- 232 Patch-cycle release process
 - 232.1 Authorization flags
 - 232.2 Image bump (when authorized)
- 233 Report Builder
- 234 RCx Report Builder (RCx Central)
 - 234.1 Flow
 - 234.2 Fault overlays
 - 234.3 DOCX
- 235 Rcx Report Builder
- 236 RCx Report Builder
 - 236.1 Workflow
 - 236.2 Implementation
 - 236.3 Safety
 - 236.4 Dependencies
 - 236.5 Central vs edge
- 237 3.1.2
- 238 Open-FDD 3.1.2
 - 238.1 Highlights
 - 238.2 Known warnings
 - 238.3 Validation
- 239 3.1.3
- 240 Open-FDD 3.1.3
 - 240.1 Patch fixes
 - 240.2 GHCR tags
 - 240.3 Validation
- 241 Release 3.1.5
- 242 Release 3.1.5
 - 242.1 Dashboard & operator UX
 - 242.2 Rule authoring docs (v1)
 - 242.3 Fixes
 - 242.4 Smoke

Generated June 16, 2026

1 Home

2 Open-FDD

Open-FDD is an open-source **building edge platform** for BACnet integration, feather historian storage, Arrow-native fault detection, and operator dashboards — designed for **trusted LAN / OT edge** deployment behind Caddy, not direct public internet exposure.

2.1 Who it is for

Role	What you get
IT / controls engineer	Pull three GHCR images, log in, poll BACnet, view faults
Commissioning integrator	Discover points, bind BRICK model, pin FDD rules in Rule Lab
Developer / maintainer	Extend the Operator Bridge, publish images, run CI and LAN security scans

2.2 Start here

Path	Go to
Try it	[Quick Start — Run with Docker] (<code>{{ "/quick-start/docker/"</code>
Operate it	Updating the stack (<code>{{ "/quick-start/updates/"</code>
Develop it	Developer Guide (<code>{{ "/developer/"</code>

2.3 v3 edge stack

Three primary containers on a Linux edge host:

Container	Role
openfdd-bridge	Operator Bridge — API, dashboard, feather ingest
openfdd-commission	BACnet discover/read/write + poll loop

Container	Role
openfdd-mcp-rag	Doc-search sidecar for agent tools

Host **Caddy** on :80 or :443 is the normal LAN front door. BACnet UDP :47808 is bound by **commission** only — the bridge ingests samples.csv into the feather historian.

Details: `Containers({{ "/architecture/containers/" | relative_url }}) · Deployment modes({{ "/architecture/deployment-modes/" | relative_url }})`

LAN / OT edge only. Do not expose the Operator Bridge to the public internet without TLS, strong auth, and site review. BACnet writes are disabled by default — see [BACnet write guard]({{ "/security/bacnet-writes/" | relative_url }}).

2.4 Distribution

Channel	Use when
GHCR ghcr.io/bbartling/openfdd-*	Production or trial edge deploy
This repository	Custom builds, commissioning, Rule Lab development
PyPI open-fdd	Arrow runtime lint/test without full UI

2.5 License

MIT — see repository LICENSE.

3 Open-FDD Central / Portfolio / RCx reports

4 Open-FDD Central / Portfolio / RCx reports

Planning doc for the next feature branch: feature/openfdd-central-portfolio-rcx-reports.

4.1 Boundary

Layer	Role
Open-FDD Edge	Lives at the building. BACnet, local FDD, model/ trends/faults, safe REST APIs.
Open-FDD Central	Multi-building desk over Tailscale/VPN. No direct BACnet. No equipment commands. Validation jobs, RCx reports, portfolio health.

Existing code to extend (do not rewrite):

- `portfolio/collector/` — edge login, rollup fetch, CSV history
- `portfolio/dash/` — multi-site Dash dashboard
- `scripts/portfolio_collect.py` — collector CLI
- Edge APIs: `/api/building/portfolio-rollup`, `/api/faults/status`, `/api/fdd/results`

4.2 Incremental build order

1. **Edge registry** — extend `portfolio/sites.json` schema (name, base URL, `site_id`, last check-in).
2. **Remote edge client** — reuse `portfolio/collector/edge_client.py`; add validation job endpoints.
3. **Portfolio page** — edge health, BACnet/model/fault status, last check-in.
4. **One-off validation** — trigger read-only harness against one edge (`acme_overnight_fdd_validate` pattern).
5. **24-hour validation planner** — dropdown intervals (2h / 6h / 12h), store cycle results.
6. **Fault-hour analytics** — elapsed fault hours from historian + FDD runs.
7. **Minimal DOCX generator** — `python-docx` + `matplotlib` (BytesIO charts).
8. **Report download endpoint** — query edges via REST, render `.docx`.
9. **Tests/fixtures** — deterministic edge mocks; no live BACnet in CI.

4.3 RCx report content (normalized roles)

- Elapsed fault hours by equipment/severity

- SAT vs setpoint, duct static vs setpoint
- Fan/motor runtime analytics
- Missing data warnings
- Duplicate/model warnings from edge audit APIs
- **Never** severity-only cards without equipment context

4.4 Prerequisites

- ACME validation PR merged and **3.0.33** deployed (equipment context on live FDD alerts).
- Follow-ups: FDD run-history equipment grouping, RTU role mapping (see [ACME validation follow-ups]({{ "/ops/acme-validation-follow-ups/" | relative_url }})).

4.5 Safety

Central is read-only toward edges. No BACnet writes, commands, or BAS changes from Central.

5 Arrow rule contract (v1)

6 Arrow rule contract (v1)

Stable v1 batch FDD, Rule Lab preview, and validation smokes share one execution contract.

6.1 Entrypoint

```
def apply_faults_arrow(table: pa.Table, cfg: dict | None = None,
context: dict | None = None):
    ...
```

Parameter	Type	Notes
table	pyarrow.Table	Historian telemetry for one site/window
cfg	dict	Rule thresholds, column names, confirmation settings
context	dict None	

Parameter	Type	Notes
		Optional bridge metadata (site_id, equipment hints)

6.2 Return type (authoring)

`apply_faults_arrow` must return a **boolean** `pyarrow.Array` or `pyarrow.ChunkedArray`:

- Length **must equal** `table.num_rows`
- `True` = raw fault sample (before confirmation)
- Non-boolean returns are cast to `bool` by the backend
- Null slots in the mask are counted; prefer explicit `False` for missing inputs

The backend normalizes via `open_fdd.arrow_runtime.backend.normalize_fault_mask`.

6.3 Runtime result (ArrowRuleResult)

After execution, `run_arrow_rule()` produces `ArrowRuleResult`:

Field	Meaning
<code>rule_id</code>	Saved rule id
<code>backend</code>	"arrow" or "datafusion_sql"
<code>row_count</code>	Input table rows
<code>true_count / false_count / null_count</code>	Mask statistics
<code>duration_ms</code>	Wall time
<code>fault_mask</code>	Confirmed boolean mask (see below)
<code>warnings / errors</code>	Lint/runtime messages
<code>summary</code>	Execution evidence, site id, backend path
<code>preview</code>	Sample fault rows for Rule Lab UI

Use `.as_dict()` for API JSON. Both PyArrow and DataFusion SQL backends normalize to this shape.

6.4 Raw mask vs confirmation

1. Rule returns **raw** boolean mask (apply_faults_arrow or SQL fault column).
2. Backend applies **fault confirmation** when cfg includes min_true_rows and/or min_elapsed_minutes (see [Fault confirmation](#)(({ { "/rule-cookbook/fault-confirmation/" | relative_url } }))).
3. ArrowRuleResult.fault_mask is the **post-confirmation** mask used for batch counts and dashboard alerts.

Confirmation is backend-owned — rules should not implement debounce logic unless documenting a special case.

6.5 DataFusion SQL rules

SQL modules still expose apply_faults_arrow; the body delegates to open_fdd.arrow_runtime.datafusion_backend. Metadata:

```
backend: datafusion_sql
fault_column: fault
sql: |
    SELECT *, "stat_zn-t" > 76.0 AS fault FROM telemetry
```

Same ArrowRuleResult after SQL execution and confirmation.

6.6 Lint & forbidden imports

Edge fault rules allow: pyarrow, pyarrow.compute, open_fdd.arrow_runtime.*, datetime, math.

Forbidden in production fault rules: pandas, numpy (for rule logic), file I/O, network calls.

See lint_arrow_rule() in open_fdd.arrow_runtime.backend.

6.7 Chunked execution

Large tables may run via run_arrow_rule_chunked() — masks are concatenated; contract unchanged.

6.8 Related

- [\[Data types & units\]\({ { "/rule-authoring/data-types-and-units/" | relative_url } }\)](#)

- [ADR: Rust-ready Arrow FDD contract](#)({{ "/adr/adr-rust-ready-arrow-fdd-contract/" | relative_url }})
- [\[Developer: Arrow-native runtime\]](#)({{ "/developer/arrow-native-runtime/" | relative_url }})

7 Data types and units

8 Data types and units

Rules read **columnar historian tables** produced by BACnet / Niagara / JSON API ingest. Author against **Feather column names** (oa-t, stat_zn-t, ...) or BRICK fdd_input aliases resolved in the bridge.

8.1 Required table shape

Column / convention	Expectation
timestamp	UTC or site-local consistent ordering; monotonic within a batch window
Point columns	One float (or castable) column per bound historian point
site_id	Optional in table; often passed via cfg / context
Row count	One row per poll sample — irregular spacing is normal

Missing columns: cookbook helpers typically return an all-False mask or zero-filled stand-ins — check helper docs before assuming a fault.

8.2 Numeric casting and nulls

Legacy (pandas gist)	Modern Arrow
HelperUtils.convert_to_float	pc.cast(col, pa.float64()) or ingest-time typing
HelperUtils.check_datatype_float	Rule Lab lint + bridge ingest validation

Legacy (pandas gist)	Modern Arrow
HelperUtils.check_datatype_int	Validate integer cfg fields (int(cfg["window_samples"]))
np.maximum / np.minimum	pc.max / pc.min
series.rolling(n).min()	arrow_rolling_min in open_fdd.arrow_runtime.windows
series.diff()	arrow_diff / arrow_abs_diff
df.resample("H")	Not ported 1:1 — use sample-window rolling helpers instead

Null behavior: comparisons involving null produce null; backend cast may treat null as false in the final mask. Prefer `pc.fill_null` or explicit guards when null should mean “no fault.”

8.3 Command normalization

BACnet analog outputs often arrive as **0-100 %**. Open-FDD normalizes with `norm_cmd_array()`:

- Values **> 1.0** → divide by 100 (0-1 fraction)
- Values **≤ 1.0** → used as-is (already fractional)

Legacy gist: `check_range_less_than_one / float_max_check_err` (command max ≤ 1.0 after conversion).

Configure per rule:

```
cfg = {"min_active_command": 0.02, "min_command_delta": 0.03}
```

8.4 Boolean / status columns

Signal	Typical handling
Fan status / run command	Normalize as command; gate with <code>pc.greater(fan, 0.01)</code>
Occupancy	Boolean column or hour-of-week mask via cookbook schedule helpers
Enable / alarm state	Cast to bool; combine with <code>pc.and_</code>
Binary points	<code>pc.equal(col, 1)</code> or cast from 0/1 floats

8.5 Sensor profiles and units

Default bounds, flatline tolerance, and rate limits live in `open_fdd.arrow_runtime.sensor_catalog.SENSOR_PROFILES`.

Profile key	Quantity	Default unit	Example fault codes
zone_temp	Temperature	°F	VAV-C
supply_air_temp	Temperature	°F	AHU-C, RTU-C
outdoor_air_temp	Temperature	°F	BLD-B
mixed_air_temp	Temperature	°F	AHU-D
return_air_temp	Temperature	°F	AHU-D
duct_static_pressure	Pressure	in H ₂ O	AHU-A
zone_humidity	Relative humidity	% RH	BLD-B
co2	CO ₂	ppm	BLD-B

Override via rule `cfg` (`bounds_low`, `bounds_high`, `flatline_tolerance`, `window_samples`, `max_per_hour`). Metric sites: set `cfg["temp_unit"] = "metric"` or scale constants (see [Expression cookbook]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}#metric-equivalents)).

8.6 Time and windows

Setting	Meaning
<code>window_samples</code>	Rolling window in poll samples (not wall-clock unless derived)
<code>rolling_avg_minutes</code>	Converted to samples using <code>poll_interval_s / median poll interval</code>
<code>hunting_window_hours</code>	Used by PID hunting helpers to derive sample count
<code>min_true_rows</code>	Confirmation: consecutive true samples required
<code>min_elapsed_minutes</code>	Confirmation: minimum wall time with fault true

Irregular timestamps: rolling helpers operate on row order within the loaded table — ensure lookback windows include enough samples for your poll cadence.

8.7 Raw fault vs confirmed fault

Stage	Where
Raw mask	Return value of <code>apply_faults_arrow</code>
Confirmed mask	<code>ArrowRuleResult.fault_mask</code> after <code>apply_fault_confirmation_from_cfg</code>

Document both when tuning — a rule may fire briefly but not meet confirmation.

8.8 Related

- [\[Expression cookbook — sensor validation\]](#)(`{{ "/rule-cookbook/expression-cookbook/" | relative_url }}` `#sensor-validation-bounds-flatline-rate-of-change`)
- [Fault confirmation](#)(`{{ "/rule-cookbook/fault-confirmation/" | relative_url }}`)
- [Legacy pandas parity](#)(`{{ "/rule-authoring/legacy-pandas-parity/" | relative_url }}`)

9 Legacy pandas parity

10 Legacy pandas parity matrix

Maps the historical **pandas gist** fault classes to Open-FDD **v1 Arrow** (and optional SQL) equivalents.

Source gist (legacy, not maintained): [FaultConditionOne-Fifteen](#)

Status legend

Status	Meaning
exact parity	Regression test proves equivalent flag behavior on fixture data
modernized	Same intent; Arrow implementation differs (documented)

Status	Meaning
retired	No v1 edge path — catalog/ metadata only
pending	Not yet ported to Arrow module + test

Do **not** claim exact parity without a named test file.

10.1 Helper utilities

Legacy	Summary	Modern equivalent	Status	Tests
<code>HelperUtils.convert_to_float</code>	Cast column to float	Ingest typing + <code>pc.cast(..., pa.float64())</code>	modernized	inges
<code>HelperUtils.isfloat</code> / float checks	Validate analog columns	Rule Lab lint + bridge validation	modernized	test_
<code>check_range_less_than_one</code>	Command must be ≤ 1 after scaling	<code>norm_cmd_array()</code>	modernized	test_
<code>np.maximum</code> / <code>np.minimum</code>	Element-wise min/max	<code>pc.max</code> / <code>pc.min</code>	modernized	cookl
<code>pandas rolling</code> / <code>resample</code>	Window aggregates	<code>arrow_rolling_*</code> , <code>arrow_rolling_sum</code>	modernized	test_

10.2 GL36 fault conditions (gist classes)

Legacy	Legacy behavior (summary)	Modern helper / module	Fault code
FC1 <code>FaultConditionOne</code>	Duct static below SP at high supply VFD	<code>duct_static_low_at_full_fan</code> pattern — [Rule A]({{ "/rule-cookbook/python-recipes-arrow/"	<code>relative_url }</code>
FC2 <code>FaultConditionTwo</code>	MAT below $\min(\text{RAT}-\Delta, \text{OAT}-\Delta)$ with fan on	<code>mixing_envelope</code> / Rules B & C	AHU-D

Legacy	Legacy behavior (summary)	Modern helper / module	Fault code
FC3 FaultConditionThree	MAT above max(RAT+ Δ , OAT+ Δ) with fan on	mixing_envelope high side	AHU-D
FC4 FaultConditionFour	Hourly AHU OS mode edges > delta_os_max	pid_hunting_command_mask, pid_hunting_ahu_os_mask, pid_hunting_fc4.py	AHU-G, VAV-F, CH-G, RTU-E
FC5 FaultConditionFive	SAT low vs MAT when heating	Rule D pattern	AHU-B
FC6 FaultConditionSix	SAT high vs MAT when cooling (multi-mode)	Rules J/K patterns	AHU-B, AHU-C
FC7 FaultConditionSeven	SAT low, full heating valve	Rule E	AHU-C
FC8 FaultConditionEight	Econ + mech cooling, MAT $\neq$ OAT	Rule H	AHU-E
FC9 FaultConditionNine	Econ-only, MAT $\neq$ OAT	Rule I	AHU-E
FC10 FaultConditionTen	Ambient warm, free cooling available	Rule G	AHU-E
FC11 FaultConditionEleven	SAT $\neq$ MAT in econ mode	Rule F	AHU-E
FC12 FaultConditionTwelve	Cooling coil Δ T when valves closed	Rule L	CH-C
FC13 FaultConditionThirteen	Heating coil Δ T when valves closed	Rule M	AHU-B
FC14 FaultConditionFourteen	Complex multi-mode SAT/MAT (gist)	Split into Rules D/E/F/J/K modules	AHU-B, AHU-C, AHU-E

Legacy	Legacy behavior (summary)	Modern helper / module	Fault code
FC15 FaultConditionFifteen	VAV / zone specific (gist)	VAV bounds, flatline, damper rules	VAV-C, VAV-I

10.3 Fault Rule 4 (FC4) — modernized hunting detector

10.3.1 Legacy (pandas gist)

- Derive four boolean AHU operating modes (heating, econ-only cooling, econ+mech, mech-only).
- Cast modes to integers, **resample hourly**, count rising edges per mode.
- Flag when any hourly transition count exceeds `delta_os_max`.

10.3.2 Modern (Open-FDD v1)

Legacy FC4 has been **modernized** into an Arrow-native **PID / control hunting** detector:

Mode	API	Detects
command (default)	<code>pid_hunting_command_mask</code>	Excessive significant steps on one analog command (damper, valve, VFD, cooling %)
<code>ahu_os</code>	<code>pid_hunting_ahu_os_mask</code>	Excessive changes in a 4-bit operating-state bitmap (economizer, fan, heat, cool)

Configuration: `delta_os_max`, `hunting_window_samples` or `hunting_window_hours`, `min_active_command`, `min_command_delta`, column names in `cfg`.

There is no strict legacy compatibility mode that reproduces pandas hourly `resample("H")` edge counting by default. If exact hourly OS-edge parity is required later, it would need a dedicated legacy mode plus regression fixtures from the gist — not claimed today.

Recommended module: workspace/data/rules_py/pid_hunting_fc4.py
with `cfg["hunting_mode"]` of `command` or `ahu_os`.

10.4 Default YAML starter pack (open_fdd/default_rules/)

YAML file	Executable in v1?	Arrow replacement
01_vav_zone_temp_bounds_occupied.yaml	No — metadata only	sensor_bounds_mask + occupied gate → VAV-C
02_vav_zone_temp_flatline_occupied.yaml	No	sensor_flatline_ma → VAV-C
03_vav_damper_command_extreme_flatline.yaml	No	flatline_1h_mask o damper cmd → VAV-D
04_ahu_runtime_outside_schedule.yaml	No	schedule / after- hours helpers → BLD-C
05_ahu_duct_static_pressure_not_maintained.yaml	No	Rule A module → AHU-A
06_ahu_internal_temp_sensor_bounds.yaml	No	sensor_bounds_mask → AHU-C
07_ahu_internal_temp_sensor_flatline.yaml	No	sensor_flatline_ma → AHU-C

YAML retains **inputs**, **params**, and legacy **expression** text for migration reference only.

10.5 Fault code mapping

Legacy	Modern
Numeric VAV-03, AHU-03	Letter codes VAV-C, AHU-C
fc4_flag, FC4	AHU-G / VAV-F / CH-G / RTU-E (equipment-specific assignment)
flag: in YAML	fault_code in Rule Lab metadata

Bridge `LEGACY_CODE_MAP` resolves old portfolio strings where needed.

10.6 Related

- [Expression cookbook — GL36 table]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}#gl36-inspired-ahu-rules-legacy-expression-fault-code)
- [Python recipes (full library)]({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }})
- [Arrow rule contract]({{ "/rule-authoring/arrow-rule-contract/" | relative_url }})

11 Rust readiness checklist

12 Rust readiness checklist

Open-FDD v1 keeps a **table-in, boolean-mask-out** contract so a future Rust or DataFusion-native executor can replace Python wrappers without changing Rule Lab metadata or driver ingest.

Use this checklist when authoring or reviewing rules for stable v1 and Rust migration prep.

12.1 Rule style

☐

No pandas in edge fault rules — PyArrow columns only

☐

No NumPy for core detection logic (optional in central analytics extras only)

☐

No Python row loops over samples for hot-path fault detection — use `pyarrow.compute` and `open_fdd.arrow_runtime.windows`

☐

Arrow arrays in, boolean mask out — length equals input row count

☐

Explicit config schema — document `cfg` keys in rule module docstring

☐

Deterministic null behavior — document how missing columns / nulls are treated

☐

- ☐ **No hidden global state** — pure functions of (table, cfg, context)
- ☐ **Stable fault-code metadata** — letter codes from [fault catalog]({{ "/fault-codes/" | relative_url }})
- ☐ **Small fixture tests** — fixed pa.table(...) inputs with expected mask slices
- ☐ **DataFusion SQL rules stay restricted** — single SELECT from t, elemetry, boolean fault column, no DDL/DML

12.2 Backend choice

Prefer PyArrow	Prefer DataFusion SQL
Rolling windows, hunting, flatline	Simple threshold / CASE
Schedule / occupancy gating	Operator-readable SQL preview
Sensor profile helpers	Parity proof before Rust port
ML feature prep (future)	Stateless row-wise logic

See [PyArrow vs DataFusion decision table]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}#pyarrow-vs-datafusion-sql).

12.3 Do not use DataFusion SQL for

- Complex rolling windows or resample-style logic
- PID / control hunting with stateful window counts (use PyArrow helpers)
- Custom helper-heavy HVAC logic
- ML feature preparation pipelines
- Arbitrary file joins or external tables
- Browser-side execution
- Pandas-style row iteration

12.4 Confirmation and evidence

- ☐ Raw mask produced by rule; confirmation via min_true_rows / min_elapsed_minutes in cfg
- ☐

Batch results include execution evidence (computation_path, backend id) for smokes

12.5 Packaging



Edge Docker image includes PyArrow runtime



DataFusion optional: `pip install 'open-fdd[datafusion]' --
matches pyproject.toml [project.optional-dependencies]
datafusion`

12.6 Related ADRs

- [ADR: Rust-ready Arrow FDD contract](#)({{ "/adr/adr-rust-ready-arrow-fdd-contract/" | relative_url }})
- [\[ADR: DataFusion Rust-ready rule backend\]](#)({{ "/adr/adr-datafusion-rust-ready-rule-backend/" | relative_url }})

13 Run with Docker images

14 Run with Docker images

Deploy Open-FDD on a Linux edge host using **three published GHCR images**. No git clone required.

14.1 Images

GHCR image	Service	Role
ghcr.io/bbartling/openfdd-bridge	bridge	Operator API, dashboard, historian ingest
ghcr.io/bbartling/openfdd-commission	commission	BACnet discover/ read/write and poll loop
	mcp-rag	

GHCR image	Service	Role
ghcr.io/bbartling/openfdd-mcp-rag		Doc-search sidecar

Edge hosts pull **latest** from GHCR (three images: bridge, commission, mcp-rag). The retired **openfdd-bacnet-poll** image is no longer published.

14.2 1. Install and validate Docker

```
sudo systemctl enable --now docker
sudo usermod -aG docker "$USER"
newgrp docker    # or log out/in

docker --version
docker compose version
docker ps
docker run --rm hello-world
```

Expect: active / enabled for docker, docker in groups, hello-world succeeds.

14.3 2. Bootstrap the site (one script)

Downloads docker-compose.yml, creates workspace/, generates auth.env.local, and sets BACNET_BIND from the host LAN NIC (e.g. ens192 → 10.200.200.185/24:47808):

```
curl -fsSL -o /tmp/openfdd_edge_bootstrap.sh \
    https://github.com/bbartling/open-fdd/raw/refs/heads/master/
scripts/openfdd_edge_bootstrap.sh
bash /tmp/openfdd_edge_bootstrap.sh
```

Bootstrap + pull + start in one go:

```
bash /tmp/openfdd_edge_bootstrap.sh --start
```

Auth — bootstrap writes ~/open-fdd/workspace/auth.env.local (gitignored). This file holds the API signing secret and one username/password per role. Use it for your first dashboard login:

```
cat ~/open-fdd/workspace/auth.env.local
```

Variable	Role
OFDD_AUTH_SECRET	Signs session tokens (do not share)
OFDD_OPERATOR_*	Read-only operator
OFDD_INTEGRATOR_*	

Variable	Role
	Default dashboard login — commissioning + BACnet
OFDD_AGENT_*	Agent / automation

Example shape (passwords are **random on first bootstrap only** — existing file is kept on re-runs):

```
OFDD_AUTH_SECRET=<random>
OFDD_OPERATOR_USER=operator
OFDD_OPERATOR_PASSWORD=<random>
OFDD_INTEGRATOR_USER=integrator
OFDD_INTEGRATOR_PASSWORD=<random>
OFDD_AGENT_USER=agent
OFDD_AGENT_PASSWORD=<random>
```

Sign in as **integrator** with the password from that file → First login and health check({{ "/quick-start/health-check/" | relative_url }}).

Action	Touches auth.env.local?
First bash ... bootstrap.sh --start	Creates file with random passwords (if missing)
bash ... bootstrap.sh --start again	Keeps your file — does not overwrite
bash ... bootstrap.sh --restart	Keeps your file — only restarts bridge to reload it
nano auth.env.local + --restart	Uses your edited passwords
--force-auth	Regenerates random passwords (opt-in only)

The **bridge** container reads auth.env.local at startup only. After you change passwords (manual edit or --force-auth), recreate bridge (env files are not reloaded by restart alone):

```
cd ~/open-fdd && docker compose up -d --force-recreate bridge
```

Regenerate passwords and reload (stack already running):

```
bash /tmp/openfdd_edge_bootstrap.sh --force-auth --restart --show-secrets
```

Manual edit then reload:

```
nano ~/open-fdd/workspace/auth.env.local
bash /tmp/openfdd_edge_bootstrap.sh --restart
```

Options:

Flag	Purpose
--start	docker compose pull && up -d after layout; curls http://127.0.0.1:8765/health
--image-tag TAG	default latest
--repo-ref BRANCH	branch for compose.edge.yml if not on master yet
--force-auth	regenerate auth.env.local (restarts bridge if stack is up)
--restart	recreate bridge to reload auth.env.local; curls /health after
--show-secrets	print passwords at end (lab only)

From a repo checkout: `./scripts/openfdd_edge_bootstrap.sh --start`

The script prints **BACnet NIC**, **BACNET_BIND**, and file paths — **validate** commission.env before polling OT devices:

```
nano ~/open-fdd/workspace/bacnet/commissioning/commission.env
```

```
If you used --start, the stack is already up. Next step → First login and health check({{ "/quick-start/health-check/" | relative_url }}).
```

14.3.1 Manual start (optional)

Use this only if you ran bootstrap **without** `--start` and want to bring the stack up yourself:

```
cd ~/open-fdd
docker compose pull
docker compose up -d
docker compose ps
curl -sf http://127.0.0.1:8765/health && echo
```

Expected: **bridge**, **commission**, **mcp-rag** — all up. Then → First login and health check({{ "/quick-start/health-check/" | relative_url }}).

14.4 Long-term operation

14.4.1 Survive power cycles

All services use restart: unless-stopped. After reboot:

```
cd ~/open-fdd && docker compose ps
curl -sf http://127.0.0.1:8765/health
```

14.4.2 Start / stop / restart

```
cd ~/open-fdd
docker compose up -d           # idempotent
docker compose stop
docker compose restart commission
docker compose logs -f --tail 100 commission
```

Never run docker compose down -v or delete workspace/ on a live site.

14.4.3 LAN access

Put **Caddy** (or nginx) on port 80 → 127.0.0.1:8765, or expose 8765 through the firewall.

14.5 Deployment choices

Mode	Compose services	When to use
Standard OT / BACnet	bridge + commission + mcp-rag	Real buildings — commission polls BACnet into samples.csv; bridge ingests to feather
Non-BACnet / demo	bridge + mcp-rag (omit commission)	JSON API, Modbus-only, or lab without field BACnet — see Driver framework ({ { “/drivers/”
TLS on OT LAN	Same stack + host Caddy OFDD_CADDY_MODE=tls	Encrypt browser↔edge; trust self-signed CA on operator PCs — not for public internet

Do **not** run the retired `openfdd-bacnet-poll` image or legacy `openfdd-bacnet-poll` systemd unit alongside Docker **commission** — that double-polls BACnet.

14.6 Next steps

→ First login and health check({{ "/quick-start/health-check/" | relative_url }})
→ Updating the stack({{ "/quick-start/updating/" | relative_url }})
— `./scripts/openfdd_site_update.sh`

15 First login and health check

16 First login and health check

Quick checks after `docker compose up -d` on the edge host. Services use `restart: unless-stopped` — after a reboot, run `docker compose ps` once Docker is up (see [Run with Docker]({{ "/quick-start/docker/" | relative_url }}#survive-power-cycles)).

16.1 Public health

```
curl -s http://127.0.0.1:8765/health
```

Through Caddy on port 80:

```
curl -s http://127.0.0.1/health
```

Expect `"ok": true` and `"auth_required": true` when auth is configured.

16.2 Login

1. Open the dashboard (`http://<host-lan-ip>/` or `:8765`).
2. Sign in with credentials from `workspace/auth.env.local`.


```
curl -s -X POST http://127.0.0.1:8765/api/auth/login \
-H 'Content-Type: application/json' \
-d '{"username":"integrator","password":"<from-auth-env>"}'
```

16.3 Smoke checklist

Check	Pass
docker compose ps	bridge, commission, mcp-rag Up
GET /health	200, ok: true
Login	Token returned
BACnet poll	samples.csv growing (tail -1 workspace/bacnet/ polls/samples.csv)
Historian	Files under workspace/data/ feather_store/

16.4 Stack detail (authenticated)

Integrator token required:

```
TOKEN=$(curl -sf -X POST http://127.0.0.1:8765/api/auth/login \
-H 'Content-Type: application/json' \
-d '{"username":"integrator","password":"..."}' | jq -r .token)
curl -sf http://127.0.0.1:8765/health/stack -H "Authorization:
Bearer $TOKEN" | jq .
```

Look for bacnet_poll green/yellow in the services list.

16.5 Troubleshooting

Symptom	Fix
401 everywhere	Configure workspace/ auth.env.local
Empty BACnet discover	Fix BACNET_BIND in commission.env — <u>network setup</u> ({ { “/ bacnet/network- setup/”
No poll rows	Commission container running? points.csv has enabled rows?
LAN browser timeout	

Symptom	Fix
	Open firewall port 80 or 8765

Advanced probes (model graph, Rule Lab, compose profiles):
[Developer health check]({{ "/developer/health-check/" | relative_url }}).

17 Quick Start

18 Quick Start

Run Open-FDD on a Linux edge host using **three GHCR Docker images**. No git clone on the host.

Step	Page
1	Run with Docker images ({{ "/quick-start/docker/" relative_url }})
2	First login and health check ({{ "/quick-start/health-check/" relative_url }})
3	Updating the stack ({{ "/quick-start/updating/" relative_url }})

One-liner bootstrap (edge host):

```
curl -fsSL -o /tmp/openfdd_edge_bootstrap.sh \
https://github.com/bbartling/open-fdd/raw/refs/heads/master/
scripts/openfdd_edge_bootstrap.sh
bash /tmp/openfdd_edge_bootstrap.sh --start
```

Prerequisites: Linux, Docker enabled on boot, BACnet LAN if polling OT equipment.

BACnet writes are disabled by default. See [Write safety](#)({{ "/bacnet/write-safety/" | relative_url }}).

Stack: bridge + commission (BACnet + poll) + mcp-rag. Details: [Containers](#)({{ "/architecture/containers/" | relative_url }}).

19 Updating the stack

20 Updating the stack

Upgrade GHCR images on the edge host: **backup workspace/, pull new tags, recreate containers**. No git pull on the host.

20.1 Before you start

1. SSH to the edge host (`cd ~/open-fdd`).
2. Pick a tag from [GitHub Packages](#) — default is **latest**.
3. Short maintenance window (containers restart briefly; restart: unless-stopped brings them back after reboot).

20.2 Fetch helper scripts (no git clone)

If you bootstrapped with `openfdd_edge_bootstrap.sh`, scripts are already under `~/open-fdd/scripts/`. Otherwise:

```
mkdir -p ~/open-fdd/scripts
curl -fsSL -o ~/open-fdd/scripts/openfdd_site_backup.sh \
https://github.com/bbartling/open-fdd/raw/refs/heads/master/
scripts/openfdd_site_backup.sh
curl -fsSL -o ~/open-fdd/scripts/openfdd_site_update.sh \
https://github.com/bbartling/open-fdd/raw/refs/heads/master/
scripts/openfdd_site_update.sh
chmod +x ~/open-fdd/scripts/openfdd_site_*.sh
```

20.3 One-command upgrade (recommended)

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
./scripts/openfdd_site_update.sh
```

Pulls **:latest** by default, verifies all three images exist on GHCR, recreates containers, and hits `/health`.

20.4 Step by step

20.4.1 1. Backup site state

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
```

Archives workspace/ (feather, BACnet CSVs, model, auth) under ~/openfdd-backups/<timestamp>/.

Custom backup location:

```
BACKUP_ROOT=~/openfdd-backups/manual ./scripts/
openfdd_site_backup.sh
```

20.4.2 2. Verify images (optional)

```
export NEW_TAG="${NEW_TAG:-latest}"

docker manifest inspect ghcr.io/bbartling/openfdd-bridge:$
{NEW_TAG} >/dev/null &&
docker manifest inspect ghcr.io/bbartling/openfdd-commission:$
{NEW_TAG} >/dev/null &&
docker manifest inspect ghcr.io/bbartling/openfdd-mcp-rag:$
{NEW_TAG} >/dev/null &&
echo "All images exist for ${NEW_TAG}"
```

20.4.3 3. Pull and recreate

```
cd ~/open-fdd
./scripts/openfdd_site_update.sh
```

Manual equivalent (same as the script):

```
cd ~/open-fdd
docker compose pull
docker compose up -d --force-recreate
docker compose ps
curl -sf http://127.0.0.1:8765/health && echo
```

20.4.4 4. Verify

```
docker compose ps
curl -sf http://127.0.0.1:8765/health | jq .
tail -1 workspace/bacnet/polls/samples.csv
ls -lah workspace/data/feather_store/
```

→ [Health check]({ { "/quick-start/health-check/" | relative_url } })

20.5 Dashboard UI updates

If the release changed the React UI, copy a new workspace/api/static/app/ build onto the host before or after the image pull. Image pull alone may not change the browser bundle hash.

20.6 Rollback

Restore docker-compose.yml from backup and pull again, or re-run bootstrap from a known-good master commit. GHCR keeps only the **three newest** versions per image; early sites should rely on **latest** plus workspace/ backups.

workspace/ is untouched by image-only upgrades.

20.7 Safe cleanup

```
docker image prune -f
```

Never run docker compose down -v, docker volume prune, or delete workspace/ on a live site.

20.8 Next steps

→ Run with Docker images({{ "/quick-start/docker/" | relative_url }}) — bootstrap a new host
→ [Health check]({{ "/quick-start/health-check/" | relative_url }})

21 Local development

22 Local development

22.1 Clone and auth

```
git clone https://github.com/bbartling/open-fdd.git && cd open-fdd
cp workspace/auth.env.example workspace/auth.env.local
# Edit integrator/operator passwords and OFDD_AUTH_SECRET (32+
chars)
```

22.2 Start stack

```
./scripts/build_and_test.sh           # dashboard build + pytest
./scripts/docker_build.sh
./scripts/openfdd_stack.sh up
./scripts/stack_health_check.sh
```

URL	Service
http://127.0.0.1:8765	Bridge (direct)
http://127.0.0.1:8765/docs	OpenAPI

22.3 BACnet bench overlay (optional)

```
docker compose -f docker/compose.dev.yml -f docker/
compose.bench.yml up -d
# commission.env – set BACNET_BIND to your OT interface
```

22.4 Production-like local stack (Caddy, LAN scans)

Same shape as an Acme edge deploy: **prod React UI, Caddy on :80**, bridge on loopback **8765**, auth enabled. Use for OWASP ZAP or nmap from another machine on the LAN.

```
./scripts/pentest_production_stack.sh start    # build prod UI +
Caddy + auth.pentest.local
./scripts/pentest_production_stack.sh status   # bridge,
commission, caddy, mcp-rag
./scripts/pentest_production_stack.sh verify   # LAN IP, /health,
ZAP target URL
./scripts/pentest_production_stack.sh stop     # when done
```

Credentials: workspace/auth.pentest.local (generated on first start). ZAP target is usually http://<lan-ip>/ (benserver example: http://192.168.204.18/). If LAN clients cannot reach :80, run `sudo ./scripts/open_lan_port.sh 80`.

See also [Health checks \(developer\)](#)(({ { "/developer/health-check/" | relative_url } }) for probe details and [ZAP baseline expectations](({ { "/security/zap-baseline/" | relative_url } }) for accepted Medium/Low findings.

22.5 Docs preview

```
cd docs && bundle install && bundle exec jekyll serve  
# http://127.0.0.1:4000/open-fdd/
```

23 Build Docker images

24 Build Docker images

24.1 Local build

```
./scripts/docker_build.sh  
# Optional tar for air-gap:  
./scripts/docker_build.sh --save
```

Images: openfdd-bridge, openfdd-commission, openfdd-mcp-rag.

24.2 Publish to GHCR (maintainers)

GitHub Actions workflow **Publish Docker images to GHCR** — manual dispatch or git tag vX.Y.Z. Publishes **pyproject.toml version** (e.g. 3.1.3), minor alias (3.1), and **latest**, then prunes old GHCR versions.

Maintainer checklist:

1. Green CI on master
2. Run **Publish Docker images to GHCR** workflow (or push tag vX.Y.Z)
3. Verify ghcr.io/bbartling/openfdd-**{bridge,commission,mcp-rag}**: 3.1.3 and :latest
4. Edge hosts: OPENFDD_IMAGE_TAG=3.1.3 ./scripts/upgrade_edge_ghcr.sh --limit <host>

Details live in .github/workflows/ and scripts/docker_build.sh — not duplicated here.

25 Developer Guide

26 Developer Guide

Clone, build, test, and contribute to Open-FDD.

Topic	Page
Local setup	Local development ({{ "/" developer/local-setup/"
Docker builds	Build Docker images ({{ "/" developer/docker-build/"
Health checks	Health checks (developer) ({{ "/"developer/health- check/"
Tests & CI	Tests and CI ({{ "/"developer/ tests-ci/"
Security testing	[Release & LAN scan cycle] ({{ "/"developer/security- testing/"
PRs	Contributing ({{ "/"developer/ contributing/"

AI-assisted contributors: see repository AGENTS.md for workspace layout, skill routing, and agent policy (one paragraph in public docs; details stay internal).

27 Tests and CI

28 Tests and CI

28.1 Local tests

```
./scripts/build_and_test.sh # UI + workspace bridge
pytest
python3 -m pytest open_fdd/tests -q # PyPI package tests
cd workspace/dashboard && npm test # dashboard unit tests (if
configured)
```


28.2 CI (GitHub Actions)

Workflow	Trigger	Checks
ci.yml	PR / push	pytest, bridge security audit, dashboard build, Jekyll docs
docs-pages.yml	push master	GitHub Pages site
publish-open-fdd.yml	tag v* / open-fdd-v*	PyPI wheel (Trusted Publishing)
docker-publish.yml	tag v* / manual	GHCR bridge, commission, mcp-rag

28.3 Docs build (same as CI)

```
cd docs && bundle exec jekyll build -d /tmp/open-fdd-site
```

Fix any template or link errors before opening a PR that touches docs/.

28.4 Security-related CI

ci.yml includes bridge security tests (tests/workspace_bridge/test_security.py). That complements — but does not replace — LAN [ZAP + Nmap scans]({{ "/security/zap-baseline/" | relative_url }}) on each patch revision. See [Security testing cycle](#)({{ "/developer/security-testing/" | relative_url }}).

29 DataFusion SQL rule recipes

30 DataFusion SQL recipes

Use when you need simple threshold, CASE WHEN, or SQL-readable **stateless** rules. Requires `pip install 'open-fdd[datafusion]'` (optional extra in `pyproject.toml`). SQL runs **server-side only**.

Not for: rolling windows, PID hunting, flatline detection, schedule logic, or ML prep — use [PyArrow recipes](#). See [decision table] (`{{ "/rule-cookbook/expression-cookbook/" | relative_url }}` `#pyarrow-vs-datafusion-sql`).

30.1 Temperature high

```
SELECT
  *,
  "duct-t" > 80.0 AS fault
FROM telemetry
```

Quote hyphenated historian columns.

30.2 Humidity high

```
SELECT
  *,
  "oa-h" > 70.0 AS fault
FROM telemetry
```

30.3 Occupied + temperature

```
SELECT
  *,
  CASE
    WHEN occupied = true AND "stat_zn-t" > 76.0 THEN true
    ELSE false
  END AS fault
FROM telemetry
```

30.4 With fault confirmation

Add to rule config:

```
{"min_true_rows": 5, "poll_interval_s": 60}
```

PyArrow remains better for rolling windows, custom helpers, and ML prep. See [PyArrow recipes](#).

31 Contributing

32 Contributing

32.1 Expectations

- Open an issue or discuss large changes before big refactors.
- Keep PRs focused; include test or docs updates when behavior changes.
- Do not commit secrets (auth.env.local, Ansible secrets/*.env.local, commissioning CSVs with real site data).
- Follow existing code style in workspace/api/ and workspace/dashboard/.

32.2 Pull request checklist

☐

Tests pass locally (./scripts/build_and_test.sh or scoped pytest)

☐

Docs updated if user-facing behavior changed

☐

docs/ Jekyll build succeeds

☐

No credentials in diff

☐

Auth/Caddy/header changes: re-run [pentest verify + LAN ZAP]({{ "/developer/security-testing/" | relative_url }}) and update [ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}) if expectations changed

32.3 Repository layout (short)

Path	Contents
workspace/api/	Operator Bridge (FastAPI)
workspace/dashboard/	React SPA
open_fdd/	PyPI package (arrow_runtime, playground)
docker/	Compose files and image contexts
infra/ansible/	Edge deploy playbooks
docs/	This site (Jekyll + Just the Docs)

32.4 Docs links (GitHub Pages)

The site is a **project page** at <https://bbartling.github.io/open-fdd/> (baseurl: /open-fdd in docs/_config.yml).

- **Do not** use `{% raw %}/path/{% endraw %}` in Markdown body text — it omits baseurl and 404s on GitHub Pages.
- **Do** use `[label]({{ "/section/page/" | relative_url }})` for internal links.
- After `bundle exec jekyll build`, run `python3 scripts/check_docs_internal_links.py --site _site` from the repo root.

32.5 Security issues

Do not file public issues for vulnerabilities. Contact the maintainer or use GitHub private security advisories.

32.6 Agent-assisted development

Cursor/Claude contributors: read `AGENTS.md` and `skills/` for automation boundaries. Public docs intentionally avoid agent playbook detail.

33 Health checks (developer)

34 Health checks (developer)

Extended validation for engineers with a **full git checkout** — CI, compose overlays, and pre-release gates.

IT operators on edge hosts should use `[Quick Start — health check]({{ "/quick-start/health-check/" | relative_url }})` and `Deployment validation({{ "/ops/deployment-validation/" | relative_url }})` instead.

34.1 Clone and local stack

```
git clone https://github.com/bbartling/open-fdd.git && cd open-fdd
cp workspace/auth.env.example workspace/auth.env.local #
loopback dev only
./scripts/docker_build.sh # or: ./
```

```
scripts/openfdd_stack.sh prod
./scripts/openfdd_stack.sh up
```

GHCR production pull (no local build):

```
OPENFDD_IMAGE_TAG=2026.06.07-edge ./scripts/openfdd_stack.sh prod
```

34.2 Stack health script

```
./scripts/stack_health_check.sh
OPENFDD_BASE_URL=http://192.168.204.18:8765 ./scripts/
stack_health_check.sh
./scripts/stack_health_check.sh --require-ollama
```

Probes: containers up, /health, /api/model/health, sites, tree, SPARQL graph (with integrator auth when configured).

34.3 Compose overlays

Overlay	Use
docker/compose.dev.yml	Local dev bind-mount
docker/compose.bench.yml	Host-network BACnet lab
docker/compose.prod.yml	GHCR images instead of local build
docker/compose.edge.yml	IT edge template (copy to ~/open-fdd/ docker-compose.yml)

```
docker compose -f docker/compose.dev.yml -f docker/
compose.bench.yml ps
docker compose -f docker/compose.dev.yml config --images
```

34.4 BACnet poll pipeline

```
tail -1 workspace/bacnet/polls/samples.csv
cat workspace/data/bacnet_ingest_state.json
docker compose logs --since 10m commission | grep -i poll
docker compose logs --since 10m bridge | grep -i ingest
```

34.5 pytest (bridge security / BACnet)

```
PYTHONPATH=workspace/api pytest tests/workspace_bridge/
test_security.py -q
```

34.6 Pentest production stack (LAN ZAP)

```
./scripts/pentest_production_stack.sh start
./scripts/pentest_production_stack.sh verify
```

Then from a **LAN workstation**, run the packaged scan:

- Windows: `scripts/security/Run-OpenFddSecurityScan.ps1`
- macOS/Linux: `scripts/security/run_openfdd_security_scan.sh`

See [scripts/security/README.md](#), `[Security — ZAP baseline]({{ "/security/zap-baseline/" | relative_url }})`, and the full [security testing cycle](#)(`{{ "/developer/security-testing/" | relative_url }}`).
Host-side notes: `workspace/deploy/PENTEST.md`.

34.7 Post-deploy insurance (inventory hosts)

For automated checks against named inventory hosts, see `infra/ansible/scripts/post_deploy_check.sh` (maintainer tooling — not required for IT docker-pull sites).

35 Security testing cycle

36 Security testing cycle

How Open-FDD validates each **patch revision** before it ships to the live Acme HVAC bench — local automation, AI-assisted PR review, LAN passive scans, and edge post-deploy checks.

Related security docs: `[ZAP baseline]({{ "/security/zap-baseline/" | relative_url }})`, `[TLS and certificates]({{ "/security/tls-and-certs/" | relative_url }})`, `[LAN hardening]({{ "/security/lan-hardening/" | relative_url }})`, `[Linux host hardening]({{ "/security/linux-host-hardening/" | relative_url }})`, `[Tenable remediation]({{ "/security/tenable-remediation/" | relative_url }})`, `[Authenticated scanning (roadmap)]({{ "/security/authenticated-scanning/" | relative_url }})`.

36.1 Who owns what

Concern	Owner	Where
HTTP security headers (CSP, X-Frame, COOP, ...)	Bridge middleware	workspace/api/ openfdd_bridge/ security_headers.py
TLS termination + HSTS	Caddy	workspace/deploy/ caddy/, Ansible Caddyfile.j2 ./scripts/ setup_caddy_certs.sh → workspace/deploy/ caddy/certs/; Ansible /etc/ openfdd/caddy/ on edge
OT LAN TLS certificates	Site integrator / maintainer	
Pentest credentials	Generated per stack	workspace/ auth.pentest.local (never commit)
LAN ZAP + Nmap scans	Developer workstation on test LAN	scripts/security/

See [TLS and certificate ownership]({{ "/security/tls-and-certs/" | relative_url }}) for cert lifecycle.

36.2 Per-revision workflow

Typical cycle on a **control machine** (local dev) through a **lab edge host** (live bench):

flowchart LR

```
A[Local dev + pytest] --> B[Pentest stack verify]
B --> C[LAN ZAP + Nmap]
C --> D[PR + GitHub CI]
D --> E[CodeRabbit AI review]
E --> F[Merge + tag open-fdd-vX.Y.Z]
F --> G[GHCR + PyPI publish]
G --> H[Acme upgrade + post_deploy_check --full]
H --> I[Bump next patch locally]
```

36.2.1 1. Local functional tests

```
./scripts/build_and_test.sh
PYTHONPATH=workspace/api pytest tests/workspace_bridge/
test_security.py -q
```

```
infra/ansible/scripts/bench_5007_arrow_battery.sh # when FDD/  
Arrow paths change
```

36.2.2 2. Pentest production stack (on Open-FDD host)

```
./scripts/pentest_production_stack.sh start  
./scripts/pentest_production_stack.sh verify
```

Confirms Caddy :80 fronts the bridge, auth is enabled, BACnet writes disabled, and security headers are singular (no Caddy duplicates). Details: [Health checks — pentest]({{ "/developer/health-check/" | relative_url }}#pentest-production-stack-lan-zap).

36.2.3 3. Host + exposure checks (on edge VM)

After IT Nessus scans or before Acme deploy sign-off:

```
./scripts/security/check_host_security.sh  
./scripts/security/check_openfdd_exposure.sh --edge-ip <lan-ip>
```

Host remediation (dry-run first): ./scripts/security/remediate_ubuntu_host.sh

36.2.4 4. LAN security scan (from laptop)

Use the packaged scripts — do not hand-roll one-off docker/nmap commands unless debugging:

Platform	Command
Windows	.\scripts\security\Run-OpenFddSecurityScan.ps1
macOS / Linux	./scripts/security/run_openfdd_security_scan.sh

Setup (Docker Desktop, Nmap): [scripts/security/README.md](#).

Target URL is usually **http://<lan-ip>/** (Caddy), not :8765.

Review openfdd-security-report/90-quick-findings-summary.txt and compare against [ZAP baseline expectations]({{ "/security/zap-baseline/" | relative_url }}).

36.2.5 5. Pull request + automated review

- Open PR against master
- **GitHub Actions** (ci.yml): pytest, bridge security audit, dashboard build, Jekyll docs
- **CodeRabbit** (or similar AI PR review): style, security footguns, missing tests/docs

Do not merge with failing CI or unresolved duplicate-header regressions.

36.2.6 6. Release

```
git tag open-fdd-v3.0.4 # example
git push origin open-fdd-v3.0.4
```

Tag triggers GHCR :latest and PyPI publish workflows.

36.2.7 7. Lab edge validation

After pulling new images on a live bench VM:

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_full.sh --limit
<inventory_host>
    infra/ansible/scripts/post_deploy_check.sh --limit
<inventory_host> --full
```

Re-run LAN ZAP + Nmap against the edge LAN IP if Caddy or auth behavior changed. Site-specific example: [GL36 lab note] (`{{ "/examples/acme-gl36-lab/" | relative_url }}`).

36.2.8 8. Next cycle

Bump patch version locally (pyproject.toml, open_fdd/__init__.py) on master for the next development round — do not tag until the next release is ready.

36.3 What each scan layer covers

Layer	Tool	Depth
Unit / integration	pytest, test_security.py	Header middleware, auth gates
Stack smoke	pentest_production_stack.sh verify	Live headers, health, auth file
Passive web	ZAP baseline	Public routes, CSP, cookies, CORS
Port exposure	Nmap scoped	One host, known service ports
Authenticated API/dashboard	ZAP full + login	Roadmap — [Authenticated scanning]({{ "/security/"

Layer	Tool	Depth
		authenticated-scanning/

Baseline ZAP does **not** exercise integrator login or protected `/api/*` routes deeply.

36.4 Open-source contributors

The `scripts/security/` folder is part of the public repo so any fork can run the same LAN smoke against their bench. PRs that change Caddy, auth, or `security_headers.py` should update `[ZAP baseline]({{ "/security/zap-baseline/" | relative_url }})` and re-run the scan scripts.

37 Python recipes (full Arrow library)

38 Python recipes — full Arrow library

Copy-paste `apply_faults_arrow` modules for Rule Lab. Replaces the legacy pandas/YAML Expression Rule Cookbook.

- **No pandas** on the edge — PyArrow + `pyarrow.compute` only
- Set `fault_code` in Rule Lab metadata (letter codes or Grade-A AHU-ECON-001)
- Map historian column names in the data model / rule bindings (`ma-t`, `oa-t`, `stat_zn-t`, ...)

Quick patterns: `[Arrow recipes]({{ "/rule-cookbook/arrow-recipes/" | relative_url }})` · Index: [Expression cookbook \(Arrow-native\)](#) `({{ "/rule-cookbook/expression-cookbook/" | relative_url }})`

38.1 Shared helpers (paste once per rule file)

```
import pyarrow as pa
import pyarrow.compute as pc
```

```

from open_fdd.arrow_runtime.cookbook import mixing_envelope_mask
from open_fdd.arrow_runtime.windows import (
    arrow_rolling_min,
    arrow_rolling_max,
    arrow_abs_diff,
)

def _norm_cmd(col: pa.ChunkedArray) -> pa.ChunkedArray:
    c = pc.cast(col, pa.float64())
    return pc.if_else(pc.greater(c, 1.0), pc.divide(c, 100.0), c)

def _col(table, name: str) -> pa.ChunkedArray:
    return pc.cast(table[name], pa.float64())

def _hypot_tol(a: float, b: float) -> float:
    return (a * a + b * b) ** 0.5

```

38.2 GL36 AHU Rules A-M

38.2.1 Rule A — duct static low at full fan speed (AHU-A)

```

FAULT_CODE = "AHU-A"
SP, SP_SP, FAN = "duct-static-pressure", "duct-static-pressure-
sp", "supply-fan-speed-command"
SP_MARGIN, DRV_HI, DRV_NEAR = 0.12, 0.93, 0.06

def apply_faults_arrow(table, cfg, context=None):
    sp, sp_sp = _col(table, SP), _col(table, SP_SP)
    fan = _norm_cmd(table[FAN])
    return pc.and_(
        pc.less(sp, pc.subtract(sp_sp, SP_MARGIN)),
        pc.greater_equal(fan, DRV_HI - DRV_NEAR),
    )

```

38.2.2 Rules B & C — blended air outside OAT/RAT band (AHU-D)

Uses `mixing_envelope_mask` (covers below-band and above-band).

```

FAULT_CODE = "AHU-D"

```

```

def apply_faults_arrow(table, cfg, context=None):
    return mixing_envelope_mask(
        table,
        {**cfg, "mixing_tol": 1.15, "normalize_cmd_percent": 1},
        mat_col="ma-t",
        oat_col="oa-t",
        rat_col="ra-t",
        fan_col="supply-fan-speed-command",
    )

```

38.2.3 Rule D — discharge cold when heating commanded (AHU-B)

```

FAULT_CODE = "AHU-B"
BLEND_TOL, SAT_TOL, FAN_DT = 1.15, 1.15, 0.55

```

```

def apply_faults_arrow(table, cfg, context=None):
    mat, sat = _col(table, "ma-t"), _col(table, "sa-t")
    valve = _norm_cmd(table["heating-valve-command"])
    fan = _norm_cmd(table["supply-fan-speed-command"])
    rhs = pc.add(pc.subtract(mat, BLEND_TOL), FAN_DT)
    cold = pc.less_equal(pc.add(sat, SAT_TOL), rhs)
    return pc.and_(cold, pc.greater(valve, 0.01), pc.greater(fan,
0.01))

```

38.2.4 Rule E — SAT too low with full heating (AHU-C)

```

FAULT_CODE = "AHU-C"
SUPPLY_ERR = 1.0

```

```

def apply_faults_arrow(table, cfg, context=None):
    sat = _col(table, "sa-t")
    sp = _col(table, "sa-t-sp") if "sa-t-sp" in
table.column_names else _col(table, "supply-air-temperature-
setpoint")
    valve = _norm_cmd(table["heating-valve-command"])
    fan = _norm_cmd(table["supply-fan-speed-command"])
    return pc.and_(
        pc.less(sat, pc.subtract(sp, SUPPLY_ERR)),
        pc.greater(valve, 0.9),
        pc.greater(fan, 0.01),
    )

```

38.2.5 Rule F — SAT/MAT mismatch in economizer mode (AHU-E)

```
FAULT_CODE = "AHU-E"
FAN_DT, BLEND_TOL, SAT_TOL, ECON_MIN = 0.55, 1.15, 1.15, 0.12
TOL = _hypot_tol(SAT_TOL, BLEND_TOL)

def apply_faults_arrow(table, cfg, context=None):
    mat, sat = _col(table, "ma-t"), _col(table, "sa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    mismatch = pc.greater(pc.abs(pc.subtract(pc.subtract(sat,
FAN_DT), mat))), TOL)
    econ = pc.and_(pc.greater(damper, ECON_MIN), pc.less(cool,
0.1))
    return pc.and_(mismatch, econ)
```

38.2.6 Rule G — ambient too warm for free cooling (AHU-E)

```
FAULT_CODE = "AHU-E"
OAT_TOL, FAN_DT, SAT_TOL, ECON_MIN = 1.15, 0.55, 1.15, 0.12

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    sp = _col(table, "sa-t-sp")
    damper = _norm_cmd(table["oa-damper-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    warm = pc.greater(oat, pc.add(pc.subtract(sp, FAN_DT),
SAT_TOL - OAT_TOL))
    econ = pc.and_(pc.greater(damper, ECON_MIN), pc.less(cool,
0.1))
    return pc.and_(warm, econ)
```

38.2.7 Rule H — OAT/MAT mismatch (econ + mech cooling) (AHU-E)

```
FAULT_CODE = "AHU-E"
OAT_TOL, BLEND_TOL = 1.15, 1.15
TOL = _hypot_tol(OAT_TOL, BLEND_TOL)

def apply_faults_arrow(table, cfg, context=None):
    oat, mat = _col(table, "oa-t"), _col(table, "ma-t")
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    return pc.and_(
        pc.greater(pc.abs(pc.subtract(mat, oat)), TOL),
```

```

        pc.greater(cool, 0.01),
        pc.greater(damper, 0.9),
    )

```

38.2.8 Rule I — OAT/MAT mismatch (economizer only) (AHU-E)

```

FAULT_CODE = "AHU-E"
TOL = _hypot_tol(1.15, 1.15)

def apply_faults_arrow(table, cfg, context=None):
    oat, mat = _col(table, "oa-t"), _col(table, "ma-t")
    damper = _norm_cmd(table["oa-damper-command"])
    return
pc.and_(pc.greater(pc.abs(pc.subtract(mat, oat)), TOL),
pc.greater(damper, 0.9))

```

38.2.9 Rule J — discharge above blended in cooling (AHU-B)

```

FAULT_CODE = "AHU-B"
FAN_DT, BLEND_TOL, SAT_TOL, ECON_MIN = 0.55, 1.15, 1.15, 0.12
TOL = _hypot_tol(SAT_TOL, BLEND_TOL)

def apply_faults_arrow(table, cfg, context=None):
    sat, mat = _col(table, "sa-t"), _col(table, "ma-t")
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    hot = pc.greater(sat, pc.add(mat, pc.add(TOL, FAN_DT)))
    mode_a = pc.and_(pc.greater(damper, 0.9), pc.greater(cool,
0.0))
    mode_b = pc.and_(pc.less_equal(damper, ECON_MIN),
pc.greater(cool, 0.9))
    return pc.and_(hot, pc.or_(mode_a, mode_b))

```

38.2.10 Rule K — discharge above setpoint in full cooling (AHU-C)

```

FAULT_CODE = "AHU-C"
SAT_TOL, ECON_MIN = 1.15, 0.12

def apply_faults_arrow(table, cfg, context=None):
    sat = _col(table, "sa-t")
    sp = _col(table, "sa-t-sp")
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])

```

```

high = pc.greater(sat, pc.add(sp, SAT_TOL))
full = pc.or_(
    pc.and_(pc.greater(damper, 0.9), pc.greater(cool, 0.9)),
    pc.and_(pc.less_equal(damper, ECON_MIN), pc.greater(cool,
0.9))),
)
return pc.and_(high, full)

```

38.2.11 Rule L — cooling coil ΔT when inactive (CH-C)

```

FAULT_CODE = "CH-C"
ENTER_TOL, LEAVE_TOL, ECON_MIN = 1.15, 1.15, 0.12
TOL = _hypot_tol(ENTER_TOL, LEAVE_TOL)

```

```

def apply_faults_arrow(table, cfg, context=None):
    ent = _col(table, "cooling-coil-entering-air-temperature")
    leave = _col(table, "cooling-coil-leaving-air-temperature")
    heat = _norm_cmd(table["heating-valve-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    drop = pc.greater(pc.subtract(ent, leave), TOL)
    mode_a = pc.and_(pc.greater(heat, 0), pc.equal(cool, 0),
pc.less_equal(damper, ECON_MIN))
    mode_b = pc.and_(pc.equal(heat, 0), pc.equal(cool, 0),
pc.greater(damper, ECON_MIN))
    return pc.and_(drop, pc.or_(mode_a, mode_b))

```

38.2.12 Rule M — heating coil ΔT when inactive (AHU-B)

```

FAULT_CODE = "AHU-B"
ENTER_TOL, LEAVE_TOL, FAN_DT, ECON_MIN = 1.15, 1.15, 0.55, 0.12
TOL = _hypot_tol(ENTER_TOL, LEAVE_TOL) + FAN_DT

```

```

def apply_faults_arrow(table, cfg, context=None):
    ent = _col(table, "heating-coil-entering-air-temperature")
    leave = _col(table, "heating-coil-leaving-air-temperature")
    heat = _norm_cmd(table["heating-valve-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    damper = _norm_cmd(table["oa-damper-command"])
    rise = pc.greater(pc.subtract(leave, ent), TOL)
    m1 = pc.and_(pc.equal(heat, 0), pc.equal(cool, 0),
pc.greater(damper, ECON_MIN))
    m2 = pc.and_(pc.equal(heat, 0), pc.greater(cool, 0),
pc.greater(damper, 0.9))
    m3 = pc.and_(pc.equal(heat, 0), pc.greater(cool, 0),

```

```
pc.less_equal(damper, ECON_MIN))
    return pc.and_(rise, pc.or_(m1, m2, m3))
```

38.3 Starter pack (VAV / AHU baseline)

38.3.1 01_vav_zone_temp_bounds_occupied (VAV-C)

```
from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask,
_unoccupied_mask
```

```
FAULT_CODE = "VAV-C"
```

```
def apply_faults_arrow(table, cfg, context=None):
    occupied = pc.invert(_unoccupied_mask(table, cfg))
    oob = sensor_bounds_mask(table, "zone_temp", cfg)
    return pc.and_(oob, occupied)
```

38.3.2 02_vav_zone_temp_flatline_occupied (VAV-C)

```
from open_fdd.arrow_runtime.cookbook import sensor_flatline_mask,
_unoccupied_mask
```

```
FAULT_CODE = "VAV-C"
```

```
def apply_faults_arrow(table, cfg, context=None):
    occupied = pc.invert(_unoccupied_mask(table, cfg))
    flat = sensor_flatline_mask(table, "zone_temp", cfg)
    return pc.and_(flat, occupied)
```

38.3.3 03_vav_damper_command_extreme_flatline (VAV-D)

```
from open_fdd.arrow_runtime.cookbook import flatline_1h_mask
```

```
FAULT_CODE = "VAV-D"
```

```
DAMPER = "damper-position-command"
```

```
def apply_faults_arrow(table, cfg, context=None):
    stuck = flatline_1h_mask(table, {**cfg, "column": DAMPER})
    wide = pc.greater(_norm_cmd(table[DAMPER]), 0.975)
    return pc.and_(stuck, wide)
```


38.3.4 04_ahu_runtime_outside_schedule (BLD-C)

Use run-hours analytics script + schedule compare; boolean mask:

```
from open_fdd.arrow_runtime.cookbook import _fan_on_mask,
_unoccupied_mask
```

```
FAULT_CODE = "BLD-C"
```

```
def apply_faults_arrow(table, cfg, context=None):
    return pc.and_( _fan_on_mask(table, cfg),
_unoccupied_mask(table, cfg))
```

38.3.5 05 / 06 / 07 — see Rules A, sensor_bounds_mask on sa-t / sensor_flatline_mask on sa-t

38.4 Economizer starters

38.4.1 ahu_econ_100oa_temp_tracking_fault (AHU-E)

```
FAULT_CODE = "AHU-E"
```

```
DAMPER_FULL, FAN_ON, TRACK_TOL, FAN_HEAT = 0.95, 0.5, 2.0, 0.5
```

```
def apply_faults_arrow(table, cfg, context=None):
    oat, mat, sat = _col(table, "oa-t"), _col(table, "ma-t"),
_col(table, "sa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    fan = _col(table, "supply-fan-status")
    econ = pc.and_(pc.greater(fan, FAN_ON),
pc.greater_equal(damper, DAMPER_FULL))
    mat_bad = pc.greater(pc.abs(pc.subtract(mat, oat)), TRACK_TOL)
    sat_bad = pc.greater(pc.abs(pc.subtract(pc.subtract(sat,
FAN_HEAT), mat)), TRACK_TOL)
    return pc.and_(econ, pc.or_(mat_bad, sat_bad))
```

38.4.2 ahu_mech_cooling_when_free_cooling_available (AHU-E)

```
FAULT_CODE = "AHU-E"
```

```
MARGIN, DAMPER_LOW, COOL_ON = 2.0, 0.50, 0.10
```

```
def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
```

```

        sp = _col(table, "sa-t-sp")
        damper = _norm_cmd(table["oa-damper-command"])
        cool = _norm_cmd(table["cooling-valve-command"])
        free = pc.less_equal(oat, pc.subtract(sp, MARGIN))
        return pc.and_(free, pc.less(damper, DAMPER_LOW),
pc.greater_equal(cool, COOL_ON))

```

38.4.3 ahu_oa_damper_excess_open_extreme_ambient (AHU-E)

```

FAULT_CODE = "AHU-E"
DAMPER_MIN, HI_OAT, LO_OAT = 0.50, 70.0, 40.0

```

```

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    extreme = pc.or_(pc.greater_equal(oat, HI_OAT),
pc.less_equal(oat, LO_OAT))
    return pc.and_(pc.greater_equal(damper, DAMPER_MIN), extreme)

```

38.5 VAV zones

38.5.1 zone_reheat_warm_ambient (VAV-A)

```

FAULT_CODE = "VAV-A"
T_CUTOFF, REHEAT_MIN = 78.0, 0.52

```

```

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    reheat = _norm_cmd(table["reheat-valve-command"])
    return pc.and_(pc.greater(oat, T_CUTOFF), pc.greater(reheat,
REHEAT_MIN))

```

38.5.2 zone_damper_valve_full_open (VAV-D)

```

FAULT_CODE = "VAV-D"
FULL_OPEN, ROLL = 97.5, 105

```

```

def apply_faults_arrow(table, cfg, context=None):
    d = _norm_cmd(table["damper-position-command"])
    hi = pc.greater(d, FULL_OPEN)
    rmin = arrow_rolling_min(d, ROLL)
    return pc.and_(hi, pc.greater(rmin, FULL_OPEN))

```

38.5.3 Zone / IAQ bounds

Use `sensor_bounds_mask(table, "zone_temp", cfg)` or `sensor_bounds_mask` with CO₂ profile — see `[sensor validation]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}#sensor-validation-bounds-flatline-rate-of-change)`.

38.6 Central plant

38.6.1 dp_below_sp_pump_max (CH-E)

```
FAULT_CODE = "CH-E"
DP_MARGIN, PMP_HI, PMP_NEAR = 2.2, 0.93, 0.06

def apply_faults_arrow(table, cfg, context=None):
    dp = _col(table, "differential-pressure")
    sp = _col(table, "differential-pressure-sp")
    pump = _norm_cmd(table["pump-speed-command"])
    return pc.and_(
        pc.less(dp, pc.subtract(sp, DP_MARGIN)),
        pc.greater_equal(pump, PMP_HI - PMP_NEAR),
    )
```

38.6.2 flow_high_pump_max (CH-B)

```
FAULT_CODE = "CH-B"
FLOW_HI, PMP_HI, PMP_NEAR = 1100.0, 0.93, 0.06

def apply_faults_arrow(table, cfg, context=None):
    flow = _col(table, "water-flow")
    pump = _norm_cmd(table["pump-speed-command"])
    return pc.and_(pc.greater(flow, FLOW_HI),
pc.greater_equal(pump, PMP_HI - PMP_NEAR))
```

38.6.3 plant_supply_temp_deadband (CH-D)

```
FAULT_CODE = "CH-D"
SP_BAND = 2.2

def apply_faults_arrow(table, cfg, context=None):
    temp = _col(table, "chilled-water-supply-temperature")
    sp = _col(table, "chilled-water-supply-temperature-sp")
    pump = _norm_cmd(table["pump-speed-command"])
    low = pc.less(temp, pc.subtract(sp, SP_BAND))
```

```

high = pc.greater(temp, pc.add(sp, SP_BAND))
return pc.and_(pc.greater(pump, 0.01), pc.or_(low, high))

```

38.6.4 chiller_excessive_runtime (CH-F)

```

from open_fdd.arrow_runtime.cookbook import arrow_rolling_mean

FAULT_CODE = "CH-F"
WINDOW, MAX_ON = 276, 264 # 5-min data ≈ 23 h window, 22 h max on

def apply_faults_arrow(table, cfg, context=None):
    on = pc.greater(_col(table, "chiller-status"),
0.5).cast(pa.float64())
    roll = arrow_rolling_mean(on, WINDOW)
    count = pc.multiply(roll, float(WINDOW))
    return pc.greater(count, float(MAX_ON))

```

38.7 Heat pumps

38.7.1 hp_discharge_cold_when_heating (HP-D)

```

FAULT_CODE = "HP-D"
MIN_SAT, ZONE_COLD, FAN_ON = 85.0, 69.0, 0.01

def apply_faults_arrow(table, cfg, context=None):
    sat = _col(table, "sa-t")
    zone = _col(table, "stat_zn-t")
    fan = _col(table, "supply-fan-status")
    return pc.and_(
        pc.greater(fan, FAN_ON),
        pc.less(zone, ZONE_COLD),
        pc.less(sat, MIN_SAT),
    )

```

38.8 Opportunistic / ventilation

38.8.1 econ_active_warm_ambient (AHU-E)

```

FAULT_CODE = "AHU-E"
T_CUTOFF, DPR_MIN = 63.0, 0.42

def apply_faults_arrow(table, cfg, context=None):

```

```

        oat = _col(table, "oa-t")
        damper = _norm_cmd(table["oa-damper-command"])
        return pc.and_(pc.greater(oat, T_CUTOFF), pc.greater(damper,
DPR_MIN))

```

38.8.2 mech_cool_when_econ_available (AHU-E)

```

FAULT_CODE = "AHU-E"
T_CUTOFF, DPR_MAX = 63.0, 0.32

```

```

def apply_faults_arrow(table, cfg, context=None):
    oat = _col(table, "oa-t")
    damper = _norm_cmd(table["oa-damper-command"])
    cool = _norm_cmd(table["cooling-valve-command"])
    return pc.and_(pc.less(oat, T_CUTOFF), pc.less(damper,
DPR_MAX), pc.greater(cool, 0.01))

```

38.8.3 low_oa_fraction_estimated (VAV-B)

```

FAULT_CODE = "VAV-B"
OA_MIN, GAP = 21.0, 2.2

```

```

def apply_faults_arrow(table, cfg, context=None):
    mat, rat, oat = _col(table, "ma-t"), _col(table, "ra-t"),
_col(table, "oa-t")
    fan = _norm_cmd(table["supply-fan-speed-command"])
    denom = pc.subtract(oat, rat)
    safe = pc.greater(pc.abs(denom), GAP)
    num = pc.subtract(mat, rat)
    oa_pct = pc.multiply(pc.divide(num, denom), 100.0)
    low = pc.less(oa_pct, OA_MIN)
    return pc.and_(pc.greater(fan, 0.01), safe, low)

```

38.8.4 preheat_excess_temp (AHU-B)

```

FAULT_CODE = "AHU-B"
EXCESS = 2.2

```

```

def apply_faults_arrow(table, cfg, context=None):
    pre = _col(table, "preheat-coil-leaving-air-temperature")
    sp = _col(table, "sa-t-sp")
    oat = _col(table, "oa-t")
    valve = _norm_cmd(table["preheat-valve-command"])
    hot_oa = pc.and_(
        pc.greater(oat, sp),
        pc.greater(pc.subtract(pre, oat), EXCESS),
    )

```

```

        cold_oa = pc.and_(
            pc.less(oat, sp),
            pc.greater(pc.subtract(pre, sp), EXCESS),
        )
    return pc.and_(pc.greater(valve, 0.01), pc.or_(hot_oa,
cold_oa))

```

38.9 Weather station

38.9.1 weather_temp_spike (BLD-B)

```

from open_fdd.arrow_runtime.cookbook import rate_of_change_mask

FAULT_CODE = "BLD-B"

def apply_faults_arrow(table, cfg, context=None):
    return rate_of_change_mask(
        table,
        {**cfg, "max_per_sample": 16.0, "column": "oa-t"},
        col="oa-t",
    )

```

38.9.2 weather_gust_lt_wind (BLD-B)

```

FAULT_CODE = "BLD-B"

def apply_faults_arrow(table, cfg, context=None):
    gust = _col(table, "wind-gust-speed")
    wind = _col(table, "wind-speed")
    return pc.and_(
        pc.is_valid(gust),
        pc.is_valid(wind),
        pc.less(gust, wind),
    )

```

38.9.3 RH bounds

```

from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask

FAULT_CODE = "DC-C"

def apply_faults_arrow(table, cfg, context=None):
    merged = {**cfg, "value_kind": "rh"}
    return sensor_bounds_mask(table, "relative_humidity", merged)

```

38.10 Schedule + weather gating (occupied hours)

```
from open_fdd.arrow_runtime.cookbook import _unoccupied_mask,
_fan_on_mask

FAULT_CODE = "BLD-C"

def apply_faults_arrow(table, cfg, context=None):
    """Fan running when schedule says unoccupied."""
    return pc.and(_fan_on_mask(table, cfg),
_unoccupied_mask(table, cfg))
```

Pass occupied_start_hour, occupied_end_hour, tz_offset_hours in Rule Lab cfg.

38.11 FC4 — PID hunting (modernized from legacy GL36)

Legacy pandas FaultConditionFour built hourly AHU operating-state transition counts. Open-FDD v1 **modernizes** FC4 into an Arrow-native **PID / control hunting** detector — sample-window rolling step counts, not pandas hourly resample("H"). See [Legacy FC4 documentation]({{ "/rule-authoring/legacy-pandas-parity/" | relative_url }}#fault-rule-4-fc4-modernized-hunting-detector).

Ports gist check_hunting intent to Arrow. Two modes:

Mode	cfg["hunting_mode"]	Use on
Per-loop command	command (default)	VAV damper, reheat, pump VFD, RTU cooling %
AHU operating-state bitmap	ahu_os	RTU/AHU with economizer + fan + heat + cool columns in wide frame

Fault codes: VAV-F (VAV outputs), **CH-G** (plant pump), **RTU-E** (RTU cooling capacity), **AHU-G** (multi-signal OS / legacy FC4 alias).

```
"""pid_hunting_fc4.py – deploy via setup_gl36_fdd.py or Rule
Lab."""

import pyarrow as pa

from open_fdd.arrow_runtime.cookbook import
pid_hunting_ahu_os_mask, pid_hunting_command_mask

FAULT_CODE = "VAV-F" # or AHU-G, CH-G, RTU-E per binding

def apply_faults_arrow(table, cfg, context=None):
    mode = str(cfg.get("hunting_mode") or
"command").strip().lower()
    if mode in ("ahu", "ahu_os", "os"):
        return pid_hunting_ahu_os_mask(table, cfg)
    col = str(cfg.get("value_column") or cfg.get("column") or
"").strip()
    if col and col not in table.column_names:
        return pa.array([False] * table.num_rows, type=pa.bool_)
    return pid_hunting_command_mask(table, cfg, col=col or None)
```

Tuning (Acme 60 s poll, 1 h window):

```
cfg = {
    "poll_interval_s": 60,
    "hunting_window_hours": 1.0,
    "delta_os_max": 10, # max command steps or OS bitmap
changes per window
    "min_command_delta": 0.03, # 3 % minimum step to count as a
reversal
    "min_active_command": 0.05,
# loop must be modulating above 5 %
}
```

Legacy interlink: LEGACY_CODE_MAP["FC4"] → **AHU-G**; per-loop VAV/
plant rules use family-specific codes above.


38.12 Next steps

1. Copy a module into workspace/data/rules_py/<site>_<rule>.py
2. Bind feather columns on the Rule Lab row
3. Set fault_code metadata
4. Quick-test on 3–24 h feather window
5. Ship via setup_gl36_fdd.py or Rule Lab save

See also: [Expression cookbook]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}) · [Fault codes](#)({{ "/fault-codes/" | relative_url }}) · [Rule Lab](#)({{ "/operator-bridge/rule-lab/" | relative_url }})

39 System overview

40 System overview



40.1 Docker edge stack (production)

Three GHCR images — see [Containers](#)({{ "/architecture/containers/" | relative_url }}):

Container	BACnet OT	Operator LAN
bridge	No (HTTP only)	Yes, via Caddy :80 or loopback :8765
commission		No (internal :8767)

Container	BACnet OT	Operator LAN
	Yes (host network, :47808)	
mcp-rag	No	No (internal :8090)

BACnet **polling** is not a separate container — it runs inside **commission**. The bridge only **ingests** poll CSV into feather.

40.2 Components

Layer	Responsibility
Operator Bridge	Auth, REST/WebSocket API, compiled dashboard, Rule Lab, historian ingest
BACnet commission	Who-Is, read/write (gated), scheduled poll loop → samples.csv
Historian	Feather files per point; local-first retention
FDD runner	workspace/data/rules_py/*.py on timer or POST /api/rules/batch
Model	Brick TTL + model.json bindings (fdd_input, equipment tree)
MCP RAG	Optional doc retrieval for agent tools
Caddy	Host reverse proxy :80 → bridge (typical edge)
Ollama	Optional host LLM for building insight (not required for FDD)

40.3 Deployment

IT operators: [Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }}). Modes and Caddy: [Deployment modes](#)({{ "/architecture/deployment-modes/" | relative_url }}).

40.4 Optional PyPI-only path

pip install open-fdd ships Arrow runtime + playground lint helpers **without** the Operator Bridge UI. Use for offline rule tests or CI. See [Appendix — Python package]({{ "/appendix/python-package/" | relative_url }}).

41 Rule authoring (v1)

42 Rule authoring (stable v1)

Open-FDD **v1 executable FDD** runs on **PyArrow tables** at the edge. Optional **DataFusion SQL** covers simple, stateless rules. The old **pandas row-loop / YAML expression** runtime is **retired** for production batch FDD.

Page	Purpose
PyArrow vs DataFusion SQL ({{ "/rule-cookbook/expression-cookbook/"	relative_url }}#pyarrow-vs-datafusion-sql)
[Arrow rule contract] ({{ "/rule-authoring/arrow-rule-contract/"	relative_url }}
[Data types & units] ({{ "/rule-authoring/data-types-and-units/"	relative_url }}
Legacy pandas parity ({{ "/rule-authoring/legacy-pandas-parity/"	relative_url }}
[Rust readiness]({{ "/rule-authoring/rust-readiness/"	relative_url }}
[Expression cookbook] ({{ "/rule-cookbook/expression-cookbook/"	relative_url }}
DataFusion SQL rules ({{ "/datafusion-sql-rules/"	relative_url }}

42.1 YAML in the repo today

Two different YAML uses — do not conflate them:

YAML location	Role in v1	Executable on edge?
open_fdd/faults/catalog/*.yaml	Fault-code metadata — letter codes, descriptions,	No — catalog only

YAML location	Role in v1	Executable on edge?
	standards crosswalk	
open_fdd/ default_rules/**/ *.yaml	Starter rule metadata — inputs, params, legacy expression text for migration reference	No — translate to rules_py Arrow modules
Rule Lab saved rules (workspace/ data/rules_py/)	Production rules — apply_faults_arrow or backend: datafusion_sql	Yes

Retired: pandas-era type: expression / type: hunting packs
executed by open_fdd.engine.RuleRunner. That engine is not shipped
on PyPI 3.x.

42.2 Install extras (packaging)

Extra	Purpose
pip install open-fdd	PyArrow runtime, lint, tests
pip install 'open-fdd[datafusion]'	Optional DataFusion SQL backend (datafusion>=40)
pip install 'open-fdd[pandas]'	Dev/central analytics only — not edge FDD

See [pyproject.toml](#) — the datafusion optional dependency group is
defined and matches docs.

42.3 Legacy reference

The historical pandas fault classes live in this gist (reference
only):

[bbartling/11cb1cb1295a1bfba5c167efa02122ef](https://gist.github.com/bbartling/11cb1cb1295a1bfba5c167efa02122ef)

Use the [legacy parity matrix]({{ "/rule-authoring/legacy-pandas-parity/" | relative_url }}) for migration — not the gist — when
binding modern fault codes and tests.

43 Deployment modes

44 Deployment modes

How Open-FDD is typically run: local development, lab LAN trials, and production edge on a trusted OT/IT network. Open-FDD is designed for **building LAN or OT edge** deployment — not direct exposure to the public internet.

44.1 Mode summary

Mode	Stack	BACnet	Front door	Auth
Local dev	Compose on control machine	Optional bench simulator	127.0.0.1:8765	OFDD_AUTH_DISABLED=1 optional on loopback
Lab LAN	Three GHCR containers	Real or simulator VLAN	Caddy :80 or direct :8765	Required unless explicit insecure lab flags
Edge production	Three GHCR containers + host Caddy	OT NIC via commission	Caddy :80 or :443 → loopback bridge	Required — workspace/auth.env.local

44.2 v3 container stack (all edge modes)

Image	Role
openfdd-bridge	Operator Bridge API, dashboard, feather historian ingest
openfdd-commission	BACnet discover/read/write + poll loop
openfdd-mcp-rag	Doc-search sidecar for agent tools

openfdd-bacnet-poll is retired. BACnet polling runs inside **commission** only. Do not run the legacy poll container or openfdd-bacnet-poll systemd unit alongside Docker commission — that double-polls the OT network.

See [Containers](#)({{ "/architecture/containers/" | relative_url }}) for ports, networks, and persistence.

44.3 Caddy HTTP (typical edge)

- Caddy listens on building LAN :80
- Reverse-proxies to bridge at 127.0.0.1:8765
- Bridge stays loopback-only; operators bookmark `http://<edge-ip>/`

Bootstrap and compose: [Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }}).


44.4 Caddy TLS (OT LAN)

For HTTPS on the edge LAN (self-signed or site CA):

1. Generate certs: `./scripts/setup_caddy_certs.sh` (control machine) or site PKI
2. Start with `OFDD_CADDY_MODE=tls`
3. Trust the CA on operator PCs

Details: [TLS and certificates](#)({{ "/security/tls-and-certs/" | relative_url }}). Security headers are set by the **Operator Bridge**; Caddy adds **HSTS** only in TLS mode.

44.5 BACnet data path



The bridge thread named `bacnet_poll_worker` is **ingest only** — it does not bind BACnet.

44.6 What not to do on production edges

- Port-forward :8765 to the public internet without TLS and strong auth
- Run `docker compose down -v` or delete workspace/ on a live site
- Deploy the retired `openfdd-bacnet-poll` image alongside `commission`

44.7 Related

Topic	Page
First deploy	[Quick Start — Docker]({{ "/quick-start/docker/"
Upgrade	<u>Updating the stack</u> ({{ "/quick-start/updates/"
LAN security	LAN hardening({{ "/security/lan-hardening/"
Lab example site	[Examples — GL36 lab note]({{ "/examples/acme-gl36-lab/"

45 Containers

46 Containers

Open-FDD v3 edge sites run **three** GHCR containers plus optional **host** services (Caddy, Ollama). There is no separate BACnet poll container — **field BACnet polling lives in commission**.

Quick answer: Who binds BACnet UDP 47808? **openfdd-commission**. Bridge only ingests samples.csv into the feather historian.

46.1 GHCR images


Image	Compose service	Role
ghcr.io/bbartling/openfdd-bridge	bridge	Operator API, React dashboard, feather ingest
ghcr.io/bbartling/openfdd-commission	commission	BACnet discover / read / write + poll loop
ghcr.io/bbartling/	mcp-rag	Doc-search sidecar for agent tools

Image	Compose service	Role
openfdd-mcp-rag		

Tag: **latest** on [GitHub Packages](#). Retired: openfdd-bacnet-poll (poll runs inside **commission**). GHCR retains only the **three newest** versions per image.

Template: docker/compose.edge.yml → copy to ~/open-fdd/docker-compose.yml.

46.2 Stack diagram



46.3 Responsibilities

Concern	Container
BACnet Who-Is / read / write	commission
BACnet scheduled RPM reads	commission (bacnet_poll_loop)
CSV → feather historian	bridge (feather ingest worker — bacnet_poll_worker module name is historical)
Operator login, Rule Lab, faults UI	bridge
Agent doc search	mcp-rag

The bridge thread named `bacnet_poll_worker` is **ingest only** — it does not bind BACnet.

46.4 Network and ports (typical edge)

Endpoint	Reachable from	Notes
Caddy :80	Building LAN	Reverse proxy to bridge
Bridge :8765	Loopback (default)	Bind 127.0.0.1 in compose
Commission : 8767	Bridge / loopback	HTTP API for BACnet ops
Commission : 47808	OT BACnet LAN	UDP; requires <code>network_mode: host</code>
MCP :8090	Bridge container network	Not exposed to LAN by default

46.5 Long-lived deployment

All compose services set `restart: unless-stopped`. After host reboot:

```
sudo systemctl enable docker
cd ~/open-fdd && docker compose ps
```

If containers are down: `docker compose up -d` (idempotent).

See [Run with Docker images](#)({{ "/quick-start/docker/" | relative_url }}).

46.6 Persistent data

State lives on the **host** under `workspace/` (bind mount). Containers are replaceable; **backup workspace/** before image upgrades.

Path	Contents
<code>workspace/data/feather_store/</code>	Historian
<code>workspace/data/*.json</code>	Model, rules, FDD results

Path	Contents
workspace/bacnet/ commissioning/	commission.env, points.csv
workspace/bacnet/ polls/samples.csv	Poll output
workspace/ auth.env.local	Login secrets
workspace/api/static/ app/	Dashboard bundle (if updated separately)

46.7 Optional host services

Service	Role
Caddy	TLS or plain HTTP :80 → 127.0.0.1:8765
Ollama	Optional LLM on :11434 (not in the three-image stack)
FDD loop timer	Optional openfdd-fdd- loop.timer on host (docker exec batch)

47 Data flow

48 Data flow

48.1 Telemetry ingest

Open-FDD supports three commissioning drivers. Each appends long-format samples to workspace CSVs and writes **feather shards** tagged by source (bacnet, modbus, json_api).

48.1.1 BACnet

1. **Commission poll loop** (inside the commission container) reads enabled BACnet points from points.csv on a schedule (host network, BACnet :47808).
2. RPM results append to workspace/bacnet/polls/samples.csv.

3. **Bridge ingest worker** loads new rows into feather_store/bacnet/.

BACnet devices → commission (poll loop) → samples.csv → bridge (ingest) → feather_store/bacnet

48.1.2 Modbus TCP

1. Operator configures registers on the **Modbus** tab (or read_and_store API).
2. Poll worker reads holding/input registers via Modbus TCP.
3. Samples append to workspace/modbus/polls/samples.csv → feather_store/modbus/.

48.1.3 JSON API (HTTP/HTTPS)

1. Operator configures REST endpoints on the **JSON API** tab — GET/POST, Bearer or Basic auth, \${ENV:VAR} placeholders from json_api.env.local, optional TLS verify off for self-signed OT gateways.
2. Poll worker issues HTTP requests (one GET can fan out to multiple JSON paths, e.g. OpenWeather web-oat-t / web-rh / web-weather-desc).
3. Samples append to workspace/json_api/polls/samples.csv → feather_store/json_api/.
4. FDD batch **merges** json_api columns with BACnet/Modbus on the same site (nearest timestamp, 30 min tolerance) for cross-source rules.

OT REST / weather API → bridge JSON API worker → samples.csv → feather_store/json_api

↘ merged

into FDD frame with bacnet/modbus

Showcase: [OpenWeatherMap bundle]({{ "/drivers/json-api/" | relative_url }})#openweathermap-showcase-recommended-demo).
Details: Driver framework({{ "/drivers/" | relative_url }}), [BACnet polling]({{ "/bacnet/polling/" | relative_url }}), JSON API driver({{ "/drivers/json-api/" | relative_url }}), Containers({{ "/architecture/containers/" | relative_url }}).

48.2 Rule evaluation

1. Rules are Python files in workspace/data/rules_py/ with metadata in rules_store.json.
2. **Bindings** map rules to points via the Brick model (fdd_input tags).
3. Batch runner (POST /api/rules/batch or host timer) produces fdd_results.json.

4. Dashboard **faults** view and check-engine status read aggregated results.

48.3 Model sync

- Commissioning imports update `model.json` / TTL graph.
- `POST /api/model/sync-ttl` refreshes SPARQL-backed tree used by the UI.

48.4 Retention

Feather files grow on disk; retention is configurable (`workspace/data.env.local`). Image upgrades must **preserve** `workspace/data/` — `backup` before `docker compose up -d --force-recreate`. See [Updating the stack](#)(`{{ "/quick-start/updating/" | relative_url }}`).

49 Architecture

50 Architecture

Open-FDD v3 edge: **three Docker containers** (`bridge`, `commission`, `mcp-rag`), BACnet polling in **commission**, feather ingest in **bridge**, optional host Caddy and Ollama.

Page	Topic
System overview (<code>{{ "/architecture/overview/" relative_url }}</code>)	<code>relative_url }}</code>)
Deployment modes (<code>{{ "/architecture/deployment-modes/" relative_url }}</code>)	<code>relative_url }}</code>)
Data flow (<code>{{ "/architecture/data-flow/" relative_url }}</code>)	<code>relative_url }}</code>)
Containers (<code>{{ "/architecture/containers/" relative_url }}</code>)	<code>relative_url }}</code>)
Driver framework (<code>{{ "/drivers/" relative_url }}</code>)	<code>relative_url }}</code>)

Operators: `[Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }})` — no git clone on the edge host.

BACnet polling: `Polling({ { "/bacnet/polling/" | relative_url } })` — commission container only.

51 Fault confirmation / minimum duration

52 Fault confirmation

A raw rule condition can flicker true for one sample. **Fault confirmation** delays the final fault mask until the condition stays true for N consecutive rows or N minutes.

52.1 Config fields

Field	Type	Meaning
<code>min_true_rows</code>	<code>int</code>	Consecutive true samples required
<code>min_elapsed_minutes</code>	<code>float</code>	Elapsed time from streak start (uses timestamp)
<code>poll_interval_s</code>	<code>float</code>	Fallback when timestamps missing
<code>timestamp_column</code>	<code>str</code>	Default timestamp

52.2 Example

At **60-second polling**, `min_true_rows: 5` means the condition must persist about **5 minutes** before fault becomes true.

PyArrow:

```
def apply_faults_arrow(table, cfg, context=None):  
    return pc.greater(table["duct-t"], 80.0)
```

Rule config:

```
{"min_true_rows": 5, "poll_interval_s": 60}
```

DataFusion SQL (same config — confirmation runs after SQL):

```
SELECT  
    *,
```

```
"duct-t" > 80.0 AS fault
FROM telemetry
```

The runtime applies confirmation in `open_fdd.arrow_runtime.confirmation` for both backends.

52.3 Paired smoke default (5 minutes)

The hardcoded paired FDD harness (`open_fdd/validation/paired_fdd_contract.py`) sets **5-minute confirmation** on every smoke rule:

```
{ "min_elapsed_minutes": 5, "min_true_rows": 5, "poll_interval_s": 60 }
```

This suppresses false positives during bench 5007 / Acme OAT spread toggles. See [Paired FDD smoke](#).

53 Rule Cookbook

54 Rule Cookbook

Practical patterns for **Arrow-native Rule Lab** on feather historian PyArrow tables — **no pandas on the IoT edge**.

Start here: [Rule authoring \(v1\)](#)(`{{ "/rule-authoring/" | relative_url }}`) — PyArrow vs SQL decision table, Arrow contract, legacy parity, Rust checklist.

Page	Use when
Rule authoring (v1) (<code>{{ "/rule-authoring/" relative_url }}</code>)	<code>relative_url }}</code>)
[Rule Lab quick start] (<code>{{ "/operator-bridge/rule-lab/" relative_url }}</code>)	<code>relative_url }}</code>)
[PyArrow rule recipes] (<code>{{ "/rule-cookbook/python-recipes-arrow/" relative_url }}</code>)	<code>relative_url }}</code>)
DataFusion SQL recipes (<code>{{ "/rule-cookbook/datafusion-sql-recipes/" relative_url }}</code>)	<code>relative_url }}</code>)

Page	Use when
Fault confirmation ({{ "/rule-cookbook/fault-confirmation/"	
Windowing & debugging ({{ "/rule-cookbook/windowing-debugging/"	relative_url }}
[Expression cookbook]({{ "/rule-cookbook/expression-cookbook/"	relative_url }}
GL36 algorithm stubs ({{ "/rule-cookbook/gl36-algorithm-stubs/"	relative_url }}

PyArrow is the primary path for complex HVAC FDD and ML prep. **DataFusion SQL** is optional, Rust-ready, and best for simple expression-style rules.

Programmatic sensor defaults:
open_fdd.arrow_runtime.sensor_catalog.SENSOR_PROFILES.

```
import pyarrow.compute as pc
from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask

def apply_faults_arrow(table, cfg, context=None):
    return sensor_bounds_mask(table, "zone_temp", cfg,
min_true_rows=5)
```

55 Windowing & debugging

56 Windowing & debugging

56.1 Lookback vs rolling window

	Historian lookback	Rolling window
Set by	Batch lookback_hours, FDD loop, Quick test UI	WINDOW_SAMPLES constant in rule.py
Typical	1 h scheduled; 24 h Update all	12 samples ≈ 1 h @ 5 min poll relative_url }}

	Historian lookback	Rolling window
Validate with	<code>_kit_lookback_stats(table) —</code> see [Lookback window helper] (<code>{{ "/rule-cookbook/lookback-window/"</code>	

56.2 Rolling windows (Arrow)

Use `open_fdd.arrow_runtime.windows` for sample-based rolling min/max and consecutive-true streaks:

```
from open_fdd.arrow_runtime.windows import arrow_rolling_min,
arrow_rolling_max, arrow_consecutive_true
```

Cookbook masks (`flatline_1h_mask`, `spread_1h_mask`, `oob_mask`) default to ~12 samples (~1 h at 5 min poll).

Bench rules use constants: `WINDOW_SAMPLES`, `FLATLINE_TOLERANCE`, `OAT_LOW` / `OAT_HIGH`, etc. Legacy `cfg` keys still work for uploaded rules that read `cfg.get(...)`.

56.3 Rule Lab console

Quick-test and batch responses include backend: `arrow`, `ms`, and flagged row counts. Arrow summary events appear in the event console on fault hits.

57 Expression cookbook (Arrow-native)

58 Expression cookbook (Arrow-native)

Reference for **Open-FDD 3.x Rule Lab**: every **executable** rule is a Python module with `apply_faults_arrow(table, cfg, context)` using `pyarrow.compute` — **no pandas, no NumPy DataFrames on the IoT edge, no pandas RuleRunner.**

YAML today: `open_fdd/faults/catalog/*.yaml` and `open_fdd/default_rules/**/*.yaml` hold **metadata and migration starters only** — not edge execution. See [Rule authoring — YAML distinction]({{ "/rule-authoring/" | relative_url }}#yaml-in-the-repo-today).

Legacy GL36-style recipes map to **fixed fault codes**({{ "/fault-codes/" | relative_url }}) and Arrow patterns below. Full migration matrix: [Legacy pandas parity](#)({{ "/rule-authoring/legacy-pandas-parity/" | relative_url }}).

58.1 PyArrow vs DataFusion SQL

Start here when choosing a backend. Both normalize to `[ArrowRuleResult]({{ "/rule-authoring/arrow-rule-contract/" | relative_url }})`.

58.1.1 Use PyArrow when

Need	Why PyArrow
Rolling windows	<code>arrow_rolling_min</code> , <code>arrow_rolling_sum</code> , <code>streak helpers</code>
Flatline detection	<code>sensor_flatline_mask</code> , <code>flatline_1h_mask</code>
Rate-of-change / spike	<code>rate_of_change_mask</code> , <code>arrow_abs_diff</code>
PID hunting / command hunting	<code>pid_hunting_command_mask</code> , <code>pid_hunting_ahu_os_mask</code>
Occupancy or schedule-aware logic	Hour/day masks, <code>_unoccupied_mask</code> , after-hours helpers
Helper functions & sensor profiles	<code>open_fdd.arrow_runtime.cookbook</code> , <code>SENSOR_PROFILES</code>
Unit normalization & null handling	<code>norm_cmd_array</code> , <code>explicit pc.fill_null</code>
Edge runtime stability	Primary path — always installed
Rust migration prep	Arrow semantics portable to a future Rust executor

58.1.2 Use DataFusion SQL when

Need	Why SQL
Simple row-wise threshold	<code>column > limit AS fault</code>

Need	Why SQL
Readable CASE WHEN logic	Operators can inspect SQL without Python
SQL-readable previews	Rule Lab Validate SQL
Future Rust/DataFusion port	Restricted SELECT from telemetry
Non-Python reviewers	Same contract, different syntax

Install: `pip install 'open-fdd[datafusion]'` (defined in `pyproject.toml`).

58.1.3 Do not use DataFusion SQL for

- Complex rolling windows or resample-style hourly logic
- Custom helper-heavy HVAC logic
- PID hunting with stateful window behavior (use PyArrow FC4 helpers)
- ML feature preparation
- Arbitrary file joins or multi-table SQL
- Browser-side rule execution
- Anything that behaves like old pandas row-loop / `DataFrame.apply` logic

See also: [DataFusion SQL rules](#)(`{{ "/datafusion-sql-rules/" | relative_url }}`) · [\[Rust readiness\]](#)(`{{ "/rule-authoring/rust-readiness/" | relative_url }}`).

Topic	Page
Full copy-paste library (GL36 A-M, VAV, plant)	**Python recipes (full Arrow library) (<code>{{ "/rule-cookbook/python-recipes-arrow/" }}</code>)
Quick templates	[Arrow recipes] (<code>{{ "/rule-cookbook/arrow-recipes/" }}</code>)
Shared imports	[Python recipes] (<code>{{ "/rule-cookbook/python-recipes/" }}</code>)
Console window stats	[Lookback window] (<code>{{ "/rule-cookbook/lookback-window/" }}</code>)
Fault code catalog	Fault codes (<code>{{ "/fault-codes/" }}</code>)
Programmatic defaults	<code>open_fdd.arrow_runtime.sensor_catalog</code>

58.2 Legacy → modern translation

Legacy (pandas / YAML)	Arrow-native (3.x)
type: expression + expression: string	apply_faults_arrow() in rules_py/*.py
type: hunting (GL36 FC4)	pid_hunting_fc4.py → AHU-G / VAV-F / CH-G / RTU-E
RuleRunner.run(df, column_map=...)	Rule Lab batch on feather PyArrow table
np.maximum(a, b)	pc.max(a, b)
series.rolling(n).min()	arrow_rolling_min(vals, n) from open_fdd.arrow_runtime.windows
series.diff().abs()	arrow_abs_diff(vals, 1)
normalize_cmd(x)	norm_cmd_array() / pc.if_else(pc.greater(x, 1), pc.divide(x, 100), x)
params.max_temp in YAML	Module constant or cfg["bounds_high"]
flag: rule_a_flag	Rule metadata fault_code → AHU-A ... VAV-C
Numeric codes VAV-03	Letter codes VAV-C (see LEGACY_CODE_MAP in bridge)
Pandas FC4 / fc4_flag	LEGACY_CODE_MAP: FC4 → AHU-G

Edge constraint: Docker / BACnet poll path never imports pandas. Central portfolio Dash may use pandas for CSV analytics only.

58.3 How Arrow rules are structured

1. **Historian columns** — Feather column names from BACnet poll (oa-t, sa-t, stat_zn-t, ...) or Brick labels via model export.
2. **Module constants** — Thresholds at top of file (bench style) or read from cfg for site tuning.
3. **apply_faults_arrow** — Returns a **boolean PyArrow array** (True = fault sample).
4. **fault_code** — Set in Rule Lab metadata; must exist in GET /api/faults/catalog.

```
import pyarrow.compute as pc
from open_fdd.arrow_runtime.cookbook import sensor_bounds_mask
```

```
FAULT_CODE = "VAV-C" # metadata in Rule Lab UI
```

```
def apply_faults_arrow(table, cfg, context=None):
    return sensor_bounds_mask(table, "zone_temp", cfg)
```

58.3.1 Command scaling (0-1 vs 0-100 %)

BACnet often exposes **0-100** for damper/VFD commands. Scale explicitly:

```
def _norm_cmd(col):
    return pc.if_else(pc.greater(col, 1.0), pc.divide(col,
100.0), col)
```

58.3.2 Occupied hours (schedule gating)

Use `open_fdd.arrow_runtime.cookbook._unoccupied_mask` or compare local hour from timestamp column. Example: **fan on when unoccupied** → **BLD-C** / `schedule_compare`.

58.4 Sensor validation (bounds, flatline, rate of change)

Use `open_fdd.arrow_runtime.sensor_catalog.SENSOR_PROFILES` for defaults, or copy constants into `rules_py`. Tune per site in Rule Lab `cfg` or building-agent tuning brief.

58.4.1 Bounds (out of range) — oob_rolling

Sensor kind	Min	Max	Flatline tol	Max Δ / hour	Max Δ / 15 min	Typical fault code
Zone temp (°F)	55	90	0.10	4.0	2.0	VAV-C
Supply air temp	50	110	0.15	8.0	3.0	AHU-C, RTU-C
Return air temp	55	95	0.10	3.0	1.5	AHU-D (also mixing)
Mixed air temp	40	110	0.15	6.0	2.5	AHU-D
Outdoor air temp	-40	130	0.10	12.0	6.0	BLD-B
	-0.5	3.0	0.02	0.5	0.25	AHU-A

Sensor kind	Min	Max	Flatline tol	Max Δ / hour	Max Δ / 15 min	Typical fault code
Duct static (inH ₂ O)						
Relative humidity (%)	0	100	1.0	15.0	8.0	DC-C
Chilled water (°F)	40	90	0.10	4.0	2.0	CH-D
Hot water (°F)	70	200	0.15	6.0	3.0	CH-D
Condenser water (°F)	50	110	0.15	5.0	2.5	CH-A
CO ₂ (ppm, occupied)	400	1000	5.0	200	80	VAV-B (ventilation)
Discharge air temp	45	120	0.15	10.0	4.0	VAV-E, HP-D

Return air uses a **narrow band** vs zone/OAT because RAT should track building return conditions, not outdoor extremes. When OAT/RAT/MAT are all present, prefer **mixing envelope** (below) over RAT bounds alone.

CO₂ upper bound is an occupied ventilation target; unoccupied rules may use 400-2000 ppm per policy.

58.4.2 Flatline (stuck sensor) — flatline_1h

Default **12 samples $\approx$ 1 hour** at 5-minute poll. True when rolling max – min $\leq$ tolerance.

```

from open_fdd.arrow_runtime.cookbook import sensor_flatline_mask

def apply_faults_arrow(table, cfg, context=None):
    return sensor_flatline_mask(table, "outdoor_air_temp", cfg)
# BLD-B

```

Bench references: workspace/data/rules_py/bench_oa-t_flatline_1h.py, bench_stat_zn-t_flatline_1h.py.

58.4.3 Rate of change (spike) — rate_of_change

Flags physically impossible step changes (comms glitch, substituted value).

```
from open_fdd.arrow_runtime.cookbook import rate_of_change_mask
from open_fdd.arrow_runtime.sensor_catalog import cfg_from_profile

def apply_faults_arrow(table, cfg, context=None):
    merged = cfg_from_profile("outdoor_air_temp", cfg)
    merged["samples_per_hour"] = 12 # 5-min poll
    return rate_of_change_mask(table, merged, col="oa-t")
```

Legacy **weather_temp_spike** (spike_limit: 16 °F per step) → **BLD-B** with max_per_15min: 6 or stricter per-step limit.

58.4.4 Mixing envelope (MAT vs OAT/RAT) — mixing_envelope

Legacy GL36 **Rule B / C** and **AHU-D**. MAT should sit between OAT and RAT ($\pm$ tolerance) while fan runs.

```
from open_fdd.arrow_runtime.cookbook import mixing_envelope_mask

def apply_faults_arrow(table, cfg, context=None):
    return mixing_envelope_mask(
        table,
        {**cfg, "mixing_tol": 1.15},
        mat_col="ma-t",
        oat_col="oa-t",
        rat_col="ra-t",
        fan_col="supply-fan-speed-command",
    )
```

58.5 GL36-inspired AHU rules (legacy expression → fault code)

ASHRAE Guideline 36-style rules from the old YAML cookbook, translated to Arrow. Assign **fault_code** per row in Rule Lab.

Legacy rule	Summary	Code	Full Arrow module
Rule A — duct static low @ full fan	SP below SP setpoint at high VFD	AHU-A	[Rule A]({{ "/rule-cookbook/python-recipes-arrow/"
Rule B — blend below band	MAT below OAT/RAT envelope	AHU-D	[Rules B & C]({{ "/rule-cookbook/python-recipes-arrow/"
Rule C — blend above band	MAT above OAT/RAT envelope	AHU-D	[Rules B & C]({{ "/rule-cookbook/python-recipes-arrow/"
		AHU-B	

Legacy rule	Summary	Code	Full Arrow module
Rule D — discharge cold when heating	SAT low vs MAT, heat valve open		[Rule D]({ { "/rule-cookbook/python-recipes-arrow/"
Rule E — SAT low, full heating	SAT below SP, valve > 90%	AHU-C	[Rule E]({ { "/rule-cookbook/python-recipes-arrow/"
Rule F — SAT/MAT mismatch econ	Econ mode, SAT $\neq$ MAT	AHU-E	[Rule F]({ { "/rule-cookbook/python-recipes-arrow/"
Rule G — ambient warm free cool	OAT > SAT SP, econ open, cool off	AHU-E	[Rule G]({ { "/rule-cookbook/python-recipes-arrow/"
Rule H — OAT/MAT mismatch econ+mech	Mech + econ, MAT $\neq$ OAT	AHU-E	[Rule H]({ { "/rule-cookbook/python-recipes-arrow/"
Rule I — OAT/MAT mismatch econ-only	Econ only, MAT $\neq$ OAT	AHU-E	[Rule I]({ { "/rule-cookbook/python-recipes-arrow/"
Rule J — discharge above blend cooling	SAT > MAT in cooling	AHU-B	[Rule J]({ { "/rule-cookbook/python-recipes-arrow/"
Rule K — discharge above SP full cool	SAT > SP, full cooling	AHU-C	[Rule K]({ { "/rule-cookbook/python-recipes-arrow/"
Rule L — cooling coil ΔT when off	CHW drop when valves closed	CH-C	[Rule L]({ { "/rule-cookbook/python-recipes-arrow/"
Rule M — heating coil ΔT when off	HW rise when valves closed	AHU-B	[Rule M]({ { "/rule-cookbook/python-recipes-arrow/"
FC4 — PID hunting	Excessive command reversals or AHU OS changes (modernized — not hourly pandas resample)	AHU-G / VAV-F / CH-G / RTU-E	[FC4 PID hunting]({ { "/rule-cookbook/python-recipes-arrow/"

All rules A-M have **full apply_faults_arrow modules** in [Python recipes \(full Arrow library\)](#)(({ { "/rule-cookbook/python-recipes-arrow/" | relative_url } })).

58.6 Starter pack (VAV / AHU baseline)

Maps to legacy YAML starter filenames in `open_fdd/default_rules/` — **metadata only**; deploy Arrow modules in `rules_py`. Use as first deploy bundle.

Legacy YAML starter	Arrow approach	Fault
01_vav_zone_temp_bounds_occupied	<code>sensor_bounds_mask(..., "zone_temp") + occupied mask</code>	VAV
02_vav_zone_temp_flatline_occupied	<code>sensor_flatline_mask(..., "zone_temp") + occupied</code>	VAV
03_vav_damper_command_extreme_flatline	<code>flatline_1h_mask</code> on damper cmd column	VAV
04_ahu_runtime_outside_schedule	<code>after_hours_fan_satisfied_mask / run-hours script</code>	BL
05_ahu_duct_static_pressure_not_maintained	<code>[Rule A]({{ "/rule-cookbook/python-recipes-arrow/"</code>	rela #ru stat full- ahu
06_ahu_internal_temp_sensor_bounds	<code>sensor_bounds_mask</code> on SAT/MAT	AH
07_ahu_internal_temp_sensor_flatline	<code>sensor_flatline_mask</code> on SAT	AH

58.6.1 Economizer starters

Full modules: `[economizer section]({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#economizer-starters)`
`(ahu_econ_100oa_temp_tracking_fault,`
`ahu_mech_cooling_when_free_cooling_available,`
`ahu_oa_damper_excess_open_extreme_ambient).`

58.7 VAV, central plant, heat pump

Full modules: `[VAV]({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#vav-zones) · Central plant({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#central-plant) · Heat pumps({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#heat-pumps).`

Rolling persistence: `arrow_rolling_min + pc.and_ (replaces pandas .rolling(n).min()).`

58.8 Opportunistic / ventilation

Full modules: [Opportunistic section]({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#opportunistic-ventilation) · [Weather]({{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}#weather-station).

58.9 Data quality vs equipment faults

Symptom	Pattern	Code	Do not confuse with
Flatline 1h	flatline_1h	VAV-C, AHU-C, BLD-B	Equipment off / damper closed
OOB sample	oob_rolling	sensor-specific	True process excursion
Spike between polls	rate_of_change	BLD-B	Fast legitimate weather front
No new samples	stale_points	BLD-D	Equipment fault
MAT ∉ [OAT, RAT]	mixing_envelope	AHU-D	Stratification during startup

Always gate sensor faults with **fan on, valve open, or occupied** where appropriate — see [Sensor & data quality]({{ "/fault-codes/sensor-quality/" | relative_url }}).

58.10 Metric (°C) equivalents

Set `cfg["temp_unit"] = "metric"` in Rule Lab or scale constants:

Imperial	Metric (approx)
55 °F	12.8 °C
90 °F	32.2 °C
50 °F	10.0 °C
110 °F	43.3 °C
2.0 °F tol	1.1 °C
0.15 inH ₂ O	~37 Pa

open_fdd.playground.temp_units documents UI field keys for °F/°C toggle.

58.11 Binding rules to the fault catalog

1. Pick a **letter code** from `Fault_codes`(`{{ "/fault-codes/" | relative_url }}`) — never invent suffixes.
2. In Rule Lab, set **fault_code** on the rule row.
3. Batch FDD aggregates into GET `/api/faults/status` and portfolio rollup.
4. Legacy numeric codes (AHU-03) migrate via `LEGACY_CODE_MAP` in the bridge.

```
curl -s http://127.0.0.1:8765/api/faults/catalog | jq
'.families[].codes[] | select(.code=="VAV-C")'
```

58.12 Pandas YAML → Arrow checklist (commissioning)

☐

Replace each executable type: expression YAML with a `rules_py` module (keep YAML as reference if useful)

☐

Map inputs Brick labels → feather column names in model/poll CSV

☐

Set `fault_code` per rule (letter suffix)

☐

Run Rule Lab kit on 7-day feather window; confirm flag rate sane

☐

Apply `sensor_catalog` defaults; tune bounds for site climate

☐

Enable building-agent check-in; verify faults in portfolio rollup

Next: `Python recipes (full Arrow library)`(`{{ "/rule-cookbook/python-recipes-arrow/" | relative_url }}`) · `[Arrow recipes]`(`{{ "/rule-cookbook/arrow-recipes/" | relative_url }}`) · `Fault_codes`(`{{ "/fault-codes/" | relative_url }}`) · `Rule Lab`(`{{ "/operator-bridge/rule-lab/" | relative_url }}`)

59 GL36 algorithm stubs

60 GL36 algorithm stubs (doc-only)

Draft **supervisory** PyArrow patterns for the future Algorithms tab. These mirror Niagara GL36 blocks documented in:

README_TRIM_RESPOND.md

FDD rules return **fault masks**. Algorithms return **setpoints or request integers** — the stubs below use `apply_algorithm_arrow` as the planned entriypoint. For early testing in Rule Lab, you can adapt the logic into advisory FDD rules (boolean “sequence unhealthy” flags).

60.1 Shared lookback helper

```
import pyarrow.compute as pc

LOOKBACK_HOURS = 6

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")
```

60.2 VAV zone cooling requests (0-3)

Simplified from GL36 VAV box request generator — zone temp vs cooling setpoint bands.

```
"""GL36 VAV cooling requests – doc stub."""

import pyarrow.compute as pc

ZONE_TEMP = "zn-t"
ZONE_SP = "zn-t-sp"
ZONE_DEMAND = "zn-cool-loop"
```

```

HIGH_DIFF_F = 5.0
MED_DIFF_F = 3.0
LOOP_ON = 95.0
LOOP_OFF = 85.0

def apply_algorithm_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    tz = pc.cast(table[ZONE_TEMP], "float64")
    sp = pc.cast(table[ZONE_SP], "float64")
    diff = pc.subtract(tz, sp)
    demand = pc.cast(table[ZONE_DEMAND], "float64")
    # Last row request level for kit demo (full port needs timer
state)

    last_diff = diff[-1].as_py() if table.num_rows else 0.0
    last_demand = demand[-1].as_py() if table.num_rows else 0.0
    if last_diff >= HIGH_DIFF_F:
        req = 3
    elif last_diff >= MED_DIFF_F:
        req = 2
    elif last_demand > LOOP_ON:
        req = 1
    else:
        req = 0
    print(f"cooling_requests={req} dT={last_diff:.1f}F
loop={last_demand:.0f}%")
    return {"cooling_requests": req}

```

60.3 AHU duct static trim & respond (advisory fault)

Detect **duct static stuck high** while VAV pressure requests are low — trim & respond may not be trimming.

```

"""AHU duct static trim advisory – doc stub."""

```

```

import pyarrow.compute as pc

```

```

DUCT_SP = "duct-static"
DUCT_SP_MAX = 1.50
DUCT_SP_TRIM_TARGET = 0.80
VAV_PRESS_REQ_SUM = "vav-press-req-sum"
LOOKBACK_HOURS = 12

```

```

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table, hours=LOOKBACK_HOURS)
    sp = pc.cast(table[DUCT_SP], "float64")
    reqs = pc.cast(table[VAV_PRESS_REQ_SUM], "float64")
    stuck_high = pc.and_(pc.greater(sp, DUCT_SP_TRIM_TARGET),

```

```
pc.less(reqs, 1.0))
    return pc.and_(stuck_high, pc.greater(sp, DUCT_SP_MAX * 0.9))
```

60.4 Chiller plant enable (valve request counting)

From GL36 §5.18.15.2 — count AHUs with CHW valve above threshold.

```
"""Chiller plant enable advisory – doc stub."""

import pyarrow.compute as pc

AHU_VALVE_COLS = ["ahu1-clg-vlv", "ahu2-clg-vlv", "ahu3-clg-vlv"]
REQ_THRESH = 95.0
DIS_THRESH = 10.0
MIN_AHUS_REQ = 2

def apply_algorithm_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    requesting = 0
    for col in AHU_VALVE_COLS:
        if col not in table.column_names:
            continue
        v = pc.cast(table[col], "float64")[-1].as_py()
        if v >= REQ_THRESH:
            requesting += 1
    enable = requesting >= MIN_AHUS_REQ
    print(f"chiller_enable={enable} requesting_ahus={requesting}/
{MIN_AHUS_REQ}")
    return {"chiller_enable": enable, "requesting_ahus":
requesting}
```

60.5 Hot water plant HWST trim & respond (advisory)

Flags **HWST trimmed too low** while heating requests remain high.

```
"""HWST trim advisory – doc stub."""

import pyarrow.compute as pc

HWST = "hw-supply-t"
HWST_SP = "hw-supply-t-sp"
HEAT_REQ_SUM = "hw-reset-req-sum"
LOW_HWST_F = 120.0
```

```
LOOKBACK_HOURS = 6
```

```
def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table, hours=LOOKBACK_HOURS)
    temp = pc.cast(table[HWST], "float64")
    reqs = pc.cast(table[HEAT_REQ_SUM], "float64")
    return pc.and_(pc.less(temp, LOW_HWST_F), pc.greater(reqs,
2.0))
```

60.6 Chilled water plant (DP + CHWST reset advisory)

Flags **CHWST at design cold** with low cooling requests — possible stuck 100% plant loop.

```
"""CHW plant reset advisory - doc stub."""

import pyarrow.compute as pc

CHWST = "chw-supply-t"
CHWST_DESIGN_COLD_F = 44.0
COOL_REQ_SUM = "chw-reset-req-sum"
LOOKBACK_HOURS = 6

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table, hours=LOOKBACK_HOURS)
    temp = pc.cast(table[CHWST], "float64")
    reqs = pc.cast(table[COOL_REQ_SUM], "float64")
    return pc.and_(pc.less(temp, CHWST_DESIGN_COLD_F + 1.0),
pc.less(reqs, 1.0))
```

60.7 Testing later

1. Bind historian columns in **Model & assignments** (fdd_input / brick types).
2. Copy a stub into Rule Lab as an FDD advisory rule, or wait for the **Algorithms** tab kit export.
3. Run python run_test.py from a downloaded kit and confirm _kit_lookback_stats prints expected start / stop / span.

Reference implementation (Niagara Java):
[README_TRIM_RESPOND.md](#).

61 Central plants (CHW / CTW / BLR)

62 Central plant Arrow recipes

Chiller plant, condenser water, cooling tower, boiler, and hot-water distribution faults use the same Arrow-native primitives as air-side rules.

62.1 Starter fault codes

Code	Primitive	Recipe
CHW-DT-001	low_delta_t_mask	Low chilled-water ΔT syndrome
CHW-DP-001	reset_stuck_mask	CHW differential pressure reset stuck high

62.2 Required point roles (CHW)

- chw_supply_temp, chw_return_temp — ΔT rules
- chw_dp, chw_dp_setpoint — reset stuck rules
- pump_command, pump_feedback — command/feedback mismatch

62.3 Synthetic test pattern

```
import pyarrow as pa
from open_fdd.arrow_runtime.primitives import low_delta_t_mask

table = pa.table({
    "chw_supply_temp": [44.0] * 10,
    "chw_return_temp": [44.5] * 10,
})
mask = low_delta_t_mask(
    table,
    {"min_delta_t": 4.0},
    supply_col="chw_supply_temp",
    return_col="chw_return_temp",
```

```
)
assert mask.to_pylist()[-1] is True
```

See [Fault codes — chiller plant]({{ "/fault-codes/" | relative_url }}) (expanded in 3.0.19).

63 Dashboard overview

64 Dashboard overview

64.1 Primary areas

Area	Purpose
Home / Building insight	Check-engine status; fault cards show equipment, rule, point, historian column, BACnet
Trends	Point history from feather store
Faults	Rule hits grouped by equipment family
Rule Lab	Edit, lint, and test Python FDD rules (PyArrow kit zip)
Algorithms	Supervisory GL36 trim & respond (coming soon)
Model & assignments	Equipment tree, FDD rule pins, commissioning JSON
BACnet	Discovery, reads, commission workflows
Settings / health	Stack status, auth mode

64.2 Live updates

Dashboard tiles use REST polling and WS /ws/dashboard for selected live views (ticket auth via POST /api/auth/ws-ticket).

64.3 Roles

Read-only operators see trends and faults; integrators access Rule Lab and model import. See [Auth and roles](#)({{ "/operator-bridge/auth-roles/" | relative_url }}).

65 Auth and roles

66 Auth and roles

66.1 Production (LAN / edge)

- Set `OFDD_AUTH_SECRET` and role passwords in `workspace/auth.env.local`.
- Bridge on non-loopback addresses **requires** auth unless explicit insecure dev flags are set (lab only).

Role	Typical access
viewer	Read trends, faults, model tree
operator	Run batch FDD, acknowledge views
integrator	Rule Lab, bindings, model import
commission	BACnet writes (plus write guard)
agent	Agent tools / app-edit gates
admin	Full configuration

Login: `POST /api/auth/login` → Bearer JWT on API calls.

66.2 Localhost dev

`OFDD_BRIDGE_HOST=127.0.0.1` with `OFDD_AUTH_DISABLED=1` is acceptable on a single machine. **Never** use auth-disabled mode on a building LAN.

Full hardening: `Security({ { "/security/" | relative_url } })`.

67 Rule Lab

68 Rule Lab

Rule Lab authors **Arrow-native** Python FDD rules against the feather historian.

68.1 Equipment-scoped test and export

Use **Equipment-scoped test & export** on Rule Lab:

1. Select site, equipment, and sensor (point).
2. **Test selected rule** or **Test all for equipment** against recent feather data.
3. **Download equipment kit** — zip with manifest.json, equipment.json, points.json, per-rule samples, expanded helper source, and commissioning export subset.

API: GET /api/rules/export-equipment-kit?equipment_id=... · expanded helpers: GET /api/playground/rules/{id}/source-expanded.

68.2 Export all rules

Integrators can download **Export all rules** — one zip with per-rule kits, manifest.json, catalog snapshots, and model TTL. API: GET /api/rules/export-all-kit. Bench rules use **module constants** at the top of rule.py — no browser config panel, no config.json in the dev kit zip.

```
"""Bench OA-T out of bounds (Arrow)."""

import pyarrow.compute as pc

VALUE_COLUMN = "oa-t"
OAT_LOW = 68.0
OAT_HIGH = 88.0
LOOKBACK_HOURS = 1

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

def _kit_value_stats(table):
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    print(
        f"column={VALUE_COLUMN} min={pc.min(vals).as_py():.2f} "
        f"max={pc.max(vals).as_py():.2f}
mean={pc.mean(vals).as_py():.2f}"
    )
```

```

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    _kit_value_stats(table)
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    return pc.or_(pc.less(vals, OAT_LOW), pc.greater(vals,
OAT_HIGH))

```

68.3 Workflow

1. **Download kit** — PyArrow zip (see below)
2. **Edit constants** locally (VALUE_COLUMN, limits, LOOKBACK_HOURS, WINDOW_SAMPLES)
3. **Run** `pip install -r requirements.txt` then `python run_test.py`
4. **Upload** rule.py on Rule Lab (integrator)

Upload validation (Phase B): AST parse, forbidden imports (**no pandas/numpy**), `apply_faults_arrow(table, cfg, context=None)` signature for fault rules. Script-mode rules must use **table** (PyArrow), not legacy **df** DataFrames — lint errors explain this for AI agents.

The bridge runs rules on **PyArrow tables** via `open_fdd.arrow_runtime`, and persists .py sources under `workspace/data/rules_py/`.

- **Quick test** — `POST /api/playground/test-rule` (default 3 h lookback)
- **Batch** — `POST /api/rules/batch / openfdd-fdd-loop timer (1 h default lookback)`
- **Update all records** — 24 h lookback, 6 h chunks (`use_chunks: true`)
- **Templates** — `GET /api/playground/arrow-templates`

Pin points to rules via **Model & assignments** (`/model`) commissioning JSON or BACnet tree right-click. Export shows Rule Lab **names** on each point (`fdd_rules_linked`); import uses rule **ids** (`fdd_rule_ids`).

Bench seed: `python3 scripts/setup_bench_afdd.py` — imports `bench_import_model.json` and bench cookbook rules with matching id/name pairs.

68.4 Dev kit zip (download)

Download kit on Rule Lab exports `openfdd-rule-kit-<rule_id>.zip` with:

File	Purpose
rule.py	Arrow rule + constants at top; optional <code>_kit_lookback_stats / _kit_value_stats</code> helpers
data.py	<code>SITE_ID, LOOKBACK_HOURS, load_table()</code> reading <code>sample.feather</code>
sample.feather	Full historian window for the kit lookback (all rows, not a CSV preview)
run_test.py	Runs <code>rule.apply_faults_arrow(table, {}, context=...)</code> and prints <code>flagged=N</code>
requirements.txt	<code>open-fdd>=3.0.1</code> and <code>pyarrow</code>
README.md	Install and run instructions
column_map.json	BRICK logical keys → feather column names
kit_meta.json	Export metadata (site, columns, row count, lookback hours)

Not included: `config.json` (retired — tune thresholds as Python constants).

Local test:

```
unzip openfdd-rule-kit-*.zip
cd openfdd-rule-kit-*
pip install -r requirements.txt
python run_test.py
```

Expected console output:

```
site=demo lookback_h=3 rows=...
lookback=3h rows=... start=... stop=... span=2.98h
column=oa-t min=... max=... mean=...
flagged=...
```

68.5 Lookback windows

Rules that need multi-hour history should call `_kit_lookback_stats(table)` (see [\[Lookback window helper\]\({{ "/rule-cookbook/lookback-window/" | relative_url }}\)](#)). Pass `hours=1, 3, 6, 12, or 24` to validate timestamp span in the console.

Rolling-window rules (`flatline`, `spread`) use `WINDOW_SAMPLES` (~12 samples ≈ 1 h at 5 min poll) — see [Windowing & debugging\({{ "/rule-cookbook/windowing-debugging/" | relative_url }}\)](#).

68.6 Algorithms (supervisory — coming soon)

GL36 trim & respond and plant reset sequences will live on the **Algorithms**(`{{ "/operator-bridge/algorithms/" | relative_url }}`) tab with the same zip kit shape but `apply_algorithm_arrow` outputs. Reference: README_TRIM_RESPOND.

68.7 Related

- Model workflow(`{{ "/operator-bridge/model-workflow/" | relative_url }}`)
- Arrow recipes(`{{ "/rule-cookbook/arrow-recipes/" | relative_url }}`)
- GL36 algorithm stubs(`{{ "/rule-cookbook/gl36-algorithm-stubs/" | relative_url }}`) (doc-only)

69 JSON API driver

70 JSON API driver

Poll **HTTP or HTTPS** REST endpoints on the OT LAN (or public APIs such as OpenWeatherMap) and store extracted JSON values in the feather historian (`source=json_api`).

Use this driver for gateways, micro-PLCs, IoT hubs, vendor APIs, and **web weather** when you want to cross-check shaky local outdoor-air sensors against a reference.

70.1 Supported features

Feature	Support
Methods	GET, POST
Transport	http:// and https://
TLS certificate verify	On by default; disable for self-signed OT gateways
Authentication	None, Bearer token , HTTP Basic , or query-string API keys via env
Env placeholders	

Feature	Support
	<code>\${ENV:VAR}</code> or <code>\${VAR}</code> in URL, headers, body, bearer token
Custom headers	Optional headers map (merged with auth headers)
Value extraction	Dot-path into JSON body (title, main.temp, weather.0.description)
Multi-extract poll	One HTTP request per URL group; fan-out to multiple json_path rows
Polling	1 / 5 / 15 / 30 min or 1 hour (shared with BACnet/Modbus)
Historian	workspace/json_api/polls/samples.csv → feather_store/json_api/
FDD merge	Scheduled FDD merges bacnet + modbus + json_api columns by nearest timestamp

70.2 Secrets: json_api.env.local

Copy workspace/json_api.env.example → workspace/json_api.env.local (gitignored). The bridge loads this file at startup and when run_local.sh starts the stack.

Use placeholders in commissioning URLs so API keys never land in git:

```
https://api.openweathermap.org/data/2.5/weather?q=${ENV:OPENWEATHER_CITY}&appid=${ENV:OPENWEATHER_API_KEY}&units=${ENV:OPENWEATHER_UNITS}
```

Check which vars are configured: GET /api/json-api/env/status.

70.3 OpenWeatherMap showcase (recommended demo)

This is the flagship example of what the generic JSON API driver can do — **one URL, three historian columns**, env-based API key, browser tree like BACnet/Modbus.

70.3.1 1. Configure env

```
cp workspace/json_api.env.example workspace/json_api.env.local
# Edit: OPENWEATHER_API_KEY, OPENWEATHER_CITY, OPENWEATHER_UNITS
(imperial = °F)
```

Restart the bridge (or `./scripts/run_local.sh restart`) so env vars load.

70.3.2 2. Register from the UI

1. Sign in as **integrator** → **JSON API** tab.
2. Open the **OpenWeatherMap showcase** panel.
3. Use the **OpenWeatherMap** preset → **Register** (default poll 30 min; choose interval in the form).

Three endpoints appear under `api.openweathermap.org` in the commissioning tree:

Label	JSON path	Historian column	Units
web-oat-t	main.temp	web-oat-t	degF / degC
web-rh	main.humidity	web-rh	%
web-weather-desc	weather.0.description	web-weather-desc	text

Poll worker deduplicates: **one GET** serves all three extractions per cycle.

70.3.3 3. Headless / script

```
# Standalone fetch (like the original playground tester)
python3 scripts/openweather_json_api_example.py

# Register via REST (integrator login)
python3 scripts/openweather_json_api_example.py --register --base
http://127.0.0.1:8000
```

70.3.4 4. FDD: local OA-T vs web weather

With BACnet oa-t and JSON API web-oat-t in the merged site frame, scheduled FDD compares local outdoor air to the weather service.

Item	Detail
Rule module	oat_vs_web_spread_1h.py
Fault code	BLD-B (outdoor air sensor fault)

Item	Detail
Default threshold	<code> oa-t - web-oat-t > 8 °F</code> (<code>max_spread_f</code> in rule cfg)
Acme rule id	<code>acme-oat-vs-web-spread</code> (via <code>setup_gl36_fdd.py</code>)
Local OAT source	RTU 1100-unknown-2 (Outdoor Air Temperature Local) — same value as boiler/AHU networked OAT
Web column	<code>web-oat-t</code> from OpenWeather bundle

Model alias: local BACnet historian column must be `oa-t`:

```
python3 scripts/acme_patch_oat_column.py --point-id 1100-unknown-2 --host "$ACME_HOST" --token "$TOKEN"
```

Or set `external_id` / `fdd_input` to `oa-t` on the chosen `Outside_Air_Temperature_Sensor` in the model.

Units: keep `OPENWEATHER_UNITS=imperial` when BACnet OAT is °F.

Enable the rule in Rule Lab (or `setup_gl36_fdd.py` push) and run an FDD batch. Missing either column → rule returns all-false (no crash).

70.4 Commissioning (UI)

The **JSON API** tab follows [Home Assistant sensor.rest](#):

1. Sign in → **RESTful sensor (JSON API)** tab.
2. Pick a **preset** (JSONPlaceholder, DummyJSON, httpbin, Open-Meteo, OpenAQ, OpenWeather) or enter a **resource URL**.
3. Add one or more **sensors** — each row is a `value_json_path` + historian **label** (multi-value from one GET, like HA `json_attributes`).
4. Click **Test resource** — probes without saving; shows extracted values and raw JSON.
5. Click **Register & poll** — writes `endpoints.csv`, enables polling at the selected interval.
6. Poll choices match BACnet/Modbus: **1 / 5 / 15 / 30 min** or **1 hour**.

70.4.1 API for agents

Endpoint	Purpose
GET <code>/api/json-api/presets</code>	Full preset catalog + poll intervals (human + AI readable)

Endpoint	Purpose
POST /api/json-api/test	Probe resource + multi-sensor extraction
POST /api/json-api/register-bundle	Register one resource with many sensors
POST /api/json-api/presets/{id}/register	One-click preset registration

70.4.2 Bench preset

Use **JSONPlaceholder** — **todo title** → **Test resource** to verify outbound HTTPS without field hardware.

70.5 Authentication examples

70.5.1 Query-string API key via env (OpenWeather)

```
{
  "url": "https://api.openweathermap.org/data/2.5/weather?q=${ENV:OPENWEATHER_CITY}&appid=${ENV:OPENWEATHER_API_KEY}&units=${ENV:OPENWEATHER_UNITS}",
  "method": "GET",
  "json_path": "main.temp",
  "label": "web-oat-t",
  "auth_type": "none"
}
```

70.5.2 Bearer token (API key)

```
{
  "url": "https://192.168.10.50/api/v1/status",
  "method": "GET",
  "json_path": "sensors.zone_temp",
  "label": "zone-temp",
  "auth_type": "bearer",
  "bearer_token": "${ENV:GATEWAY_API_KEY}",
  "verify_tls": false
}
```

70.5.3 HTTP Basic

```
{
  "url": "http://192.168.10.50/data.json",
  "method": "GET",
  "json_path": "value",
  "label": "sensor-value",
}
```

```

    "auth_type": "basic",
    "basic_user": "operator",
    "basic_password": "changeme"
  }

```

70.5.4 POST with JSON body

```

{
  "url": "https://gateway.local/api/read",
  "method": "POST",
  "json_path": "result.pv",
  "label": "pv",
  "body": { "point": "AHU-1_SAT", "command": "read" },
  "auth_type": "bearer",
  "bearer_token": "..."
}

```

Credentials in endpoints.csv are redacted in API responses (***).
Prefer \${ENV:...} for production keys.

70.6 REST API

Method	Path	Role	Description
GET	/api/json-api/env/status	operator+	Which env vars are configured (no secret values)
POST	/api/json-api/presets/openweather	integrator+	Register 3-point OpenWeather bundle + optional poll
GET	/api/json-api/driver/tree	operator+	Commissioning tree grouped by host
GET	/api/json-api/poll/status	operator+	Poll worker status
POST	/api/json-api/poll/once	integrator+	Run one poll cycle
POST	/api/json-api/request	operator+	One-shot HTTP request (no store)
POST	/api/json-api/read_and_store	integrator+	Request + CSV + feather ingest
POST	/api/json-api/refresh	operator+	Re-fetch one endpoint
PATCH	/api/json-api/endpoint/poll	integrator+	Enable/disable poll interval
DELETE		integrator+	Remove endpoint

Method	Path	Role	Description
	/api/json-api/ endpoint/ {point_id}		

Full route list: `API routes({ { "/appendix/bridge_api/" | relative_url } })`.

70.7 Typical OT URLs

Device type	Example URL	Notes
Web weather	<code>https://api.openweathermap.org/data/2.5/weather?...</code>	Env-based appid; 3 historian columns
Gateway status	<code>http://192.168.1.50/api/status</code>	Often plain HTTP on LAN
HTTPS BMS API	<code>https://10.0.0.12/rest/points/zone1</code>	May need <code>verify_tls: false</code>
Local mock	<code>https://jsonplaceholder.typicode.com/todos/1</code>	Bench / CI only

70.8 Limitations

- Response body must be **JSON** (not XML or plain text).
- Numeric paths (e.g. `main.temp`) are stored as strings in poll CSV; FDD rules cast with `pc.cast(..., "float64")`.
- Outbound requests originate from the **bridge** container/host — ensure routing and firewall rules allow the edge box to reach the target (OT subnet or public internet for weather).

70.9 Disable polling (save API quota)

Stop scheduled calls without deleting endpoints: JSON API tree → select OpenWeather points → **Stop polling**, or integrator API:

```
curl -X PATCH http://127.0.0.1:8765/api/json-api/endpoint/poll \
  -H "Authorization: Bearer $TOKEN" \
  -d '{"point_id":"ja-api-openweathermap-org-get-web-oat-t","enabled":false,"poll_interval_s":0}'
```

API keys live in `json_api.env.local` (gitignored) — never committed; audit logs do not record expanded URLs with `appid=`. See [Logging and audit](#)(`{{ "/ops/logging/" | relative_url }}`).

70.10 Smoke test

```
python3 scripts/smoke_multi_driver_stack.py
```

Validates JSON API ingest alongside BACnet and Modbus, feather isolation, BRICK scope, and FDD batch.

71 Algorithms

72 Algorithms (coming soon)

The **Algorithms** dashboard tab (`/algorithms`) is a placeholder for **supervisory Python sequences** — the mirror image of Rule Lab FDD:

	FDD (Rule Lab)	Algorithms (planned)
Purpose	Detect faults	Compute setpoints, request levels, plant enables
Entrypoint	<code>apply_faults_arrow(table, cfg, context)</code>	<code>apply_algorithm_arrow(table, cfg, context)</code> (planned)
Output	Boolean fault mask	Numeric outputs / structured dict
Historian	Same feather_store PyArrow tables	Same

Until the tab ships, draft patterns live in this doc and in [GL36 algorithm stubs](#)(`{{ "/rule-cookbook/gl36-algorithm-stubs/" | relative_url }}`).

72.1 GL36 Trim & Respond reference

Open-FDD algorithms will follow the same ASHRAE Guideline 36 trim & respond methodology already implemented for Niagara in:

README_TRIM_RESPOND.md

That guide covers:

- VAV zone request generators (cooling + static pressure)

- AHU duct static pressure reset
- AHU supply air temperature reset
- Central plant chiller / boiler enable and HWST / CHWST trim & respond

Porting those blocks to PyArrow is in progress; the dashboard tab shows **COMING SOON** until upload, batch, and BACnet write paths are wired.

72.2 Planned workflow (same kit shape as Rule Lab)

1. Download **algorithm kit** zip from the Algorithms tab (future)
2. Edit **constants** at the top of algorithm.py (no config.json)
3. Run `python run_test.py` locally against `sample.feather`
4. Upload algorithm.py when satisfied

Kit files will match the Rule Lab zip layout (see [Rule Lab — dev kit zip]({{ "/operator-bridge/rule-lab/" | relative_url }}#dev-kit-zip-download)).

72.3 Lookback windows

Rules and algorithms that need multi-hour history should use the shared **lookback stats helper** documented in [Lookback window helper]({{ "/rule-cookbook/lookback-window/" | relative_url }}). Pass `hours=1, 3, 6, 12, or 24` to print row count, timestamp start/stop, and span for console validation.

Scheduled batch defaults: **1 h** lookback on the FDD loop; **Update all records** in Rule Lab uses **24 h** with 6 h chunks.

72.4 AHU supervisory checks (doc-only stubs)

These are **not** uploaded rules yet — copy-paste references for future algorithm or FDD work.

72.4.1 Duct static pressure too high

Flags sustained high duct static (possible stuck setpoint, blocked filter, or trim/respond not trimming).

```
"""AHU duct static high – doc stub (Arrow constants)."""
```

```
import pyarrow.compute as pc
```

```

VALUE_COLUMN = "duct-static"
HIGH_INWC = 1.20
LOOKBACK_HOURS = 3
MIN_SAMPLES_ABOVE = 6

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    vals = pc.cast(table[VALUE_COLUMN], "float64")
    high = pc.greater(vals, HIGH_INWC)
    # Require several consecutive highs (~30 min at 5 min poll)
    from open_fdd.arrow_runtime.windows import
arrow_consecutive_true

    streak = arrow_consecutive_true(high, MIN_SAMPLES_ABOVE)
    return streak

```

72.4.2 Supply air temperature too cold (cooling coil over-delivering)

```

"""AHU SAT too cold vs setpoint – doc stub."""

import pyarrow.compute as pc

SAT_COLUMN = "sa-t"
SP_COLUMN = "sa-t-sp"
COLD_DELTA_F = 5.0
LOOKBACK_HOURS = 1

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin = pc.min(ts).as_py()
    tmax = pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

```

```
def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    sat = pc.cast(table[SAT_COLUMN], "float64")
    sp = pc.cast(table[SP_COLUMN], "float64")
    return pc.less(pc.subtract(sat, sp), -COLD_DELTA_F)
```

72.5 Plant supervisory checks (doc-only)

See [GL36 algorithm stubs](#)({{ "/rule-cookbook/gl36-algorithm-stubs/" | relative_url }}) for chiller plant enable, HWST trim & respond, and CHW DP/CHWST reset patterns aligned with the Niagara README.

72.6 Related

- [Rule Lab](#)({{ "/operator-bridge/rule-lab/" | relative_url }}) — live FDD authoring
- [Model workflow](#)({{ "/operator-bridge/model-workflow/" | relative_url }}) — point bindings
- [Windowing & debugging](#)({{ "/rule-cookbook/windowing-debugging/" | relative_url }}) — rolling windows

73 Model workflow

74 Model workflow

74.1 Brick model

- **Equipment tree** — SPARQL over synced TTL (workspace/data/data_model.ttl)
- **Point registry** — BACnet inventory → series_id for historian bindings
- **Health score** — orphan points, missing fdd_input, stale telemetry

74.2 Typical integrator flow

1. Import or sync BACnet point registry.

- 2. Map equipment classes (AHU, VAV, ...) in the model UI — set brick_type on points and feeds on equipment (AHU→VAV).
- 3. Tag points with fdd_input roles (zone temp, SAT, damper cmd, ...).
- 4. Bind Rule Lab rules to points, equipment, or BRICK classes (bindings in rules_store.json).
- 5. Run POST /api/model/sync-ttl after bulk imports.
- 6. Validate on **Trend plot** with FDD overlays (?fdd=1) — faults render on a right-hand 0/1 axis per device scope.

AI Agent and commissioning JSON import can bulk-apply steps 2-4; integrator should review model health before production FDD. See [FDD and assignments\({{ "/operator-bridge/fdd-assignments/" | relative_url }}\)](#) and [Ollama and analytics\({{ "/operator-bridge/ollama-analytics/" | relative_url }}\)](#).

Export: GET /api/model/export (TTL/JSON). Commissioning bundle: GET /api/model/commissioning-export — includes per-point fdd_rules_linked (Rule Lab names) plus fdd_rules[] catalog. Use **Import / export** tab preview table or **Point → FDD rule pins** before editing raw JSON. API detail in [Appendix\({{ "/appendix/bridge_api/" | relative_url }}\)](#).

75 Driver framework

76 Driver framework

Open-FDD edge commissioning uses a **shared driver pattern** for OT data sources. Each driver polls field devices on a schedule, stores long-format samples in workspace CSVs, and ingests into the **feather historian** under a distinct source tag for FDD and plots.

76.1 Drivers

Driver	Protocol	Feather source	Commissioning tab
BACnet({{ "/bacnet/" relative_url }})	relative_url }}	MS/TP / IP (: 47808)	bacnet
Modbus	Modbus TCP	modbus	Modbus
[JSON API]({{ "/drivers/json-api/" relative_url }})	relative_url }}	HTTP/HTTPS REST (+ [OpenWeather showcase]	relative_url }} #openweathermap-showcase-

Driver	Protocol	Feather source	Commissioning tab
		({{ { "/drivers/json-api/"	recommended-demo))

All three drivers share the same operator workflow:

1. **Discover or configure** — add devices/endpoints to the driver registry.
2. **Request once** — on-demand read to verify connectivity and JSON path / register map.
3. **Request & store** — append to poll CSV and write a feather shard.
4. **Enable polling** — 1 / 5 / 10 / 15 minute intervals via tree right-click or bulk toolbar.
5. **Poll all now** — force one worker cycle without waiting for the interval.

76.2 Data layout

```
workspace/
  bacnet/commissioning/  points.csv, discovered inventory
  bacnet/polls/          samples.csv
  modbus/commissioning/  registers.csv
  modbus/polls/          samples.csv
  json_api/commissioning/ endpoints.csv
  json_api/polls/        samples.csv
  data/feather_store/
    bacnet/{site_id}/    shard-*.feather
    modbus/{site_id}/
    json_api/{site_id}/
```

76.3 Historian and FDD

- **Plot tab** — numeric columns from bacnet and modbus sources (GET /api/timeseries/plot?source=...).
- **String JSON fields** — stored in feather under json_api; use the JSON API tree or feather directly (plot is numeric-only).
- **FDD batch** — merges bacnet + modbus + json_api historian columns by nearest timestamp; rules use BRICK-bound external_id names (e.g. compare BACnet oa-t vs JSON API web-oat-t — see [JSON API]({{ { "/drivers/json-api/" | relative_url }}}).
- **BRICK model** — bind points in **Model & assignments** commissioning JSON; sync TTL for SPARQL scope.

76.4 Rule Lab (Arrow upload/download)

1. **Download kit** — zip with rule.py (constants at top), data.py, sample.feather (~3h), run_test.py, requirements.txt.
2. Local test: pip install -r requirements.txt then edit constants in rule.py and python run_test.py.
3. **Upload rule.py** — Arrow-only; must define apply_faults_arrow(table, cfg, context=None).
4. Browser shows **read-only** source; use Quick test + Update all records.

API: GET /api/rules/export-kit, POST /api/rules/upload.

76.5 Smoke validation

From repo root on a running stack (http://127.0.0.1:8765):

```
python3 scripts/smoke_multi_driver_stack.py
python3 scripts/validate_modbus_temp_e2e.py --no-server
```

76.6 Related docs

- [Data flow](#)({{ "/architecture/data-flow/" | relative_url }}) — poll → CSV → feather → FDD
- [API routes](#)({{ "/appendix/bridge_api/" | relative_url }}) — REST reference
- [\[BACnet polling\]](#)({{ "/bacnet/polling/" | relative_url }}) — commission container loop

77 Operator Bridge

78 Operator Bridge

The Operator Bridge is the FastAPI service and React dashboard operators use daily.

Page	Topic
Dashboard overview ({{ "/operator-bridge/dashboard/" relative_url }})	relative_url }}
Auth and roles ({{ "/operator-bridge/auth-roles/" relative_url }}	relative_url }}
	relative_url }}

Page	Topic
Rule Lab ({{ "/operator-bridge/rule-lab/"	
Algorithms ({{ "/operator-bridge/algorithms/"	relative_url }}
Model workflow ({{ "/operator-bridge/model-workflow/"	relative_url }}
FDD and assignments ({{ "/operator-bridge/fdd-assignments/"	relative_url }}
Ollama and analytics ({{ "/operator-bridge/ollama-analytics/"	relative_url }}

REST details: [Appendix — API routes]({{ "/appendix/bridge_api/" | relative_url }}). Env files: [Workspace env files](#)({{ "/appendix/workspace-env-files/" | relative_url }}).

79 Ollama and analytics

80 Ollama and analytics

80.1 What runs without login

The **Building status** home page (/) and GET /openfdd-agent/building-insight are **public** (same policy as fault status). Anyone on the LAN can read the briefing sentence and underlying numeric levers; only the **AI Agent** chat and stack revision endpoints require sign-in.

80.2 Ollama setup

1. Copy workspace/ollama.env.example → workspace/ollama.env.local.
2. Pick a model for available RAM (comments in the example file):

RAM tier	Suggested model
4 GB Pi	qwen3:0.6b
8 GB	qwen3:1.7b

RAM tier	Suggested model
16 GB	qwen3:4b
32 GB	qwen3:8b
64 GB	qwen3:14b

1. Set OFDD_OLLAMA_BASE_URL (default `http://127.0.0.1:11434`).
2. Optional: OFDD_OLLAMA_GPU_MODE (`cpu` / `auto` / `gpu`), OFDD_OLLAMA_TIMEOUT_S for slow CPUs.
3. Bootstrap helper: `./scripts/bootstrap_ollama.sh`.

Bridge reads env via `run_local.sh` / `compose`. Model resolution: `workspace/api/openfdd_bridge/ollama_profiles.py`.

80.3 Automatic analytics (deterministic, always on)

These pandas calculations run on a refresh interval and feed the home dashboard **whether or not Ollama is up**:

Lever	Module	Refresh env	What it computes
Zone temperature snapshot	<code>zone_temp_analytics.py</code>	OFDD_ZONE_TEMP_INTERVAL_S (default 3600s)	Site-wide and per AHU zone temperature averages, spread out-of-band counts using BRICK feeds (AHU→VAV) which are modeled; falls back to all Zone_Air_Temperature points
Device poll health	<code>device_poll_health.py</code>	stack health cycle	BACnet device health seen / stale poll detection
Operational brief	<code>building_insight.py</code> → <code>get_operational_brief</code>	same as insight	Compact numerical status for integrators
Root-cause hints	<code>root_cause_hints.py</code>	on insight refresh	Multi-zone fault chains using brick:feeds from

Shared lookback window: OFDD_ANALYTICS_LOOKBACK_DAYS (default 14) in `operational_analytics.py`.

API routes (auth optional unless noted):

- GET `/openfdd-agent/building-insight` — sentence + zone snapshot + fault sentences

- GET /openfdd-agent/zone-temp-analytics
- GET /openfdd-agent/device-poll-health
- GET /openfdd-agent/ollama/health — integrator diagnostics

80.4 When Ollama is used

`building_insight.get_building_insight():`

1. Refreshes zone + device snapshots (pandas).
2. Calls `ollama_client.health()`.
3. If Ollama is reachable and `should_use_ollama_for_insight()` passes, sends a **compact context** (status, zone levers, feeds chains) to the configured model for a one-sentence briefing (source: "ollama").
4. On failure, uses `_fallback_sentence()` (source: "deterministic").

Context assembly: `building_insight._compact_context()`. Prompt template references BRICK feeds and `root_cause_hints`.

80.5 AI Agent (authenticated)

/agent page uses POST /openfdd-agent/chat with tool access (`agent_tools.py`): BRICK graph, scope bundles, rule binding patches, model health, etc. This is separate from the public home briefing.

80.6 Code map

```
workspace/api/openfdd_bridge/
  building_insight.py      # cached home briefing + Ollama
sentence
  zone_temp_analytics.py  # zone temp levers (BRICK feeds)
  device_poll_health.py   # BACnet poll staleness
  operational_analytics.py # lookback window + methodology dict
  root_cause_hints.py     # multi-fault BRICK chain hints
  ollama_client.py        # HTTP client to Ollama
  ollama_profiles.py      # RAM tiers / model names
```

Dashboard consumers: `BuildingStatusPage.tsx`,
`StackStatusStrip.tsx` (WebSocket /ws/dashboard).

81 FDD and assignments

82 FDD and assignments

82.1 What the product actually does

Open-FDD separates **data modeling** (BRICK equipment, points, feeds relationships) from **rule assignment** (which FDD rules apply to which points, equipment, or BRICK classes). Both are editable in **Model & assignments** and via commissioning JSON import.

82.1.1 BRICK modeling (integrator + AI-assisted)

Concern	Where it lives	Notes
Equipment tree	ModelService + TTL sync	AHU, VAV, sensors; equipment_type and brick_type on points
brick:feeds	model_feeds.py, ttl_service.py	AHU→VAV→zone relationships; used by zone analytics and root-cause hints
Point registry	BACnet inventory → model points	fdd_input roles (oa-t, stat_zn-t, ...), series_id / historian column
Commissioning import	POST /api/model/commissioning-import	Bulk JSON: sites, equipment, points, optional fdd_rules

AI Agent (agent_tools.py) can read slim_brick_graph, scope_bundle, patch rule bindings, and upsert points — but it does **not** auto-generate a full site model without operator review. Expected workflow:

1. BACnet discover/poll populates point registry.
2. Integrator or agent tags brick_type, fdd_input, and feeds on equipment.
3. POST /api/model/sync-ttl writes workspace/data/data_model.ttl.

4. Model health (model_health.py) flags orphan points and missing fdd_input.

82.1.2 Rule assignment (three binding kinds)

Saved rules in rules_store.json carry bindings:

```
{
  "point_ids": ["5007-analog-input-1173"],
  "equipment_ids": ["bench-1"],
  "brick_types": ["Outside_Air_Temperature_Sensor"]
}
```

Binding kind	Effect
point_ids	Rule runs for that historian point / series
equipment_ids	Rule runs for all points on equipment (mass bind)
brick_types	Rule runs for any point with that BRICK class on site

Assign via:

- **Model & assignments** UI — equipment/point chips, rule pin menu on trend plot
- **Rule Lab** — bindings panel
- **Commissioning import** — fdd_rules[].bindings and per-point fdd_rule_ids
- **AI Agent** — patch_rule_binding tool

Runtime evaluation: fdd_runner.py (batch FDD) and plot_readings.evaluate_fault_plots() (trend overlays). Plot scope filters rules to those bound to **selected telemetry** (point, equipment, or BRICK class); unbound rules still evaluate site-wide.

Brick bindings (3.0.20+): when a rule binds brick_types (or equipment_ids / point_ids), the batch runner resolves **every** matching historian column via historian_columns_for_rule, runs the Arrow rule per column with value_column set, and OR-combines fault masks. One rule config therefore applies consistently to all zone temps, discharge temps, etc.

82.1.3 CLASS vs device

- **BRICK class** (brick_type on points, or brick_types on rule bindings) — template-style assignment (“all Zone_Air_Temperature_Sensor”).
- **Device / equipment** (equipment_id, BACnet device instance) — instance assignment (“this VAV-12”).
- **Point** (point_ids) — single-sensor assignment.

applies_to on legacy rules is deprecated; use bindings in 3.0+.

82.2 Commissioning JSON shape

Export: GET /api/model/commissioning-export. Import accepts import_ready_json wrappers (see commissioningImport.ts).

82.2.1 Rule names vs ids (Rule Lab alignment)

Rule Lab shows **human names** (Bench OA-T flatline 1h). Saved rules use stable **ids** (bench-oa-t-flatline-1h from setup scripts, or a UUID for uploaded custom rules). Commissioning export includes both so you never have to cross-reference sections by hand:

Field	Direction	Purpose
points[].fdd_rule_ids	import + export	Assignment surface — array of rule ids
points[].fdd_rules_linked	export only	[{id, name}] — Rule Lab names beside each point
fdd_rules[].id	import + export	Stable rule key (matches Rule Lab / rules_store.json)
fdd_rules[].name	import + export	Same label as Rule Lab dropdown
fdd_rules[].source_file	export	Baseline of deployed .py when present (e.g. bench-oa-t-flatline-1h.py)

On import, fdd_rules_linked is stripped (like fdd_rule_ids — not stored in model.json). Use the **Point → FDD rule pins** table on Model & assignments to read names without parsing JSON.

Minimum fields integrators/AI should produce:

- sites, equipment[] with id, equipment_type, optional feeds[]
- points[] with site_id, equipment_id, brick_type, fdd_input, BACnet IDs, optional fdd_rule_ids
- fdd_rules[] with id, name, bindings, enabled (optional source_file on export)

After import, verify in **Trend plot** with ?fdd=1 — fault lanes appear on the right-hand 0/1 axis for bound rules.

82.3 Related

- [Model workflow](#)({{ "/operator-bridge/model-workflow/" | relative_url }})
- [Rule Lab](#)({{ "/operator-bridge/rule-lab/" | relative_url }})
- [\[Trend plot / fault overlays\]](#)({{ "/operator-bridge/dashboard/" | relative_url }}#trend-plot)

83 Network setup

84 Network setup

84.1 Bind address

Commission and poll containers need the **OT interface** IP and UDP **47808**:

```
# workspace/bacnet/commissioning/commission.env
BACNET_BIND=192.168.1.50/24:47808
BACNET_INSTANCE=599999
```

- Use the NIC that can reach controllers (not only the management VLAN unless routed).
- Poll driver uses network_mode: host on Linux edges.

84.2 Discovery range

```
DISCOVER_LOW=1
DISCOVER_HIGH=4194302
DISCOVER_TIMEOUT=30
```

Narrow the range in large sites to avoid broadcast storms.

84.3 Verify

From commission container logs or API: Who-Is → I-Am responses. If zero devices, check firewall, bind IP, and VLAN routing before tuning rules.

85 Discover and read

86 Discover and read

The **commission** container exposes HTTP APIs for discovery and read-property workflows used by the dashboard BACnet tools.

Capability	Notes
Who-Is / I-Am	Device discovery on OT subnet
Read property	Present value, object name, units
RPM	Bulk reads for inventory export
Write property	Gated — see Write safety (<code>{{ "/bacnet/write-safety/"</code>

Exported inventory feeds `points_discovered.csv` and the Brick point registry.

86.1 Operator workflow

1. Confirm [network_setup](#)(`{{ "/bacnet/network-setup/" | relative_url }}`}).
2. Run discover from dashboard or API.
3. Review discovered objects; enable points for poll profiles.
4. Sync model bindings for FDD inputs.

87 Polling

88 Polling

BACnet field reads run in the openfdd-commission container.
The Operator Bridge does not bind UDP 47808.

Retired: openfdd-bacnet-poll image and openfdd-bacnet-poll systemd unit. Poll loop lives in **commission** only — do not run both.

BACnet polling has two stages:

1. **Field reads** — commission poll loop → workspace/bacnet/polls/samples.csv
2. **Historian ingest** — bridge background worker → workspace/data/feather_store/

88.1 Commission poll loop (default)

The **commission** container runs the poll loop at startup. It reads enabled rows from points.csv and appends BACnet RPM results to samples.csv.

Setting	Location
BACnet bind	workspace/bacnet/commissioning/commission.env
Enabled points	workspace/bacnet/commissioning/points.csv
Poll output	workspace/bacnet/polls/samples.csv
Historian	workspace/data/feather_store/

Check activity:

```
tail -1 workspace/bacnet/polls/samples.csv  
docker compose logs --since 5m commission | grep -i poll
```

88.2 Bridge ingest worker

Inside **bridge**, a background thread watches samples.csv and ingests new rows into feather. Disable only for debugging:
OFDD_DISABLE_POLL_WORKER=1.

88.3 Health

Dashboard stack health (GET /health/stack) reports bacnet_poll status from the commission agent — not a separate container.

Stale points trigger data-quality fault patterns — see [Sensor quality faults]({{ "/fault-codes/sensor-quality/" | relative_url }}).

88.4 Poll strategy (edge)

Open-FDD intentionally keeps BACnet field traffic **minimal**:

- **One enabled row per object** in points.csv — poll only what the model/FDD needs.
- **Uniform cycle** — every enabled point is RPM-pollled each cycle; the loop sleeps $\max(15, \min(\text{poll_interval_s}))$ (typically **60 s** on Acme).
- Per-point poll_interval_s in the UI is the **commissioned target**; throughput analytics compare configured vs observed samples.
- **Unit conversion** (e.g. Trane °C → °F) uses device_poll_profiles.csv at ingest — not a poll-rate file.

Acme ships **FDD-minimal polling** (~76 points on a typical GL36 lab when 8 rules are enabled), not the full discovery tree (~340+ GL36 objects or 566 discovered objects). Disable unneeded objects in BACnet commissioning rather than raising global poll rates.

AI agents / MCP: Never enable BACnet polling for every discovered object. Poll **only** historian columns bound to **enabled** FDD rules (rules_store.json brick_types, point_ids, and rule config column hints). Use bacnet_toolshed.fdd_minimal_poll or acme_commission_fdd_minimal.sh — not bulk --all enable scripts.

88.5 Async driver and single-stack I/O

Layer	Behavior
Dedicated bacnet-io thread	One asyncio loop + serial lock for all field I/O
RPM batching	Present-value reads chunked (25 objects) to cut APDUs
Poll loop	Sequential per-device RPM when interruptible=True so operator UI can preempt

Layer	Behavior
Operator UI	INTERACTIVE priority — cancels in-flight background work
Override scans	BACKGROUND , 15 min timeout — see Operator override scans ({{ “/bacnet/override-scans/”
Bridge ingest	Async notify after each poll cycle → feather historian

Do **not** run a second BACnet bind on 47808 (no parallel openfdd-bacnet-poll container). See [Containers](#)({{ “/architecture/containers/” | relative_url }}).

88.6 Operator override scans

Hourly P8 supervisory scans rotate one device at a time. Documented in [Operator override scans](#)({{ “/bacnet/override-scans/” | relative_url }}).

89 Operator override scans

90 Operator override scans (P8)

The commission agent rotates **one BACnet device per hour** (default) through a supervisory priority-array scan. Results are persisted for operator review and portfolio rollup — not for automatic writes.

90.1 Schedule

Setting	Default	Meaning
OFDD_OVERRIDE_SCAN_INTERVAL_S	3600	Seconds between single-device scans
OFDD_OPERATOR_OVERRIDE_PRIORITY	8	BACnet priority counted as

Setting	Default	Meaning
		“operator override”
Device list	points_discovered.csv	Unique device_instance rows
Rotation	registry.json cursor	Full plant rotation $\approx$ device_count $\times$ interval

Example: **33 devices $\times$ 1 h $\approx$ 33 h** for a full pass. Dashboard shows **next device** and **last scan** time.

90.2 What each scan does

1. point_discovery on the target device (commandable objects).
2. read_property on each object’s **priority-array** (not RPM — RPM loses priority slots).
3. Merge into workspace/bacnet/overrides/registry.json and append overrides_export.csv.
4. Advance cursor to the next device.

Fault code **operator_override** (P8) surfaces active overrides on the BACnet tree and building status.

90.3 BACnet I/O priority

Override scans run at **BACKGROUND** priority on the single shared BACnet stack (UDP 47808). Operator reads/writes use **INTERACTIVE** and preempt background work. Scheduled RPM polling also uses BACKGROUND and shares the same asyncio lock — polls and override scans take turns; neither starves the other indefinitely.

Override scans allow up to **15 minutes** per device (`_run_bacnet_override_scan` timeout). Bridge `POST /api/bacnet/overrides/scan-once` proxies with a matching 900 s timeout.

90.4 Manual trigger

```
curl -X POST -H "Authorization: Bearer $TOKEN" \
  http://EDGE:8765/api/bacnet/overrides/scan-once
```

Dashboard: BACnet page → **Scan next device now**.

90.5 Health checks

```
curl -H "Authorization: Bearer $TOKEN" http://EDGE:8765/api/bacnet/overrides/status
```

Expect `device_count > 0`, `last_scan_at` within the last few hours on a healthy edge, and `export_row_count` growing over time.

90.6 Data paths

Path	Content
workspace/bacnet/overrides/registry.json	Per-device last scan + override points
workspace/bacnet/overrides/overrides_export.csv	Flat export for spreadsheets

Preserved across Docker upgrades when `workspace/` is on the edge volume — see [Backup & restore]({{ "/ops/backup-restore/" | relative_url }}).

91 Write safety

92 Write safety

BACnet writes can change live plant behavior. Open-FDD disables writes by default. Enable only with operator sign-off, a tested allowlist, and audit logging.

92.1 Defaults

Control	Default
Supervisory writes	Off
Write allowlist	Empty — must enumerate device/object
Audit	Commands logged when writes enabled

92.2 Enable writes (commission role)

1. Set env flag documented in [Security](#)({{ "/security/" | relative_url }}) (OFDD_BACNET_WRITE_ENABLED or site equivalent).
2. Populate write allowlist CSV / config with explicit object IDs.
3. Use **commission** role JWT; every write should include reason/ note where API supports it.
4. Test on bench hardware before production OT.

92.3 Operator rules

- Never write setpoints or overrides on life-safety or fire/smoke interlocks through experimental rules.
- Prefer read-only polling for FDD until rules are validated in Rule Lab.
- Revert overrides through BACnet priority relinquish where supported.

93 BACnet

94 BACnet

Open-FDD integrates with field controllers via BACnet/IP (and bench MSTP overlays in dev compose).

Page	Topic
Network setup ({{ "/bacnet/network-setup/" relative_url }})	relative_url }}
Discover and read ({{ "/bacnet/discover-read/" relative_url }})	relative_url }}
Polling ({{ "/bacnet/polling/" relative_url }})	relative_url }}
Operator override scans ({{ "/bacnet/override-scans/" relative_url }})	relative_url }}
Write safety ({{ "/bacnet/write-safety/" relative_url }})	relative_url }}

95 Convention

96 Fault code convention

96.1 Format (Grade-A, 3.0.18+)

Short stable code: FAMILY-SUBSYSTEM-NNN — e.g. AHU-ECON-001, CHW-DT-001, DATA-STAL-001.

Semantic ID: dotted canonical_id —
e.g. ahu.economizer.not_using_free_cooling.

Legacy letter codes (AHU-E, VAV-C) remain **aliases** in open_fdd/faults/catalog/*.yaml until bridge sync completes.

Field	Example
code	AHU-ECON-001
canonical_id	ahu.economizer.not_using_free_cooling
family	AHU, VAV, CHW, DATA, CRS, ...
rule_doc_path	Link to rule cookbook recipe

Full schema: open_fdd/faults/schema.py. Catalog loader: open_fdd/faults/catalog.py.

96.2 Categories (Grade-A)

Category	Meaning
energy	Waste, reset stuck, plant inefficiency
comfort	Setpoint not met, poor zone performance
reliability	Short cycling, staging, equipment stress
maintenance	Leaking valves, filters, fouling proxies
indoor_air_quality	Ventilation shortfall, humidity
healthcare_risk	Pressure, isolation, critical-space excursions
data_quality	Stale, flatline, OOB, missing historian
controls_integrity	Overrides, chatter, schedule violations

96.3 Severity

Level	Operator response
info	Log; trend for maintenance window
low	Review in routine rounds
medium	Investigate within days
high	Prompt attention; comfort/energy impact likely
critical	Immediate operational risk (especially healthcare_risk)

96.4 Linking rules

In Rule Lab, set `fault_code` on the rule metadata. Batch FDD aggregates hits into `GET /api/faults/status` by family.

96.5 Cookbook mapping

Each catalog entry lists `cookbook_patterns` (e.g. `flatline_1h`, `mixing_envelope`, `rate_of_change`) — see [Expression cookbook \(Arrow-native\)](#)(`{{ "/rule-cookbook/expression-cookbook/" | relative_url }}`).

Legacy pandas type: `expression` YAML in `open_fdd/default_rules/` is **not executed** on the edge in 3.x — metadata for migration only. Translate to `rules_py` Arrow modules and bind **`fault_code`** in Rule Lab. See [\[Rule authoring — YAML\]](#)(`{{ "/rule-authoring/" | relative_url }}`)`#yaml-in-the-repo-today`).

97 Live site update

98 Live site update

Upgrade GHCR images on a **live edge host** that already has `~/open-fdd/` — no git pull on the host.

IT operators: prefer [\[Quick Start — Updating the stack\]](#)(`{{ "/quick-start/updating/" | relative_url }}`) and `openfdd_site_backup.sh` / `openfdd_site_update.sh` on the edge host. This page adds control-machine UI deploy and Ansible paths.

98.1 Layout on the edge host

```
~/open-fdd/  
  docker-compose.yml  
  workspace/          # site state – backup first
```

workspace/ holds BACnet commissioning, poll CSV, feather historian, BRICK model, FDD rules, and auth.env.local. Image upgrades must **preserve** it.

See [Backup and restore](#)({{ "/ops/backup-restore/" | relative_url }}) before any upgrade.

98.2 Concepts

Term	Meaning
Container	Running instance (bridge, commission, mcp-rag) — recreated on upgrade
Image	GHCR package (tag latest or dated tag)
workspace/	Open-FDD site state on disk — do not delete

98.3 1. Verify new images on GHCR

Three images must exist for every tag:

```
export NEW_TAG="${NEW_TAG:-latest}"  
  
docker manifest inspect ghcr.io/bbartling/openfdd-bridge:${  
{NEW_TAG}} >/dev/null &&  
docker manifest inspect ghcr.io/bbartling/openfdd-commission:${  
{NEW_TAG}} >/dev/null &&  
docker manifest inspect ghcr.io/bbartling/openfdd-mcp-rag:${  
{NEW_TAG}} >/dev/null &&  
echo "All three images exist for ${NEW_TAG}"
```

98.4 2. Update dashboard UI (when release changed React)

Image pull alone does not update the browser UI. The Operator Bridge serves workspace/api/static/app/ from the bind mount **before** image-baked assets.

From control machine (full repo):

```
cd /path/to/open-fdd
./scripts/build_operator_dashboard.sh prod
cd infra/ansible
RUN_POST_CHECK=0 ./deploy.sh ui --limit <inventory_host>
```

Confirm hash on edge:

```
curl -sf http://<edge-ip>/ | grep -o 'index-[^"]*\.' | head -1
```

One command (UI + images + insurance check):

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_full.sh --limit
<inventory_host>
```

98.5 3. Pull and recreate (edge host)

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
./scripts/openfdd_site_update.sh
```

Manual equivalent:

```
cd ~/open-fdd
docker compose pull
docker compose up -d --force-recreate
docker compose ps
curl -sf http://127.0.0.1:8765/health
```

98.6 4. Ansible image-only (control machine)

```
OPENFDD_IMAGE_TAG=latest RUN_POST_CHECK=1 ./scripts/
upgrade_edge_ghcr.sh --limit <inventory_host>
```

98.7 5. Validate

→ Deployment validation({ { “/ops/deployment-validation/” | relative_url } })

98.8 Rollback

Restore docker-compose.yml from backup, pull previous tag, docker compose up -d --force-recreate. workspace/ is unchanged. Details: Backup and restore({ { “/ops/backup-restore/” | relative_url } }).

98.9 Related

- [Updating the stack](#)({{ "/quick-start/updating/" | relative_url }}) — edge-host helper scripts
- [Containers](#)({{ "/architecture/containers/" | relative_url }}) — three-image architecture

99 Central collection

100 OpenFDD RCx Central — collection

OpenFDD Edge sites emit **interval summaries** (not raw historian by default). **OpenFDD RCx Central** ingests rollups over Tailscale/VPN, stores them locally, and feeds the Dash overview and validation jobs.

RCx Central is read-only toward Edge/BACnet. It runs on an analyst workstation or Docker Desktop — not on the OT edge by default.

100.1 Interval summary schema

Defined in `portfolio/store/interval_schema.py` as `FaultIntervalSummary`:

- Identity: `site_id`, `building_id`, `equipment_id`, `equipment_family`
- Window: `timestamp_start`, `timestamp_end`
- Fault: `fault_code`, `canonical_id`, `severity`, `confidence`
- Activity: `active_minutes`, `percent_active`, `occurrence_count`
- Evidence: `evidence_json` (summarized, not full trend)
- Tuning: `tuning_version`, `tuning_params_hash`
- Operator: `operator_status` (new | acknowledged | resolved | false_positive | ...)

100.2 Edge export formats

- JSONL (append-only events)
- Parquet / Feather (batch intervals)

100.3 Collect today (rollup API)

```
source infra/ansible/secrets/acme.env.local
python3 scripts/portfolio_collect.py
```

100.4 Tuning proposals

Human-reviewable proposals use TuningProposal in the same module. The AI agent **never** auto-writes BACnet points on edge — use GET /api/building-agent/tuning-brief and POST /api/building-agent/apply-tuning with apply: false first. Maintainer workflow: skills/openfdd-edge-deploy-tune/SKILL.md.

101 AHU faults

102 AHU faults

Air handling unit codes (sample from catalog).

Code	Title	Severity	Detection summary	Likely causes	Operator checks
AHU-A	Supply fan performance degradation	warning	Spread/runtime vs baseline	Belt slip, dirty filters, VFD limit	Trend speed vs airflow; filter dP
AHU-B	Simultaneous heating and cooling	critical	Heat + cool outputs active together	Sequencing bug, leaking valve	Trend coil commands; valve feedback
AHU-C	SAT sensor fault	warning	Flatline / OOB SAT	Failed sensor, bad calibration	SAT trend; compare to coil discharge
AHU-D	MAT inconsistent with OAT/RAT	warning	MAT outside OAT-RAT envelope	MAT/OAT/RAT sensor errors	Verify damper positions; cross-check OAT
AHU-E	Economizer not economizing	warning	Free cool available, OA minimum	Stuck damper, lockout	OA damper vs OAT trend

Code	Title	Severity	Detection summary	Likely causes	Operator checks
AHU-F	Damper command vs feedback mismatch	warning	Cmd $\neq$ feedback	Stuck actuator, linkage	Compare cmd/feedback trends

Example rule: flatline_1h on SAT $\rightarrow$ tag **AHU-C**. Recipe: [Python recipes]({{ "/rule-cookbook/python-recipes/" | relative_url }}).

103 Standards crosswalk

104 Standards crosswalk

Grade-A fault definitions carry a standards_crosswalk block in open_fdd/faults/catalog/*.yaml.

Field	Source	Use in Open-FDD
ornl_lbnl_taxonomy	ORNL/ LBNL unified HVAC fault taxonomy	Canonical ontology backbone
ashrae_g36_reference_type	ASHRAE Guideline 36	Trim-and-respond, plant requests, supervisory sequences
ashrae_207_reference_type	ASHRAE Standard 207	Economizer FDD test categories
brick_classes	<u>Brick</u> <u>Schema</u>	Equipment/point semantic roles
haystack_tags	Project Haystack (optional)	Interoperability tags

104.1 Example

```
standards_crosswalk:
  ornl_lbnl_taxonomy: ahu/economizer/free_cooling
  ashrae_g36_reference_type: supply_air_temp_reset
  ashrae_207_reference_type: economizer_fault_detection
```

```
brick_classes: [brick:Air_Handler_Unit, brick:Economizer]
haystack_tags: [equip, ahu, econ]
```

```
Export full catalog: python3 -c "from open_fdd.faults.catalog
import catalog_export; import json;
print(json.dumps(catalog_export(), indent=2))"
```

105 Backup and restore

106 Backup and restore

workspace/ on the edge host is the **live site state** — feather historian, BACnet commissioning files, BRICK model, FDD rules, auth, and dashboard static bundle. Container images are replaceable; **backup workspace/ before every upgrade.**

106.1 Quick backup (edge host)

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
```

Archives default to **~/openfdd-backups/latest** on the edge host (overwrites each run — one rolling copy for rigorous testing).

```
cd ~/open-fdd
./scripts/openfdd_site_backup.sh
```

Custom location (also overwritten each run unless you use a new path):

```
BACKUP_ROOT=~/openfdd-backups/manual ./scripts/
openfdd_site_backup.sh
```

Fast pre-upgrade backup (skips large workspace/bacnet/polls/ CSV history; feather/model/rules kept):

```
BACKUP_INCLUDE_POLL_SAMPLES=0 ./scripts/openfdd_site_backup.sh
```

On **bensserver**, site packs under `edge_backup/local/<site>/<building>/` are likewise overwritten by `edge_site_backup.sh` — no timestamp pile-up during validation.

From **bensserver** for any edge host (Ansible — backup runs **on the edge**, no workspace transfer over Tailscale):

```
OPENFDD_IMAGE_TAG=3.1.3 ./scripts/upgrade_edge_site.sh --limit
acme_vm_bbartling
```



```
OPENFDD_IMAGE_TAG=3.1.3 ./scripts/upgrade_edge_site.sh --limit
acme_vm_bbartling --fast-backup
```

Acme wrapper (same flow):

```
OPENFDD_IMAGE_TAG=3.1.3 ./scripts/upgrade_acme_site.sh --fast-
backup
```

106.2 Manual backup (SSH)

Container processes may write files as **root:root** with mode **0600**.
Use **sudo** for a full archive:

```
cd ~/open-fdd

export BACKUP_ROOT="$HOME/openfdd-backups/$(date +%Y%m%d-%H%M%S)"
mkdir -p "$BACKUP_ROOT"

cp docker-compose.yml "$BACKUP_ROOT/docker-compose.yml.before"
docker compose ps > "$BACKUP_ROOT/docker-compose-ps-before.txt"
docker compose config --images > "$BACKUP_ROOT/docker-images-
before.txt"

sudo tar --xattrs --acls -czf "$BACKUP_ROOT/workspace-full.tgz"
workspace
sudo chown "$USER:$USER" "$BACKUP_ROOT/workspace-full.tgz"

du -h "$BACKUP_ROOT/workspace-full.tgz"
```

106.3 What to protect

Path	Contents
workspace/data/ feather_store/	Feather historian
workspace/bacnet/ commissioning/	points.csv, commission.env
workspace/bacnet/ polls/samples.csv	Poll output
workspace/data/*.json	Model, rules store, FDD results
workspace/ auth.env.local	Login secrets
workspace/api/static/ app/	Dashboard bundle (if deployed separately)

106.4 Restore after a bad upgrade

1. Stop containers: `docker compose stop` (do **not** use `down -v`)
2. Restore `docker-compose.yml` from backup
3. If data corruption: extract selective files from `workspace-full.tgz` — model, rules, feather shards
4. `docker compose pull && docker compose up -d --force-recreate`
5. Verify: `Deployment validation({{ "/ops/deployment-validation/" | relative_url }})`

106.5 Safe cleanup

```
docker image prune -f
```

Never on live sites: `docker compose down -v`, `docker volume prune`, `docker system prune -a --volumes`, or deleting `workspace/`.

106.6 Related

- `Updating the stack({{ "/quick-start/updating/" | relative_url }})`
- `Live site update({{ "/ops/live_site_update/" | relative_url }})`

107 OpenFDD RCx Central API

108 OpenFDD RCx Central API

Local analyst API for multi-edge RCx workflows over Tailscale/VPN. **Read-only toward OpenFDD Edge** — no BACnet, no commands.

Package path: `portfolio/central/api.py` — service name **openfdd-rcx-central**.

108.1 Start

```
pip install -r portfolio/requirements.txt
./scripts/run_central_api.sh # http://127.0.0.1:8060/health
./scripts/run_portfolio_dash.sh # http://127.0.0.1:8050
```

Bind defaults: 0.0.0.0 (OPENFDD_CENTRAL_API_HOST, OPENFDD_RCX_DASH_HOST). LAN: sudo ./scripts/open_rcx_central_lan_ports.sh.

Agent guide: [docs/agent-skills/rcx-central-dash-agent.md](#)

108.2 Edge registry (browser auth)

Method	Path	Purpose
GET	/api/central/edges	Saved Edge instances (secrets masked)
POST	/api/central/edges	Add/update Edge
POST	/api/central/edges/test	Test connection (health + model)
PUT	/api/central/edges/{site_id}	Update Edge
DELETE	/api/central/edges/{site_id}	Remove Edge

108.3 Analytics & RCx

Method	Path	Purpose
GET	/api/central/overview/{site_id}	Dash payload: KPIs, fault pie, building summary, P8
GET	/api/central/mechanical-summary/{site_id}	Equipment counts, BACnet, narrative
GET	/api/central/fdd-analytics/{site_id}	FDD rules + fault descriptions
GET	/api/central/fdd-preset/{site_id}/{preset_id}	Proxy Edge FDD/BRICK preset (Data Model tab parity)
POST	/api/central/rcx/preview	Data readiness + chart catalog

Method	Path	Purpose
POST	/api/central/rcx/charts/preview	Matplotlib PNG previews (base64)
POST	/api/central/rcx/report	Download DOCX report

108.4 Validation (legacy collect workflow)

Method	Path	Purpose
GET	/api/central/sites	Edge registry + last check-in
POST	/api/central/sites/{site_id}/collect-validate	Collect rollup + validation
POST	/api/central/validation/run	One-off or scheduled plan
GET	/api/central/validation/jobs	Stored jobs
GET	/api/central/validation/jobs/{id}	Job detail

108.5 RCx report body

```
{
  "site_id": "acme",
  "hours": 24,
  "charts": ["fault_hours_by_severity", "ahu_sat_vs_setpoint"],
  "sections": ["executive_summary", "mechanical_summary"],
  "save_to_volume": true
}
```

Reports save under portfolio/data/reports/ (configurable via OPENFDD_RCX_CENTRAL_DATA).

Legacy endpoint: POST /api/central/rcx/report-legacy

109 VAV faults

110 VAV faults

Variable air volume terminal codes (sample).

Code	Title	Severity	Detection summary	Likely causes	Operator checks
VAV-A	Zone heating/cooling overlap	warning	Heat and cool at terminal	Reheat valve stuck, SAT too low	Zone temp vs SAT; valve cmd
VAV-B	Poor zone temperature control	warning	Persistent deviation from setpoint	Oversized box, bad tuning	PI loop trends; occupancy
VAV-C	Zone temperature sensor fault	warning	Flatline / OOB zone temp	Failed zone sensor	Flatline test; compare to neighbor zones
VAV-D	Minimum airflow not met	warning	Flow below minimum cmd	Damper stuck, pressure issue	Airflow vs damper cmd
VAV-E	Discharge temp deviation from SAT	warning	DAT far from SAT setpoint	Coil issue, sensor drift	DAT vs SAT SP

Example rule: oob_rolling on zone temp → **VAV-C** or comfort bounds per site policy.

111 Docker images (GHCR)

112 Docker images (GHCR)

Full **Open-FDD edge/operator stack** — not the PyPI library.

112.1 Images

GHCR image	Service	Role
ghcr.io/bbartling/openfdd-bridge	bridge	API, dashboard, historian
ghcr.io/bbartling/openfdd-commission	commission	BACnet discover/read/poll
ghcr.io/bbartling/openfdd-mcp-rag	mcp-rag	MCP + doc-search sidecar

Image name openfdd-mcp-rag is retained for compatibility; the container runs the unified MCP server.

112.2 Tags

Tag	Meaning
3.0.30	Exact release (preferred for production)
3.0	Minor alias on release tags
latest	Latest tagged release only
edge	Not published by default — use pinned versions on OT hosts

```
export OPENFDD_IMAGE_TAG=3.0.30
docker pull ghcr.io/bbartling/openfdd-bridge:${OPENFDD_IMAGE_TAG}
docker pull ghcr.io/bbartling/openfdd-commission:${
{OPENFDD_IMAGE_TAG}
docker pull ghcr.io/bbartling/openfdd-mcp-rag:${OPENFDD_IMAGE_TAG}
```

112.3 Publish

Triggered by git tag vX.Y.Z → workflow **Publish Docker images to GHCR** (tags X.Y.Z, X.Y, latest).

Manual: Actions → **Publish Docker images to GHCR** (workflow_dispatch) — reads version from pyproject.toml and publishes the same tags (3.1.3, 3.1, latest). Optional image_tag input overrides the version.

112.4 vs PyPI

Need	Use
Embed FDD in your Python/cloud job	<code>pip install open-fdd</code>
BACnet + UI + bridge on an edge host	GHCR images

See [Release process](#)({ { "/developer/release-process/" | relative_url } }).

113 RTU faults

114 RTU faults

Packaged rooftop unit codes (sample).

Code	Title	Severity	Detection summary	Likely causes	Operator checks
RTU-A	Compressor short cycling	warning	Rapid on/off cycles	Low charge, oversized unit	Run-time histogram
RTU-B	Economizer / OA damper fault	warning	OA behavior vs conditions	Actuator, sensor	OA damper vs enthalpy/OAT
RTU-C	Supply air temperature fault	warning	SAT flatline or OOB	Sensor failure	SAT trend vs outdoor conditions
RTU-D	Simultaneous heat and cool	critical	Heat + cool stages together	Control board, relay stuck	Stage status trends

Bind rules to packaged unit `fdd_input` points (SAT, OAT, compressor cmd, ...).

115 Deployment validation

116 Deployment validation

For the **live Acme site** after GHCR updates, use the dedicated harness documented in [Acme live validation](#)({{ "/ops/acme-live-validation/" | relative_url }}) (acme_post_deploy_validate.sh).

Non-destructive checks after deploy or image upgrade. Run from the **edge host** (smoke) or from a **control machine** with the full repo (insurance suite).

116.1 Edge host smoke (5 minutes)

```
cd ~/open-fdd

docker compose ps
curl -sf http://127.0.0.1:8765/health | jq . || curl -sf http://
127.0.0.1:8765/health

tail -1 workspace/bacnet/polls/samples.csv
du -sh workspace/data/feather_store/

docker compose logs --since 20m | grep -Ei "error|exception|
traceback|critical" | tail -20 || true
```

Via Caddy (building LAN):

```
curl -sf http://<edge-ip>/health
curl -sf http://<edge-ip>/ | grep -o 'index-[^"]*\.\js' | head -1
```

116.2 Browser checklist

1. Open <http://<edge-ip>/> (Caddy :80, not only loopback :8765)
2. Integrator login (workspace/auth.env.local on the edge host)
3. **Host stats** — container image tag / git SHA
4. **BACnet** — driver tree shows devices; last poll timestamp recent
5. **Model & assignments** — commissioning export returns JSON
6. **Rule Lab** — quick-test a saved rule (backend: arrow)

116.3 Control-machine insurance check

From a machine with the full open-fdd repo and Ansible inventory:

```
cd infra/ansible/scripts
./post_deploy_check.sh --limit <inventory_host> --full
```

Or by IP:

```
./post_deploy_check.sh --host <edge-ip> --ssh-user <deploy-user>
--full
```

Checks include: Caddy → React dashboard, /health/stack, MCP RAG, BACnet tree, BRICK/SPARQL, Docker log scan.

Do not run on live commissioned sites without approval: acme_operational_verify.sh with BACnet rediscover — use --skip-discover for smoke only. See [Examples — GL36 lab]({{ "/examples/acme-gl36-lab/" | relative_url }}).

116.4 LAN security smoke (optional)

From a workstation on the same LAN as the edge:

- Windows: scripts/security/Run-OpenFddSecurityScan.ps1
- macOS/Linux: scripts/security/run_openfdd_security_scan.sh

Expected findings: [ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}).

116.5 Arrow / FDD rules (3.0+)

On control machine:

```
./scripts/validate_fdd_backends.sh --docker
```

On edge after upgrade:

```
grep -R "apply_faults_arrow" workspace/data/rules_py | wc -l
```

116.6 Related

- [Health check]({{ "/quick-start/health-check/" | relative_url }})
- Security testing cycle({{ "/developer/security-testing/" | relative_url }}) (maintainers)

117 Sensor and data quality

118 Sensor and data quality

Sensor faults use cookbook patterns `flatline_1h`, `oob_rolling`, `rate_of_change`, and `mixing_envelope`. Full thresholds: [Expression cookbook — sensor validation]({{ “/rule-cookbook/expression-cookbook/” | relative_url }}#sensor-validation-bounds-flatline-rate-of-change).

118.1 Catalog codes

Code	Title	Severity	Pattern	Detection summary
BLD-B	Outdoor air sensor fault	warning	flatline, oob, rate_of_change	OAT flatline, OOB, or unrealistic spike
BLD-D	Stale telemetry	critical	stale_points	No new samples within threshold
AHU-C	SAT sensor fault	warning	flatline_1h, oob_rolling	Supply air temp stuck or out of band
AHU-D	MAT inconsistent with OAT/RAT	warning	mixing_envelope	Mixed air outside OAT-RAT envelope
VAV-C	Zone temperature sensor fault	warning	flatline_1h, oob_rolling	Zone temp stuck or 55–90 °F band breach
RTU-C	Supply air temperature fault	warning	flatline_1h, oob_rolling	Packaged unit SAT fault
CH-D	CHW supply temperature sensor fault	warning	flatline_1h, oob_rolling	Plant CHW sensor fault
DC-C	Datacom sensor anomaly	warning	flatline_1h	CRAH/room sensor flatline or RH OOB

Code	Title	Severity	Pattern	Detection summary
HP-D	Discharge/suction temperature sensor fault	warning	flatline_1h, oob_rolling	Heat pump refrigerant/air temp sensor

118.2 Default bounds (imperial, occupied)

Sensor	Min	Max	Flatline tol	Max Δ /hr
Zone temp	55 °F	90 °F	0.10 °F	4 °F
Supply air temp	50 °F	110 °F	0.15 °F	8 °F
Return air temp	55 °F	95 °F	0.10 °F	3 °F
Duct static	−0.5	3.0 inH ₂ O	0.02	0.5
RH	0 %	100 %	1.0 %	15 %
CHW	40 °F	90 °F	0.10 °F	4 °F
HW	70 °F	200 °F	0.15 °F	6 °F
Condenser water	50 °F	110 °F	0.15 °F	5 °F
CO ₂ (occupied)	400 ppm	1000 ppm	5 ppm	200 ppm

Return-air checks use **narrow bands**; when MAT/OAT/RAT are available, prefer **mixing envelope** over RAT bounds alone.

118.3 Communication quality

- Monitor poll cycle timestamps in dashboard.
- Use `stale_points` for dropout detection (**BLD-D**).
- Do not confuse **comm loss** with **equipment fault** — verify BACnet device online before dispatching mechanical.

118.4 Operator workflow

1. Confirm **BLD-D** (stale) is resolved before trusting other sensor codes.
2. Cross-check **BLD-B** OAT against weather service or JSON API driver.
3. For **VAV-C** / **AHU-C**, compare neighbor zones / coil behavior before replacing sensor.

119 Logging and audit

120 Logging and audit

Open-FDD uses a **two-tier logging model** familiar to IT and security teams: structured **audit/error JSONL** for forensics and compliance, plus **service stdout** for engineering troubleshooting. Defaults include **age pruning**, **size rotation in MB**, and **Docker log caps** — no operator cron required.

120.1 Log types

Tier	Location	Format	Who reads it
Audit	workspace/logs/audit.jsonl	JSON Lines	Security, MSI, integrator API
Errors	workspace/logs/error.jsonl	JSON Lines	Support, integrator API
Service stdout	Docker: docker compose logs · Dev: workspace/.local-run/*.log	Plain text (uvicorn, workers)	Engineering
Historian	workspace/data/feather_store/	Feather	FDD, plots — separate retention (data.env.local)

Structured audit logs are **not** mixed into uvicorn access logs. That separation matches common practice: SIEM-friendly JSONL for auth and OT commands; unstructured stdout for stack traces and poll worker noise.

120.2 Audit record schema

Each line in audit.jsonl / error.jsonl is one JSON object:

Field	Example	Notes
@timestamp	2026-06-07T19:57:21+00:00	UTC ISO-8601
event_id	UUID	Unique per event
event_type	auth.login.failure	Stable taxonomy (see below)
severity	warning	debug ... critical
outcome	failure	success, failure, denied, ...

Field	Example	Notes
service	openfdd-bridge	
host	hostname	
action	login	Human-readable verb
actor	{username, role}	After successful auth
client	{ip, user_agent}	Respects OFDD_TRUST_X_FORWARDED_FOR behind Caddy
http	method, path, status	When HTTP-triggered
resource	BACnet object, model id, ...	When applicable
detail	Sanitized map	Passwords, tokens, secrets stripped by key name
request_id	UUID	On audited HTTP paths

120.2.1 Auth events (industry-standard login trail)

event_type	When
auth.login.success	Valid credentials
auth.login.failure	Bad password (generic client message)
auth.login.lockout	Rate limit exceeded (default 5 failures / 5 min)

Login rate limits and lockouts are **audited**; responses never reveal whether the username exists.

120.2.2 OT / commissioning events

event_type	When
bacnet.command	Supervisory write (allowed, denied, dry-run)
bacnet.discover	Who-Is / point discovery
model.write	BRICK model mutations
agent.tool	Agent tool calls (prompts hashed/truncated)
api.access	Sensitive POST/PUT/PATCH/DELETE (BACnet, ingest)
error.unhandled	Unhandled exception (also in error.jsonl)

Not audited: routine GETs (dashboard reads, plot data, health). This reduces noise while keeping **auth** and **field commands** on the trail.

120.2.3 Secret redaction

Never logged: passwords, bearer tokens, `OFDD_AUTH_SECRET`, private keys. Detail objects drop keys containing password, token, secret, authorization. Agent tool arguments use additional hashing for prompts and rule source.

Opt-in full prompt logging (lab only): `OFDD_AUDIT_LOG_PROMPTS=1`.

120.3 Integrator API (read logs in the UI stack)

Method	Path	Role
GET	<code>/api/audit/events?limit=100</code>	integrator
GET	<code>/api/audit/errors?limit=100</code>	integrator
GET	<code>/api/audit/summary</code>	integrator

Use these for post-incident review without shell access. Forward `workspace/logs/*.jsonl` to SIEM (rsyslog, Filebeat, Wazuh) on production edges.

120.4 Retention and rotation (defaults)

Configured in `workspace/data.env.local` (copy from `data.env.example`):

Variable	Default	Behavior
<code>OFDD_LOG_RETENTION_DAYS</code>	90	Drop audit/error JSONL lines older than N days; delete aged <code>.local-run</code> and archived <code>*.log / audit/*.jsonl</code>
<code>OFDD_LOG_MAX_MB</code>	50	When <code>audit.jsonl</code> or <code>error.jsonl</code> exceeds N MB, archive to <code>audit.{UTC}.jsonl</code> and start fresh
<code>OFDD_LOCAL_RUN_LOG_MAX_MB</code>	25	

Variable	Default	Behavior
OFDD_LOG_ROTATE_INTERVAL_HOURS	6	Rotate workspace/.local-run/*.log (bridge, Caddy, FDD loop, ...) Background retention while bridge is running (not only at restart)

Rotation runs at **bridge startup** and on the **scheduled interval**. No logrotate.d entry is required for audit JSONL.

Optional path overrides:

```
OFDD_AUDIT_LOG_PATH=/var/log/openfdd/audit.jsonl
OFDD_ERROR_LOG_PATH=/var/log/openfdd/error.jsonl
```

120.5 Docker edge: json-file caps (not journald for app audit)

Production stacks use **Docker Compose** (docker/compose.edge.yml). Container stdout uses the **json-file driver with size limits**:

```
logging:
  driver: json-file
  options:
    max-size: "25m"
    max-file: "5"
```

That caps each service at roughly **125 MB** of rotated container logs on disk — the same pattern many teams use instead of unbounded docker logs.

Why audit JSONL stays on disk (not journald)?

- Append-only files under workspace/logs/ survive container recreate and bind-mount to the host.
- JSONL lines import cleanly into SIEM without journal field parsing.
- OT incident response often needs **months** of auth/BACnet write history on the edge box.

When journald still applies: native systemd units (Caddy, Ollama on bare metal) — use `journalctl -u <unit>` per your Linux runbook. Bridge audit remains in `workspace/logs/` even when uvicorn stdout goes to Docker or `.local-run/`.

120.6 Local dev (run_local.sh)

File	Service
workspace/.local-run/bridge.log	Bridge / uvicorn
workspace/.local-run/commission.log	BACnet commission agent
workspace/.local-run/caddy.log	Caddy
workspace/.local-run/fdd_loop.log	Scheduled FDD
workspace/.local-run/mcp_rag.log	MCP RAG
workspace/.local-run/ollama.log	Ollama

These are **engineering logs**. Structured audit still lands in `workspace/logs/audit.jsonl` when auth is enabled.

120.7 Quick checks

```
# Last auth failures
grep 'auth.login' workspace/logs/audit.jsonl | tail -5

# Integrator API (after login)
curl -s -H "Authorization: Bearer $TOKEN" http://127.0.0.1:8765/
api/audit/summary | jq .

# Docker edge
docker compose logs bridge --tail 50
```

120.8 Comparison to typical web apps

Practice	Open-FDD
Structured auth audit	Yes — JSONL with actor, IP, outcome
Login rate limit + logout audit	Yes
Secret redaction in logs	Yes — key-based + agent sanitization
Request correlation ID	Yes — on audited mutation paths
Centralized stdout JSON	No — stdout is plain text; audit is JSONL

Practice	Open-FDD
Full HTTP access log	No — mutations and auth only (OT noise reduction)
Log rotation / size caps	Yes — defaults above + Docker max-size
SIEM-ready export	Yes — file tail / Filebeat on workspace/logs/

For BACnet write safety and credential generation, see [SECURITY.md](#) and [Secrets and auth](#)({{ "/security/secrets-auth/" | relative_url }}).

120.9 Related

- [JSON API driver](#)({{ "/drivers/json-api/" | relative_url }}) — OpenWeatherMap showcase, env-based API keys (json_api.env.local)
- [Live site update](#)({{ "/ops/live_site_update/" | relative_url }}) — docker compose logs after upgrades
- [Data flow](#)({{ "/architecture/data-flow/" | relative_url }}) — historian retention (OFDD_FEATHER_*) is separate from audit logs

121 GHCR image retention

122 GHCR image retention

Open-FDD publishes edge images to **GHCR** (ghcr.io/bbartling/openfdd-*). During rapid development, old package versions accumulate. This retention system prunes **noise** while protecting rollback tags for **Acme**, our live validation building.

122.1 Policy (conservative)

Always keep:

- latest and edge
- Latest 5 SemVer release tags per image (configurable)
- Tags listed in scripts/ghcr-retention-protected-tags.txt
- Current Acme deployed tag (workflow input or --current-acme-tag)
- Previous Acme known-good tag (--previous-acme-tag)

Delete candidates (only with `--confirm-delete`):

- Untagged versions older than **7** days
- SHA-only tags older than **30** days
- Feature/dev-style tags older than **30** days
- SemVer releases beyond the latest N window (unless protected)

Images are defined in `docker/images.yaml`:

- `openfdd-bridge`
- `openfdd-commission`
- `openfdd-mcp-rag`
- `openfdd-cloud-exporter`

122.2 Dry-run first

The script defaults to **dry-run**. It prints a keep/delete table and optional JSON/Markdown reports. Nothing is deleted until you pass `--confirm-delete`.

There is **no scheduled automatic deletion** yet — only manual runs locally or via GitHub Actions `workflow_dispatch`.

122.3 Protect Acme rollback tags

Before cleanup, edit `scripts/ghcr-retention-protected-tags.txt`:

```
latest
edge
v3.0.31
v3.0.30
```

Or pass tags at runtime:

```
./scripts/ghcr_prune_packages.sh --all-images --dry-run \  
  --current-acme-tag v3.0.31 \  
  --previous-acme-tag v3.0.30
```

122.4 Run locally

```
gh auth login    # needs read:packages + delete:packages for  
confirm-delete
```

```
./scripts/ghcr_prune_packages.sh --all-images --dry-run  
./scripts/ghcr_prune_packages.sh --image openfdd-bridge --dry-run \  
  --json-out reports/ghcr-prune-plan.json \  
  --confirm-delete
```

```
--markdown-out reports/ghcr-prune-plan.md

# After reviewing the plan:
./scripts/ghcr_prune_packages.sh --all-images --confirm-delete \
--current-acme-tag v3.0.31 --previous-acme-tag v3.0.30
```

122.5 GitHub Actions workflow

Workflow: **Prune old GHCR images** (.github/workflows/ghcr-prune.yml)

1. Actions → **Prune old GHCR images** → **Run workflow**
2. Leave **Dry run only** = true for the first run
3. Download the ghcr-prune-report artifact
4. Re-run with **Dry run only** = false only after reviewing the plan
5. Set **Current Acme deployed tag** and **Previous Acme rollback tag** when known

122.6 Permissions

Deleting package versions requires:

- Local: gh auth login with delete:packages (and read:packages)
- Actions: permissions.packages: write on the workflow (already set)

If deletion fails, the script prints:

```
Deleting GHCR package versions requires package delete
permissions...
```

122.7 Verify images still pull

After pruning:

```
docker pull ghcr.io/bbartling/openfdd-bridge:latest
docker pull ghcr.io/bbartling/openfdd-commission:latest
```

On Acme:

```
export OPENFDD_IMAGE_TAG=v3.0.31
./scripts/upgrade_edge_ghcr.sh --limit acme_vm_bbartling
./scripts/acme_post_deploy_validate.sh --limit acme_vm_bbartling
--quick
```

122.8 Rollback example

```
export OPENFDD_IMAGE_TAG=v3.0.30
./scripts/upgrade_edge_ghcr.sh --limit acme_vm_bbartling
```

122.9 Related issues

Track open Acme/deploy blockers in [GitHub issue #276](#).

123 Fault Codes

124 Fault Codes

Open-FDD uses a **check-engine** model: one building-level status (green / yellow / red) with a catalog of fixed fault codes per equipment family.

Page	Content
Convention ({ { "/fault-codes/convention/"	relative_url }}
AHU faults ({ { "/fault-codes/ahu/"	relative_url }}
VAV faults ({ { "/fault-codes/vav/"	relative_url }}
RTU faults ({ { "/fault-codes/rtu/"	relative_url }}
[Sensor & data quality]({ { "/fault-codes/sensor-quality/"	relative_url }}
Short lookup ({ { "/fault-codes/short-lookup/"	relative_url }}

Live catalog API: GET /api/faults/catalog on the Operator Bridge.

125 Operations

126 Operations

Runbooks for live edge hosts after the initial `Quick Start({{ "/quick-start/" | relative_url }})` deploy.

Page	When to use
Live site update({{ "/ops/live_site_update/" relative_url }})	relative_url }}
Backup and restore({{ "/ops/backup-restore/" relative_url }})	relative_url }}
Logging and audit({{ "/ops/logging/" relative_url }})	relative_url }}
Deployment validation({{ "/ops/deployment-validation/" relative_url }})	relative_url }}
ACME live validation({{ "/operations/acme-live-validation/" relative_url }})	relative_url }}
Bench 5007 long FDD smoke({{ "/operations/bench-5007-long-fdd-smoke/" relative_url }})	relative_url }}
Bench 5007 dual-source smoke({{ "/operations/bench-5007-dual-source-smoke/" relative_url }})	relative_url }}

Site-specific lab notes (example BACnet scope, GL36 rules):
[Examples & lab notes\({{ "/examples/" | relative_url }}\)](#).

For first-time deploy: `[Quick Start — Docker]({{ "/quick-start/docker/" | relative_url }})`.

127 Portfolio

128 Portfolio (central desk)

Multi-site analytics on **benserver** — not part of the edge Docker stack.

Topic	Page
Collect rollups from edge sites	Central collection ({{ "/" portfolio/central-collection/"

Repo layout: portfolio/ (collector, Dash, sites.json). Maintainer tuning API flow: skills/openfdd-edge-deploy-tune/SKILL.md.

129 Acme VAV/AHU rule guidance

130 Acme VAV/AHU FDD rule bundle

Practical Arrow-native rule set for **acme** (vm-bbartling): one RTU/AHU (acme-vm-bbartling-rtu-01, BACnet **1100**) feeding **JCI VAVs** (instances 1-100, imperial °F at wire) and **Trane VAVs** (11000-13000, metric °C converted to °F before feather via device_poll_profiles.csv).

Install / refresh rules:

```
python3 scripts/setup_gl36_fdd.py --site-id acme --building-id vm-bbartling \
--ahu-equipment-id acme-vm-bbartling-rtu-01 --fan-point-id 1100-analog-output-1
```

Validate bundle locally:

```
python3 scripts/acme_validate_fdd_bundle.py
```

130.1 Mixed manufacturers and units

Manufacturer	BACnet instances	Wire units	Open-FDD handling
JCI VAV	1-100	°F	Rules use temp_unit: imperial; no poll conversion
Trane VAV	11000-13000	°C	metric_temp_f in edge_config/acme/vm-bbartling/device_poll_profiles.csv converts to °F before feather
RTU AHU	1100	°F	AHU rules bind to equipment / fan point

All zone-temperature rules share **imperial bounds** after poll conversion. If a new Trane box is added without a profile row, zone OOB/flatline will be wrong until the profile is added and data re-ingested.

Command scaling (damper, reheat, fan): rules normalize **0-1 vs 0-100%** with `pc.if_else(greater(c, 1.0), divide(c, 100), c)`.

Poll interval: Acme BACnet poll loop is **60 s**. Flatline windows use `poll_interval_s: 60` and `flatline_minutes: 60` → **60 samples per hour**, not the legacy 5-min × 12 assumption.

130.2 Rule matrix

Phase	Priority	Rule ID (prefix acme-)	Module	Fault	Equip
0	1	oat-bounds	oat_sensor_bounds.py	BLD-B	Buildi
0	2	oat-flatline-1h	oat_sensor_flatline.py	BLD-B	Buildi
0	3	oat-spike	oat_sensor_spike.py	BLD-B	Buildi
0	3b	oat-vs-web-spread	oat_vs_web_spread_1h.py	BLD-B	Buildi

Phase	Priority	Rule ID (prefix acme-)	Module	Fault	Equipment
0	4	zn-t-oob-occupied	vav_zone_temp_bounds_occupied.py	VAV-C	VAV
0	5	zn-t-flatline-1h	vav_zone_temp_flatline_occupied.py	VAV-C	VAV
0	6	da-t-flatline-1h	flatline_1h.py	VAV-E	VAV
0	7	sat-flatline-1h	flatline_1h.py	AHU-C	AHU
0	8	sap-flatline-1h	flatline_1h.py	AHU-F	AHU
1	9	vav-damper-stuck	vav_damper_stuck_flatline.py	VAV-D	VAV
1	10	vav-airflow-low	vav_airflow_low.py	VAV-D	VAV
1	11	vav-reheat-warm-ambient	zone_reheat_warm_ambient.py	VAV-A	VAV
1	12	vav-reheat-leak	vav_reheat_dat_vs_sat.py	VAV-A	VAV
2	13	ahu-afterhours-runtime	ahu_afterhours_runtime.py	BLD-C	AHU
2	14	mat-oob-economizer	oob_rolling.py	AHU-D	AHU
2	15	ahu-run-hours	ahu_run_hours.py	—	AHU
—	—	Stale telemetry	Poll health dashboard	BLD-D	All

130.2.1 Phase 2+ (not enabled by default)

Enable only after point coverage on RTU **1100** is verified (OAT, MAT, RAT, SAT, OA damper, cooling cmd):

- **AHU-A** duct static not maintained — needs static SP + fan speed (future rule)
- **AHU-D** mixed air envelope — `mixing_envelope_mask` + fan on
- **AHU-E** economizer trio — 100% OA tracking, mech cooling when free cooling available, OA damper excess open

130.2.2 Phase 3 rollups (future)

- Many simultaneous **VAV-D** airflow-low → suggest AHU static / fan issue
- Many **VAV-B/C** comfort faults → AHU scheduling or SAT problem
- Hot-water plant support when HW supply temp is modeled

130.3 Data model checks

Before enabling more rules:

1. **No duplicate BACnet device instances** on equipment rows (poll health merges by `bacnet_device_id`).
2. **No duplicate point_id** rows with different `external_id` / `fdd` aliases (causes `historian_lag` double-count).
3. **Trane devices** in `device_poll_profiles.csv` with `metric_temp_f`.
4. Run `scripts/acme_validate_fdd_bundle.py` after model edits.

130.4 Tuning notes

- **acme-zn-t-oob-occupied**: if flag rate > ~70%, use tuning brief / bounds auto-tune (needs ≥85% flagged + analytics on Arrow sweep).
- Disable noisy rules via `enabled: false` in `setup_gl36_fdd.py` rather than deleting modules.
- Economizer and reheat-leak rules stay off until OAT/MAT/SAT columns are confirmed on the 7-day feather window.

130.5 JSON API weather + BACnet OAT

- OpenWeather registered on edge JSON API tab (`web-oat-t`, `web-rh`, ~20–30 min poll).
- Local OAT: bind **1100-unknown-2** (RTU outdoor air local) with `external_id: oa-t` — `scripts/acme_patch_oat_column.py`.

- Rule acme-oat-vs-web-spread flags when local vs web spread exceeds 8 °F.

130.6 BACnet override scans

Commission agent rotates **one device/hour** through P8 priority-array reads. Status: GET /api/bacnet/overrides/status. See Operator override scans({{ "/bacnet/override-scans/" | relative_url }}).

130.7 Docker backup / recovery

Edge upgrades via scripts/upgrade_edge_ghcr.sh preserve workspace/data and feather volumes on the VM. After upgrade:

1. curl /health → expect matching openfdd_version
2. ./infra/ansible/scripts/acme_operational_verify.sh
3. Re-push rules if rules_store.json was reset: setup_gl36_fdd.py --host ... --token ...

Feather backup: snapshot workspace/data/feather/ (or site pack export) before major model changes.

131 Bench 5007 dual-source smoke

132 Bench 5007 dual-source smoke

Validates BACnet MS/TP device **5007** and Niagara baskStream station **bench9065** on the same physical bench.

132.1 Run

```
./scripts/run_local.sh start
./scripts/smoke_bench_5007_dual_source.sh
```

Environment (optional):

Variable	Default
OPENFDD_BASE_URL	http://127.0.0.1:8765
OPENFDD_AUTH_ENV	workspace/auth.env.local
OPENFDD_SMOKE_SITE_ID	demo
OPENFDD_SMOKE_POLL_SECONDS	60
OPENFDD_SMOKE_DURATION_MINUTES	10

The script wraps scripts/smoke_benserver_bench.py and adds DataFusion SQL lab preview when open-fdd[datafusion] is installed.

132.2 Paired semantic points

Semantic	BACnet column	Niagara column
oa-t	oa-t	niagara-oa-t
oa-h	oa-h	niagara-oa-h
duct-t	duct-t	niagara-duct-t
stat_zn-t	stat_zn-t	niagara-stat-zn-t

Import workspace/data/bench_dual_source_model.json if the model is empty.

133 Bench 5007 long FDD smoke

134 Bench 5007 long FDD smoke

Validates **data-source-agnostic FDD, PyArrow vs DataFusion SQL equivalence**, and the **fault confirmation window** on BACnet 5007 + Niagara bench9065 (site demo).

Read-only: polls devices; only Open-FDD evaluation thresholds change. Never prints credentials.

134.1 Commands

Mode	Command
CI synthetic	<code>python scripts/ smoke_bench_5007_long_fdd.py -- synthetic</code>
Dev dry-run (~15 min)	<code>python scripts/ smoke_bench_5007_long_fdd.py --dry- run</code>
Default (2 h)	<code>./scripts/ smoke_bench_5007_long_fdd.sh</code>
Overnight (12 h)	<code>python scripts/ smoke_bench_5007_long_fdd.py -- overnight</code>

134.2 Key environment

Variable	Default
<code>OPENFDD_BASE_URL</code>	<code>http://127.0.0.1:8765</code>
<code>OPENFDD_SMOKE_DURATION_MINUTES</code>	120 (720 if <code>OPENFDD_SMOKE_OVERNIGHT=true</code>)
<code>OPENFDD_SMOKE_POLL_SECONDS</code>	60
<code>OPENFDD_SMOKE_BASELINE_MINUTES</code>	20
<code>OPENFDD_SMOKE_CONFIRMATION_ROWS</code>	10
<code>OPENFDD_SMOKE_CONFIRMATION_MINUTES</code>	10
<code>OPENFDD_SMOKE_PRIMARY_SEMANTIC</code>	<code>duct-t</code>
<code>OPENFDD_SMOKE_FORCED_THRESHOLD_F</code>	80.0

134.3 Fault confirmation window

At 1-minute polling, `min_true_rows = 10` means the raw condition must stay true for about **10 minutes** before a **confirmed fault** is reported. See [fault-confirmation.md](#).

134.4 Artifacts

- `workspace/reports/bench_5007_long_fdd_<timestamp>.md`
- `workspace/reports/bench_5007_long_fdd_<timestamp>.json`
- `workspace/reports/bench_5007_long_fdd_<timestamp>_events.csv`

134.5 Pass / fail

Verdict	Meaning
PASS	All checks passed; confirmation fully vectorized (not expected today)
WARN	Core FDD uses pyarrow_compute / datafusion_sql; confirmation engine is python_loop_over_arrow_mask (known tech debt)
FAIL	python_list core crunching, early confirmed fault, backend mismatch, missing data, or secrets in output

Live mode uses POST /api/bench/long-fdd/evaluate (validation/
smoke only).

134.6 Related

- [Dual-source smoke](#)
- [Fault confirmation](#)

135 ACME live validation

136 ACME live validation

ACME (site_id: acme, Acme Building) is the **live BACnet HVAC validation site** on the OT LAN. Use it for real VAV/AHU behavior, RCx rule tuning, and overnight FDD runs.

Do **not** confuse ACME with **Bench 5007** dual-source validation (site demo, BACnet 5007 + Niagara bench9065). Bench 5007 proves backend equivalence; ACME proves production HVAC rules on field hardware.

Reference model (no secrets): workspace/data/fixtures/
acme_data_model.json. Validate locally:

```
python scripts/validate_acme_model_context.py  
python scripts/validate_acme_model_context.py --json
```

136.1 Model export / import

1. **Export** — GET /api/model/commissioning-export (dashboard **Import / export** tab or API).
2. **Validate** — python scripts/validate_acme_model_context.py on saved JSON; dashboard dry-run before import.
3. **Import** — POST /api/model/commissioning-import only after review. Preserve point id, fdd_input, metadata.series_id, and existing fdd_rule_ids. Never invent rule IDs.

Someday ACME will be updated from live export again; until the bench harness is stable, treat the committed fixture as the regression baseline.

136.2 Run FDD (read-only)

Goal	Command / API
Post-upgrade smoke	./scripts/acme_post_deploy_validate.sh --limit acme_vm_bbartling --full
Selected rules	Rule Lab preview / POST /api/playground/test-rule
All enabled rules	POST /api/rules/batch → workspace/data/fdd_results.json
Overnight cycles	OPENFDD_LIVE_ACME=1 python3 scripts/acme_overnight_fdd_validate.py --limit acme_vm_bbartling

Normal validation is **read-only**: no BACnet writes, no Pooge reset, no setpoint commands. BACnet writes require commission role + explicit enable — see [BACnet write safety]({{ "/security/bacnet-writes/" | relative_url }}).

136.3 Reports

- Post-deploy JSON: reports/acme-live-validate.json (gitignored)
- Overnight FDD: under reports/ from overnight script
- FDD batch: workspace/data/fdd_results.json (local edge only)

Redact tokens and hostnames before sharing.

136.4 Fault confirmation

Rules may fire **raw** faults before **confirmed** faults. Configure `min_true_rows` and `min_elapsed_minutes` in rule `cfg` (e.g. 10 rows at 1-minute poll $\approx$ 10 minutes). See `Fault confirmation`(`{{ "/rule-cookbook/fault-confirmation/" | relative_url }}`).

136.5 Safe rules on ACME

Prefer read-only sensor bounds, flatline, spread (OAT vs weather), damper stuck, and zone temperature rules. Avoid supervisory writes unless explicitly commissioned and guarded.

136.6 Related

- `ACME VAV/AHU rule guidance`(`{{ "/operations/acme_vav_ahu_rule_guidance/" | relative_url }}`)
- `Deployment validation`(`{{ "/ops/deployment-validation/" | relative_url }}`)
- `Bench 5007 long FDD smoke`(`{{ "/operations/bench-5007-long-fdd-smoke/" | relative_url }}`) — dual-source bench only

137 AI agent context

138 AI agent context

Canonical map for humans and MCP/RAG agents operating Open-FDD on the OT edge. **No secrets** in docs, exports, reports, or chat context.

138.1 1. Open-FDD in one paragraph

Open-FDD is an **edge FDD platform**: BACnet / Niagara / JSON API drivers ingest telemetry into a **BRICK-style JSON model** and **Feather/Arrow historian**; **PyArrow** (primary) and optional **DataFusion SQL** rules produce boolean fault masks with a shared **confirmation window**; the **Operator Bridge** dashboard and **MCP sidecar** expose commissioning, Rule Lab, batch FDD, and doc search. Deploy via **GHCR Docker** (`openfdd-bridge`, `openfdd-commission`, `openfdd-mcp-rag`) on a trusted LAN — not the public internet.

138.2 2. Deployment mental model

Piece	Role
GHCR stack	openfdd-bridge (API + UI), openfdd-commission (BACnet poll), openfdd-mcp-rag (doc RAG)
Host Caddy	:80 / :443 front door to bridge
workspace/	Model, rules, feather store, auth env — persist across image upgrades
Auth	workspace/auth.env.local (gitignored); JWT via POST / api/auth/login
Update	Updating the stack({{ “/ quick-start/updating/”

Rebuild MCP index after doc changes: ./scripts/build_mcp_rag_index.sh.

138.3 3. Source / driver modes

Mode	Feather source	When
BACnet direct	bacnet	Production OT — commission container polls :47808
Niagara baskStream	niagara_baskstream	Bench / sites with Niagara HTTP API
JSON API	json_api	Weather, REST sensors, OpenWeather demo
Platform API profile	scaffold	Future portfolio central — not production duplicate poll

Do **not** run legacy BACnet poll alongside Docker **commission** on the same device (double poll). Validation smokes may intentionally dual-source **Bench 5007** only.

138.4 4. Data model contract

Commissioning bundle: GET /api/model/commissioning-export → POST /api/model/commissioning-import (dry-run in UI first).

Field	Rule
sites[], equipment[], points[], fdd_rules[]	Required structure
Point id	Preserve on import — never renumber
fdd_input	Rule column role (oa-t, zn-t, sat, ...)
metadata.series_id	Historian series key
metadata.external_ref	Stable feather/BACnet reference
fdd_rule_ids	Must reference existing fdd_rules[].id — never invent rule on import
Column map	open_fdd.arrow_runtime.build_column_map_from_model_points(site_id)

Live HVAC reference model: **ACME** (site_id: acme) — fixture at workspace/data/fixtures/acme_data_model.json. Bench dual-source model: site demo / device 5007 — not ACME.

138.5 5. Rule execution contract

Backend	Use when
PyArrow (apply_faults_arrow)	Full HVAC logic, rolling windows, ML prep, cookbook helpers
DataFusion SQL (backend: datafusion_sql)	Simple threshold / CASE / SQL-readable rules; optional pip install open-fdd[datafusion]

Both normalize to **Arrow boolean mask** / ArrowRuleResult. SQL runs **server-side only** against registered telemetry; unsafe SQL is rejected. No browser-side SQL. No pandas row-loop runtime on edge.

138.6 6. Fault confirmation window

- **Raw fault** — rule mask true on one row.

- **Confirmed fault** — `min_true_rows` consecutive trues and/or `min_elapsed_minutes` elapsed.
- Example: **10 rows** at **1-minute** polling $\approx$ **10 minutes** confirmed.

See `Fault confirmation({{ "/rule-cookbook/fault-confirmation/" | relative_url }})`.

138.7 7. Validation modes

Mode	Purpose
Bench 5007	Dual-source BACnet vs Niagara backend equivalence — [long FDD smoke]({{ "/operations/bench-5007-long-fdd-smoke/" relative_url }})
ACME live	Real BACnet HVAC, VAV/AHU rules, RCx — <code>ACME live validation({{ "/operations/acme-live-validation/" relative_url }})</code>
Synthetic CI	<code>python scripts/smoke_bench_5007_long_fdd.py --synthetic --dry-run</code>
Model fixture	<code>python scripts/validate_acme_model_context.py</code>

138.8 8. Security rules

- **No secrets** in docs, logs, exports, MCP bundle, or validation reports.
- Bridge binds **127.0.0.1** by default; LAN exposure requires explicit operator choice.
- **BACnet writes** disabled/guarded — see [BACnet write safety]({{ "/security/bacnet-writes/" | relative_url }}).
- Niagara / JSON API service accounts: dedicated, read-only where possible.
- Full tracebacks only when `OFDD_DEBUG_TRACEBACKS=1`.

138.9 9. Where to look

Topic	Doc
Start	<code>Quick Start({{ "/quick-start/" relative_url }})</code>
Drivers	<code>Driver framework({{ "/drivers/" relative_url }})</code>
Rules	

Topic	Doc
	Rule Cookbook ({{ "/rule-cookbook/"
API	API routes ({{ "/"
Operations	Operations ({{ "/ops/"
Architecture	[ADR: Rust-ready Arrow contract]({{ "/adr/adr-rust-ready-arrow-fdd-contract/"
MCP	MCP server ({{ "/ai/mcp-server/"
Contributor policy	AGENTS.md (repo root)

139 LAN hardening

140 LAN hardening

Open-FDD targets **trusted building LAN / OT edge** deployment. The Operator Bridge is not intended for direct public internet exposure.

Full mode matrix: [Deployment modes](#)({{ "/architecture/deployment-modes/" | relative_url }}).

140.1 Auth and bind

Mode	Bridge bind	Auth
Local dev	127.0.0.1	Optional OFDD_AUTH_DISABLED=1 on loopback
Lab LAN	0.0.0.0	Required unless explicit insecure lab flags
Edge production	Loopback + Caddy on LAN	Required — OFDD_AUTH_SECRET + role passwords

Startup **fails** on non-loopback bind without credentials (unless insecure lab flags are set).

140.2 Network exposure

- Put **Caddy** on :80 / :443; keep bridge :8765 on loopback when possible.
- Do not port-forward the Operator Bridge to the public internet without TLS and strong auth.
- Keep BACnet on OT VLANs; management UI on IT VLAN with firewall rules.
- BACnet **writes** are gated by default — [BACnet write guard] (`{{ "/security/bacnet-writes/" | relative_url }}`).

140.3 Rule Lab

Rule Lab runs **operator-authored Python** in a sandbox. Restrict integrator accounts; review rules before enable on production sites.

140.4 TLS and LAN security scans

Topic	Page
Certificates (self-signed / site CA)	TLS and certificates (<code>{{ "/security/tls-and-certs/"</code>
ZAP + Nmap bench smoke	[ZAP baseline] (<code>{{ "/security/zap-baseline/"</code>
Ubuntu host + Tenable/Nessus	Linux host hardening (<code>{{ "/security/linux-host-hardening/"</code>
Release test cycle (maintainers)	[Security testing] (<code>{{ "/developer/security-testing/"</code>

140.5 Ollama on the edge

Ollama has **no built-in auth**. Bind `OLLAMA_HOST=127.0.0.1:11434` on the host; never expose :11434 on the OT LAN. Open-FDD bridge reaches Ollama server-side only. Validation: `scripts/security/check_openfdd_exposure.sh`.

141 ZAP baseline (local bench)

142 ZAP baseline (local bench)

Passive OWASP ZAP baseline against the **pentest production stack** on benser server is the standard LAN security smoke before Acme edge deploys.

Full per-revision workflow (pytest → PR → GHCR → Acme):
[Developer — security testing cycle]({{ "/developer/security-testing/" | relative_url }}).

Packaged scan scripts (Windows + Mac/Linux): scripts/security/README.md.

142.1 Run

On the Open-FDD host:

```
./scripts/pentest_production_stack.sh start  
./scripts/pentest_production_stack.sh verify
```

From a LAN workstation (after verify passes):

```
# Windows – optional integrator auth probe (copy auth.env.local to  
scan PC; never commit)  
.\scripts\security\Run-OpenFddSecurityScan.ps1 -TargetUrl "http://  
192.168.204.18" `  
-AuthEnvFile "C:\path\to\auth.env.local"
```

The script writes 40-release-gate-summary.txt with **SECURITY GATE: PASS/FAIL:** - Fails if production JS bundles contain private LAN IPs or bench Niagara defaults - Warns if auth env is missing (Auth loaded: False) — pass -AuthEnvFile or shell vars OFDD_INTEGRATOR_USER / OFDD_INTEGRATOR_PASSWORD (values are never logged)

```
# macOS / Linux  
./scripts/security/run_openfdd_security_scan.sh --url http://  
192.168.204.18
```

ZAP target (example): `http://192.168.204.18/` — Caddy on `:80` only; bridge `:8765` stays loopback. TLS bench: see [TLS and certificates](#)(`{{ "/security/tls-and-certs/" | relative_url }}`)).

142.2 Expected results (HTTP bench mode)

Finding	Severity	Status
CSP style-src 'unsafe-inline'	Medium	Accepted — Vite/React inline styles; TODO to nonce/hash
Missing COEP	Low	Accepted — require-corp not enabled (breaks some assets)
Port 80 open (Caddy)	Info	Expected — intentional LAN entry
Ports 8765, 5173, 8000, 8080 closed	—	Good
Port 443 filtered	—	Expected in HTTP mode; use <code>OFDD_CADDY_MODE=tls</code> for HTTPS bench
Duplicate Referrer-Policy / X-Frame-Options	Low	Fixed — bridge owns headers; Caddy does not duplicate

142.3 Header ownership

Layer	Sets
Bridge (security_headers.py)	CSP, X-Frame-Options: DENY, frame-ancestors 'none', COOP, CORP, Permissions-Policy, Referrer-Policy, X-Content-Type-Options
Caddy HTTP	Reverse proxy only; strips Server banners
Caddy TLS	Adds Strict-Transport-Security only

142.4 Authenticated scan (later)

Baseline scan hits ~4 public endpoints (/health, public agent insight routes). Deep API/dashboard coverage requires ZAP with integrator login — see [Authenticated scanning \(roadmap\)](#)({{ "/security/authenticated-scanning/" | relative_url }}).

142.5 After fixes

Re-run `pentest_production_stack.sh verify`, then the packaged LAN scan from `scripts/security/`. Confirm response headers show **one** `X-Frame-Options: DENY` and no duplicate `Referrer-Policy`.

143 TLS and certificates

144 TLS and certificates

Who generates, stores, and renews TLS material for Open-FDD on OT LANs — and how that ties into ZAP/Nmap bench testing.

Developer release cycle: [Security testing cycle](#)({{ "/developer/security-testing/" | relative_url }}).

144.1 Ownership

Environment	Who owns certs	Storage
Local / benserver bench	Developer / maintainer	workspace/ deploy/caddy/ certs/ (cert.pem, key.pem)
Ansible edge (Acme, customer sites)	Site integrator	/etc/openfdd/ caddy/ on the VM (playbook- managed or manual)
Public internet	Not in scope	Open-FDD targets OT LAN; use site

Environment	Who owns certs	Storage
		PKI or self-signed

Open-FDD does **not** ship Let's Encrypt or public CA automation. OT benches use **self-signed** or customer-provided certs.

144.2 Generate bench certs (local)

```
./scripts/setup_caddy_certs.sh
# or: ./scripts/setup_caddy_certs.sh --cn openfdd.local --out
workspace/deploy/caddy/certs
```

Then start with TLS mode:

```
OFDD_CADDY_MODE=tls ./scripts/run_local.sh
# or pentest stack with OFDD_CADDY_MODE=tls
```

Caddy serves :443 and redirects :80 → HTTPS. Caddy adds **Strict-Transport-Security** only; all other security headers remain on the **bridge** ([ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}#header-ownership)).

144.3 ZAP / Nmap with TLS bench

When `OFDD_CADDY_MODE=tls`:

- Nmap: expect **443 open**, 80 may redirect
- ZAP: use `https://<lan-ip>/` (add `-k trust` or import `cert.pem` on the scan workstation)
- PowerShell: `.\Run-OpenFddSecurityScan.ps1 -TargetUrl "https://192.168.204.18"`
- Bash: `./run_openfdd_security_scan.sh --url https://192.168.204.18`

Self-signed certs produce ZAP TLS warnings — expected on OT LAN.

144.4 Renewal

Self-signed certs from `setup_caddy_certs.sh` default to **365 days**. Re-run the script before expiry or bake renewal into site runbooks.

Edge Ansible deploys should document whether the integrator rotates certs manually or via site PKI.

144.5 Enterprise CA on Caddy (edge)

When IT requires **clean Nessus SSL plugins** (no self-signed / untrusted chain), install a site-provided certificate on the edge VM instead of `setup_caddy_certs.sh` output.

Typical layout (Ansible / manual):

```
/etc/openfdd/caddy/cert.pem  # full chain (leaf + intermediates)
/etc/openfdd/caddy/key.pem   # private key (0600, root or caddy
user)
```

Ansible TLS mode (`caddy_mode: tls`) already points Caddy at those paths — see `infra/ansible/templates/Caddyfile.j2`.

Internal enterprise CA workflow:

1. Generate CSR on the edge host or request cert from site PKI for the operator hostname (e.g. `openfdd.acme.local`).
2. Install `cert.pem` + `key.pem` under `/etc/openfdd/caddy/`.
3. Distribute the **CA root** to admin laptops (trust store) so browsers and ZAP scans validate the chain.
4. Monitor expiry:

```
openssl x509 -in /etc/openfdd/caddy/cert.pem -noout -dates
```

Caddyfile snippet (TLS, enterprise cert):

```
:443 {
    tls /etc/openfdd/caddy/cert.pem /etc/openfdd/caddy/key.pem
    header {
        Strict-Transport-Security "max-age=31536000;
includeSubDomains"
    }
    reverse_proxy 127.0.0.1:8765
}
```

Lab/self-signed mode still produces expected **Medium** Tenable findings — document as accepted risk or switch to enterprise CA. See [Tenable remediation]({{ "/security/tenable-remediation/" | relative_url }}).

144.6 Caddy internal CA mode (lab)

`./scripts/setup_caddy_certs.sh` generates a **self-signed** pair for bench TLS. Trust `cert.pem` on scan workstations (`-k curl`, ZAP import) or accept browser warnings. Not suitable when IT mandates trusted chains.

144.7 Secrets

- **Never commit** `key.pem` or production cert bundles
- `workspace/deploy/caddy/certs/` is for local bench only unless your `.gitignore` already excludes generated keys (verify before push)

145 Authenticated scanning (roadmap)

146 Authenticated scanning (roadmap)

[ZAP baseline]({{ "/security/zap-baseline/" | relative_url }}) is **unauthenticated** — it checks public pages, response headers, and a handful of routes reachable without login. That is the right default for every docker image / patch revision smoke on a test LAN.

For **deep** coverage of integrator dashboards, `/api/*` routes, WebSocket sessions, and role-gated writes, plan a separate **authenticated** scan — only on fake/bench stacks with explicit approval.

Release context: `Security testing cycle`({{ "/developer/security-testing/" | relative_url }}).

146.1 Current state (3.0.x)

Capability	Status
ZAP baseline via <code>scripts/security/</code>	Shipped
Pentest creds in <code>workspace/auth.pentest.local</code>	Shipped (host-local, not in git)
ZAP full / active scan automation	Not shipped — manual only
ZAP authenticated context (login script + session)	Roadmap
CI running ZAP against PR previews	Not planned (LAN bench only)

146.2 Why baseline is not enough

After login, the bridge exposes model editing, BACnet/JSON API configuration, Rule Lab, commissioning export, and write-gated commands. Baseline ZAP never exercises:

- Session cookies / JWT persistence
- CSRF or auth bypass on mutating endpoints
- IDOR on site-scoped resources
- Rate limits and audit logging on failed auth

146.3 Planned approach (contributors welcome)

1. **Bench-only target** — same pentest stack; never point active scans at live OT controllers
2. **Login hook** — ZAP zap-full-scan.py or Automation Framework with:
 - POST /api/auth/login using integrator creds from env (not committed)
 - Regex or JSON extractor for session token / cookie
3. **Scope file** — include /api/model/*, /api/commissioning/*, dashboard static assets; exclude BACnet UDP and unrelated LAN hosts
4. **Report parity** — extend scripts/security/ with opt-in - Authenticated / --zap-full flags and separate report prefix (22-zap-authenticated-*)
5. **Gate** — document accepted findings; fail release only on High/Critical regressions

146.4 Manual authenticated ZAP today

1. Start pentest stack; note creds in workspace/auth.pentest.local
2. Open ZAP desktop or docker with API port exposed
3. Configure **Context** → **Authentication** → script or form-based login to /api/auth/login
4. Run **Spider** then **Active Scan** on http://<lan-ip>/ only
5. Compare with baseline report in openfdd-security-report/

Do **not** run active scans against production Acme without a maintenance window and BACnet write lock.

146.5 Related

- [scripts/security/README.md](#) — baseline setup
- [Secrets and auth\({{ "/security/secrets-auth/" | relative_url }}\)](#) — env file layout

- [LAN hardening](#)({{ "/security/lan-hardening/" | relative_url }})
— bind and auth modes

147 Secrets and auth

148 Secrets and auth

148.1 Files (gitignored)

File	Contents
workspace/ auth.env.local	JWT secret, role passwords
workspace/ json_api.env.local	REST API keys for JSON API <code>\${ENV:VAR}</code> URLs (e.g. OpenWeather <code>OPENWEATHER_API_KEY</code>)
workspace/ data.env.local	Historian + audit log retention (<code>OFDD_LOG_*</code> , <code>OFDD_FEATHER_*</code>)
workspace/ ollama.env.local	Ollama URL, model, RAM tier, GPU mode
workspace/ mcp.env.local	MCP RAG sidecar
workspace/ caddy.env.local	Reverse proxy TLS/HTTP mode
workspace/ pentest.env.local	LAN security scan stack
infra/ansible/secrets/ <host>.env.local	SSH deploy secrets (maintainers)

Copy from *.example templates only. Full inventory: [Workspace env files](#)({{ "/appendix/workspace-env-files/" | relative_url }}).

148.2 Required variables (production)

Variable	Purpose
OFDD_AUTH_SECRET	HMAC signing (32+ chars)
OFDD_INTEGRATOR_USER / PASSWORD	Rule Lab, bindings
OFDD_OPERATOR_USER / PASSWORD	Operations

148.3 GHCR pulls

Use read-only registry credentials on edge if images are private; rotate tokens periodically.

148.4 Backup

Back up workspace/data/ and auth env in secure operator vault — not in git.

Audit JSONL under workspace/logs/ may contain client IPs and usernames — treat like security logs. See `Logging and audit({{ "/ops/logging/" | relative_url }})`.

149 BACnet write allowlists

150 BACnet write allowlists

Supervisory writes require:

1. **Feature flag** enabled in environment (off by default).
2. **Allowlist** file at workspace/bacnet/write_allowlist.json (copy from `write_allowlist.example.json`). If the flag is on but the allowlist is missing, writes are **denied**.
3. **Integrator** role on API calls.
4. **Audit** log review after commissioning sessions.

Allowlist entries support device_instance, object_identifier, property_identifier, optional priority_min/priority_max, value_min/value_max, and allowed_values for binary/multistate targets.

Lab-only override: `OFDD_BACNET_WRITE_ALLOW_ANY=1` (audited; not for production edges).

See operator guide: `[BACnet write safety]({{ "/bacnet/write-safety/" | relative_url }})`.

Never enable blanket write access for agent or integrator automation without human approval per site.

151 Linux host hardening

152 Linux host hardening

Generic **Ubuntu edge VM** guidance for Open-FDD deployments scanned by IT tools (Tenable/Nessus, Qualys, etc.). This complements application-level [LAN hardening](#)(`{{ "/security/lan-hardening/" | relative_url }}`) and [\[TLS\]](#)(`{{ "/security/tls-and-certs/" | relative_url }}`).

Nessus-specific finding tables: [\[Tenable remediation\]](#)(`{{ "/security/tenable-remediation/" | relative_url }}`).

152.1 Scope

Layer	Owner	Repo support
Ubuntu kernel, OpenSSH, apt packages	Site IT / integrator	<code>scripts/security/remediate_ubuntu_host.sh</code>
Docker engine, compose, Caddy	Integrator	Ansible + <code>check_openfdd_exposure.sh</code>
Open-FDD containers (pip/pyOpenSSL)	Open-FDD maintainers	<code>docker/python-security-constraints.txt</code> , GHCR images
Self-signed TLS on OT LAN	Expected lab finding	Enterprise CA path in [TLS] (<code>{{ "/security/tls-and-certs/"</code>

152.2 Quick operator workflow

On the edge VM (SSH):

```
cd ~/open-fdd
./scripts/security/check_host_security.sh
./scripts/security/check_openfdd_exposure.sh --edge-ip "$
(hostname -I | awk '{print $1}')
```

Remediate host OS (maintenance window):

```
./scripts/security/remediate_ubuntu_host.sh # dry-run
sudo ./scripts/security/remediate_ubuntu_host.sh --apply
# if /var/run/reboot-required exists:
sudo reboot
./scripts/security/check_host_security.sh
```

Pull new Open-FDD images after a release that pins container pip/pyOpenSSL:

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_ghcr.sh --limit
<inventory_host>
```

152.3 Ubuntu version and EOL

Supported targets: **Ubuntu 22.04 LTS** or **24.04 LTS** (64-bit).
Rebuild hosts still on **16.04** or **18.04** — apt upgrade cannot clear an SEoL finding.

Validate a surprising 16.04 Nessus hit:

```
lsb_release -a
cat /etc/os-release
# Scan credential / stale DNS / container banner mismatch?
```

152.4 Kernel and package updates

```
sudo apt update
sudo apt full-upgrade -y
uname -r
test -f /var/run/reboot-required && echo "reboot required"
sudo reboot # maintenance window
```

Optional status tools:

```
ubuntu-security-status # or: pro status
apt list --upgradable | grep -i security
```

152.5 Host Python (pip, wheel, pyOpenSSL)

Tenable often reports **host** pip, wheel, and pyOpenSSL versions installed by Ubuntu packages or admin pip install. Prefer **apt** on the host:

```
python3 -m pip show pip setuptools wheel pyOpenSSL
sudo apt install --only-upgrade python3-pip python3-openssl
python3-wheel
```

Open-FDD **containers** pin toolchain versions at image build — see `docker/python-security-constraints.txt`. Rescan after `docker compose pull`.

152.6 Ollama — no LAN exposure

Ollama has **no built-in authentication** in typical deployments. Treat LAN exposure as **Critical**.

Rule	Implementation
Bind loopback only	OLLAMA_HOST=127.0.0.1:11434 in systemd (ollama.service) or dev bootstrap
Bridge calls server-side	OFDD_OLLAMA_BASE_URL=http://127.0.0.1:11434 or host.docker.internal:11434 from containers
Never publish :11434 on 0.0.0.0	Compose uses 127.0.0.1:11434:11434 when Docker Ollama is enabled

Validation:

```
ss -tulpn | grep 11434
curl -sf http://127.0.0.1:11434/api/tags | head
curl -sf --max-time 3 http://<edge-lan-ip>:11434/api/tags
# must FAIL from another host
```

Firewall (if management host needs GPU Ollama — rare):

```
# Example: block LAN → 11434; allow loopback only (adjust
interface names)
sudo ufw deny 11434/tcp
sudo ufw allow from 127.0.0.0/8 to any port 11434 proto tcp
```

152.7 OpenSSH Terrapin (CVE-2023-48795)

Apply Ubuntu security updates first (openssh-server, openssh-client). Verify:

```
ssh -V
sudo sshd -T | grep -Ei '^(ciphers|macs|kexalgorithms)'
```

Manual algorithm hardening is **optional** and can lock out clients — document rollback (`sshd_config.bak`) before changes. Do not automate cipher stripping in repo scripts.

152.8 ICMP timestamp (Low)

Nessus may report ICMP timestamp disclosure. Optional hardening at host firewall or upstream network — low priority for isolated OT VLANs.

Example (nftables — site-specific):

```
# Block ICMP timestamp / type 13 – verify with IT before applying
sudo nft add rule inet filter input icmp type timestamp-request
drop
```

152.9 TLS and certificate scans

Self-signed or internal CA certificates produce **Medium** Nessus SSL findings (untrusted, self-signed, expiry). That is **expected** for lab/OT encryption-in-transit. For clean SSL plugin results, install a **site enterprise CA** certificate on Caddy — [TLS and certificates](#)({ { “/security/tls-and-certs/” | relative_url } } #enterprise-ca-production).

152.10 Maintainer security audits (CI parity)

```
./scripts/security/run_maintainer_audits.sh
```

Matches GitHub Actions operator-bridge-security job where possible.

153 Tenable / Nessus remediation

154 Tenable / Nessus remediation

Remediation plan for **IT/Tenable.io Nessus** findings on an Open-FDD **OT/LAN edge** deployment (e.g. Acme GL36 lab VM). Open-FDD runs behind a building firewall on Ubuntu with Docker Compose, Caddy, and optional host Ollama.

Related: [Linux host hardening](#)({{ "/security/linux-host-hardening/" | relative_url }}), [TLS and certificates](#)({{ "/security/tls-and-certs/" | relative_url }}), [LAN hardening](#)({{ "/security/lan-hardening/" | relative_url }}), [Security testing cycle](#)({{ "/developer/security-testing/" | relative_url }}).

154.1 Prioritized action plan

Priority	Action	Owner
P0	Confirm Ubuntu is not 16.04/18.04; rebuild if EOL	IT / integrator
P0	Bind Ollama to 127.0.0.1 only; verify LAN cannot reach :11434	Integrator
P0	apt full-upgrade + reboot for kernel USNs (8254, 8278, 8373)	IT / integrator
P1	Upgrade host pip/wheel/pyOpenSSL via apt or documented pip path	IT / integrator
P1	Pull GHCR images built with docker/python-security-constraints.txt	Integrator
P2	OpenSSH packages current; review Terrapin after patch	IT
P2	TLS: accept self-signed findings or install enterprise CA cert	IT decision
P3	ICMP timestamp: optional firewall rule	Network / IT

154.2 Finding classification table

Nessus finding	Severity	Class	Remediation
	Critical		lsb_release -a — rebuild VM on 24.04 LTS if truly

Nessus finding	Severity	Class	Remediation
Canonical Ubuntu Linux SEoL (16.04.x)		Host OS / false positive?	16.04; if host is 22.04/24.04, check scan target IP, credentials, stale asset record
Ollama Unauthenticated Access	Critical	Deployment config	OLLAMA_HOST=127.0.0.1:11434; no 0.0.0.0:11434; firewall deny; see Ollama
Ubuntu kernel USN-8254-1	Critical	Host OS	sudo apt update && sudo apt full-upgrade -y && sudo reboot
pyOpenSSL 22.0.x < 26.0.0 Buffer Overflow	Critical	Host pip and container	Host: apt upgrade python3-openssl or pip ≥26; Container: GHCR image with constraints file
Ubuntu pip USN-8344-1	High	Host OS + container build	apt full-upgrade; image build upgrades pip>=26
SSL Certificate Cannot Be Trusted	Medium	Accepted risk (lab) / deployment	Self-signed Caddy — use enterprise CA for clean scan
SSL Self-Signed Certificate	Medium	Accepted risk (lab)	Same as above
SSL Certificate Expiry	Medium	Deployment / monitoring	openssl x509 -dates; renew setup_caddy_certs.sh or site PKI
SSH Terrapin (CVE-2023-48795)	Medium	Host OS	Upgrade openssh-server; validate ssh -V
Ubuntu wheel USN-8221-1	Medium	Host OS	apt full-upgrade
Ubuntu kernel USN-8278-1, USN-8373-1	Medium	Host OS	apt full-upgrade + reboot
pyOpenSSL 0.14.x Security Bypass	Medium	Host + container	Same as pyOpenSSL Critical — upgrade to ≥26
ICMP Timestamp Request	Low	Network / optional host	Firewall drop; often accepted on isolated OT VLAN

Class legend: (1) repo-owned fix · (2) Docker base/image · (3) host OS · (4) deployment/config · (5) accepted risk · (6) validate false positive

154.3 Operator commands (edge VM)

154.3.1 Validate (read-only)

```
cd ~/open-fdd
./scripts/security/check_host_security.sh
./scripts/security/check_openfdd_exposure.sh --edge-ip "$
(hostname -I | awk '{print $1}')"
lsb_release -a
uname -r
test -f /var/run/reboot-required && cat /var/run/reboot-
required.pkgs
python3 -m pip show pip setuptools wheel pyOpenSSL 2>/dev/null |
grep -E '^(Name|Version):'
ss -tulpn | grep -E ':80|:443|:8765|:11434'
curl -sf http://127.0.0.1:11434/api/tags | head -3
```

From a **different LAN workstation** (must fail):

```
curl -sf --max-time 3 http://<edge-ip>:11434/api/tags
```

154.3.2 Remediate host (maintenance window)

```
./scripts/security/remediate_ubuntu_host.sh # dry-run
./scripts/security/remediate_ubuntu_host.sh --apply
sudo reboot # if reboot-required
./scripts/security/check_host_security.sh
```

154.3.3 Remediate Open-FDD containers

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_ghcr.sh --limit
<inventory_host>
docker compose pull && docker compose up -d
```

154.3.4 Rescan

After reboot and image pull, request IT **Nessus rescan** of the edge IP. Compare plugin output to the table above.

154.4 Ollama unauthenticated access (Critical)

Not an Open-FDD code bug — Ollama's API is unauthenticated by design. Risk is **network exposure**.

Repo defaults (3.0.5+):

- Systemd: Environment=OLLAMA_HOST=127.0.0.1:11434 in infra/ansible/templates/ollama.service.j2
- Compose Ollama (optional profile): 127.0.0.1:11434:11434 only
- Acme-style edge: host Ollama + bridge via host.docker.internal:11434 (container → host loopback path)
- post_deploy_check.sh warns if :11434 listens on 0.0.0.0

Re-apply Ansible Ollama unit after upgrade:

```
ansible-playbook -i inventory.yml ollama_bootstrap.yml --limit  
<host> -e enable_ollama=true
```

154.5 pyOpenSSL and pip in containers

Docker build installs docker/python-security-constraints.txt before application requirements:

- pip>=26.0, setuptools>=75.0, wheel>=0.45
- pyOpenSSL>=26.0.0, cryptography>=44.0.0

CI pip-audit runs against bridge + bacnet requirements with the same constraints.

154.6 TLS — expected vs production

Mode	Nessus SSL plugins	When to use
Caddy HTTP :80	No TLS plugins	Dev / HTTP-only VLAN
Caddy self- signed : 443	Medium: untrusted, self- signed, expiry	OT LAN encryption, lab
Enterprise CA cert on Caddy	Clean SSL plugins (if chain trusted)	IT mandates clean Nessus

See [TLS — enterprise CA]({{ "/security/tls-and-certs/" |
relative_url }}#enterprise-ca-on-caddy-edge).

154.7 Residual findings after remediation

Even with a patched host and loopback-only Ollama, IT may still see:

- **SSL** Medium on self-signed TLS (accepted for lab; document in risk register)
- **ICMP** Low (optional network block)
- **Container** plugins if Nessus scans Docker overlay networks — clarify scan scope with IT

154.8 Notes for IT / security team

1. Scan the **edge VM IP**, not individual container IPs, unless container CVE correlation is required.
2. Open-FDD **bridge :8765** should be **loopback-only**; LAN entry is **Caddy :80/:443**.
3. **BACnet UDP 47808** on commission is expected OT traffic — out of scope for web/plugin remediation.
4. Do not expose Ollama **11434** to the building LAN; agent chat is server-side only.
5. Kernel CVEs require **host reboot** — schedule with operations.
6. For authenticated web/API depth, see roadmap [Authenticated scanning]({{ "/security/authenticated-scanning/" | relative_url }}).

154.9 Repo-owned fixes (this document's release)

Item	Location
Container pip/pyOpenSSL pins	docker/python-security-constraints.txt, docker/Dockerfile
Ollama loopback systemd	infra/ansible/templates/ollama.service.j2
Host/exposure check scripts	scripts/security/check_*.sh, remediate_ubuntu_host.sh
Post-deploy Ollama bind warn	infra/ansible/scripts/post_deploy_check.sh
CI pip-audit + constraints	.github/workflows/ci.yml

155 AI agents

156 AI agents and MCP

- [AI agent context](#)({{ "/ai-agent-context/" | relative_url }}) — canonical map for deploy, drivers, model, rules, validation (**start here**)
- [MCP server](#)({{ "/ai/mcp-server/" | relative_url }}) — FastMCP tools over the operator bridge
- Skills under skills/openfdd-* -agent/ and skills/openfdd-mcp-server/
- Operator memory: workspace/MEMORY.md (see workspace/MEMORY.md.example)

Internal runbooks (not primary nav): [agent-skills/]({{ "/agent-skills/bench-validation-agent/" | relative_url }}).

157 Security

158 Security

LAN deployment security for the Operator Bridge and BACnet write guard. Open-FDD is for **trusted edge / OT LAN** — not direct public internet exposure.

Page	Topic
LAN hardening ({{ "/security/lan-hardening/" relative_url }})	relative_url }}
ZAP baseline (local bench) ({{ "/security/zap-baseline/" relative_url }})	relative_url }}
TLS and certificates ({{ "/security/tls-and-certs/" relative_url }})	relative_url }}
Linux host hardening ({{ "/security/linux-host-hardening/" relative_url }})	relative_url }}
Tenable / Nessus remediation ({{ "/security/tenable-remediation/" relative_url }})	relative_url }}
Authenticated scanning (roadmap) ({{ "/security/authenticated-scanning/" relative_url }})	relative_url }}

Page	Topic
Secrets and auth ({{ "/" security/secrets-auth/"	relative_url }}
BACnet write allowlists ({{ "/" security/bacnet-writes/"	relative_url }}
[Release & LAN scan cycle] ({{ "/" developer/security-testing/"	relative_url }}
Logging and audit ({{ "/" ops/logging/"	relative_url }}

159 API routes

160 API routes

REST API served by **openfdd-bridge** (default <http://127.0.0.1:8765>).
Production: Caddy on :80 proxies to the bridge.

OpenAPI: GET /docs and GET /redoc when the bridge runs.

Auth: JWT via POST /api/auth/login. Most routes require Authorization: Bearer <token>. Roles: viewer, operator, integrator, commission, agent, admin. BACnet writes require commission role + [write safety](#)({{ "/" bacnet/write-safety/" | relative_url })). Dev: OFDD_AUTH_DISABLED on loopback only.

WebSocket: WS /ws/dashboard — POST /api/auth/ws-ticket, then pass the ticket via Sec-WebSocket-Protocol: ofdd.ws, <ticket>. Query ?ticket= is dev-only when OFDD_WS_ALLOW_QUERY_TICKET=1. Tickets are short-lived and not interchangeable with the Bearer token.

160.1 Health & audit

Method	Path	Role	Description
GET	/health	public	Minimal liveness (ok, service, version, auth_required)
GET	/health/stack	auth	Stack traffic-light (verbose URLs/bind with OFDD_DEBUG_DIAGNOSTICS)

Method	Path	Role	Description
POST	/api/auth/ws-ticket	auth	Short-lived WebSocket ticket
GET	/api/audit/summary	auth	Audit counters
GET	/api/audit/events	auth	Audit log (query params)
GET	/api/audit/errors	auth	Recent API errors

*Exact public set depends on OFDD_AUTH_DISABLED and middleware.

160.2 Auth

Method	Path	Description
POST	/api/auth/login	Username/password → JWT
GET	/api/auth/me	Current user
GET	/api/auth/status	Auth mode / lockout hints

160.3 Rules & FDD

Method	Path	Role	Description
GET	/api/rules/saved	user	Rule index
POST	/api/rules/save	operator+	Create/update rule metadata
GET	/api/rules/saved/{id}/source	user	Python source
PUT	/api/rules/saved/{id}/source	operator+	Write .py file
GET	/api/rules/assignments	user	Point bindings
POST	/api/rules/bind	integrator+	Bind rule to point
POST	/api/rules/bindings	integrator+	Bulk bindings

Method	Path	Role	Description
POST	/api/rules/ batch	operator+	Run all enabled rules → fdd_results.json
GET/POST	/api/rules/ drafts	user	Draft rules

160.4 Rule Lab playground

Method	Path	Description
POST	/api/ playground/ lint	AST lint Python rule
POST	/api/ playground/ test-rule	Run apply_faults_arrow() on feather PyArrow window
POST	/api/ playground/ run-script	Execute script mode
GET	/api/ playground/ sample-frame	Sample DataFrame for editor

160.5 BRICK / data model

Method	Path	Role	Description
GET	/api/model/ sites	user	Site list
GET	/api/model/ tree	user	Equipment tree (SPARQL)
GET	/api/model/ graph	user	RDF graph fragment
GET	/api/model/ scope	user	Scoped query
GET	/api/model/ export	user	Export TTL/JSON
GET	/api/model/ commissioning- export	user	Full commissioning bundle (points + fdd_rule_ids + fdd_rules)
POST		integrator+	

Method	Path	Role	Description
	/api/model/commissioning-import		Bulk import; validate in UI dry-run first
GET	/api/model/health	user	Model point/equipment counts
GET	/api/model/ttl	user	TTL metadata
POST	/api/model/sync-ttl	integrator+	Regenerate TTL from JSON
POST	/api/model/import	integrator+	Import model payload
POST	/api/model/sites	integrator+	Create site
GET/POST	/api/model/bacnet-sync	integrator+	BACnet ↔ model sync state
GET	/api/model/fdd-query-presets	user	Saved FDD query presets
GET	/api/model/fdd-coverage	user	Rule coverage summary
POST	/api/model/sparql	user	SPARQL query (scoped)

160.6 Rule Lab (dashboard)

Method	Path	Role	Description
POST	/api/rules/lab/validate	operator+	Validate rule source
POST	/api/rules/lab/preview	operator+	Preview rule on historian window
POST	/api/rules/lab/compare	operator+	Compare two rule versions
POST	/api/rules/lab/lint-sql	operator+	DataFusion SQL safety lint
POST	/api/rules/lab/save	operator+	Save Rule Lab draft

Mounted at /api/rules/lab — see OpenAPI /docs.

160.7 Bench validation (read-only)

Method	Path	Role	Description
GET	/api/bench/health	operator+	Bench harness health
GET	/api/bench/mapping	operator+	Semantic cross-source mapping
GET	/api/bench/poll-status	operator+	BACnet + Niagara poll heartbeat
POST	/api/bench/validate/bacnet-vs-niagara	operator+	Dual-source equivalence check
POST	/api/bench/long-fdd/evaluate	operator+	Long FDD smoke evaluate (PyArrow/DataFusion)

See [Bench 5007 long FDD smoke](#)({{ "/operations/bench-5007-long-fdd-smoke/" | relative_url }}).

160.8 Niagara baskStream

Method	Path	Role	Description
GET	/api/niagara/health	read	Connector health
GET	/api/niagara/stations	read	Configured stations
POST	/api/niagara/stations/{id}/discover	read	Discover points
POST	/api/niagara/stations/{id}/poll/once	poll	One poll cycle

Method	Path	Role	Description
GET	/api/niagara/stations/{id}/poll/status	read	Poll worker status
GET	/api/niagara/driver/tree	read	Driver commissioning tree

Read-only by default. See `Niagara baskStream connector({{ “/niagara-baskstream-connector/” | relative_url }})`.

160.9 BACnet

Method	Path	Role	Description
GET	/config/bacnet	read	Commission URL / config
GET	/api/bacnet/commission/status	read	Commission agent health
GET	/api/bacnet/server/points	read	Server point table
GET	/api/bacnet/inventory	read	Discovered inventory
POST	/api/bacnet/whois	commission	Who-Is
POST	/api/bacnet/discover	commission	Discover devices
POST	/api/bacnet/read	commission	Read property
POST	/api/bacnet/read-multiple	commission	RPM read
POST	/api/bacnet/write	write	Supervisory write (gated)

Method	Path	Role	Description
POST	/api/bacnet/import-to-model	integrator	Inventory → BRICK
POST	/api/bacnet/driver/sync-discovery	commission	Sync driver tree
POST	/api/bacnet/poll/once	commission	Trigger poll cycle
GET	/api/bacnet/poll/status	read	Poll worker status
POST	/ingest/bacnet	read	Ingest samples into feather

Bind address: BACNET_BIND in commission env — see [BACnet network setup]({{ "/bacnet/network-setup/" | relative_url }}).
 Operator guide: [Discover and read](#)({{ "/bacnet/discover-read/" | relative_url }}).

PATCH | /api/bacnet/driver/point | commission | Enable poll + interval on point |
 PATCH | /api/bacnet/driver/device | commission | Enable poll for all points on device |
 PATCH | /api/bacnet/driver/device/remap | commission | Change instance and/or address |
 DELETE | /api/bacnet/driver/point/{point_id} | commission | Remove point from registry |
 DELETE | /api/bacnet/driver/device/{device_instance} | commission | Remove device |
 DELETE | /api/bacnet/driver/registry | commission | Clear CSVs + model sync |

160.10 Faults (check-engine)

Method	Path	Description
GET	/api/faults/catalog	Fixed fault codes
GET	/api/faults/status	GREEN/YELLOW/RED aggregate
GET	/api/faults/tree	Fault tree by equipment
GET		Code metadata

Method	Path	Description
	/api/faults/code/{code}	

160.11 Timeseries & sites

Method	Path	Description
GET	/api/timeseries/sites	Feather sites
GET	/api/timeseries/series	Series metadata
GET	/api/timeseries/plot	Plot payload
GET	/api/timeseries/readings	Raw readings
GET	/api/sites	Site list
GET	/api/sites/{site_id}/frame	Wide frame for site

160.12 Building & host

Method	Path	Description
GET	/api/building/status	Building summary
GET	/api/building/alerts	Active alerts
GET	/api/host/stats	CPU/mem/disk

160.13 Local agent (Ollama)

Prefix `/openfdd-agent`. Role `agent` for tool execution.

Method	Path	Description
GET	/openfdd-agent/context	Composed prompt context
GET	/openfdd-agent/tools	Tool manifest
POST	/openfdd-agent/tool	Execute tool (e.g. rules.save)
GET	/openfdd-agent/ollama/health	Ollama reachability
GET		

Method	Path	Description
GET	/openfdd-agent/building-insight	Check-engine narrative context
	/openfdd-agent/zone-temps	Zone temperature insight
	/openfdd-agent/chat	Chat completion (catalog-bound)

Optional host Ollama for building insight — not required for core FDD. Configure via compose profile or host service; see [Architecture overview]({{ "/architecture/overview/" | relative_url }}).

160.14 Modbus

Method	Path	Role	Description
GET	/api/modbus/driver/tree	operator+	Commissioning tree
GET	/api/modbus/poll/status	operator+	Poll worker status
POST	/api/modbus/poll/once	integrator+	Force poll cycle
POST	/api/modbus/read_registers	operator+	One-shot register read
POST	/api/modbus/read_and_store	operator+	Read + CSV + feather (source=modbus)
POST	/api/modbus/refresh	operator+	Re-read one register
PATCH	/api/modbus/register/poll	integrator+	Enable poll interval

See [Driver framework](#)({{ "/drivers/" | relative_url }}).

160.15 JSON API (HTTP/HTTPS)

Method	Path	Role	Description
GET	/api/json-api/env/status	operator+	

Method	Path	Role	Description
			Env var configured flags (no secret values)
POST	/api/json-api/presets/openweather	integrator+	Register 3-point OpenWeather bundle + optional poll
GET	/api/json-api/driver/tree	operator+	Endpoints grouped by host
GET	/api/json-api/poll/status	operator+	Poll worker status
POST	/api/json-api/poll/once	integrator+	Force poll cycle
POST	/api/json-api/request	operator+	One-shot GET/POST (no store)
POST	/api/json-api/read_and_store	operator+	Request + CSV + feather (source=json_api)
POST	/api/json-api/refresh	operator+	Re-fetch endpoint
PATCH	/api/json-api/endpoint/poll	integrator+	Enable poll interval
DELETE	/api/json-api/endpoint/{point_id}	integrator+	Remove endpoint

Outbound auth: auth_type = none | bearer | basic; optional verify_tls (default true). See [JSON API driver](#)({{ "/drivers/json-api/" | relative_url }}).

160.16 PyPI package (separate)

Library-only HTTP is **not** bundled. See [Python package](#)({{ "/appendix/python-package/" | relative_url }}) for open_fdd.arrow_runtime (Arrow rules offline).

160.17 Errors

JSON error bodies; stack traces hidden unless OFDD_DEBUG_TRACEBACKS=1. See [LAN hardening](#)({{ "/security/lan-hardening/" | relative_url }}).

161 Python package

162 Python package (open-fdd)

Install from PyPI (embeddable FDD runtime — not the Docker edge stack):

```
pip install open-fdd
pip install "open-fdd[datafusion]"    # optional DataFusion SQL
rule backend
pip install "open-fdd[analytics]"     # optional NumPy helpers
pip install "open-fdd[ml]"           # optional sklearn for
offline experiments
```

162.1 Modules

Module	Purpose
open_fdd.arrow_runtime	Default — apply_faults_arrow on PyArrow Tables, cookbook masks, column maps
open_fdd.playground	Rule Lab lint/compile helpers for Arrow rules

Retired in 3.0.1+: open_fdd.engine (YAML/pandas RuleRunner) is **not** shipped on PyPI. Use Operator Bridge Rule Lab or import rules from workspace/data/rules_py/.

162.2 When to use package-only

Scenario	Use
Lint/test Arrow rules offline	open_fdd.arrow_runtime + open_fdd.playground
Graph ML experiments (Layer B)	open-fdd[ml] in experiments/ (see issue #211)
Full building operator stack	Docker Operator Bridge

162.3 Versioning

Publish: `git tag vX.Y.Z` (or legacy `open-fdd-vX.Y.Z`) → GitHub Actions **Publish open-fdd to PyPI**. See [Release process](#) ({{ "/developer/release-process/" | relative_url }}).

```
import open_fdd
print(open_fdd.__version__)
```

162.4 Offline Arrow example

```
import pyarrow as pa
import pyarrow.compute as pc
from open_fdd.arrow_runtime import run_arrow_rule

code = '''
import pyarrow.compute as pc

def apply_faults_arrow(table, cfg, context=None):
    return pc.greater(table["SAT"], float(cfg["high"]))
'''

table = pa.table({"SAT": [70.0, 90.0, 88.0]})
result = run_arrow_rule(code, table, {"high": 85})
print(result.flagged_count)
```

API surface: `open_fdd/arrow_runtime` docstrings and [Arrow recipes] ({{ "/rule-cookbook/arrow-recipes/" | relative_url }}).

163 Configuration reference

164 Configuration reference

164.1 Bridge / auth

Variable	Default	Notes
OFDD_BRIDGE_HOST	127.0.0.1	0.0.0.0 for LAN
OFDD_AUTH_SECRET	—	Required for LAN
OFDD_AUTH_DISABLED	0	Localhost dev only
OFDD_INSECURE_LAN_DEV	0	Lab only with auth disabled

164.2 BACnet

Variable	Notes
BACNET_BIND	ip/mask:47808 in commission.env
OFDD_BACNET_WRITE_ENABLED	Default off — site-specific name may vary

164.3 Docker edge

Variable	Notes
OPENFDD_IMAGE_TAG	GHCR tag for Ansible deploy
openfdd_docker_pull_from_ghcr	Ansible host_var

Rule Lab Python rules use `rules_store.json + workspace/data/rules_py/*.py`. Legacy YAML schema (`docs/config_schema.json`) is archived — not used by Operator Bridge 3.0.1+.

165 Glossary

166 Glossary

Term	Definition
Operator Bridge	FastAPI service serving API + static dashboard
Rule Lab	UI and APIs for Arrow <code>apply_faults_arrow()</code> rules
Feather store	On-disk columnar historian under <code>workspace/data/feather_store/</code>
fdd_input	Brick tag linking a point to a rule binding role
Check-engine	Building-level GREEN/YELLOW/RED fault summary
Commission	BACnet discovery/read (and optional write) agent container
Poll driver	Scheduled BACnet RPM reads into historian
GHCR	

Term	Definition
	GitHub Container Registry — ghcr.io/ bbartling/openfdd-*

167 Workspace env files

168 Workspace env files

All live under workspace/. Copy from *.example templates; committed *.local files are gitignored.

File	Loaded by	Purpose
auth.env.local	run_local.sh, Docker compose, Ansible	JWT secret (OFDD_AUTH_SECRET), integrator/operator/agent passwords, OFDD_AUTH_DISABLED for localhost dev only
data.env.local	run_local.sh, bridge, feather maintain	Feather historian caps (OFDD_FEATHER_*), audit/error log rotation (OFDD_LOG_*), BACnet discovery mutation toggle
json_api.env.local	bridge, Ansible edge sync	API keys for JSON API driver \${ENV:VAR} substitution (e.g. OPENWEATHER_API_KEY)
ollama.env.local	run_local.sh, bridge	Ollama base URL, model name, RAM tier, GPU mode, timeouts — see Ollama and analytics ({{ "/operator-bridge/ollama-analytics/"
mcp.env.local	run_local.sh, MCP sidecar	Enable MCP RAG REST (OFDD_MCP_*), index path
caddy.env.local	run_local.sh, Ansible edge	Reverse proxy mode (http / tls / off), TLS CN, port overrides
pentest.env.local	pentest_production_stack.sh	

File	Loaded by	Purpose
		Production-like LAN scan stack: CORS, auth, passive BACnet defaults

168.1 Ansible / edge extras

Path	Purpose
infra/ansible/secrets/<host>.env.local	SSH deploy credentials, GHCR pull tokens, site-specific BACnet bind — maintainers only

168.2 Related docs

- [Secrets and auth](#)({{ "/security/secrets-auth/" | relative_url }}) — required production variables
- [Logging and audit](#)({{ "/ops/logging/" | relative_url }}) — OFDD_LOG_* detail
- [JSON API driver](#)({{ "/drivers/json-api/" | relative_url }}) — \${ENV:VAR} pattern
- [Configuration reference](#)({{ "/appendix/configuration/" | relative_url }}) — bridge runtime flags not in env files

169 Appendix

170 Appendix

Reference material for integrators and library users.

Page	Content
API routes ({{ "/appendix/bridge_api/" relative_url }})	relative_url }}
Python package ({{ "/appendix/python-package/" relative_url }})	relative_url }}
Configuration reference ({{ "/appendix/configuration/" relative_url }})	relative_url }}

Page	Content
Workspace env files ({{ "/appendix/workspace-env-files/"	
Glossary ({{ "/appendix/glossary/"	relative_url }}

171 GL36 lab site (Acme)

172 GL36 lab site (Acme)

Lab note only. This documents a maintainer **example edge host** (site acme, building vm-bbartling) used for Guideline 36 supervisory FDD development. Replace inventory host names, IPs, and BACnet ranges for your site.

Reference for **ASHRAE Guideline 36** supervisory monitoring on a live lab edge. Rule code lives in workspace/data/rules_py; commissioning uses **Arrow constants** (no config.json).

Trim & respond Niagara reference: [README_TRIM_RESPOND](#).

172.1 BACnet poll scope

Device filter (infra/ansible/scripts/acme_trim_devices.sh):

Range	Equipment
1-100	JCI VMA/VAV
1100	RTU-01 (AHU)
1002	Hot water plant
11000-13000	Trane UC210 VAV

Poll interval: **60 s**. Commission from control machine:

```
cd infra/ansible
POLL_INTERVAL=60 ./scripts/acme_commission_gl36.sh
```

Points land in edge_backup/local/acme/vm-bbartling/points.csv for Ansible sync.

172.2 Example FDD rules (Arrow)

172.2.1 Duct static pressure high (AHU)

```
"""AHU duct static high – GL36 trim advisory."""

import pyarrow.compute as pc

VALUE_COLUMN = "duct-static"
HIGH_INWC = 1.20
LOOKBACK_HOURS = 3

def _kit_lookback_stats(table, *, hours=None):
    h = hours if hours is not None else LOOKBACK_HOURS
    ts = pc.cast(table["timestamp"], "timestamp[us, UTC]")
    tmin, tmax = pc.min(ts).as_py(), pc.max(ts).as_py()
    span_h = (tmax - tmin).total_seconds() / 3600.0 if tmin and
tmax else 0.0
    print(f"lookback={h}h rows={table.num_rows} start={tmin}
stop={tmax} span={span_h:.2f}h")

def apply_faults_arrow(table, cfg, context=None):
    _kit_lookback_stats(table)
    return pc.greater(pc.cast(table[VALUE_COLUMN], "float64"),
HIGH_INWC)
```

172.2.2 SAT too cold vs setpoint

```
"""AHU SAT too cold vs setpoint."""

import pyarrow.compute as pc

SAT_COLUMN = "sa-t"
SP_COLUMN = "sa-t-sp"
COLD_DELTA_F = 5.0

def apply_faults_arrow(table, cfg, context=None):
    sat = pc.cast(table[SAT_COLUMN], "float64")
    sp = pc.cast(table[SP_COLUMN], "float64")
    return pc.less(pc.subtract(sat, sp), -COLD_DELTA_F)
```

172.2.3 Site rule stubs in the repo

Rule file	Use
bench_stat_zn-t_flatline_1h.py	Zone temp flatline —

Rule file	Use
	bind ZN-T per VAV
acme_duct_static_flatline_1h_gl36_duct_t_r_input.py	RTU duct static flatline
oat_vs_web_spread_1h.py	Local OAT vs OpenWeather JSON API

172.2.4 Local OA-T vs web weather (JSON API)

1. Control machine: workspace/json_api.env.local with OPENWEATHER_API_KEY
2. JSON API tab → **OpenWeatherMap** preset → **Register** (default poll **30 min**)
3. Bind BACnet local OAT in the model (oa-t historian column)
4. Enable oat_vs_web_spread_1h.py in Rule Lab — flags when |oa-t - web-oat-t| > 8 °F

172.3 Deploy / upgrade (Ansible, this lab only)

```
cd infra/ansible
OPENFDD_IMAGE_TAG=latest ./deploy.sh docker --limit
<inventory_host> -e enable_bacnet_poll_driver=true
```

Full UI + image upgrade from control machine:

```
OPENFDD_IMAGE_TAG=latest ./scripts/upgrade_edge_full.sh --limit
<inventory_host>
infra/ansible/scripts/post_deploy_check.sh --limit
<inventory_host> --full
```

Do **not** rsync dev auth.env.local to the edge (deploy_sync_auth: false in private host_vars). Regenerate credentials on the edge host if login fails after upgrade.

172.4 AI-assisted data modeling (lab workflow)

1. BACnet poll running (~340 GL36 points @ 60 s on this lab host).
2. **Model & assignments** → export commissioning JSON for LLM-assisted binding.
3. Import returned JSON via commissioning import.

4. Pin FDD rules on ZN-T, DA-T, duct-static, OAT, etc. — export shows readable names in fdd_rules_linked.

Model seed: workspace/data/acme_gl36_model.json.

173 Examples & lab notes

174 Examples & lab notes

Site-specific commissioning notes, GL36 examples, and maintainer lab workflows. These pages are **not** required for a generic edge deployment.

Page	Description
GL36 lab site (Acme)({{ "/examples/acme-gl36-lab/" relative_url }})	

For production IT operators, start with [Quick Start](#)({{ "/quick-start/" | relative_url }}) and [Operations](#)({{ "/ops/" | relative_url }}).

175 Paired FDD smoke (bench + Acme)

176 Paired FDD smoke

Hardcoded cross-site validation: **bensserver bench 5007** and **Acme** run the **same schedule** with mid-test fault-parameter toggles. PyArrow and DataFusion SQL rules must agree on flagged row counts.

176.1 What is tested

Site	Rule	Normal phase	Blatant phase
Bench (demo)	stat_zn-t bounds on	65-75 °F	99-100 °F

Site	Rule	Normal phase	Blatant phase
	BACnet 5007 + Niagara bench9065		
Acme	Local oa-t vs web-oat- t spread	$\leq 10\text{ }^{\circ}\text{F}$	$\leq 0.001\text{ }^{\circ}\text{F}$

Rule IDs are fixed in open_fdd/validation/paired_fdd_contract.py.
Each site has **arrow** and **datafusion_sql** variants.

176.2 Fault confirmation (5 minutes)

All paired smoke rules use:

```
        {"min_elapsed_minutes": 5, "min_true_rows": 5, "poll_interval_s":  
60}
```

A condition must stay true for **~5 minutes** before it counts as a confirmed fault. See [Fault confirmation](#).

176.3 Modes (hardcoded)

Mode	Duration	Toggle interval
tryout	6 min	3 min
short	30 min	15 min
standard	2 h	every 15 min
overnight	12 h	every 15 min

Toggles alternate **normal** ↔ **blatant** fault parameters via the rules API (same as an operator or AI agent adjusting thresholds mid-run).

176.4 Run detached (required for in-depth runs)

Bench **5007 + Acme** paired smoke runs for **30 minutes to 12 hours**. Always start **short**, **standard**, and **overnight detached** — from a plain terminal or via `--detached` — so Cursor, SSH, or IDE disconnects do not kill the harness.

Recommended (wrapper re-invokes itself under `nohup`):

```

OPENFDD_LIVE_ACME=1 ./scripts/smoke_paired_fdd_harness.sh --short
--detached
OPENFDD_LIVE_ACME=1 ./scripts/smoke_paired_fdd_harness.sh --
standard --detached
OPENFDD_LIVE_ACME=1 ./scripts/smoke_paired_fdd_harness.sh --
overnight --detached

```

Logs: /tmp/paired_fdd_smoke_<mode>_*.log · PID file: /tmp/paired_fdd_smoke_<mode>.pid · tail -f the log to watch progress.

Manual nohup (equivalent):

```

nohup env OPENFDD_LIVE_ACME=1 ./scripts/
smoke_paired_fdd_harness.sh --overnight \
    > /tmp/paired_fdd_overnight.log 2>&1 &
echo $! > /tmp/paired_fdd_overnight.pid

```

--tryout (6 min) may run attached for quick dev checks.

176.5 Run

Prereqs: local stack on :8765, Acme edge on matching GHCR image, OPENFDD_LIVE_ACME=1.

```

OFDD_SKIP_UI_BUILD=1 ./scripts/run_local.sh start
OPENFDD_IMAGE_TAG=3.1.5 ./scripts/upgrade_edge_site.sh --limit
acme_vm_bbartling

```

```

OPENFDD_LIVE_ACME=1 ./scripts/smoke_paired_fdd_harness.sh --
tryout          # attached OK
OPENFDD_LIVE_ACME=1 ./scripts/smoke_paired_fdd_harness.sh --short
--detached
OPENFDD_LIVE_ACME=1 ./scripts/smoke_paired_fdd_harness.sh --
standard --detached
OPENFDD_LIVE_ACME=1 ./scripts/smoke_paired_fdd_harness.sh --
overnight --detached

```

scripts/smoke_sites_parity.sh delegates to this harness.

176.6 Reports

- reports/paired_fdd_smoke_validation.md
- reports/paired_fdd_smoke_validation.json
- reports/site_parity_smoke.json (UI bundle + API revision parity)

176.7 Pass criteria

- Site parity smoke passes (matching UI hash, no 401 on health endpoints).
- No PyArrow vs SQL flagged-count mismatch per cycle.
- No save/batch API errors in either site loop.

Blatant-phase fault counts may be zero on Acme when the historian is still on demo fallback — check feather ingest and live OAT columns before overnight runs.

177 Arrow-native runtime

178 Arrow-native runtime

Open-FDD 3.0 executes Rule Lab rules on **PyArrow tables** end to end.

```
feather_store.read_site_table()
→ fdd_runner / playground.run_arrow_table()
→ apply_faults_arrow(table, cfg, context)
→ pyarrow.compute masks
```

178.1 Authoring contract

```
import pyarrow.compute as pc

def apply_faults_arrow(table, cfg, context=None):
    return pc.greater(table["zone_temp"], cfg["max_zone_temp"])
```

Cookbook helpers: `open_fdd.arrow_runtime.cookbook` (flatline, spread, OOB, after-hours fan).

v1 contract: `[ArrowRuleResult]({{ "/rule-authoring/arrow-rule-contract/" | relative_url }})` — input `pa.Table`, output boolean mask, confirmation applied by backend.

Script-mode analytics rules receive `table` (PyArrow) and `cfg` in the sandbox — not pandas DataFrames.

178.2 PyArrow-only policy (edge + Rule Lab)

Allowed	Forbidden
pyarrow (pa), pyarrow.compute (pc)	import pandas, pd.DataFrame, to_pandas()
open_fdd.arrow_runtime.cookbook helpers	import numpy for rule logic
Script mode globals: table, cfg, out	Legacy df DataFrame scripts

Rule Lab **lint** (POST /api/playground/lint) and rule **save** reject pandas patterns with agent-facing errors, e.g. *use table (PyArrow), not df*.

Fault rules: `apply_faults_arrow(table, cfg, context=None)`. Analytics scripts: top-level code on `table/cfg`, set `out = {"events": [...], "metrics": {...}}`.

178.3 Package layout

Module	Role
<code>open_fdd.arrow_runtime.backend</code>	Execute rule code, batch chunks
<code>open_fdd.arrow_runtime.cookbook</code>	Shared fault masks
<code>open_fdd.arrow_runtime.windows</code>	Rolling min/max, consecutive-true
<code>open_fdd.playground.arrow_templates</code>	Rule Lab starter templates

179 Release process

180 Release process

Open-FDD has **two publish paths**:

Artifact	Trigger	Registry
PyPI open-fdd	Git tag vX.Y.Z (or legacy open-fdd-vX.Y.Z)	pypi.org/project/open-fdd
Docker edge stack		

Artifact	Trigger	Registry
	Same release tag (or manual workflow)	ghcr.io/bbartling/ openfdd-*

Do **not** publish from ordinary branch pushes. Merge to master, bump version, tag, push tag.

180.1 1. Prepare version

```
git checkout master
git pull --ff-only
# Edit pyproject.toml + open_fdd/__init__.py → same X.Y.Z
python scripts/release/check_version.py
```

180.2 2. Merge and tag

```
git tag -a v3.0.30 -m "open-fdd 3.0.30"
git push origin v3.0.30
```

Tag push runs:

- [.github/workflows/publish-open-fdd.yml](#) — build, test, twine check, PyPI via **Trusted Publishing**
- [.github/workflows/docker-publish.yml](#) — GHCR images with tags 3.0.30, 3.0, latest

Legacy tag open-fdd-v3.0.30 is still accepted during transition.

180.3 3. PyPI Trusted Publishing setup (one-time)

On [pypi.org](#) → project **open-fdd** → Publishing → **Add a new trusted publisher**:

Field	Value
PyPI project name	open-fdd
Owner	bbartling
Repository	open-fdd
Workflow name	Publish open-fdd to PyPI
Environment	pypi (optional; enables approval gate)

No long-lived API token in the repo.

180.4 4. Verify release

```
pip install open-fdd==3.0.30
python -c "import open_fdd; print(open_fdd.__version__)"

docker pull ghcr.io/bbartling/openfdd-bridge:3.0.30
docker manifest inspect ghcr.io/bbartling/openfdd-bridge:3.0.30
```

180.5 5. Manual workflow_dispatch

- **PyPI:** Publish open-fdd to PyPI with dry_run=true (default) — build/test only
- **Docker:** Publish Docker images to GHCR — publishes pyproject.toml version + minor alias + latest (optional image_tag override)

180.6 Package vs Docker

See `PyPI package({{ "/developer/pypi-package/" | relative_url }})` and `[Docker images]({{ "/ops/docker-images/" | relative_url }})`.

181 PyPI package

182 PyPI package (open-fdd)

182.1 What it is

Embeddable **Arrow-native FDD compute** for consultants, cloud pipelines, and test benches:

- Lint and test `apply_faults_arrow(table, cfg, context)` rules
- Run rules on PyArrow Tables, Feather, or Parquet
- Optional NumPy analytics helpers (`pip install "open-fdd[analytics]"`)

182.2 What it is not

The PyPI wheel does **not** include:

- Operator Bridge / FastAPI app
- React dashboard

- BACnet commission/poll service
- MCP server
- Ansible / Tailscale deploy tooling

Use **GHCR Docker images** for the full edge stack.

182.3 Install

```

pip install open-fdd
pip install "open-fdd[analytics]" # optional NumPy helpers
pip install "open-fdd[ml]"       # offline sklearn experiments

```

182.4 CLI

```

open-fdd version
open-fdd lint-rule path/to/rule.py
open-fdd test-rule path/to/rule.py --input sample.feather --
config cfg.json
open-fdd run-arrow path/to/rule.py --input in.feather --output
out.feather
open-fdd validate-rule-pack ./rules

```

182.5 Rule contract

```

def apply_faults_arrow(table, cfg, context=None):
    # return PyArrow bool mask, length == table.num_rows
    ...

```

Use `open_fdd.arrow_runtime.run_arrow_rule` for structured ArrowRuleResult (counts, errors, preview).

182.6 Modules shipped on PyPI

Module	Purpose
<code>open_fdd.arrow_runtime</code>	Rule execution, cookbook masks, column maps
<code>open_fdd.playground</code>	Lint/compile helpers
<code>open_fdd.faults</code>	Fault catalog YAML
<code>open_fdd.schema</code>	Result schemas

`open_fdd.engine` (pandas/YAML) is **not** in the wheel.

182.7 Examples

Repo examples/ — [arrow_minimal](#), Feather batch, generic IoT pipeline.

182.8 Local validation

```
pip install -e ".[test,dev,analytics]"
python scripts/release/check_version.py
pytest open_fdd/tests -q
python -m build && twine check dist/*
```

183 MCP server

184 Open-FDD MCP server

FastMCP agent interface over the **operator bridge** — not a parallel FDD stack.

184.1 Modes

Mode	OFDD_MCP_MODE	Site resolution
Edge	edge	OPENFDD_BRIDGE_BASE_URL (default http://127.0.0.1:8765)
Portfolio	portfolio	portfolio/sites.json + optional site_id per tool

RCx Central (:8050 Dash, :8060 API) is a **separate HTTP stack** — not the MCP server. Agents doing RCx overview, FDD preset tables, or DOCX reports should call Central API (/api/central/*) or use the Dash; see [RCx Central agent guide](#).

Acme production edge runs **without** MCP (enable_mcp: false). Run MCP centrally and call http://100.122.106.124 via Tailscale, or use RCx Central with Edge Connections registry.

184.2 Transport

Transport	Env	Use
Streamable HTTP	OFDD_MCP_TRANSPORT=streamable-http (default in Docker)	http://127.0.0.1:8090/mcp
Stdio	OFDD_MCP_TRANSPORT=stdio	Cursor / Claude Desktop

Legacy bridge doc search: POST /tools/search_docs on :8090 (unchanged).

184.3 Human approval

These tools require human_approved=true:

- save_rule
- apply_fdd_tuning
- run_fdd_batch

MCP does not command BACnet writes — only Open-FDD bridge APIs.

184.4 Client examples

Cursor (~/.cursor/mcp.json):

```
{
  "mcpServers": {
    "open-fdd": {
      "command": "python",
      "args": ["-m", "mcp_server.run"],
      "env": {
        "PYTHONPATH": "/path/to/open-fdd/workspace:/path/to/open-fdd/workspace/api",
        "OPENFDD_REPO_ROOT": "/path/to/open-fdd",
        "OFDD_MCP_TRANSPORT": "stdio",
        "OFDD_MCP_MODE": "portfolio",
        "OFDD_PORTFOLIO_SITES_PATH": "/path/to/open-fdd/portfolio/sites.json"
      }
    }
  }
}
```

HTTP (bensserver dev stack):

```
docker compose -f docker/compose.dev.yml up -d mcp-rag
curl -fsS http://127.0.0.1:8090/health
```

184.5 Site registry example

```
{
  "sites": [
    {
      "site_id": "acme",
      "name": "Acme GL36 Lab",
      "base_url": "http://100.122.106.124",
      "username": "integrator"
    }
  ]
}
```

Store passwords in env or OS keychain — not in git.

184.6 RCx Central (not MCP)

Service	Default URL	Agent docs
Central API	http://127.0.0.1:8060	central-api.md
RCx Dash	http://127.0.0.1:8050	rcx-central-dash-agent.md

MCP portfolio_rollup hits Edge /api/building/portfolio-rollup per site. RCx GET /api/central/overview/{site_id} adds Dash KPIs, fault pie (with [short fault descriptions](#)), and mechanical narrative from FDD presets.

184.7 Fault code labels (agents)

Use fixed lookup — do not paraphrase codes in UI copy:

- Docs: [fault-codes/short-lookup.md](#)
- Python: portfolio/central/fault_code_lookup.py
- Edge API: GET /api/faults/catalog

184.8 Doc RAG refresh

After editing docs/ consumed by MCP search:

```
./scripts/build_mcp_rag_index.sh
```

- workspace/mcp_server/ — FastMCP tools, resources, prompts

- workspace/mcp_rag/retrieval.py — RAG index (rebuild separately)
- Docker image openfdd-mcp-rag — compatibility name; runs unified server

184.9 Module layout

185 Adr Datafusion Rust Ready Rule Backend

186 ADR: DataFusion as optional Rust-ready rule backend

186.1 Status

Accepted — Open-FDD 3.1.0

186.2 Context

Open-FDD v3 executes FDD rules over **Apache Arrow** tables. The primary contract is:

```
apply_faults_arrow(table, cfg, context=None) -> BooleanArray |
ChunkedArray
```

Operators and integrators author rules in Python/PyArrow. BACnet polling, bridge APIs, dashboard, MCP, and Docker deployment all consume normalized ArrowRuleResult payloads.

We want a migration path toward Rust/DataFusion components **without** rewriting the project in Rust or weakening the PyArrow contract.

186.3 Decision

Add an **optional** second rule backend:

Backend	Entry
arrow	<code>apply_faults_arrow(...)</code> (default, first-class)
<code>datafusion_sql</code>	Restricted SELECT over registered telemetry

DataFusion is Apache Arrow-native and implemented in Rust. The Python `datafusion` package gives Open-FDD a clean seam where a future Rust service can replace or accelerate the wrapper while preserving the same result schema.

186.4 Why

- Same Arrow memory model end-to-end
- SQL expressions are easy to read for simple threshold/CASE rules
- Compare mode can prove SQL masks match PyArrow before migration
- Optional extra — normal `pip install open-fdd` unchanged

186.5 Non-goals (this milestone)

- No Rust rewrite
- No replacing PyArrow rules
- No pandas on edge runtime
- No arbitrary SQL console (injection-safe subset only)
- No changes to BACnet, bridge auth, or MCP unless required for tests

186.6 Future path

Phase A — PyArrow + optional DataFusion Python backend (this ADR)

Phase B — Shared Arrow rule result contract across batch, Rules Lab, and reporting

Phase C — Optional Rust DataFusion crate/service replaces Python wrapper

Phase D — ML/graph analytics consume Arrow/Parquet outputs without changing the FDD rule contract

186.7 Consequences

- CI adds a job with `pip install -e ".[test,dev,datafusion]"` for backend validation

- Rule store persists sql and fault_column separately from Python code
- Rules Lab gains backend selector; SQL executes server-side only

187 Adr Rust Ready Arrow Fdd Contract

188 ADR: Rust-ready Arrow FDD contract

188.1 Status

Accepted

188.2 Context

Open-FDD runs supervisory FDD over historian telemetry from BACnet, Niagara, JSON API, and future connectors. PyArrow is the primary rule path; DataFusion SQL is an optional backend for SQL-authored rules and Rust migration prep.

188.3 Decision

1. **PyArrow remains primary.** Rules implement `apply_faults_arrow(table, cfg, context=None)` and return Arrow boolean masks normalized to `ArrowRuleResult`.
2. **DataFusion SQL is optional.** Install via `open-fdd[datafusion]`. Rules declare `backend: datafusion_sql`, execute server-side only, read the registered telemetry Arrow table, and normalize to the same `ArrowRuleResult` shape.
3. **Common historian contract.** Drivers ingest timestamp, `site_id`, point columns, and `metadata.source` into Feather shards. Point metadata (`fdd_input`, `cross_source_semantic`, `equipment_id`) drives rule binding — not vendor-specific code in rule engines.

4. **Future Rust.** A Rust execution service may replace the Python Arrow/DataFusion wrappers behind the same table-in, boolean-mask-out contract. UI, commissioning, and driver orchestration stay in Python until migrated.
5. **Drivers must not bypass the contract.** No connector may emit a custom FDD result shape or row-loop rule path for production batch evaluation.
6. **No browser-side SQL.** DataFusion runs in the bridge process only.
7. **No pandas row-loop runtime on edge.** PyArrow columnar masks only for production FDD.
8. **Confirmation.** May use correctness-first Python streak loops today; future vectorized/window implementations must keep the same raw vs confirmed mask contract.

Authoring guide: [Rule authoring \(v1\)](#)(`{{ "/rule-authoring/" | relative_url }}`) · [\[Arrow rule contract\]](#)(`{{ "/rule-authoring/arrow-rule-contract/" | relative_url }}`).

188.4 Consequences

- Rule Lab, batch FDD, and validation smokes share one mask contract.
- Confirmation window filters apply after raw masks for all backends.
- Vectorizing confirmation (window functions / Arrow kernels) is planned; correctness-first Python streak loops are acceptable for bench scale today.

189 Bench Validation Agent

190 Bench validation agent (local bensever)

Local bench only. Read-only.

190.1 Topology

Item	Value
Open-FDD host	benserver
BACnet device	instance 5007 , router 2000:7 (MS/TP)
Niagara station	https://192.168.204.11
Niagara BACnet folder	slot:/Drivers/BacnetNetwork/BENS\$20BENCHTEST\$20BOX/points
Password env	OPENFDD_NIAGARA_ADMIN_PASSWORD (never commit)

/stream/health returns **302** before login (reachability). **200** after SCRAM.

190.2 One-command validation

```
export OPENFDD_NIAGARA_ADMIN_PASSWORD='...'  
python3 scripts/bootstrap_bench_dual_source.py  
python3 scripts/bench_validate_bacnet_vs_niagara.py --write-report
```

190.3 API tools (bridge must be running)

Action	Endpoint
Bench health	GET /api/bench/health
Cross-source validate	POST /api/bench/validate/bacnet-vs-niagara
Poll status	GET /api/bench/poll-status
Poll cadence	GET /api/bench/poll-cadence
Niagara test	POST /api/niagara/stations/bench9065/test
Niagara discover	POST /api/niagara/stations/bench9065/discover
Start/stop Niagara poll	POST .../poll/start / .../poll/stop
BACnet driver tree	GET /api/bacnet/driver/tree

190.4 MCP / agent notes

- Browser → Open-FDD API only (no direct Niagara WebSocket from React).

- Preserve Niagara ORDs exactly (\$20, \$2d, \$23). PowerShell: single-quote ORDs.
- Default Niagara discovery excludes proxyExt (10 points, not 20).
- Branch: fix/3.0.34-bugs; push and watch PR #300 CI + CodeRabbit.

190.5 Overnight

`python3 scripts/run_overnight_bench_smoke.py`

See [overnight-bench-smoke.md](#) and [bench-bacnet-vs-niagara.md](#).

191 Rcx Central Dash Agent

192 RCx Central Dash — agent guide

For Cursor/Codex agents working on **OpenFDD RCx Central** (portfolio/) — analyst Dash + Central API over read-only Edge REST.

192.1 Runtime stack (benserver / analyst workstation)

Service	Script	Port	Bind
RCx Central API	<code>./scripts/run_central_api.sh</code>	8060	0.0.0.0 (OPENFDD_CENTRAL_API_HOST)
RCx Central Dash	<code>./scripts/run_portfolio_dash.sh</code>	8050	0.0.0.0 (OPENFDD_RCX_DASH_HOST)

Env: `OPENFDD_CENTRAL_API_URL=http://127.0.0.1:8060` (Dash → API).
 LAN access: `sudo ./scripts/open_rcx_central_lan_ports.sh` (UFW 8050+8060).

Not the operator bridge (:8765) — RCx Central polls Edge sites via Tailscale/LAN URLs in `portfolio/config/sites.json`.

192.2 Dash UI (2026-06)

Single **Dashboard** tab (faults, building summary, FDD rules, preset buttons, RCx report) + **Edge Connections** tab.

Area	Data source
Fault pie + legend	fault_code_lookup.py + live/CSV faults
Building summary	build_mechanical_narrative() → Edge FDD presets
FDD rules table	GET /api/central/fdd-analytics/{site_id}
FDD preset buttons	GET /api/central/fdd-preset/{site_id}/{preset_id} → same as Edge Data Model tab
P8 overrides	KPI count always; chart only when overrides present
RCx DOCX	POST /api/central/rcx/report

192.3 Edge parity (Data Model tab)

RCx Central must **not** scrape React. Use Edge REST:

- GET /api/model/fdd-query-presets + GET /api/model/fdd-query-presets/{id}
- GET /api/model/sparql/predefined + POST /api/model/sparql
- GET /api/model/health, GET /api/model/tree

Preset ids: rules_to_equipment, rules_to_sensors, ahus_vavs_zones, missing_rule_bindings, orphan_points, rule_coverage_by_equipment_type, etc. — see portfolio/central/fdd_preset_catalog.py.

192.4 BRICK equipment typing (common bug)

Acme and many sites store types in **brick_type** (AHU, VAV), not equipment_type.

- Count/classify with portfolio/central/equipment_classify.py (mirrors workspace/api/openfdd_bridge/equipment_classify.py).
- TTL sync maps short types → Brick classes (AHU → Air_Handling_Unit, VAV → Variable_Air_Volume_Box) in ttl_service.py.
- After model.json edits on Edge: **sync TTL** before SPARQL HVAC buttons return counts.
- Packaged rooftop serving VAVs: prefer **brick_type: AHU** and display name AHU 01 (not Rtu 01) when it is a full air handler.

192.5 Fault codes (stable labels)

Layer	Path
Docs table	docs/fault-codes/short-lookup.md
Dash lookup	portfolio/central/fault_code_lookup.py
Edge catalog	GET /api/faults/catalog · workspace/api/openfdd_bridge/fault_catalog.py

Never invent codes. Letter suffix only (VAV-C, not VAV-03).

192.6 Central API routes (agent smoke)

```
curl -s http://127.0.0.1:8060/health
curl -s http://127.0.0.1:8060/api/central/overview/acme
curl -s "http://127.0.0.1:8060/api/central/fdd-analytics/acme?hours=24"
curl -s http://127.0.0.1:8060/api/central/fdd-preset/acme/ahus_vavs_zones
```

192.7 Tests

```
pytest tests/portfolio/ tests/scripts/
test_rcx_overnight_patch_cycle.py
pytest tests/workspace_bridge/test_fdd_query_presets.py
```

192.8 PRs (typical split)

- **Edge bridge + TTL + model fixes** → fix/edge-dashboard-bridge (#299)
- **RCx Dash / portfolio only** → feature/rcx-central-overview-ui (#298)

192.9 Related

- Overnight patch cycle
- Model queries
- MCP server — portfolio mode vs RCx Central HTTP API

193 Rcx Central Overnight Patch Cycle

194 RCx Central overnight patch-cycle (agent runbook)

See also: [RCx Central Dash agent guide](#) for UI/API modules and BRICK typing.

Mission: validate **OpenFDD RCx Central** against local services and (optionally) live **ACME Edge** read-only, up to **10 patch cycles** with **2-hour** spacing.

194.1 Safety (non-negotiable)

- **Read-only** on BACnet and live BAS equipment.
- Never commit secrets, .env, tokens, or raw building dumps.
- Merge, publish, and deploy only when RCX_ALLOW_MERGE=1, RCX_ALLOW_PUBLISH=1, or RCX_ALLOW_DEPLOY=1 and the owner authorizes.

194.2 One patch cycle

1. `git pull --ff-only` on feature/rcx-central-overview-ui (or follow-up branch).
2. `gh pr checks 298` and `gh run view <id> --log-failed` for failures.
3. Classify CodeRabbit comments: must-fix / nice-to-have / false positive.
4. Run tests: `python3 -m pytest tests/portfolio tests/workspace_bridge -q`.
5. Start RCx Central: `./scripts/run_central_api.sh`, `./scripts/run_portfolio_dash.sh` (bind 0.0.0.0; LAN: `sudo ./scripts/open_rcx_central_lan_ports.sh`).
6. Run `python3 scripts/rcx_central_overnight_patch_cycle.py` (try-out or overnight env).
7. Patch bugs, commit, push, confirm CI green.
8. Write `reports/rcx_central_overnight_logs/cycle_NN.md`.

194.3 GH Actions

```
gh pr checks 298
gh run list --branch feature/rcx-central-overview-ui --limit 10
gh run view <RUN_ID> --log-failed
```

Fix order: unit tests → operator-bridge → docs → Docker supervisor.

194.4 RCx Central local

```
./scripts/run_central_api.sh # :8060
OPENFDD_CENTRAL_API_URL=http://127.0.0.1:8060 ./scripts/
run_portfolio_dash.sh # :8050
curl -s http://127.0.0.1:8060/health
curl -s -o /dev/null -w '%{http_code}\n' http://127.0.0.1:8050/
```

Edge connections: save URL + credentials on **Edge Connections** tab (local portfolio/config/).

194.5 Live ACME (gated)

```
export OPENFDD_LIVE_ACME=1
export RCX_EDGE_SITE=acme
export RCX_CENTRAL_API_URL=http://127.0.0.1:8060
```

Requires ACME credentials in local registry — never log passwords.

194.6 Try-out vs overnight

Mode	RCX_PATCH_CYCLES	RCX_CYCLE_SLEEP_MINUTES
Try-out	2	0
Overnight	10	120

194.7 Rev bump / deploy

Only when tests and CI pass and owner sets RCX_ALLOW_PUBLISH=1 / RCX_ALLOW_DEPLOY=1. Use existing scripts/upgrade_edge_full.sh — do not invent new deploy paths.

194.8 Branch cleanup after merge

```
git checkout master && git pull --ff-only
git branch -d feature/rcx-central-overview-ui
git push origin --delete feature/rcx-central-overview-ui
```

195 Bench Bacnet Vs Niagara

196 BACnet direct vs Niagara bench validation

Local **benserver** read-only cross-check: same physical BACnet device via two paths.

196.1 Topology

```
BENS BENCHTEST BOX (BACnet device 5007, MS/TP 2000:7)
├─ Open-FDD native BACnet poll (commission agent → samples.csv →
feather source=bacnet)
└─ Niagara Windows station → baskStream WebSocket → Open-FDD
Niagara driver (source=niagara_baskstream)
```

196.2 Quick start

```
export OPENFDD_NIAGARA_ADMIN_PASSWORD='...' # never commit
python3 scripts/bootstrap_bench_dual_source.py
python3 scripts/bench_validate_bacnet_vs_niagara.py --write-report
```

Or via API (bridge running):

```
curl -X POST http://127.0.0.1:8765/api/bench/validate/bacnet-vs-
niagara \
-H "Authorization: Bearer $TOKEN" -H "Content-Type: application/
json" \
-d '{"write_report": true}'
```

196.3 Mapping config

Edit workspace/data/bench_bacnet_vs_niagara.yaml for semantic point mapping, tolerances, and Niagara ORDs (\$20 / \$2d preserved).

196.4 Brick model

Import dual-source semantics:

```
# Included in bootstrap; or manually:
python3 -c "
import json, os, sys
from pathlib import Path
REPO = Path('.').resolve()
sys.path.insert(0, str(REPO/'workspace/api'))
os.environ['OFDD_DESKTOP_DATA_DIR'] = str(REPO/'workspace/data')
from openfdd_bridge.model_service import ModelService
from openfdd_bridge.ttl_service import TtlService
ModelService().import_json(json.loads((REPO/'workspace/data/
bench_dual_source_model.json').read_text()), replace=False)
TtlService().sync()
"
```

196.5 Normalized data model

All drivers normalize through driver_point_contract.py:

- **bacnet** → canonical bacnet_direct
- **niagara_baskstream, modbus, json_api**

Semantic identity (fdd_input / cross_source_semantic) links both sources to one Brick point role.

196.6 Poll intervals

- BACnet: poll_interval_s in points.csv (standard: 60, 300, ...)
- Niagara: poll_interval_seconds on station config; worker re-reads each cycle (no restart required)
- Lab minimum Niagara interval: 15s (API validates ≥ 15)

Validate cadence: GET /api/bench/poll-cadence?
source=bacnet_direct&expected_interval_s=60

196.7 Overnight smoke

```
python3 scripts/run_overnight_bench_smoke.py --dry-run # one
checkpoint
python3 scripts/run_overnight_bench_smoke.py # 12h,
checkpoint every 2h
```

Reports: reports/overnight_bench/<timestamp>/

196.8 Read-only rules

No BACnet writes, no Niagara overrides, no alarm ack. Relay booleans are read-only observations only.

197 Dashboard Analytics

198 Dashboard analytics

Engineering analytics pages live under **Analytics** in the operator dashboard (/analytics).

198.1 Pages

Route	Purpose
/analytics	Overview KPIs, fault-hour charts, top faults table
/analytics/faults	Time-range fault analytics
/analytics/equipment	AHU / VAV fault-hour summary
/analytics/health	BACnet / BRICK model health
/analytics/rcx	RCx Report Builder (preview + DOCX download)

198.2 API (read-only)

- GET /api/analytics/overview
- GET /api/analytics/faults?hours=24
- GET /api/analytics/model-health
- POST /api/reports/rcx/preview

- `POST /api/reports/rcx/generate` → DOCX download

198.3 Fault hours

Elapsed fault hours are estimated from FDD batch run analytics.estimated_fault_duration_sec when present, otherwise from flagged/total sample ratio. See open_fdd/reports/fault_hours.py.

198.4 Theme

All Plotly charts use `getPlotlyThemeLayout(theme)` from `workspace/dashboard/src/lib/plotly-theme.ts`.

198.5 Tests

```
pytest tests/workspace_bridge/test_dashboard_analytics.py
open_fdd/tests/test_fault_hours.py
cd workspace/dashboard && npm test
```

Live BACnet is not required. Gate live ACME validation with `OPENFDD_LIVE_ACME=1`.

199 Datafusion Sql Rules

200 DataFusion SQL rules (optional)

Open-FDD v3 remains **PyArrow-first**. Rules implement `apply_faults_arrow(table, cfg, context=None)` and return a boolean Arrow mask.

The optional **DataFusion SQL** backend (`backend: datafusion_sql`) is a future-Rust-prep seam:

- Input: PyArrow Table registered as telemetry
- Rule body: a restricted SELECT that adds a boolean fault column
- Output: the same ArrowRuleResult shape as PyArrow rules

Install:

```
pip install 'open-fdd[datafusion]'
```

200.1 When to use SQL vs PyArrow

See the full decision table in the [Expression cookbook — PyArrow vs DataFusion SQL]({{ "/rule-cookbook/expression-cookbook/" | relative_url }}#pyarrow-vs-datafusion-sql).

Use DataFusion SQL	Use PyArrow
Simple thresholds, CASE WHEN, boolean logic	Rolling windows, flatline, rate-of-change, hunting
SQL-readable expressions for operators	Custom HVAC helpers, sensor profiles, schedule gating
Proving parity before Rust migration	Primary supported authoring path
Stateless row-wise rules	ML prep, complex multi-signal logic

200.1.1 Do not use DataFusion SQL for

Rolling windows, PID hunting, helper-heavy logic, ML features, file joins, browser execution, or pandas-style row loops. Use PyArrow helpers instead.

200.2 Rule metadata (saved rules)

```
id: zone_temp_high_sql
name: Zone temperature high - SQL
backend: datafusion_sql
fault_column: fault
sql: |
    SELECT
        *,
        zone_temp > 75.0 AS fault
    FROM telemetry
```

200.3 Safety

SQL rules are **not** a database console. The linter rejects:

- Multiple statements, DDL/DML
- Reads other than FROM telemetry
- File paths and external URLs
- Missing or non-boolean fault column
- Row counts that differ from input telemetry

- Wrong fault column alias (e.g. `not_fault` when `fault` is required)

Server-side execution only — the Rules Lab browser editor never runs SQL locally.

200.4 Rules Lab

In **Rule Lab**, choose **PyArrow** or **DataFusion SQL**:

- **Validate SQL** — lint + optional server preview on latest historian sample
- **Run Preview** — bounded sample against site telemetry
- **Compare backends** — prove an equivalent SQL rule matches a PyArrow rule mask

See [ADR: DataFusion Rust-ready backend](#).

201 Dashboard Rcx Makeover Inventory

202 Dashboard + RCx Makeover — Inventory

Branch: `feature/dashboard-rcx-mega-makeover`
Date: 2026-05-30

202.1 What exists

Area	Location	Notes
React operator dashboard	<code>workspace/dashboard/</code>	Vite + React 19, theme via <code>contexts/theme-context.tsx</code> , CSS vars
Plotly charts	<code>lib/plot-chart.ts</code> , <code>PlotPage.tsx</code> , <code>HostStatsPage.tsx</code>	Partial theme handling; not centralized
Building check-engine	<code>building_status.py</code> , <code>FaultsPage</code> , <code>BuildingInsightDashboard</code>	Single source for alerts

Area	Location	Notes
FDD batch + analytics	fdd_results.py, fdd_fault_analytics.py	Per-run sample analytics, equipment enrichment
Poll / model health	poll_throughput.py, model_health.py, device_poll_health.py	Used by agent, not dashboard analytics pages
Zone temp analytics	zone_temp_analytics.py	VAV comfort metrics via agent routes
Central RCx DOCX	portfolio/central/rcx_report.py, fault_hours.py	Central-only (POST /api/central/rcx/report)
Generic open_fdd reports	open_fdd/reports/docx_generator.py, fault_viz.py	Equipment FDD reports, optional deps
Portfolio desk	portfolio/dash/app.py, portfolio/central/api.py	Separate Dash + FastAPI stack
Frontend unit tests	14 Vitest files under workspace/dashboard/src/lib/	Not in CI
Bridge Python tests	tests/workspace_bridge/, tests/portfolio/	Strong coverage for building insight, central

202.2 What partially exists

- **Theme toggle** — app shell updates; Plotly uses inline colors in plot-chart.ts / HostStatsPage.tsx (inconsistent).
- **Fault display** — equipment names in check-engine alerts when model maps columns; catalog page is not analytics-focused.
- **RCx DOCX** — portfolio central builder with basic sections; not exposed on edge bridge; no chart/section checkboxes.
- **Fault hours** — portfolio/central/fault_hours.py estimates from rollups; FDD run analytics has duration estimates but no REST aggregation.
- **Demo data** — workspace/data/acme_gl36_model.json, fdd_results.json, samples/demo_site.csv; no unified analytics fixture.

202.3 What is missing (this branch targets)

- Shared `getPlotlyThemeLayout()` helper + all charts using it
- Analytics pages: Overview, Fault Analytics, Equipment, BACnet/Model Health, RCx Report Builder
- Bridge REST: `/api/analytics/overview`, `/faults`, `/equipment/{id}`, `/model-health`, `/reports/rcx/preview`, `/reports/rcx/generate`
- Edge RCx DOCX with selectable sections/charts (`open_fdd/reports/rcx_docx.py`)
- Fault-hour aggregation module with tests
- Demo analytics fixture for CI
- Docs: `docs/dashboard-analytics.md`, `docs/rcx-report-builder.md`

202.4 Files inspected

AGENTS.md, README.md, pyproject.toml
workspace/dashboard/src/App.tsx, AppLayout.tsx, theme-context.tsx, plot-chart.ts
workspace/api/openfdd_bridge/main.py, building_status.py, fdd_results.py, fdd_fault_analytics.py
workspace/api/openfdd_bridge/routes/analytics_routes.py
portfolio/central/rcx_report.py, fault_hours.py, api.py
open_fdd/reports/
tests/workspace_bridge/, tests/portfolio/test_central.py

202.5 Recommended implementation path

1. **Foundation** — `open_fdd/reports/fault_hours.py`, `charts.py`, `rcx_docx.py`; bridge `dashboard_analytics.py` + routes; deps in bridge requirements.
2. **Theme** — `plotly-theme.ts`; refactor `plot-chart.ts` + `HostStatsPage.tsx`.
3. **UI** — Analytics nav section + pages wired to new APIs; RCx Report Builder with preview/generate.
4. **Fixtures + tests** — demo JSON, backend pytest, Vitest for theme + report builder.
5. **Docs** — operator-facing how-to.

202.6 Known risks

- **Scope** — full prompt is multi-PR; this branch delivers edge dashboard + bridge RCx; Central Dash remains separate.
- **Live BACnet** — analytics read persisted FDD/model/poll data only (read-only).

- **Trend charts in RCx** — need timeseries API + point roles; may be partial when historian empty.
- **ACME coupling** — use demo fixture + model-driven roles, not hard-coded point names.

203 Rcx Central Current State

204 OpenFDD RCx Central — current state

Updated: 2026-05-30

Branches: feature/rcx-central-overview-ui (#298)

Status: Local TTL mirror + SPARQL on Central; benserver sign-off before Docker GHCR publish.

204.1 Product names

User-facing	Internal path
OpenFDD Edge	workspace/, docker/, GHCR images
OpenFDD RCx Central	portfolio/ (Dash + Central API)

204.2 Entrypoints

Service	Command	Port	Bind default
RCx Central Dash	./scripts/ run_portfolio_dash.sh	8050	0.0.0.0
RCx Central API	./scripts/ run_central_api.sh	8060	0.0.0.0
Docker (both)	docker/rcx-central/ docker-compose.yml	8050, 8060	

LAN firewall (benserver): `sudo ./scripts/
open_rcx_central_lan_ports.sh`

204.3 Central API

- GET/POST/PUT/DELETE /api/central/edges, POST /api/central/edges/test
- GET /api/central/overview/{site_id} — KPIs, fault pie, mechanical narrative, P8
- GET /api/central/fdd-analytics/{site_id} — rules table + descriptions
- GET /api/central/fdd-preset/{site_id}/{preset_id} — Edge FDD preset proxy + Central enrichment
- POST /api/central/model/remediate/{site_id} — equipment types, BACnet metadata, Edge TTL sync, Central mirror
- POST /api/central/model/sync-ttl/{site_id} — pull data_model.ttl to portfolio/data/sites/{site_id}/model/
- GET /api/central/model/sparql/validate/{site_id} — local AHU/VAV/site SPARQL counts
- POST /api/central/model/sparql/{site_id} — read-only SPARQL on mirrored TTL
- GET /api/central/mechanical-summary/{site_id}
- GET /api/central/model-tree/{site_id} — on-demand BRICK tree (lazy; not on auto-refresh)
- GET /api/central/rcx/points/{site_id} — BACnet point catalog for Report Builder
- POST /api/central/rcx/preview, /charts/preview, /report

204.4 Edge REST (read-only, shared with Data Model tab)

Model: /api/model/tree, /api/model/health, SPARQL, /api/model/fdd-query-presets/{id}

Trends: /api/timeseries/readings

Analytics: /api/analytics/faults

Faults: /api/faults/status, /api/faults/catalog

204.5 Dash UI tabs

Dashboard · Report Builder · Edge Connections

Dashboard: fault mix + legend, building summary, P8 KPI, FDD rules (lazy load), FDD/BRICK preset buttons, **local SPARQL** (TTL mirror).

Report Builder: 3-step wizard — building/time → charts & sections → custom points → preview DOCX.

Edge data fetched on demand (not with dashboard load).

204.6 Pre-Docker owner checklist (benserver :8050)

1. Dashboard loads in under 5s without hanging on model tree.
2. **Load full BRICK model** and **Load FDD rules** buttons work when clicked.
3. Report Builder: load catalog → preview charts → generate DOCX for Acme.
4. Fault overlays visible on trend previews when enabled.
5. Sign off here before docker/rcx-central image rebuild or RCX_ALLOW_PUBLISH=1.

204.7 BRICK model notes (agents)

- Classify equipment with brick_type **and** equipment_type — see equipment_classify.py
- TTL maps AHU/VAV → Brick schema classes for SPARQL HVAC queries
- Acme roof unit: brick_type: AHU, name AHU 01 (not Rtu 01 in new models)

204.8 Fault codes

- Stable short labels: docs/fault-codes/short-lookup.md, portfolio/central/fault_code_lookup.py
- Full catalog: GET /api/faults/catalog on Edge

204.9 Agent docs

- [RCx Central Dash agent guide](#)
- [AI agent workflow](#)
- [MCP server](#)

204.10 Tests

```
pytest tests/portfolio/ · tests/workspace_bridge/  
test_fdd_query_presets.py
```

204.11 Remaining gaps

- **Owner Dash sign-off** on benserver before Docker GHCR publish
- GHCR publish for openfdd-rcx-central image (gated: RCX_ALLOW_PUBLISH=1)

- Optional OpenAI insights hook (templates used today)
- True Edge start/end bounded timeseries (hours lookback used for now)
- Summarize HVAC SPARQL buttons on Dash — **done** (local TTL mirror on Central)

205 Short Lookup

206 Fault code short descriptions

Stable lookup for pie charts, tables, and RCx reports. Titles match `workspace/api/openfdd_bridge/fault_catalog.py`.

Code	Short description
AHU-A	Supply fan performance degradation
AHU-B	Simultaneous heating and cooling
AHU-C	Supply air temperature sensor fault
AHU-D	Mixed-air temperature inconsistent with OAT/RAT
AHU-E	Economizer not economizing
AHU-F	Damper/valve command vs feedback mismatch
AHU-G	PID hunting / excessive control oscillation
VAV-A	Reheat active during cooling demand
VAV-B	Airflow not meeting setpoint
VAV-C	Zone temperature sensor fault
VAV-D	Damper command vs airflow mismatch
VAV-E	Rogue zone (chronic reheat/overcooling)
VAV-F	VAV actuator PID hunting
BLD-A	Whole-building energy deviation
BLD-B	Outdoor-air temperature sensor fault
BLD-C	Equipment running outside occupancy schedule
BLD-D	Point data dropout (stale points)
RTU-A	Supply fan performance degradation
RTU-B	Simultaneous heating and cooling
RTU-C	Discharge air temperature sensor fault
RTU-D	Damper/valve command vs feedback mismatch
RTU-E	Cooling capacity PID hunting

Code	Short description
CH-G	Pump / variable-speed PID hunting

Full catalog: [index.md](#) and live GET `/api/faults/catalog` on Edge.

Python mirror: `portfolio/central/fault_code_lookup.py` (RCx Central Dash).

207 Niagara Baskstream Connector

208 Niagara baskStream connector (read-only)

Open-FDD integrates with **Niagara Framework** stations through the vendor **baskStream** module. The bridge API performs SCRAM login, opens a persistent WebSocket, and reads point values via MessagePack — the browser never connects directly to Niagara.

208.1 Read-only posture

This connector is **read-only**. It does not implement writes, overrides, alarm acknowledge, or emergency actions. Use Niagara Workbench for OT commands.

208.2 Niagara station setup

1. Install the **baskStream** module on the Niagara station (same module validated by `niagara-baskstream-python-tools` on Linux).
2. Add **BASkStreamService** (or equivalent `baskStream` service) on the station.
3. Ensure HTTPS (port **443**) is reachable from the Open-FDD bridge host.
4. Firewall: allow the bridge server → station on 443.

208.2.1 Health check behavior

- **Before login:** GET `/stream/health` returns **302** redirect to `/login`.

- **After SCRAM login:** GET /stream/health returns **200** with JSON including authenticatedUser.

From Linux bench:

```
curl -k -i https://192.168.204.11/stream/health  
# Expect 302 before login
```

208.3 Open-FDD configuration

1. Copy workspace/niagara.env.example → workspace/niagara.env.local (gitignored).
2. Set OPENFDD_NIAGARA_ADMIN_PASSWORD (or your custom env name).
3. In the dashboard **Niagara** tab, add a station:
 - URL: https://<station-ip>
 - Username: Niagara web user
 - **password_env**: OPENFDD_NIAGARA_ADMIN_PASSWORD
 - **verify_tls**: off for self-signed bench certs
 - **default_points_root**: e.g. slot:/Drivers/BacnetNetwork/BENS\$20BENCHTEST\$20BOX/points

208.3.1 ORD encoding

Niagara ORDs use encoded characters (\$20 = space, \$2d = hyphen, \$23 = #). **Preserve these strings exactly** in config, API, and UI. Do not URL-decode or shell-expand them.

PowerShell users: use **single-quoted** strings for ORDs so \$20 is not treated as a variable.

208.3.2 Allowed Origins

The Open-FDD **backend** connector does not require Niagara “Allowed Origins” for browser CORS — traffic is **Browser** → **Open-FDD** /api/niagara → **Niagara**. Direct browser-to-Niagara WebSocket is discouraged.

208.4 Dependencies

Bridge API requires aiohttp and msgpack (see workspace/api/requirements.txt). If missing, the app still boots; /api/niagara/health reports dependencies_ok: false.

208.5 Polling

Enable poll per station in the UI. The worker uses one persistent WebSocket per active station, batched reads, cached discovery metadata, and historian ingest with source=niagara_baskstream.

Disable background worker: 0FDD_DISABLE_NIAGARA_POLL_WORKER=1.

208.6 Bench reference (benserver)

Item	Value
Station URL	https://192.168.204.11
BACnet device folder	slot:/Drivers/BacnetNetwork/ BENS\$20BENCHTEST\$20BOX/points
Expected points	~10 BACnet components (proxy extensions excluded by default)

Validate: **Test connection** → **Discover** → **Read selected / Poll once**. Values should match the standalone baskstream_cli.py values output (OA-T, DUCT-T, STAT ZN-T, etc.).

209 Data Model

210 Data Model — sync and FDD queries

210.1 Explorer (BACnet poll sync)

The **Explorer** tab focuses on **BACnet poll CSV** ↔ **model.json** sync status and **Sync poll** → **model**. Write TTL lives under **Advanced** (or SPARQL RDF tools).

210.2 FDD query presets

The **SPARQL** tab includes **FDD / BRICK query presets** — composed queries across model.json, rule bindings, and BACnet metadata:

- Rules → Equipment / Sensors / BACnet devices
- Equipment → Points, AHUs/VAVs/Zones

- Missing rule bindings, orphan points, sensor classes, coverage by equipment type

API: GET /api/model/fdd-query-presets, GET /api/model/fdd-query-presets/{id}.

211 Host Resources

212 Host Resources — Easy Pooge reset

Integrators see a **Danger Zone** on the Host Resources tab for job-site redeploys.

- Typed confirmation: POOGE THIS EDGE
- Dry-run preview by default
- Allowlisted path cleanup (historian, BACnet scratch, exports)
- Optional Linux apt upgrade and GHCR image pull

API: POST /api/host/pooge/preview, POST /api/host/pooge/run (integrator only).

213 Trend Plots

214 Trend plots

The **Trend plot** tab reads feather historian data via GET /api/timeseries/readings.

214.1 HTTP / Tailscale

Charts work over plain HTTP on localhost, LAN, and Tailscale — COOP/CORP security headers are omitted on non-HTTPS origins so Plotly is not blocked.

214.2 Troubleshooting

If the chart is blank, open **Trend plot debug** at the bottom of the tab:

- Endpoint called
- Site, equipment, selected keys
- Series and timestamp row counts
- Last error message

Common fixes: enable BACnet polling, pick points with feather columns, reduce FDD overlay scope.

215 Cloud Exporter

216 Cloud exporter sidecar

Optional `openfdd-cloud-exporter` container polls the bridge API and POSTs JSON to a webhook-compatible URL (PostBin, `webhook.site`, etc.).

216.1 Enable (edge compose)

```
export OPENFDD_EXPORT_ENDPOINT=https://webhook.site/your-uuid
export OPENFDD_EXPORT_DRY_RUN=1
docker compose --profile cloud-export up -d cloud-exporter
```

Set `OPENFDD_EXPORT_DRY_RUN=0` only when you intend live export.

216.2 Security

- Disabled by default (`OPENFDD_EXPORT_DRY_RUN=1`).
- Does not export operator passwords or auth env files.
- Tokens are redacted in logs.

See `workspace/cloud_exporter/README.md` for environment variables.

217 Overnight Bench Smoke

218 Overnight bench smoke test

12-hour local validation on **benserver** only. Read-only.

218.1 Command

```
export OPENFDD_NIAGARA_ADMIN_PASSWORD='...'
python3 scripts/run_overnight_bench_smoke.py
```

Options:

Flag	Default	Purpose
--duration-hours	12	Total run length
--checkpoint-hours	2	Wake interval
--dry-run	off	Single checkpoint then exit
--skip-bootstrap	off	Skip BACnet/Niagara setup
--test-poll-freq	off	Run poll interval change test at t=0

218.2 Each checkpoint

1. Cross-source validate (bench_validate_bacnet_vs_niagara)
2. Poll cadence report (BACnet + Niagara)
3. Targeted pytest (contract, validator, Niagara)
4. JSON + Markdown report under reports/overnight_bench/<run_id>/

218.3 Final deliverable

final_report.md / final_report.json with PASS/FAIL and next actions.

218.4 GH Actions loop

After code fixes during a wake cycle:


```
git add ... && git commit -m "..." && git push origin fix/3.0.34-bugs
gh pr checks 300 --watch
```

No empty commits when validation-only cycles pass.

219 Ai Agent Workflow

220 AI agent workflow vs runtime use

220.1 Three agent surfaces

Surface	Port	Use when
OpenFDD Edge (bridge)	8765 / :80 Caddy	Rule Lab, BACnet, Data Model SPARQL, live FDD
OpenFDD RCx Central	8050 Dash, 8060 API	Multi-site analyst dashboard, RCx DOCX, Edge registry
OpenFDD MCP	8090	Cursor/Codex tools over bridge or portfolio/sites.json

Acme production edge runs **without** MCP (enable_mcp: false). Use **RCx Central API** or **portfolio MCP** against http://100.122.106.124 (Tailscale).

220.2 Runtime analyst (no git clone)

1. docker compose -f docker/rcx-central/docker-compose.yml up
or ./scripts/run_central_api.sh + ./scripts/run_portfolio_dash.sh
2. Open http://localhost:8050 (LAN: sudo ./scripts/open_rcx_central_lan_ports.sh on benserver)
3. **Edge Connections** → add Acme URL → Test → Save
4. **Dashboard** → select building → verify building summary (AHU/VAV counts), FDD preset buttons, fault pie descriptions
5. **RCx report** → Preview → Generate DOCX

Kill containers when done. Registry in Docker volume rcx-central-config.

220.3 Developer / coding agent (git working tree)

Use Cursor or Codex against open-fdd. Read:

- [RCx Central Dash agent guide](#)
- [Overnight patch cycle](#)

Key modules: portfolio/dash/overview_tab.py, portfolio/central/mechanical_narrative.py, portfolio/central/fault_code_lookup.py, workspace/api/openfdd_bridge/fdd_query_presets.py, ttl_service.py.

After doc changes consumed by MCP RAG: ./scripts/build_mcp_rag_index.sh (optional on benserver).

220.4 Model / SPARQL validation (Acme)

1. Confirm model.json equipment uses brick_type (AHU, VAV) — not only legacy equipment_type
2. Sync TTL on Edge (Data Model tab or bridge restart)
3. Edge UI: **Summarize HVAC → AHUs / VAV boxes** must return non-zero for Acme lab
4. RCx Dash: **AHUs / VAVs / Zones** preset → same row counts as Edge

220.5 Secrets

- Never commit portfolio/config/credentials.json or passwords in sites.json
- Env: OFDD_AGENT_PASSWORD, per-site credentials in config store
- Live ACME tests: OPENFDD_LIVE_ACME=1 only when explicitly requested

220.6 Model routing (test triage)

See AGENTS.md — classify CI failures as SIMPLE vs COMPLEX before processing.

221 Docker Desktop Windows

222 RCx Central on Docker Desktop (Windows)

222.1 Prerequisites

- Docker Desktop for Windows
- Edge reachable from the host (e.g. Tailscale)

222.2 Run

```
cd open-fdd
docker compose -f docker/rcx-central/docker-compose.yml up --build
```

Open:

- Dash: <http://localhost:8050>
- API health: <http://localhost:8060/health>

No git clone required at runtime if you pull [ghcr.io/bbartling/openfdd-rcx-central](https://github.com/bbartling/openfdd-rcx-central) (when published). Build locally with `OPENFDD_IMAGE_TAG=local`.

222.3 Volumes

Volume	Purpose
rcx-central-data	Rollups, reports (portfolio/data/reports/)
rcx-central-config	sites.json, masked credentials

222.4 Tailscale networking

If Edge is reachable on the Windows host but not from inside the Linux container:

1. Test from host: `curl https://<tailscale-ip>:8765/health`
2. Test from container: `docker compose exec rcx-central-api curl -s http://<tailscale-ip>:8765/health`

3. If container cannot route, use the host's Tailscale IP (Docker Desktop often routes LAN correctly) or document `host.docker.internal` proxy for dev.

222.5 Smoke test

```
./scripts/test_rcx_central_docker.sh
```

Windows PowerShell variant: run `compose up`, then `curl` health URLs manually per steps above.

223 Edge Auth

224 Edge authentication (RCx Central)

224.1 Browser flow

1. Open RCx Central → **Edge Connections**
2. Enter `site_id`, name, Edge base URL (`https://<tailscale-ip>:8765`)
3. Enter username/password (or bearer token via API)
4. **Test Connection** — probes `/health`, `/api/model/health`, `/api/faults/status`
5. **Save Edge** — writes to `portfolio/config/sites.json` + `credentials.json` (Docker volume)

224.2 API

```
GET /api/central/edges
POST /api/central/edges
POST /api/central/edges/test
PUT /api/central/edges/{site_id}
DELETE /api/central/edges/{site_id}
```

Secrets are **never** returned in API responses or committed to git. Passwords are masked in UI after save.

224.3 Auth types

- password — `POST /api/auth/login` on Edge

- bearer — static token in credentials store
- none — public Edge endpoints only (dev)

224.4 Rejected URLs

file://, ftp://, and hosts without scheme are rejected.

225 Index

226 OpenFDD RCx Central

OpenFDD RCx Central is the local analyst / RCx engineer dashboard. It runs on an analyst workstation or **Docker Desktop (Windows/Linux)** — not on the OT edge by default.

Product	Role
OpenFDD Edge	Arrow-native, no-pandas OT-LAN FDD machine at the building
OpenFDD RCx Central	Read-only multi-edge analytics, chart preview, DOCX reports

Internal source path: portfolio/ (package name unchanged).

226.1 Quick start (host Python)

```
pip install -r portfolio/requirements.txt
./scripts/run_central_api.sh    # :8060
./scripts/run_portfolio_dash.sh # :8050
```

226.2 Docker Desktop

```
./scripts/run_rcx_central_docker.sh
# Dash http://localhost:8050  API http://localhost:8060/health
```

See [docker-desktop-windows.md](#).

226.3 Pages

- Overview — collected rollup trends (Plotly, light/dark theme)
- Edge Connections — add/test/save Edge URLs (secrets in local volume)
- Mechanical Summary — BRICK equipment counts from Edge APIs
- FDD Rules & Analytics — configured rules, chart packs
- Trend Explorer — pointer to Overview Plotly charts (local collect CSVs)
- RCx Report Builder — matplotlib preview, fault overlays, DOCX download
- Validation Runs — one-off read-only Edge probes
- Settings — API URL and volume paths

Model query details: [model-queries.md](#)

226.4 Safety

RCx Central is **read-only** toward Edge and BACnet. No writes, commands, or setpoint changes.

227 Model Queries

228 Model queries (RCx Central → OpenFDD Edge + local TTL mirror)

OpenFDD RCx Central reuses the **same read-only Edge REST APIs** as the Edge operator React **Data model** tab. RCx Central does not scrape the React UI.

Local BRICK SPARQL: POST /api/central/model/sync-ttl/{site_id} fetches Edge model.json, builds TTL with the same ttl_service as Edge, and stores it under portfolio/data/sites/{site_id}/model/data_model.ttl. Central runs SPARQL locally (rdflib). Optionally calls Edge POST /api/model/sync-ttl first so on-site TTL stays aligned when the Edge image is current.

228.1 Primary endpoints

Method	Edge path	Purpose
GET	/api/model/tree	Equipment + points (BRICK roles, timeseries columns)
GET	/api/model/health	Point/equipment counts, model issues
GET	/api/model/sparql/predefined	Prebuilt SPARQL query list
POST	/api/model/sparql	Run SPARQL (<code>{"query": "..."} </code>)
GET	/api/model/fdd-query-presets	FDD commissioning query presets
GET	/api/model/fdd-query-presets/{id}	Run preset by id
GET	/api/model/ttl?save=false	Turtle text (used by Central TTL mirror)
POST	/api/model/sync-ttl	Regenerate TTL on Edge from <code>model.json</code>

228.2 Trends (matplotlib preview + fault overlays)

Method	Edge path	Purpose
GET	/api/timeseries/series?site_id=	Plottable columns per site
GET	/api/timeseries/readings?site_id=&columns=&hours=	Trend samples + optional FDD fault flags

RCx Central maps BRICK **point roles** (e.g. `supply_air_temperature`) to historian columns via `/api/model/tree`, then calls `/api/timeseries/readings` with `include_faults=true` for overlay bands.

228.3 Analytics

Method	Edge path	Purpose
GET	/api/analytics/overview	KPIs, fault hours by severity/equipment
GET	/api/analytics/faults?hours=	Fault rows for selected window
GET	/api/analytics/model-health	Stale/missing roles

228.4 RCx Central API wrappers

Method	Central path
GET	/api/central/overview/{site_id}
GET	/api/central/mechanical-summary/{site_id}
GET	/api/central/fdd-analytics/{site_id}
GET	/api/central/fdd-preset/{site_id}/{preset_id}
POST	/api/central/model/remediate/{site_id}
POST	/api/central/model/sync-ttl/{site_id}
GET	/api/central/model/ttl/{site_id}
GET	/api/central/model/sparql/predefined/{site_id}
POST	/api/central/model/sparql/{site_id}
GET	/api/central/model/sparql/validate/{site_id}
POST	/api/central/rcx/preview

Edge model mutations use integrator auth via remediate; SPARQL on Central is read-only.

228.5 FDD preset ids (Edge parity)

Same as React DataModelSparqlPanel FDD buttons:

rules_to_equipment, rules_to_sensors, rules_to_bacnet_devices,
equipment_to_points, ahus_vavs_zones, missing_rule_bindings,
points_by_bacnet_device, sensor_classes_used_by_fdd,
rule_coverage_by_equipment_type, orphan_points

Dash **Local BRICK SPARQL** buttons call Central paths above (mirrored TTL).

228.6 BRICK typing (do not mis-count AHUs/VAVs)

Many sites (including Acme) set **brick_type** (AHU, VAV) without **equipment_type**. Presets and mechanical narrative use **equipment_classify** — not **equipment_type** alone.

After `model.json` changes on Edge, **sync TTL** (POST `/api/central/model/sync-ttl/{site_id}` or `remediate`) so SPARQL predefined queries (`Air_Handling_Unit`, `Variable_Air_Volume_Box`) match equipment counts.

Packaged rooftop air handlers feeding VAVs should be modeled as **brick_type: AHU** even when the legacy BACnet name contains “RTU”.

229 Overnight Acme Validation

230 Overnight ACME validation via RCx Central

RCx Central drives read-only validation of the ACME OpenFDD Edge over Tailscale.

230.1 Prerequisites

- Local RCx Central API (:8060) and Dash (:8050).
- ACME Edge registered under **Edge Connections** with credentials in `portfolio/config/` (gitignored).
- gh CLI authenticated for PR/CI inspection.

230.2 Try-out (2 cycles, no sleep)

```
OPENFDD_LIVE_ACME=1 \  
RCX_CENTRAL_API_URL=http://127.0.0.1:8060 \  
RCX_CENTRAL_DASH_URL=http://127.0.0.1:8050 \  
RCX_EDGE_SITE=acme \  
RCX_PATCH_CYCLES=2 \  

```

```
RCX_CYCLE_SLEEP_MINUTES=0 \
python3 scripts/rcx_central_overnight_patch_cycle.py
```

230.3 Overnight (10 cycles, 2 h spacing)

Set `RCX_PATCH_CYCLES=10` and `RCX_CYCLE_SLEEP_MINUTES=120`.

Reports land in `reports/rcx_central_overnight_logs/cycle_NN.md`.

230.4 Read-only scope

Collects health, model tree counts, fault status, and overview data. No BACnet writes.

231 Patch Cycle Release Process

232 Patch-cycle release process

A **patch cycle** completes when CI is green, local smoke passes, optional ACME read-only validation passes, changes are committed, and the cycle log is written.

232.1 Authorization flags

Flag	Action
<code>RCX_ALLOW_MERGE=0</code> (default)	Do not merge PRs
<code>RCX_ALLOW_PUBLISH=0</code>	Do not push GHCR images
<code>RCX_ALLOW_DEPLOY=0</code>	Do not deploy to ACME

Set to 1 only when the repo owner authorizes.

232.2 Image bump (when authorized)

1. Tests and `gh pr` checks green.
2. Bump patch tag only.

3. `./scripts/docker_build.sh` and publish via existing GHCR workflow.
4. `./scripts/upgrade_edge_full.sh --limit <host>` when deploy authorized.
5. Re-run overnight validator with `OPENFDD_LIVE_ACME=1`.

233 Report Builder

234 RCx Report Builder (RCx Central)

234.1 Flow

1. Select saved Edge site
2. Choose date range (2h / 24h / 7d)
3. **Collect Data / Preview** — `POST /api/central/rcx/preview`
4. **Preview Charts** — matplotlib PNG as base64 in browser
5. Select chart/section checkboxes
6. **Generate DOCX** — `POST /api/central/rcx/report`

Reports save to `portfolio/data/reports/` when `save_to_volume=true`.

234.2 Fault overlays

Preview charts include severity-colored bands when fault rows exist and overlay toggle is on.

234.3 DOCX

Uses `open_fdd/reports/rcx_docx.py` when available (selectable sections/charts). Falls back to `portfolio/central/rcx_report.py`.

Read-only safety note is included in every report.

235 Rcx Report Builder

236 RCx Report Builder

The **RCx Report Builder** (/analytics/rcx) collects a read-only snapshot from the edge bridge and generates a Word document.

236.1 Workflow

1. Choose report window (2 h / 24 h / 7 d).
2. Click **Collect Data / Preview** — calls `POST /api/reports/rcx/preview`.
3. Review available vs disabled charts (disabled charts show missing point roles or no fault data).
4. Select sections and charts.
5. Click **Generate DOCX** — `POST /api/reports/rcx/generate` returns `application/vnd.openxmlformats-officedocument.wordprocessingml.document`.

236.2 Implementation

- Preview/readiness: `workspace/api/openfdd_bridge/dashboard_analytics.py`
- DOCX builder: `open_fdd/reports/rcx_docx.py`
- Charts: `open_fdd/reports/charts.py` (matplotlib → BytesIO, no temp PNGs)

236.3 Safety

Report generation is **read-only**. No BACnet writes, commands, overrides, or setpoint changes.

236.4 Dependencies

Bridge API requires `python-docx` and `matplotlib` (see `workspace/api/requirements.txt`).

236.5 Central vs edge

Portfolio Central (portfolio/central/rcx_report.py, port 8060) supports multi-site rollups. The edge builder uses local FDD results and building status for single-site RCx exports from the operator UI.

237 3.1.2

238 Open-FDD 3.1.2

Release date: 2026-06-15

238.1 Highlights

- **DataFusion / Rust-prep validation** — Bench long FDD smoke exercises PyArrow and DataFusion SQL backends with execution evidence and backend equivalence checks.
- **Bench 5007 long FDD smoke** — Model-driven dual-source validation (BACnet MS/TP device 5007 + Niagara bench9065) with 10-minute fault confirmation window.
- **Fault confirmation window** — Confirmed faults require consecutive true samples; reports include raw vs confirmed timing.
- **GHCR tags** — ghcr.io/bbartling/openfdd-bridge:3.1.2, openfdd-commission:3.1.2, openfdd-mcp-rag:3.1.2.

238.2 Known warnings

- `confirmation_engine=python_loop_over_arrow_mask` — confirmation still uses a Python loop over the Arrow fault mask; vectorized confirmation is planned.

238.3 Validation

```
python scripts/smoke_bench_5007_long_fdd.py --synthetic --dry-run
python scripts/smoke_bench_5007_long_fdd.py --live --duration-
minutes 35 --baseline-minutes 10 \
    --confirmation-rows 10 --confirmation-minutes 10 --poll-seconds
60 --strict-live-freshness
```

```
python scripts/inspect_bench_5007_long_fdd_report.py workspace/
reports/bench_5007_long_fdd_*.json
```

Reports now classify **historian_mode** (live_recent, historical_replay, synthetic, dry_run) and refuse to claim live polling was validated when sample timestamps are outside the wall-clock run window. Use --allow-historical-replay only for debugging replay data.

For live bench sign-off, the inspector must show data_is_fresh: true and historian_mode: live_recent, plus non-zero BACnet/Niagara rows.

239 3.1.3

240 Open-FDD 3.1.3

Release date: 2026-06-15

240.1 Patch fixes

- **Bench long FDD evaluate** — when wall-clock run_started_at / lookback filtering would empty a non-empty historian table (demo CSV fallback or stale feather replay), evaluate now uses the full loaded table and sets time_filter_relaxed: true. Strict smoke freshness gates still FAIL/WARN honestly on non-fresh samples.
- **Live smoke lookback** — final matrix evaluate uses the same 24h minimum lookback as cycle evaluates.

240.2 GHCR tags

- ghcr.io/bbartling/openfdd-bridge:3.1.3
- ghcr.io/bbartling/openfdd-commission:3.1.3
- ghcr.io/bbartling/openfdd-mcp-rag:3.1.3

240.3 Validation

```
python scripts/smoke_bench_5007_long_fdd.py --synthetic --dry-run
python scripts/smoke_bench_5007_long_fdd.py --live --duration-
minutes 35 \
    --baseline-minutes 10 --confirmation-rows 10 --confirmation-
minutes 10 \
```

```
--poll-seconds 60 --strict-live-freshness  
python scripts/inspect_bench_5007_long_fdd_report.py workspace/  
reports/bench_5007_long_fdd_*.json
```

241 Release 3.1.5

242 Release 3.1.5

242.1 Dashboard & operator UX

- BAS-style latched alarms with **Clear** for authenticated operators (/api/faults/clear)
- Optimistic BACnet / Modbus / JSON API driver tree deletes (no JS confirm except Pooge nuclear reset)
- Rule Lab SQL CodeMirror editor; Host Stats Pooge + Ollama disabled styling
- Public read-only building snapshot for wall displays

242.2 Rule authoring docs (v1)

- New docs/rule-authoring/ — PyArrow vs DataFusion decision table, Arrow contract, legacy pandas parity, FC4 modernization, Rust checklist

242.3 Fixes

- CI: rename duplicate test_cookbook.py pytest module collision
- WebSocket redacted dashboard includes fault families (not empty)

242.4 Smoke

Detached paired FDD harness default for short / standard / overnight — see paired FDD smoke.